



PUBLIC INFORMATION MEETING

City of New Haven's Combined Sewer Overflow Long Term Control Plan Update Public Information Meeting Report Prepared by CH2MHill on behalf of the Greater New Haven Water Pollution Control Authority

FEBRUARY 14, 2017

Meeting Agenda

- About the Authority
- Overview of the City of New Haven LTCP Updates


Rainfall Conditions

- Metered or Measured Flow
- 2-year, 6-hour Design Storm
- Typical Rainfall Year
- 2016 Baseline Conditions Model

Long Term Control Plan Update Recommended Plan:

- Short Term Improvements
- Intermediate Term Improvements
- Long Term Improvements
- LTCP Update Project Schedule & Costs





Greater New Haven Water Pollution Control Authority WWW.GNHWPCA.COM

- Four Member Communities
 - Hamden
 - East Haven
 - Woodbridge
 - New Haven
- Over 500 Miles of Collections Systems
- 30 Pump Stations
- East Shore Treatment Plant
 - 29 MGD Average
 - 40 MGD Secondary Design Flow
 - 100 MGD Wet Weather Primary

We are not a manufacturing facility!



Rather, we clean whatever you put down the pipes of your home!

Challenging work!

CUSTOMER

SERVICE


INDUSTRIAL

PRETREATMENT

COLLECTION

SYSTEMS

& SAFETY



OPERATIONS

CONTRACTORS SYNAGRO, CJ FUCCI, NATIONAL WATER MAIN

FINANCE AND

ENGINEERING

ADMINISTRATION



HAVEN

NEW

ADMINISTRATION BUILDING

PROTECTING THE ENVIRONMENT WATER POLLUTION

C

GNHWPCA COLLECTIONS CREW

> GNHWPCA OPERATIONS CREW



PROTECTING THE ENVIRONMENT

GNHWPCA ENGINEERING

> GNHWPCA CUSTOMER SERVICE

HISTORY OF COMBINED SEWERS

Map notes Mayor Henry Lewis who served between 1883-1885

1

Union Street PS (2016

ESWPAF (2016)

Sewerage System NEW HAVEN CV. DESIGNED BY E.S. Chesbrough, C.E.

East Street PS (2016)

Starles G. Fowler Sharles G. Fowler


Boulevard PS (2016)

Wastewater Collection and Treatment



What Is A Combined Sewer?

Combined Sewer Overflow Diagram



Dry Weather: Weir Wall Directs Flow To Treatment Plant

Wet Weather: Some Flow Passes Over Weir Wall



Where are The GNHWPCA CSO's?

• 13 CSO Outfalls

- 3 New Haven Harbor
- 4 West River
- 3 Mill River
- 3 Quinnipiac River


2016 Annual Metered Volume = 35.2 MG^{*}

- New Haven Harbor = 15.73 MG
- West River = 6.16 MG
- Mill River = 2.22 MG
- Quinnipiac River = 11.11 MG

CSOS

Active/Regulator
 Abandomed/Regulator
 Sewer Separation Status
 Combined
 Separated
 Sanitary
 0 0.5 1 2 3

CONNECTICUT DEEP APPROVED CITY OF NEW HAVEN'S LONG TERM CONTROL PLAN (LTCP)



- ORIGINAL LTCP APPROVED IN 2003
- LAST UPDATED IN 2011
- 2015 DEEP AMENDED CONSENT ORDER REQUIRES AN UPDATE EVERY 5 YEARS (NEXT DUE BY THE END OF 2016)

Goal:

The ultimate objective is to provide measures necessary to achieve zero discharge from all CSO outfalls during the 2-year, 6-hour storm by 2040

LTCP Work Completed

- The City of New Haven and, since 2005, GNHWPCA have made improvements to the combined sewer system that have reduced CSO frequency, duration and volume
 - Sewer separation projects
 - Truman CSO Storage Tank
 - Phase I Wet Weather Capacity Improvements at the ESWPAF
 - To be complete in 2017 at a cost of \$60 M
 - Regulator improvement projects
 - Utilizing data from CSO Flow Monitoring and Hydraulic Modeling
- Between 1997 and 2015, CSO volume has effectively been reduced by
 - 46% during the design storm from 26 MG to 14 MG
 - 66% during the typical year from 126 MG over 51 events to 43 MG over 30 events

2016 LTCP UPDATE FOCUS

MAXIMIZE FLOW TO THE EAST SHORE ABATEMENT FACILITY BY:

- **MAXIMIZING USE OF STORAGE AND CONVEYANCE**
- ✤ IMPROVEMENTS TO KEY PUMP STATIONS
- ✤ GREEN INFRASTRUCTURE







UNDERSTANDING RAINFALL CONDITIONS


KEY TERMINOLOGY:

- ✤ 2-YEAR DESIGN STORM
- ***** TYPICAL YEAR RAINFALL
- **MODELING / METERED FLOW**



Rainfall Conditions 2-year 6-hour Design Storm

- The 2-year, 6-hour design storm represents the level of control required in the Consent Decree
- During the 2001 LTCP, the rainfall depth was 2.05 inches (used during the 2015 Hydraulic Model Update)
- Due to climate change and increased extreme weather, storm frequencies change overtime and need to be reevaluated
- Rainfall depth increased to 2.13 inches (Cornell, NRCC)
- Change has some effect on system performance
 - 2.05 in: 12.9 MG of Overflow (2016 model)
 - 2.13 in: 14.3 MG of Overflow (2016 model)



Rainfall Conditions Typical Year Rainfall

• During the 2001 LTCP, 1967 was determined as a typical year of rainfall from the Tweed-New Haven Airport


- Due to climate change, increased extreme weather, and more available data, a typical year was reevaluated
- 1967 still the most typical year of rainfall in New Haven

Year	Annual Precipitation	Monthly Precipitation	Number of Events	Maximum Event Volume	Maximum Event Intensity
1967	\checkmark	\checkmark		\checkmark	\checkmark
1991	\checkmark		\checkmark		\checkmark
2007	\checkmark		\checkmark		
70 60 50 40 30 20		967			ven Tweed Airport rt Sikorsky Memorial Airport

Year

2016 Baseline Conditions Model **Overview**

- The baseline conditions model is used as the standard in which all control strategies are measured against
- The baseline conditions model reflects existing conditions to avoid inaccurate benefits of the control strategies
- The 2014 Condition Model was updated to reflect 2016 Conditions
- Model calibration was validated with historic flow monitoring data collected from 30+ meters (metered flow) within the CSO system.



EPA SWM Hydraulic Model 5

How Did We Get Immediate Benefits? KNOWLEDGE IS POWER!

- Near-term solutions
 - Reduce CSOs by modifying existing regulator structures
 - Maximize conveyance and storage in the Boulevard Trunk Sewer
- Maximize/Optimize use of the Truman Tank
- Maximize use of the Boulevard Pump Station
- Green Infrastructure Redevelopment Requirements


2016 LTCP KEY MILESTONES

- SUMMARY OF PROJECTS SINCE 2014 (2014-2016)
- SHORT TERM CONTROL PLAN (2016-2018)
- INTERMEDIATE TERM CONTROL PLAN (2018-2028)
- LONG TERM CONTROL PLAN (2028-2040)

LTCP UPDATES ARE REQUIRED BY OUR CONSENT ORDER EVERY 5-YEAR SO PROJECTS AND SCHEDULES MAY CHANGE




2016 Baseline Conditions Model Completed Projects Since 2014




2016 Baseline Conditions Model System Performance: 2-year, 6-hour Design Storm

- 2014 total CSO volume: 15.9 MG
- 2016 total CSO volume: 14.3 MG
- CSO volume reduction: 1.6 MG





2016 Baseline Conditions Model System Performance: Typical Year

- 2014 total CSO volume: 45.2 MG
- 2016 total CSO volume: 32.3 MG
- CSO volume reduction: 12.9 MG




Short Term Control Plan **Components**






Short Term Control Plan System Performance: 2-year, 6-hour Design Storm

- 2016 Total CSO Volume: 14.3 MG
- STCP Total CSO Volume: 12.1 MG
- CSO volume reduction: 2.2 MG




Short Term Control Plan System Performance: Typical Year


- 2016 Total CSO Volume: 32.3 MG
- STCP Total CSO Volume: 19.6 MG
- CSO volume reduction: 12.7 MG



Intermediate Term Control Plan Components



Intermediate Term Control Plan East Street Pump Station Site Plan



Intermediate Term Control Plan


East Street Pump Station Dry and Wet Weather Pumps

Design Criteria	Dry Weather	Wet Weather
	weather	weather
Number of pumps	3	5
Max flow	8.4 MGD	16.25 MGD

Intermediate Term Control Plan Union Pump Station Site Plan

Union Pump Station Upgrades:

- Capacity upgrades
- Flood resiliency
- Improved reliability



Intermediate Term Control Plan Union Pump Station Dry and Wet Weather Pumps

Design Criteria	Dry Weather	Wet Weather
Number of pumps	2	3
Max flow	6.2 MGD	17.5 MGD


Intermediate Term Control Plan Union Pump Station Force Main Replacement and Pipe Bridge Rehabilitation

CONSTRUCTION CHALLENGES

Existing 24-in Force main to be replaced

- Union Pump Station will require bypass pumping
- Railroad to require casing over new 24-inch force main
- Structural Evaluation to Consider Increased Load Rehab to Address
- Rehabilitate existing pipe bridge over railroad
- Consider RR track shutdown requirements and permitting requirements with RR
- The Gas Company added a gas main to the original bridge structure. Main will require relocation prior to our construction.


Intermediate Term Control Plan Boulevard Pump Station Site Plan



Intermediate Term Control Plan Boulevard Pump Station Dry and Wet Weather Pumps

Design Criteria	Dry Weather	Wet Weather
Number of pumps	3	4
Max flow	9.08 MGD	15 MGD


Intermediate Term Control Plan ITCP Flow Diagram Maximizing Use of Our Existing Infrastructure



Wastewater Collection and Treatment


Intermediate Term Control Plan System Performance: 2-year, 6-hour Design Storm

- STCP Total CSO Volume: 12.1 MG
- ITCP Total CSO Volume: 9.4 MG
- CSO volume reduction: 2.7 MG





Intermediate Term Control Plan System Performance: Typical Year

- STCP Total CSO Volume: 19.6 MG
- ITCP Total CSO Volume: 12.8 MG
- CSO volume reduction: 6.8 MG




Long Term Control Plan Components





Long Term Control Plan System Performance: 2-year, 6-hour Design Storm


- ITCP Total CSO Volume: 9.4 MG
- LTCP Total CSO Volume: 0.0 MG




Long Term Control Plan System Performance: Typical Year

• ITCP Total CSO Volume: 12.8 MG

• LTCP Total CSO Volume: 0.0 MG



CSO Long Term Control Plan Components



Evaluate Additional Methods to Minimize CSOs

- Evaluate Green Infrastructure alternatives within the Boulevard sewer tributary area can they reduce CSOs?
- Do we continue sewer separation in CSO sewersheds?
- Do we need to site CSO storage tanks in the future?

Each decisions will be based on a combination of all solutions evaluated on a sub-sewershed basis

CSO Long Term Control Project Cost Estimate Basis

- Project Costs are Expressed in 2016 Dollars and Include
 - Construction Cost Estimates
 - Contingency 20 to 35%
 - Engineering and Administration Allowance 20%

Implementation Schedule and Project Cost Estimates

				NH	GNH										
	Million	Grant	CWF	Loan	Loan										
CSO LTCP COMPONENTS	(2016 \$)	%	Grant	Share	Share	2016	2017	2018	2019	2020	2021	2022	2023-2028	2029- 2034	2035 - 2040
2016 Long Term Control Plan Update															
Short Term Improvements (2016-2018)	\$ 10.4						I	I							
Regulators 012 and 020 Relief Sewers (CWF 2016-02)	5.4	50%	2.7	1.1	1.6		I I								
West River CSO Improvements (CWF 2016-03)	2.5	50%	1.3	0.5	0.8			1							
Regulator 034 Relief Sewer (CWF 2016-05)	1.0	50%	0.5	0.2	0.3		1								
Green Infrastructure Improvements (CWF 2016-07)	1.5	50%	0.8	0.3	0.5		1								
Intermediate Term Improvements (2018-2028)	\$ 99.5														
intermediate rein improvements (2018-2028)															
Capacity Upgrade of East Street Pump Station	35.0	50%	17.5	7.0	10.5					1					
Yale Campus/Trumbull Street Phase 2A Separation (CWF 2009-04)	12.0	50%	6.0	2.4	3.6										
Capacity Upgrade of Union Pump Station	17.0	50%	8.5	3.4	5.1										
Capacity Upgrade of Boulevard Pump Station	35.0	50%	17.5	7.0	10.5										
2022 Long Term Control Plan Update	0.5	55%	0.3	0.1	0.1										
Long Term Improvements (2024-2040)	\$325.0														
Phase II ESWPAF Wet Weather Capacity Improvements	134.5	40%	53.8	32.3	48.4										
2028 Long Term Control Plan Update	0.5	55%	0.3	0.1	0.1										
Phase III ESWPAF IFAS/Incinerator Improvements	34.5	23%	8.1	0.0	26.4										
2034 Long Term Control Plan Update	0.5	55%	0.3	0.1	0.1										
Fair Haven Sewer Separation	95.0	50%	47.5	19.0	28.5										
CSO Storage Tanks/Separation/GI Alternatives	60.0	50%	30.0	12.0	18.0										
Elimination of CSOs during a 2-year, 6 hr storm	\$434.9	45%	\$194.9	\$85.4	\$154.5										

We Stay Engaged With Our Community



Please Stay Engaged with us!

- Additional Information and Periodic Updates: <u>www.gnhwpca.com</u>
- GNHWPCA Board Meetings
- Community Activities
- Community Environmental Benefit Fund
- Contact Us Engineering Department Telephone: (203) 466-5280 ext 321
- 24 hour Emergency number: (203) 466-5260
- LTCP Question Submission Deadline March 15, 2017 email to: <u>Engineering@GNHWPCA.com</u>