Appendix D Union Pump Station Preliminary Design Report

Long-Term Control Plan Update
Union Pump Station —Preliminary
Design Report

Prepared for

Greater New Haven Water Pollution Control Authority

November 2016



CH2M HILL Engineers, Inc. 100 Great Meadow Road Suite 707 Wethersfield, CT 06109

Contents

Sect	ion		Page
Acro	nyms an	d Abbreviations	ii
1	Hydr	aulics	1 -1
	1.1	Introduction	1-1
	1.2	Basis of Design	1 -1
		1.2.1 Hydraulic Design Objectives	1-1
		1.2.2 Design Flows and Pumping Strategy	1-1
	1.3	Hydraulic Model	1-2
	1.4	Hydraulic Analyses	1-2
		1.4.1 Hydraulic Profile	1-2
		1.4.2 Pipe Flow Modeling	1-3
2	Proce	ess Mechanical	2 -1
	2.1	Introduction	2-1
	2.2	Pump Station Existing Conditions	2-1
		2.2.1 Background and Existing Conditions	2-1
	2.3	Inlet Works Facilities Design Criteria	2-3
		2.3.1 General	2-3
	2.4	Pumping Systems Design	2-4
		2.4.1 Pump Configuration	2-4
		2.4.2 Pump Operating Criteria	2-7
		2.4.3 Wet Well Intake Configuration	2-7
		2.4.4 Effluent Piping	2-8
		2.4.5 Valves and Flow Meters	2-8
		2.4.6 Equipment Access and Removal	2-8
3	Struc	tural	3 -1
	3.1	Introduction	3-1
	3.2	Codes and Standards	3-1
	3.3	Structural Condition Assessment	3-1
		3.3.1 Observations and Recommendations	3-2
	3.4	Design Criteria	3-4
		3.4.1 Loading	3-4
		3.4.2 Resiliency Planning and Design Basis	3-4
		3.4.3 Design Loads	3-5
		3.4.4 Concrete	3-6
		3.4.5 Masonry	3-6
		3.4.6 Structural Steel	3-7
		3.4.7 Monorail Cranes	3-7
4	Archi	tectural	
	4.1	Introduction	
	4.2	Building Codes	
		4.2.1 Authorities Having Jurisdiction	
		4.2.2 Current Connecticut Codes	
	4.3	Union Pump Station	
		131 Ruilding Code Analysis	1_1

		4.3.2	Energy Conservation Code	4-2
		4.3.3	Building Condition Assessment	4-2
		4.3.4	New Rooms and Spaces	4-4
5	Heati		ilation, and Air Conditioning	
	5.1	Introd	uction	5-1
	5.2	Design	n Approach	5-1
	5.3	Equipr	ment	5-2
		5.3.1	Heating Equipment	5-2
		5.3.2	Ventilating Equipment	5-2
		5.3.3	Air Conditioning Equipment	5-2
	5.4	Mater	ials	5-2
	5.5	Design	n Criteria	5-3
		5.5.1	Outdoor Design Criteria	5-3
		5.5.2	Mechanical System Criteria	5-4
		5.5.3	Miscellaneous Design Criteria	5-4
		5.5.4	Louver Sizing	
		5.5.5	Ductwork Friction Rate Sizing	
	5.6	Refere	ences	
		5.6.1	Codes	
		5.6.2	Standards	
		5.6.3	Miscellaneous	
6	Plum	bing and	Fire Protection	6-1
	6.1	_	uction	
	6.2		n Approach	
		6.2.1	General	
	6.3	Equipr	ment, Materials and Systems	
		6.3.1	Equipment	
		6.3.2	Materials	
	6.4	Design	n Criteria	
		6.4.1	Potable Water System	
		6.4.2	Service Water System	
		6.4.3	Sanitary Drainage System	
		6.4.4	, , ,	
	6.5	Refere	ences	
		6.5.1	Codes	
		6.5.2	Standards	
7	Electi	rical		7-1
	7.1	Introd	uction	7-1
	7.2	Codes	and Standards	7-1
	7.3	Utility	Service	7-1
	7.4	Equipr	ment and Sequence of Equipment Replacement	7-2
		7.4.1	Existing Equipment	
		7.4.2	New Electrical Equipment	
		7.4.3	Sequence of Equipment Replacement	
	7.5		n Criteria	
		7.5.1	Energy Efficient Design	
		7.5.2	Area Classification	
		7.5.3	Design Flood Elevation and Electrical Equipment Elevation	

		7.5.4	Single Line Diagrams and Preliminary Equipment Layout	
		7.5.5	Lighting	7-5
8	Instru	mentatio	on and Controls	8-1
	8.1	Introd	uction	8-1
		8.1.1	Existing Instrumentation and Control System	8-1
	8.2	Design	n Approach	8-1
	8.3	Contro	ol System Design Philosophy	8-3
		8.3.1	Equipment Control	8-3
		8.3.2	Valve and Gate Control	8-3
		8.3.3	Motor Control Centers	8-3
		8.3.4	Adjustable Frequency Drives	8-4
		8.3.5	Power Monitors	8-4
		8.3.6	Instruments and Transmitters	8-5
		8.3.7	Surge Suppressors	8-5
		8.3.8	Pilot-Light Colors	8-5
		8.3.9	Equipment and Instrument Tag Numbers	8-5
		8.3.10	PLC I/O signals	8-5
	8.4	Contro	ol System Operating Philosophy	8-5
	8.5	Remot	e Telemetry System	8-6
	8.6	Codes	and Standards	8-6
9	Odor (Control .		9-1
	9.1	Introd	uction	9-1
	9.2	Basis c	of Design	9-1
		9.2.1	Containment	9-1
		9.2.2	Conveyance	9-1
		9.2.3	Odor Control System Sizing	9-2
		9.2.4	Anticipated Odor Causing Compounds	9-2
	9.3	Contro	ol Technology Selection	9-2
		9.3.1	Biotowers	9-3
		9.3.2	Carbon Scrubbers	9-4
	9.4	Econoi	mic Evaluation	9-6
	9.5	Odor C	Control System Design Recommendations and Overview	9-7
A	J			
Appen				
Α	Prelim	inary De	esign Drawings	
Tables				
Table 1	L-1. Flov	v Scenar	ios	1-1
Table 1	L-2. Pun	np Opera	ation	1-4
Table 2	2-1. Exis	ting Pun	nps	2-2
Table 2	2-2. Gri n	der Sele	ection	2-4
Table 2	2-3. Dry	Weathe	r Pump Selection	2-5
	-		er Pump Selections	
			quirements for Structural Steel	
			rials of Construction	
Table 5	5-2. HVA	C Outdo	oor Design Criteria	5-3
			System Criteria	
			nd Fire Protection Materials of Construction	

CONTENTS

Table 9-1. Process Area Ventilation Rates	9-2
Table 9-2. Capital, O&M and NPV Assumptions	9-6
Table 9-3. Capital, Annual O&M and NPV Evaluation	9-7
Table 9-4. Major Equipment, Design Criteria and Operating Conditions	9-7
Figures	
Figure 2-1. Existing Screen Channels	2-1
Figure 2-2. Suction and Discharge arrangement for Pump 2	2-2
Figure 2-3. Discharge header	2-3
Figure 2-4. Typical Grinder Installation	2-4
Figure 2-5: Dry Weather Pump Selections	2-6
Figure 2-6. Wet Weather Pump Selections	2-7
Figure 7-1. Building Access Hatches and Vent Pipes	
Figure 9-1. Simplified Schematic of a Biotower System	
Figure 9-2. Photograph of a Biotower System	
Figure 9-3. Schematic Dual Carbon Bed System	
Figure 9-4. Photograph of a Dual Bed Carbon Scrubber	

Acronyms and Abbreviations

AASHTO American Association of State Highway and Transportation Officials

ACGIH American Conference of Governmental Industrial Hygienists

ACH air changes per hour

ACI American Concrete Institute
AFD adjustable frequency drive

AISC American Institute of Steel Construction
ANSI American National Standard Institute
ASCE American Society of Civil Engineers

ASHRAE American Society of Heating, Refrigerating, and Air Conditioning

ASPE American Society of Plumbing Engineers
ASTM American Society for Testing and Materials

ATC automatic temperature control

Authority Greater New Haven Water Pollution Control Authority

AWWA American Water Works Association

BEP best efficiency point BFE base flood elevation

CAIECC Connecticut Amendments to the International Energy Conservation Code

CFD computational fluid dynamics

cfm cubic feet per minute
CISPI Cast Iron Soil Pipe Institute
CMU concrete masonry unit

CSBC Connecticut State Building Code

CSO combined sewer overflow

DC direct current

DDC direct digital control
DFE design flood elevation
DLR device level ring
DWF dry weather flow
DX direct expansion

fps feet per second

FRP fiberglass reinforced plastic

ft² square feet ft³ cubic feet

GNHWPCA Greater New Haven Water Pollution Control Authority

gpm gallon(s) per minute

H₂S hydrogen sulfide HI Hydraulic Institute

HMI human-machine interface

hp horsepower

HSS hollow structural sections

HVAC heating, ventilation, and air conditioning

I&C instrumentation and controls

I/O input/output

IBC International Building Code

ICRI International Concrete Repair Institute, Inc.

IEBC International Existing Building Code
IECC International Energy Conservation Code

IMC International Mechanical Code IPC International Plumbing Code

ksi kilopound(s) per square inch

kVA kilovolt-ampere(s)

LTCP long-term control plan

MAU make-up air unit
MCC motor control center
mgd million gallon(s) per day

mph mile(s) per hour

NaOH sodium hydroxide

NAVD 88 North American Vertical Datum of 1988

NEC National Electric Code

NEMA National Electrical Manufacturer's Association (NEMA)

NFPA National Fire Protection Association
NGVD 29 National Geodetic Vertical Datum of 1929

NPV net present value

O&M operations and maintenance OIT operator interface terminal

pcf pound(s) per cubic foot

PLC programmable logic controller
POR preferred operating range
ppmv part(s) per million by volume
psf pound(s) per square foot
psi pound(s) per square inch

RPM revolution(s) per minute

SLR sea level rise

SMACNA Sheet Metal and Air Conditioning Contractors' National Association

SSPC Structural Steel Painting Council

TDH total dynamic head

UI United Illuminating
UL Underwriter's Laboratory
UPS uninterruptable power supply

VFD variable-frequency drive

WEF Water Environment Federation
WPAF water pollution abatement facility

WSE water surface elevation

WWF wet weather flow

WWTP wastewater treatment plant

Hydraulics

1.1 Introduction

The Long-Term Control Plan (LTCP) Update includes alternatives that control combined sewer overflow (CSO) discharges from all CSO outfalls to meet a 2-year, 6-hour level of CSO control (zero discharges) by 2040. The LTCP Update includes short term, intermediate term, and long term improvements to meet these stated goals. This Preliminary Design Report of the LTCP focuses on intermediate and long term improvements at the Union Street Pump Station (Union). Preliminary Design Drawings are shown in Appendix A of the report.

1.2 Basis of Design

1.2.1 Hydraulic Design Objectives

The hydraulic design objective is to upgrade the Union, East Street and Boulevard Pump Stations to convey the maximum flow to the East Shore Water Pollution Abatement Facility (ESWPAF) resulting in CSO mitigation.

Models were developed to calculate how much flow can be conveyed to the wet well of the pump station using the existing and upgraded infrastructure and to evaluate improvements to the pump station to allow the station to convey the design flows.

1.2.2 Design Flows and Pumping Strategy

The flow scenarios (Table 1-1) analyzed were developed from the 2015 Hydraulic Model. The model identified the design flows necessary for the system to meet the 2-year, 6-hour level of service. Three flow scenarios were analyzed during the LTCP Update: short-term, intermediate-term, and long term.

The short-term improvements do not impact the existing flows from the three GNH pump stations. The total flow conveyed to the East Shore WPAF from the pump stations is 60 million gallons per day (mgd) split between Boulevard and East Street with each pump station pumping 30 mgd. Union currently pumps 15 mgd to East Street.

The intermediate term improvements increase the total flow conveyed to the ESWPAF. Union will be upgraded to pump 35 MGD capacity under the intermediate improvements, but capacity will be limited to between 15 and 25 MGD. East Street will be upgraded to pump up to 65 MGD, but capacity will be limited to 40 MGD. This is an increase of 10 MGD over existing capacity. Boulevard will be increased to pump up to 45 MGD, but capacity will be limited to 30 MGD.

The long-term improvements increase the total flow conveyed to the East Shore WPAF by the three pump stations to 110 mgd. The flows from the pump stations are 35 mgd from Union (pumping to East Street), 65 mgd from East Street, and 45 mgd from Boulevard.

Table 1-1. Flow Scenarios

Pump Station	Short-Term Flows (mgd)	Intermediate-Term Flows (mgd)	Long-Term Flows (mgd)
Union (to East)	15	25	35
East	30	40	65
Boulevard	30	30	45

The design parameters and considerations in selecting pumps for the stations include;

- 1. Create maximum reliability, efficiency and redundancy for flows in the dry weather range since flows in the dry weather range occur 98 percent of the time during a typical year.
- 2. Utilize extended shaft centrifugal pumps.
- 3. Maintain N+1 for dry weather and wet weather pumping conditions.
- 4. Consider space restrictions in existing station footprints.
- 5. Avoid cycling of flows at the East Street and Boulevard Pump Stations since these flows go directly to the ESWPAF.
- 6. Select pumps to operate well within the pump manufacturers' defined allowable operating range (AOR) for both wet and dry weather conditions.
- 7. For high frequency flow capacities, select pumps to operate within the pump's preferred operating range (POR) as defined by the Hydraulic Institute Standards (HIS) to obtain high wire-to-water pump efficiencies for both wet and dry weather conditions. For less frequent lower flow capacities, size pumps for operation well within the candidate pump manufacturers' defined allowable operating range (AOR).
- 8. Maintaining impeller tip speed to prevent accumulation of rags within the volute.
- 9. Maintaining scouring velocities in pump discharges to prevent grit accumulation.
- 10. Avoiding high VFD and corresponding pump speed turndown.

1.3 Hydraulic Model

Two models were developed for each pump station to identify the improvements necessary to meet the design flows.

Improvements necessary to convey the design flows by gravity from the sanitary sewer to the wet well were identified by computing a hydraulic profile using CH2M's proprietary software, WinHydro. The hydraulic model was prepared using available mechanical, structural, and civil plan-and-profile record drawings, site visits and photos.

Improvements to the existing pump station pumping capacity and force mains were identified through incompressible pipe flow modeling using AFT Fathom version 8.0. The hydraulic model was prepared using available mechanical, structural, and civil plan-and-profile record drawings and photos.

Record drawings are in the National Geodetic Vertical Datum of 1929 (NGVD 29) and have been converted to the North American Vertical Datum of 1988 (NAVD 88) by subtracting 1.05 feet from NGVD 29. All elevations referenced in this section are in NAVD 88.

1.4 Hydraulic Analyses

1.4.1 Hydraulic Profile

The hydraulic profile from the influent sewer through the station and into the wet well at Union includes the following:

- Influent Chamber flow split between screening channels
- Screening Channel (two channels)
- Junction Chamber downstream of the screening channels
- Flow split to the divided wet well

The analysis included the following two alternatives:

- Alternative 1 replacement of mechanical screens.
- Alternative 2 provide a grinder in each screening channel to grind debris entering the pump station for protection of the pumps.

The alternatives were run at the proposed long-term flow of 35 mgd. At this flow rate it was assumed both screening channels would be in service.

The results of the analysis are as follows:

- Alternative 1. The water surface elevation (WSE) coming into the influent chamber is -6.6 feet. The sewer invert coming into the chamber is -6.8 feet. This shows at max flows there is 0.2 feet of water depth as the sewer enters the chamber. A model run was performed with a WSE at the influent chamber of -6.6 feet. The run shows that the upstream infrastructure was able to deliver 35 mgd to the pump station under this alternative.
- Alternative 2. The WSE coming into the influent chamber with the grinders installed is -5.3 feet. The grinders' head loss was taken from the manufacturer's literature. A model run was performed with a WSE at the influent chamber of -5.3 feet. The run shows that the upstream infrastructure was able to deliver 35 mgd to the pump station with the grinders installed.

1.4.2 Pipe Flow Modeling

A pipe flow model was created using AFT Fathom to represent the pressurized system. The model included East Street, Union, and Boulevard Pump Stations, their force mains, the harbor crossings, and force main to East Shore WPAF. The model base was built from existing conditions. Various alternatives were added to the model to identify the improvements necessary to meet the design flows at the short-term, intermediate-term, and long-term scenarios. All scenarios used an N+1 design to meet the design flow rate with the largest pump out of service.

1.4.2.1 Union Pump Station

Union Pump Station currently has four pumps with space for a fifth pump. There are three different pump sizes. There are two large pumps with capacities of 12.9 mgd, one medium pump with a capacity of 7.2 mgd and one small pump with a capacity of 3.6 mgd. The station's firm pumping capacity is 23.7 mgd and the total pumping capacity is 36.6 mgd. Pump station flows are limited to 15 mgd during peak flows to avoid overflows in the Water Street gravity system. The station pumps to a 24-inch force main over the railroad to the submergence chamber where the flow transitions to gravity. The gravity sewer flows to the East Street Pump Station

The dry weather flow rates were calculated from the 2015 Hydraulic Model. The minimum dry weather flow to the Union Pump Station is 1.5 mgd and the average dry weather flow to Union is 3.8 mgd. The maximum flows of 35 mgd occur twice a year.

The existing pumps do not have the capacity to meet the long-term pumping scenario with the largest pump out of service (N+1 redundancy criteria). Several scenarios were investigated to meet the design flows.

• Scenario 1 (five pumps, three large and two small): This scenario utilizes the large pumps for wet weather flows and the small pumps for dry weather flows. The dry weather pumps were sized to efficiently pump the minimum flows to avoid cycling. To achieve this, the dry weather pumps were sized for 3.8 mgd and would require both pumps in service to meet the maximum dry weather flowrate. Pump redundancy would be provided by one of the wet weather pumps which would cycle at the maximum dry weather flows in the event one of the dry weather pumps was out of service.

The wet weather pumps would be sized to pump the maximum flows with one pump out of service. Each wet weather pump would be rated at 17.5 mgd.

- Scenario 2 (five pumps, three large and two small): This scenario was similar to the previous with one exception: The dry weather pumps were sized to pump the maximum dry weather flowrate with one pump out of service. To achieve this, the pumps would cycle at the minimum dry weather flowrate. The wet weather pumps are identical to those described above.
- Scenario 3 (five pumps, two large and three small): This scenario would require two pumps at 12.5 mgd and three pumps at 7.5 mgd. All pumps would be sized to pump together during wet weather. This closely matches existing capacities and would not require modifications to the existing suction piping. At max flow, the suction velocity in the existing 16-inch suction pipe is 7.5 feet per second (fps), below the max velocity recommendation of 8 fps in Hydraulic Institute (HI) standards.

It was determined that Scenario 2 was the best option to meet the design flows. This scenario allows for one of the dry weather pumps to meet the maximum dry weather flow with possible cycling (allowing the second dry weather pump to be the N+1 pump), does not require replacement of the existing wall pipes to meet maximum suction velocities, and allows for 480V service loads.

Table 1-2 shows the proposed pump operation under several flow regimes for the intermediate- and long-term flow scenarios.

Table 1-2. Pump Operation

		Total Flow (mgd)	Dry Weather Pump	Wet Weather Pump
Intermediate	Min. Dry Weather	1.5	1 pump	0
	Avg. Dry Weather	3.8	1 pump	0
	Max. Dry Weather	6.3	1 pump	0
	Max Wet Weather	25	0	2 Pumps
Long-Term	Min. Dry Weather	1.5	1 pump	0
	Avg. Dry Weather	3.8	1 pump	0
	Max. Dry Weather	6.3	1 pump	0
	Max Wet Weather	35	0	2 Pumps

1.4.2.2 Force Mains

The existing force main from Union is 24 inch and extends 230 feet to the submergence chamber where it discharges via gravity. Velocities within the force main average below 8 fps, and can peak at velocities around 16 fps a few times during the year. The duration of these peak flows are minimal. Design velocities are well within the acceptable range for this size force main. It is recommended to maintain a 24 inch forcemain.

Process Mechanical

2.1 Introduction

This section describes the basis of the process mechanical design associated with improvements to meet the intermediate and long-term flow scenarios and improve reliability of the station.

2.2 Pump Station Existing Conditions

2.2.1 Background and Existing Conditions

The design drawings for Union are dated February 25, 1960 and it is assumed the station was constructed shortly thereafter. Union is located below the elevated roadway of State Street North to the west of the Amtrak Rail Line. The station is bounded by the rail line to the east, Water Street to the south, South State Street to the west, the Knights of Columbus Museum to the north, and State Street North above. Due to the site constraints there is limited space available for expansion.

A 42-inch reinforced-concrete pipe (RCP) sewer enters an influent junction chamber from the west. A sluice gate is installed on the sewer entering the pump station. Flow splits between two screen channels downstream of the influent junction chamber. Sluice gates are installed on the influent and effluent of the screen channels. Mechanical bar screens were installed in the screen channels but have since been removed. The screen housings above the channels are still present. Figure 2-1 shows the screen channels and housings.



Figure 2-1. Existing Screen Channels

Downstream of the screen channels, the flow combines again. The flow then splits to the two sides of the divided wet well. Sluice gates are located on the wet well influent channels and a sluice gate is located on the wet well dividing wall.

There are four pumps currently installed; two on each side of the divided wet well. A small pump and large pump are connected to the north wet well and a medium pump and large pump are connected to the south wet well. An additional suction wall pipe is located on the south wet well for installation of a fifth pump. The small pump has a 16-inch wall pipe, the large pumps have 24-inch wall pipes and the medium pump and additional suction wall pipe are 20 inches.

Each pump listed in Table 2-1 is an extended shaft centrifugal pump manufactured by Fairbanks-Morse.

Pump	Make/Model	Rated Capacity	Motor Size	Speed
1	Fairbanks Morse 12"- 5710	3.6 mgd	25 HP	860 rpm
2	Fairbanks Morse 18" - E5711	12.9 mgd	75 HP	590 rpm
3	Fairbanks Morse 14"- 5710	7.2 mgd	50 HP	860 rpm
4	Fairbanks Morse 18" - E5711	12.9 mgd	75 HP	590 rpm

A gate valve is provided on the suction to each pump and a check valve and gate valve are provided on the discharge of each pump. Figure 2-2 represents the suction and discharge arrangement for Pump 2. All other pumps are typical.



Figure 2-2. Suction and Discharge arrangement for Pump 2

A wye with a plug valve is provided on the discharge riser for each pump to allow maintenance to drain and flush the risers, which have a tendency to collect grit when the pump is not operated. Figure 2-3 depicts the wye and plug valve on the riser for Pump 4.




Figure 2-3. Discharge header

The wet wells are ventilated through 10-inch diameter ducts on each side of the divided wet well. A fan located in the screening room originally vented the ducts outside of the pump station. The fan has been removed and the ducts currently vent to the atmosphere inside the screening room.

The pumps discharge to a 24-inch pipe that leaves the pump station from the south. Outside the pump station, there is a flow meter before the force main crosses the rail lines to the east.

2.3 Inlet Works Facilities Design Criteria

2.3.1 General

The current pump station arrangement does not include inlet works for protection of the pump and force main. Screens were installed with the original pump station but they have since been removed/abandoned.

Grit removal was not considered for Union. The station does not have existing grit channels and there is no place to build them due to the site constraints.

Mechanical screens were discussed and explored but does not appear to be feasible due to the constraints overhead from State Street North and limited space to locate a screenings container, washer and compactor. The container would need to be located inside the station to contain odors or be installed in a new enclosure. Installation of the screen would also be problematic without space overhead but could be feasible if installed in sections. Removal and maintenance would be difficult due to the limited space overhead. For these reasons mechanical screening was not considered feasible.

Coarse manual bar racks could be installed but they would require regular cleaning to remove collected debris and could potentially cause backups into the system.

Channel grinders can be installed in the existing screen channels to protect the pumps from stringy material and large objects. Two grinders would be installed, one in each channel, that would be able to handle the long-term flow scenario. Bar racks can be installed above the grinder in the event a grinder gets jammed. Flow would be able to pass over the top of the grinder while maintaining some level of protection for the pumps. The existing channel ranges from 4 to 5 feet wide and the grinder is 54-inches wide, a stainless steel mounting frame could be provided to make up the distance on either side of the grinder. Wipes ready cutters would be provided to further reduce the size of materials preventing them from reweaving at the pump intake.

A preliminary grinder selection is provided in Table 2-2.

Table 2-2. Grinder Selection

Max Flow Rate	21.8 mgd
Width	54-inches
Height	51.878-inches
Grinder Motor	5 HP
Drum Motors (two)	1 HP
Manufacturer	JWC CDD4020-XDM

Figure 2-4 shows a typical installation with a bar rack.



Figure 2-4. Typical Grinder Installation

2.4 Pumping Systems Design

2.4.1 Pump Configuration

As stated in Section 1, the proposed configuration for Union is to have five pumps installed; two dry weather pumps rated at 6.2 mgd and three large pumps rated at 17.5 mgd. The two dry weather pumps would be installed at positions 1 and 3 on the 16-inch and 20-inch suction wall pipes, and the three wet weather pumps would be installed at positions 2, 4, and 5 on the 20-inch and 24-inch suction wall pipes.

There are two alternatives for type of pumps to be provided at Union:

- Extended shaft vertically mounted centrifugal pumps
- Dry pit submersible vertically mounted pumps

The existing pumps are extended shaft vertically mounted centrifugal pumps. These types of pumps have the pump located in the dry well and the motor located at the top floor. A shaft from the motor extends to the pump. After an alternatives analysis, GNH has elected to remain with the extended shaft vertically mounted centrifugal pumps. Preliminary pump selections for dry and wet weather are listed in Tables 2-3 and 2-4.

Table 2-3. Dry Weather Pump Selection

Design Criteria	DWF Avg	DWF Min	DWF Max	
Number of pumps	2	2	2	
Number of pumps operating	1	1	1	
Design flow (mgd) (each pump)	3.8	1.5	6.2	
Design flow (gpm) (each pump)	2,639	1,042	4,306	
TDH at design flow (ft)	30	28.5	31	
Efficiency at design flow	78%		80%	
NPSHA (ft)	42		42	
NPSH3	4.4		8.9	
Motor (HP)	50			
Impeller (in)	22.65			
Speed	600 RP	М		
Type of Pump	Extend	Extended Shaft Vertical Centrifugal		
Model	12MN24E			
Manufacturer	Flowse	rve		

Table 2-4. Wet Weather Pump Selections

Design Criteria	DWF Max	WWF	
Number of pumps installed	3	3	
Number of pumps in operation	1	2	
Design flow each pump (mgd)	6.2	17.5	
Design flow each pump (mgd)	4,306	12,153	
TDH at design flow (ft)	31	55	
Efficiency at design flow	75%	81%	
NPSHA (ft)	41	39	
NPSH3	7.7		
Motor (HP)	250		
Impeller (in)	21.5		
Speed	900 RPM		
Type of Pump	Extended Shaft Vertical Centrifugal		
Model	16MW25B		

Figures 2-5 and 2-6 display the selected pump system curves for the dry weather and wet weather pumps.




Figure 2-5: Dry Weather Pump Selections

Figure 2-5 shows the variable-frequency drive (VFD) curve for a single pump in operation. Under the minimum dry weather flow (DWF), a single pump is operating outside the allowable operating range (AOR); under this condition, the station would cycle. Under average DWF, a single pump is operating

120 Union WWF Pumps 100 80 Head (ft) WWF 60 40 20 **DWF MAX** Intermediate 0 0 5000 10000 15000 20000 25000 30000 Flow (gpm)

within the preferred operating range (POR). Under maximum DWF, a single pump is operating within the POR.

Figure 2-6. Wet Weather Pump Selections

540 RPM

630 RPM

Series12

Figure 2-6 shows the max DWF is just outside the AOR of a single wet weather pump. During the Intermediate term the WWF (25 MGD) is near the BEP for two wet weather pumps and within the POR. During the Long Term the WWF (35 MGD) is within the POR when two pumps are in operation.

BEP

- 810 RPM

---- POR

- 720 RPM

The motors for extended shaft vertically mounted centrifugal pumps should be installed in a location that protects the pumps from damage during a flooding event. Dry floodproofing will be installed to safeguard the pumps from damage due to flooding.

2.4.2 Pump Operating Criteria

900 RPM

- AOR

During dry weather, one pump is required to meet the minimum, average, and maximum flows. The pumps were sized such that one dry weather pump would be able to meet the maximum flows (using the second dry weather pump as the N+1 redundant pump). The minimum flow for the large pumps is greater than the maximum dry weather flow of 6.3 mgd. These pumps would be used solely for wet weather pumping.

2.4.3 Wet Well Intake Configuration

The existing wet well configuration does not meet HI standards in the following areas:

- Anti-rotational baffles are required for pumps larger than 3,000 gallons per minute (gpm) (4.3 mgd).
- Pumps suctions should be located in a confined wet well where each suction inlet bell is located in a confined pocket to isolate the pump from any flow disturbances that might be generated by adjacent pumps.

For retrofit designs, meeting the requirements of HI standards is often not feasible. If designs other than those required by HI standards are shown by prototype or model tests performed in accordance with HI standards the alternative designs are considered to comply with HI standards. During detailed design,

the wet wells will be evaluated using computational fluid dynamics (CFD) modeling to verify the hydraulic efficiency and further physical testing may be required to model the existing wet well to identify measures that can be taken to comply with HI standards.

HI also provides recommendations for retrofit designs of rectangular wet wells that would help improve suction conditions. Recommendations are as follows:

- Inclusion of a baffle wall to minimize air entrainment due to falling liquid
- Setting the baffle wall below the maximum wet well level to allow any floatable material to pass over the wall
- Inclusion of fillets below the pump intake
- Inclusion of baffles between the pump intakes
- Inclusion of fillets along the sides of the wet well to eliminate dead zones

2.4.4 Effluent Piping

The existing effluent piping allows for grit to accumulate in the pipe when the pump is not in operation. This occurs because each pump discharge piping enters the discharge header at the invert. In the new mechanical configuration, the isolation valve and check valve remain at the pump level. The discharge piping enters the header from the side instead of from the bottom. This prevents grit from settling out in the discharge header as a result of upstream pump flows in the manifold. Any grit generated by that specific pump will settle to the bottom of the discharge header which should get re-suspended on high flows.

The discharge piping will wye into the header. A wye has less friction loss but only allows flow to go in a single direction further limiting the deposition of grit in each individual discharge header. This discharge header/manifold configuration is consistent with the process mechanical configuration at East Street and Boulevard pump stations.

2.4.5 Valves and Flow Meters

Gate valves are recommended for isolation upstream and downstream of each pump. American Water Works Association (AWWA) C500 double disk metal seated valves are recommended for this application. Resilient seated gate valves (AWWA C509 or 515) are prone to damage from grit, double disk metal seated valves are more robust than the resilient seated valves and leak less than a solid metal seated disk.

Check valves are provided for prevention of flow reversal on all pumps.

A flow meter will be installed on each pump discharge and on the existing 24-inch force main after it leaves the pump station.

2.4.6 Equipment Access and Removal

The grinder can be installed on slide rails to facilitate removal. A jib or gantry crane would need to be provided to remove the grinder from the channel for maintenance.

The existing monorail is rated for 2 tons. This is insufficient for the new pumps and would need to be replaced.

Structural

3.1 Introduction

This section is intended to assess the building structure components of the Union Pump Station and identify design criteria for the rehabilitation of the facility. It outlines proposed solutions to address structural deterioration, deficiencies, and upgrades to incorporate architectural, process mechanical, and MEP findings.

3.2 Codes and Standards

The current governing code utilized by the City of New Haven and the State of Connecticut is the 2016 Connecticut State Building Code. This code is based on the 2012 International Building Code and 2012 International Existing Building Code.

The following standards shall be used in support of the building code:

Standards

- ACI 318-11 Building Code Requirements for Structural Concrete
- ACI 530-11 Building Code Requirements for Masonry Structures
- ASCE/SEI 7-10 (Supp 1)—Minimum Design Loads for Buildings and Other Structures.
- ASCE 24 14 Flood Resistant Design and Construction
- CH2M HILL Water Business Group Design Guide.
- International Concrete Repair Institute Technical Guidelines (ICRI)
- ICC-ES Evaluation Reports for specific products.
- Structural Steel Painting Council (SSPC)

Reinforced Concrete

- Typical Unless Noted Otherwise: ACI 318-11 Building Code Requirements for Structural Concrete.
- Liquid Containment Structures: ACI 350-06 Code Requirements for Environmental Engineering Concrete Structures.

Concrete Repair

- ICRI GS03130 Guide Specifications for Structural Concrete Repair.
- ICRI Technical Guideline No. 03732 Selecting and Specifying Concrete Surface Preparation for Coatings, Sealers, and Polymer Overlays.

Steel

- AISC 360-10 Specification for Structural Steel Buildings, including Supplement No. 1 dated 2005.
- Manual of Steel Construction, Thirteenth Edition.
- AWS: D1.1, Structural Welding Code Steel Design Loads

3.3 Structural Condition Assessment

The construction of the Union Pump Station structure was completed in the early 1960s. The structure was designed by Gneovese and Cahn Consulting Engineers of New Haven Connecticut; original design drawings available for review are dated November 30, 1959.

The Union Pump Station structure is primarily composed of conventionally reinforced cast-in-place concrete. The foundation system is a mat foundation supported by undisturbed soils with 2-foot thick

concrete foundation walls around the below-grade wet well and dry well areas. The above-grade exterior elevations of the pump station structure is clad with brick veneer with a non-structural concrete masonry unit (CMU) backup and an 8-inch CMU partition wall has been provided between the motor room and the screen room.

The cast-in-place roof over the pump station structure is integral with a vehicular roadway above. A bridge approach slab exists on the south side and is supported by the spandrel beam. A monorail crane system supported by the roof structure is provided for maintenance of the four pumps in the dry well.

3.3.1 Observations and Recommendations

The following observations and rehabilitation recommendations (in italics) are divided into the five main areas of the Union Pump Station, and the vehicular roadway above:

- 1. Motor Room: The motor room houses electrical control panels and pump motors and provides access to the dry well area below. Some concrete deterioration was noted in the southeast corner where two 8-inch diameter pipes penetrate the wall and slab in the stair down to the Dry Well area.
 - a. The concrete floor structure in the Motor Room is in good condition; no spalling or structural distress cracking was noted.
 - b. The structure above the motor room appears to be in good condition with no observed leaks or distress.
 - c. The existing monorail crane beam and assembly appears to be in working order. The extents of the crane for access at the outside of the facility is a concern. It is recommended that the existing monorail crane be replaced with structure allowing the crane to extend outside of the building on the south side. Because a monorail crane with greater capacity may be necessary for the new pumps, the existing structure will be analyzed for reserve capacity to confirm this potential upgrade.
 - d. The floor openings for access to the dry well have a 2-inch deep metal grating over four 6x10foot openings. The grating was not flush with the floor creating a potential trip hazard. There is
 also concern over the capacity of the grating to resist point loads over an opening of this size.

 Supplemental steel framing to support new heavy duty steel bar grating or new solid access
 covers shall be provided to increase load carrying capacity over each of the dry well pumps.
- 2. Screen Room: The screen room provides access to influent channels below, screening equipment, and slide gate operators. All screening equipment in this room is no longer in service.
 - a. The concrete structure in the screen room appears to be in good condition. From sounding of the concrete with a masons hammer, deterioration was isolated around the five access hatches. All deteriorated concrete will be repaired when equipment and access hatches are replaced. A protective coating should be applied to all concrete floor surfaces in the screen room.
 - b. The five access hatches provided over the influent channels are significantly deteriorated and will require replacement. All deteriorated concrete shall be replaced around existing hatches, new flush mount aluminum access hatches rated for a minimum of 150 pounds per square foot (psf) live load shall be provided throughout the screen room. All new access hatches shall include neoprene seals to work with the proposed odor control system for this facility.
 - c. The floor drain provided in the screening room is corroded, clogged and no longer functioning. A new floor drain should be installed to aid drainage and maintenance (washdowns) within the screen room.
- 3. Dry Well: The dry well is located approximately 25 feet below the Motor Room and houses the pumps for discharge from the adjacent wet well.

- a. The dry well area concrete surfaces were in good condition. Minor leakage was noted through the existing concrete foundation walls.
- b. Structural steel braces have been provided to provide support or the pump motor shafts which extend from the motor room above. The steel appears to be in good condition, but should be recoated for protection.
- c. The stairs leading from the motor room down to the dry well are composed of galvanized steel and in good condition. A new CMU wall will be necessary to isolate the stair from the drywell area (see Section 4 Architectural in this report).
- 4. Influent Channels: Two influent channels are located below the Screen Room, the channels are constructed of reinforced cast-in-place concrete. Access to the influent channels was limited to visual inspection from above.
 - a. The access covers could be removed to view the slide gates and concrete conditions on the north and south ends. The gates and respective supports exhibit significant deterioration and corrosion and will require concrete repair at channel walls when replaced. Deterioration and corrosion of the channel structure outside of the slide gates was not observed, but with limited access the concrete surfaces should be further reviewed. Concrete repairs will be necessary around the gate structures. A protective coating should be applied to all channel concrete surfaces.
- 5. Wet Well: The wet well is located outside of the northwest side of the Motor Room and is accessed from the exterior of the Union Pump Station Structure. There are two surface mounted aluminum access hatches provided above the wet well. Access to the wet well was limited to visual inspection from above.
 - a. The two aluminum access hatches appear to be in good condition and have been replaced since original construction. The safety grating provided below each hatch was bent and did not appear to function as intended. Replace safety grating, or provide quardrails around the access hatches
 - b. The concrete surfaces within the wet well did not exhibit deterioration in areas that could be observed, but the concrete does not appear to have a protective coating. A protective coating should be applied to all concrete wet well surfaces.
- 6. Vehicular Roadway: The Roadway located directly above the Union Pump Station is also composed of cast-in-place concrete.
 - a. The roadway bridge approach on the south side of pump station is also a concrete structure, and is currently supported by steel brackets embedded into the building south elevation spandrel beam. These brackets are intended to provide an expansion joint between the structures. Leaks have developed from the roadway above allowing water infiltration into the exterior wall assemblies and onto structural elements below. Corrosion of the steel support brackets (5 locations) has occurred; leaks also expose the concrete structural elements to deicing salts which will lead to deterioration. The extents of deterioration of the roadway approach support brackets could not be determined due to the buildup of corrosion. At a minimum the brackets should be cleaned of corrosion and protected with a coating system. The roadway expansion joint assembly above should be replaced to minimize further structure exposure to moisture and deicing salts infiltrating from above.

3.4 Design Criteria

3.4.1 Loading

Design loading criteria is not noted on the existing drawings available for review. Prior to renovation/rehabilitation, a structural analysis should be completed to confirm expected loads during construction and during future service.

3.4.2 Resiliency Planning and Design Basis

As part of its recognition of future coastal resiliency impacts, the State of Connecticut has directed that all projects using State funding, such as the Clean Water Fund (CWF), must include features that address potential sea level rise and coastal resiliency issues within its design. Each of these stations are either within or directly adjacent to the 100-year floodplain, as determined by the Federal Emergency Management Agency (FEMA). The current Flood Insurance Rate Maps (FIRMs) for the New Haven area have recently been updated as a result of documented impacts from Hurricane Sandy, and recent regional evaluations of sea level rise trends and future projections. Due to this revision, the regulatory base flood elevations have risen by 1 foot at both East Street and Boulevard Pump Stations, but remain the same for Union Pump Station.

In accordance with the Public Act Nos. 13-15, the CWF is required to consider the necessity and feasibility of implementing measures designed to mitigate the impact of a rise in sea level over the projected life span of such a project. To further the abilities of municipalities to implement this requirement, the New England Interstate Water Pollution Control Commission (NEIWPCC) updated its Technical Release 16, Guides for the Design of Wastewater Treatment Works (TR-16) and provided guidance on selecting an appropriate protection elevation related to the criticality of each process component and the impact on the environment if that process was impacted during a storm event. The guidance document separates facilities into two types: critical and non-critical. Critical facilities are defined as those systems that are required for the conveyance of wastewater to and through a treatment facility. This includes all electrical, mechanical, and control systems within a pump station. The recommendation in TR-16 is to elevate these critical elements a minimum of 3 feet above the 100-year flood elevation.

As part of the recent Phase 1 Wet Weather Capacity Improvements and Nitrogen Reduction Project at the South Shore WPAF, an evaluation was conducted to establish the resiliency elevation for use during this construction project. This evaluation included consideration of recent regional coastal sea level rise evaluations, along with elevating equipment above the 500-year flood elevation. Combining these two elements resulted in a protection elevation for the East Shore WPAF of 2.95 feet (NAVD 88) above the established 100-year base flood elevation. As part of this Preliminary Design Report, the protection elevation is being set at 3 feet to be consistent with the TR-16 guidance.

The Union Pump Station was evaluated for the feasibility and necessity of elevating critical equipment to maintain operations during a flooding event. It was deemed not feasible or cost-effective to elevate all equipment due to existing space limitations, or overall station configuration. In addition, due to the interconnectivity of the station with existing outfalls adjacent to the stations, certain areas will be inundated without the ability to protect the interior of the facilities from rising flood waters. For this purpose, GNH has taken the approach of providing dry floodproofing where critical equipment must remain below the resiliency protection elevation, and providing wet floodproofing where appropriate to maintain structural stability and allow the facility to quickly regain full operations once the flood waters recede. In general, floodproofing methods include construction of cast-in-place structural walls around the perimeter of each area to be dry floodproofed, with implementation of removable bulkheads at roll up doors and personnel doors as needed. Wet floodproofing methods include installation of flood vents

to allow hydrostatic pressures to equalize on either side of facility walls during the flooding event allowing immediate return to service following cessation of flood waters. Specific floodproofing locations are included in the Preliminary Design Drawings included in Appendix A.

3.4.3 Design Loads

Loads shall be based on the most stringent criteria of the Building Codes and Standards listed above. In some cases, the minimum loads listed in the American Society of Civil Engineers *Minimum Design Loads* for Buildings and other Structures (ASCE 7) may be equivalent criteria and may be substituted for the loads listed below. In all cases, the minimum criteria shall conform to the minimum requirements of the International Building Code (IBC), as amended by the 2016 Connecticut State Building Code.

3.4.3.1 Floor Live Loads

In accordance with codes and standards listed above, and the following minimums:

Process Rooms 300 psf on slabs and beams and

200 psf on girders, columns

Electrical Rooms 300 psf Storage Areas 150 psf

Mechanical/HVAC Rooms 150 psf or Equipment weight plus 50 psf

Allow for rolling equipment out

Stairs, Walkways and Platforms 100 psf Platforms Only for Access 60 psf

Vehicular Traffic AASHTO HS 20-44

3.4.3.2 Wind Loads

Wind loads will be based on Risk Category III unless otherwise noted, with an ultimate design wind speed (Vult) of 135 mph (3-second gust), Exposure C.

3.4.3.3 Snow Loads

Some of the areas of the existing structure are exposed to potential snow loads. Existing areas requiring analysis and areas of new construction will be analyzed with the following assumptions.

Ground Snow Loads 30 psf Importance Factor 1.1 Snow Exposure Factor 1.0

3.4.3.4 Flood Loads

Hydrostatic Loading of 63 pcf will be assumed up to the proposed Sea Level Rise Elevation (SLR). The screening room portion of the structure will be designed for Wet Flood resistance, and the pump room dry well areas will be designed for Dry Flood resistance.

The following assumptions apply to the Union Pump Station, all elevations are based on NAVD 88.

Base Flood Elevation (BFE): +11.0'
Design Flood Elevation (DFE): +12.0'
Sea Level Rise Elevation (SLR): +14.0'

3.4.3.5 Liquid Loads

Refer to Drawings for design water levels and top of base slab elevations. Extreme loads during a seismic event will also be taken into account during detailed design.

Load cases that will be considered in detailed design of liquid holding basins are:

- All basins full of liquid, no backfill.
- Backfill and groundwater with empty tank
- Any tank cell empty or full in any combination.
- A fluid pressure of 62.4 pcf will be used for hydrostatic loads from ground water and flooding.
- A fluid pressure of 63 pcf will be used for process liquid in these basins, unless otherwise noted.

3.4.4 Concrete

Materials and design procedures for concrete are described below.

3.4.4.1 Materials

The following minimum requirements apply (concrete compressive strength at 28 days):

•	Typical Concrete, unless otherwise noted	4,500 psi
•	Concrete Fill, unless otherwise noted	3,000 psi
•	Curbs and Sidewalks	3,000 psi
•	Conduit Encasements and Pipe (encasements not integral with foundation)	4,500 psi
•	Precast Concrete	5,000 psi

Reinforcement:

Conventional Steel: ASTM A615, Grade 60 (f_v = 60 kilopounds per square inch [ksi])

3.4.4.2 Design Procedures

Strength design will be used for concrete in accordance with ACI 318 unless noted otherwise. Hydraulic structures will be designed in accordance with ACI350.

Design of concrete hydraulic structures will include use of environmental durability factor (Sd), for anticipated fluid and earth loads during normal operation only. Available capacity of members will be checked for loads that may occur during extreme design events.

During detailed design, existing slabs and structural elements will be checked for intended design load capacity.

3.4.4.3 Details of Steel Reinforcement

Minimum concrete cover over steel reinforcement will be as follows:

•	Surfaces cast against soil	3 inches
•	Typical unless otherwise noted	2 inches

3.4.5 Masonry

Materials and design procedures for masonry are described below.

3.4.5.1 Materials

The following requirements apply:

- Hollow concrete masonry units will conform to ASTM C 90 and will be normal- or medium-weight units with a net area compressive strength of 1,900 psi.
- Mortar will conform to ASTM C 270, Type S.

- Grout will conform to ASTM C 476. Minimum 28-day compressive strength will be 2,000 psi.
- Steel reinforcement will conform to ASTM A615, Grade 60.
- Horizontal joint reinforcing steel will conform to ASTM A82.

3.4.5.2 Design Procedures

Allowable stress design will be used for masonry in accordance with ACI 530. Compressive strength of masonry, f'_m , for masonry assembly will be 1,500 psi. For design, calculated tensile/compressive stress, f_s , of steel reinforcement is 24,000 psi for deformed bars and 30,000 psi for wire in joints.

3.4.5.3 Details of Steel Reinforcement

- 1. Limit maximum spacing of vertical steel reinforcement in bearing walls and partition walls to 4 ft. and 8 ft., respectively.
- 2. Provide bond beams at top of walls.
- 3. Use joint reinforcement at 16-in. maximum vertical spacing.

3.4.6 Structural Steel

Materials and design procedures for structural steel are described below.

3.4.6.1 Material

The material requirements for structural steel are listed in Table 3-1.

Table 3-1. Material Requirements for Structural Steel

Shape	ASTM	Grade	Fy (ksi)	Fu (ksi)
Rolled Shapes, Plates and Rods	A36	-	36	58
W-shapes & WT-shapes	A992	-	50	65
Pipes	A53	В	35	60
Round Hollow Structural Sections (HSS)	A500	В	42	58
Square and Rectangular Hollow Structural Sections (HSS)	A500	В	46	58
Bolts for Connections (1/2" to 1" diameter)	A325 or F1582	-	-	120
Anchor Rods – Dry Areas Only	F1554	36	36	58
Anchor Rods – Typical	F593	316, Cond. CW	40	80
Welding Electrode	E70XX			70

3.4.6.2 Design Procedures

Structural steel design will be in accordance with the American Institute of Steel Construction's (AISC's) *Steel Construction Manual*.

3.4.7 Monorail Cranes

Monorail Cranes shall meet requirements of the AISC's *Steel Construction Manual* and ASCE 7. Unless noted otherwise, vertical impact shall be 25 percent of maximum wheel load. Lateral force on crane

runway shall be calculated as 20 percent of sum of rated capacity of crane and weight of hoist and trolley. Lateral force shall be assumed to act horizontally at traction surface of a runway beam, in either direction perpendicular to beam. Longitudinal force on crane runway beams shall be calculated as 10 percent of maximum wheel loads of crane. Longitudinal force shall be assumed to act horizontally at traction surface of a runway beam in either direction parallel to beam.

Architectural

4.1 Introduction

This section assesses the architectural components of the Union Pump Station and presents the design criteria for upgrades to the facility. The architectural assessment consisted of three tasks: interviewing staff, visiting facility site, and reviewing available facility documentation. It outlines proposed solutions to deficiencies found from building and code assessment completed. These recommendations are intended to serve as preliminary guidance for the design of facility renovations.

4.2 Building Codes

The 2016 Connecticut Building Code, which is based on the 2012 International Building Code (IBC) and 2012 International Existing Building Code (IEBC) will be used as a basis of this.

4.2.1 Authorities Having Jurisdiction

The Union Pump Station is located in the City of New Haven, Connecticut. The City of New Haven Building Department enforces the Connecticut State Building Code.

4.2.2 Current Connecticut Codes

Per the State of Connecticut Department of Construction Services, the following codes have been adopted and are applicable to this project:

Building Code: 2012 International Building Code (IBC) as modified by CSBC.

Existing Building Code: 2012 International Existing Building Code (IEBC) as modified by CSBC.

Accessibility Code: ICC/ANSI A117.1-2003 Accessible and Usable Buildings and Facilities as

modified by CSBC.

Fire Code: Connecticut State Fire Safety Code including all current Amendments to

the fire code.

Energy Code: 2012 International Energy Conservation Code (IECC)

Mechanical Code: 2012 International Mechanical Code International Mechanical Code

(IMC) as modified by CSBC.

Plumbing Code: 2012 International Plumbing Code (IPC) as modified by CSBC.

Electrical Code: 2014 National Electrical Code (NEC) as modified by CSBC.

4.3 Union Pump Station

4.3.1 Building Code Analysis

4.3.1.1 Enclose Stairs

Egress distance from north end of Pump Room to egress door is greater than the 75 feet allowed by code. It is important to note that rollup doors are not considered an exit from the room, so there is no exit from the south side of the building. The design will include the following components:

- 1. Enclose existing stair with 1-hour fire-rated CMU walls.
- 2. Add exterior fiberglass reinforced plastic (FRP) door in existing wall at existing window.

- 3. Add interior fire-rated FRP doors on both levels.
- 4. Relocate or remove gas piping from stair.
- 5. Add FRP door and opening into concrete wall on southwest corner of the space south of the pump station.

4.3.1.2 Sprinkler System

Current code requires floors with limited fire fighter access doors and openings to have a sprinkler system. The lower level Pump Room has limited fire access, so a sprinkler system is required. The design will include the addition of a sprinkler system to the lower level Pump Room.

4.3.2 Energy Conservation Code

4.3.2.1 Insulation

The walls and ceilings have no insulation, which does not meet Energy Code for conditioned spaces. The design will include the addition of a 5-inch spray-on, fire-retardant insulation to the bottom of the concrete roof slab and beams, which will provide an R-value of 19.

4.3.3 Building Condition Assessment

4.3.3.1 Brick

Exterior brick is deteriorated from water damage with face of the brick exhibiting spalling, efflorescence on surfaces, and brick ties rusted out. The brick damage is worse on the south and west elevations where water is leaking from above. The design will include the following:

- 1. Repair joint in road at the south end of the Union Pump Station to prevent water from getting into south wall.
- 2. Add coating to top and side of Union Pump Station concrete roof on east and west sides of the road. An alternate may be to add built-up roofing and aluminum fascia instead of a coating.
- 3. Add stainless steel flashing to top and bottom of exterior walls to direct water out of the cavity wall. Add vapor retarder on the outside face of existing CMU inside wythe.
- 4. Replace brick including new stainless steel wall ties, mortar nets, and weep holes.

4.3.3.2 Painting

The ground floor walls and ceilings are not painted. Equipment and piping is in need of painting. The following solutions are recommended:

- 1. Surface prepare and paint walls and ceilings in all the ground floor rooms with a chemical resistant epoxy paint system. If the insulation is added to the ceiling, then paint may not be necessary.
- 2. Epoxy paint floor of new restroom.
- 3. Surface prepare and paint piping, equipment, and supports in all the rooms with a chemical resistant epoxy paint system.

See below on Lintels, Windows, and Doors for more details on painting.

4.3.3.3 Lintels

The lintels above doors and windows are rusted on the south wall of the Motor Room and Screen room and the north wall of the Screen Room. The design will include the following:

- 1. Ventilate rooms to help remove moisture and fumes. Add new FRP louvers.
- 2. Seal around louvers.

- 3. Implement brick improvements to help prevent water infiltration.
- 4. Replace damaged steel lintels with galvanized steel framing painted with a chemical resistant epoxy paint system.

4.3.3.4 Windows

Existing steel windows need replacement. The design will include the following:

- 1. Remove windows/plywood from three Screen Room and one west Motor Room openings, and replace with CMU and brick. These windows are not on exterior of building but open into the enclosed space under the bridge structure, so they are not needed.
- 2. Remove four windows from east Motor Room openings and replace with insulated translucent panels with 8x8-inch grid pattern and aluminum frame. Paint existing steel lintels with a chemical resistant epoxy paint system.
- 3. Seal around windows.

4.3.3.5 Doors

Doors to Screening Room are deteriorated and need replacement. The rollup door to the Motor Room also needs replacement. Note, rollup doors are not considered an exit from the room, so the current Pump and Motor rooms have only one exit. All other doors appear to be in good condition, but may be replaced so all doors are new. The design will include the following:

- 1. Remove rollup door on south Motor Room wall and masonry above door to bottom of concrete roof beam. Install new nominal 10-foot-high FRP double door and frame.
- 2. Monorail could be extended to run through the double door and have monorail seals on the doors.
- 3. Remove Screen Room south double door and single north door and replace with FRP doors and frames with heavy duty stainless steel hardware.
- 4. Seal around doors.
- 5. See document sections for Stair Enclosure, Restroom, and Control Room for additional doors.

4.3.3.6 Grating, Hatches, and Handrail

Grating in the Screen Room is missing or corroded and needs to be replaced. Grating in Motor Room is not level and is not attached, which is a tripping hazard. There is only one handrail on stair into Motor Room. Handrails are required by code on both sides of stairs. Roof hatch above Screening Room is rusted and in need of replacement. The design will include the following:

- 1. Remove Screen Room grating and replace with FRP grating. Make all grating level with floor.
- 2. Remove Motor Room grating, clean recesses and reinstall with clips and fasteners.
- 3. Add aluminum wall handrail on the north side of stair.
- 4. Remove existing hatch and replace with new Type 316 stainless steel hatch.

4.3.3.7 Wood Enclosure

The wood walls are a fire hazard and restrict exiting from Pump Station. The walls also trap moisture and will mold. The wood walls were installed as a means of access restriction to the area. The design will include the following:

- 1. Remove wood walls.
- 2. Install chain link security fence with 8-foot swing gate at east side of road above. Fence to be constructed to maintain access control from the Water Street overpass area.

4.3.4 New Rooms and Spaces

4.3.4.1 Restroom

No restroom, sink or drinking fountain is required by code but has been requested by Owner. The design will include the following:

- 1. Add CMU walls to enclose a restroom with a toilet and sink near the Motor Room stair.
- 2. Add FRP door and frame to Restroom with privacy lock.
- 3. Replace existing service sink with stainless steel service sink and faucet.
- 4. Add drinking fountain outside of restroom.
- 5. Add commercial grade stainless steel partitions and accessories.

4.3.4.2 Control Room

Enclose new electrical equipment so it can be climate controlled. The design will include the following:

- 1. Add CMU walls to enclose new control and electrical equipment in Motor Room.
- 2. Add FRP door and frame to Control Room.

Heating, Ventilation, and Air Conditioning

5.1 Introduction

Ventilation measures will be established based on the 2012 National Fire Protection Association standard - *Fire Protection in Wastewater Treatment and Collection Facilities* (NFPA 820). NFPA 820 establishes outside air ventilation rate criteria as well as ventilation design recommendations for safeguarding against fire and explosion hazards specific to wastewater treatment plants and associated collection systems.

5.2 Design Approach

Air handling units will be located outside on an elevated platform above the sea level rise elevation on the east side of the structure. Air handling units serving electrically classified areas will be designed to supply tempered 100 percent outside air without recirculation, except where NFPA 820 allows dual ventilation rate during cold weather and the space atmosphere is relatively moisture and corrosive vapor free. Combustible gas detectors will override air handling systems operating in dual mode if combustible gases are detected.

Ventilation will be continuous and at rates adequate to reduce area NFPA 820 electrical classifications one category where required to suit the design. Ventilation systems that are required to reduce electrically classified spaces one category shall be monitored and provided with alarm stations located within and at entrances to these spaces. Air handling units in electrically classified areas will be designed in such a way as to isolate the unit supply air stream from the process area in the event the unit is turned off or loses power. An intermediate damper will open to atmosphere to provide a naturally vented air break space between the unit interior and the process space.

Air will be exhausted via exhaust fans mounted where foul air is not present within the space. Areas containing foul air will be exhausted to a Cross-flow Carbon Treatment System, as described in Section 9 – Odor Control in this report. Air will be exhausted low within the space to facilitate removal of hydrogen sulfide that collects along the floor.

Supplemental electric unit heaters will be provided throughout spaces as required to maintain local heating needs during winter.

Louvers/vents/exhaust fans or supply/exhaust fans will be used to supplement ventilation in areas requiring higher summer ventilation rates or intermittent ventilation.

Staff areas and electrical rooms requiring air conditioning will be provided with ductless split system DX equipment as required to suit the space need. Critical electrical and control rooms will be provided with redundant air conditioning systems if necessary to ensure space temperatures can be met if primary units should fail.

Facilities will be provided with an automatic temperature control (ATC) system for global monitoring and control of heating, ventilation, and air conditioning (HVAC) equipment. The control system will be based on an open architecture (Lon or BACnet) direct digital control (DDC) system or programmable logic controller (PLC) based system, the selection of which will be determined during design. ATC panels will be located in "clean spaces" (e.g., electric room, control room) where possible. Control devices such as sensors and thermostats will be provided with suitable enclosures designed for the associated atmosphere in which they are located.

A new heating/ventilating unit (HV-1) will be provided for the Screen Room. The unit will be located at grade above the flood protection elevation. The unit will supply 12 air changes/hour (ACH) with 100 percent outside air in order to reduce the NFPA electrical classification from Class 1 Division 1 to Class 1 Division 2. The supply air will be tempered to minimum 55 degrees F during winter in order to protect plumbing and water piping from freezing. The ventilation rate will be reduced to 6 ACH, as allowed by NFPA 820 and whenever the outside air temperature is 50 degrees F or below, the space is unoccupied and the combustible gas detector is 10 percent below the lower explosive limit of methane. The heating/ventilating unit and exhaust fans will be provided with AFDs and a separate exhaust fan will be provided to maintain proper temperature conditions for the pump motors during the summer months. The heating/ventilating unit (HV-1) will be sized to provide tempered make-up air for wet wells through screen room floor penetrations.

A separate heating/ventilating unit (HV-2) and exhaust fan will be will be provided for the Dry Well/Motor Control Center (MCC) Room. The unit (HV-2) will be located on an elevated platform on the east side of the building. The space will be heated and ventilated at a rate of 12 ACH with 100 percent outside air. The supply air will be tempered to minimum 55 degrees F during winter in order to protect plumbing and water piping from freezing.

5.3 Equipment

The specific type of equipment used on a particular building will be determined during detailed design based on application. Roof or platform mounted equipment will be used where possible to preserve floor space and to minimize equipment exposure to aggressive environments. The following types of HVAC equipment may be utilized on this project.

5.3.1 Heating Equipment

- Air handling units incorporating outside air hoods, filters, Natural Gas HX, fans, and air break plenums, as required.
- Electric unit heaters.

5.3.2 Ventilating Equipment

- Exhaust fans
- Supply fans
- Wall louvers
- Roof vents

5.3.3 Air Conditioning Equipment

• Split system air conditioning units

5.4 Materials

Table 5-1 provides various material choices that may be used for HVAC systems depending on the type of atmosphere in which equipment is installed. Specific materials will be selected during detailed design to suit the application.

Table 5-1. HVAC Materials of Construction

Area	Atmosphere (1)	Equipment or System	Materials of Construction
Process Corrosive		Ductwork	SS, FRP
		Equipment	HPCS
Process Non-corrosive		Ductwork	Al
		Equipment	HPCS
		Ductwork	GS/AI
Non-process	Non-corrosive	Equipment	GS/AI

Table Notes and Abbreviations:

(1) Corrosive areas are areas that have elevated levels of moisture, hydrogen sulfide or chemical vapors.

Al – Aluminum

FRP – Fiberglass Reinforced Plastic

GS - Galvanized Steel

HPCS - High Performance Coated Steel

SS - Stainless Steel (Type 316)

5.5 Design Criteria

5.5.1 Outdoor Design Criteria

Table 5-2. HVAC Outdoor Design Criteria

Location	Elevation (Ft.)	Cooling Criteria (ASHRAE 0.4%) ⁽¹⁾		Heating Criteria (ASHRAE 99.6%)
Navy Haven CT	20	DB (°F)	MCWB (°F)	DB (°F)
New Haven, CT	20 —	90.7	73.2	8.5

Table Notes and Abbreviations:

 $^{(1)}$ Cooling criteria for critical spaces such as electrical equipment rooms shall be based on extreme conditions (100° F).

ASHRAE – American Society of Heating, Refrigeration and Air Conditioning Engineers, 2013 Fundamentals

DB – Dry Bulb Temperature

MCWB – Mean Coincident Wet Bulb Temperature

5.5.2 Mechanical System Criteria

Table 5-3. Mechanical System Criteria

Space or Area	Cooling (°F)	Cooling Method	Heating (°F)	Heating Method	Ventilation Basis
Process Areas	5-10 °F above ambient	Outside Air Ventilation	55	G	100% OA
Control Rooms	75	AC	68	E	6 ACH min (5 cfm/person and 0.06 cfm/ft ² OA)
Electric Rooms	75	AC	55	E	6 ACH min (0% OA)
Personnel Areas	75	AC	68	G,E	6 ACH min (5 cfm/person and 0.06 cfm/ft ² O.A.)

Table Abbreviations:

AC – Air Conditioning

G - Gas Heating Method

ACH - Air changes/hour

OA - Outside Air

E – Electric

5.5.3 Miscellaneous Design Criteria

Not Used.

5.5.4 Louver Sizing

- 1. Intake Louvers 500 ft. per minute
- 2. Exhaust Louvers 800 ft. per minute

5.5.5 Ductwork Friction Rate Sizing

- 1. Low Pressure: 0.1 in. of water column pressure drop per 100 ft. of ductwork up to an air velocity of 1,500 to 1,800 ft. per minute.
- 2. Medium Pressure: 0.2 in. of water column pressure drop per 100 ft. of ductwork up to an air velocity of 2,000 to 2,500 ft. per minute.
- 3. Transfer Ducts: 0.03-0.05 in. of water column pressure drop per 100 ft. of ductwork.
- 4. Outside Air Intake Shafts: 0.05-0.10 in. of water column pressure drop per 100 ft. of ductwork up to an air velocity of 1,000 ft. per minute.
- 5. Gravity Relief Shafts: 0.03-0.05 in. of water column pressure drop per 100 ft. of ductwork up to an air velocity of 1,000 ft. per minute.

5.6 References

5.6.1 Codes

The HVAC design shall follow all applicable local, state, and federal codes and criteria. The following codes will be used for the mechanical design of this project:

2016 Connecticut State Building Code

- 2012 International Building Code
- 2012 International Mechanical Code
- 2012 International Energy Conservation Code
- 2005 Connecticut State Fire Safety Code

5.6.2 Standards

The following standards and guides will be used for the mechanical design of this project:

- 1. ASHRAE (American Society of Heating, Refrigerating and Air Conditioning Engineers)
- 2. SMACNA (Sheet Metal and Air Conditioning Contractors' National Association)
- 3. ACGIH (American Conference of Governmental Industrial Hygienists) Industrial Ventilation Manual of Recommended Practice
- 4. NFPA (National Fire Protection Association)

5.6.3 Miscellaneous

5.6.3.1 Calculation Software

Heating and Cooling Load Analysis: Trane Trace 700

Plumbing and Fire Protection

6.1 Introduction

Any modification to existing plumbing system to support the existing or new processes and facilities including potable water piping, service water piping, sanitary drainage piping, storm drainage piping, will be selectively provided for each facility as required by the current building codes or local authority.

6.2 Design Approach

6.2.1 General

Limited existing plumbing system modification has been considered for project as detailed in subsequent sections.

- The existing plumbing fixtures are recommended to be replaced.
- The existing potable and non-potable water piping is recommended to be replaced with new piping, as required.
- Provide a new restroom facility.

6.3 Equipment, Materials and Systems

6.3.1 Equipment

The specific type of equipment that will be used on a particular building will be determined during detailed design based on application. Listed below are types of plumbing equipment that may be used for this project.

- Storage type electric or gas-fired water heaters
- Wall-mounted instantaneous electric water heaters
- Backflow preventers
- Emergency eyewash and shower stations
- Sump and sewage ejector pumps
- Plumbing fixtures such as service sink, water closet, lavatory, drinking fountain and kitchen sink
- Hose stations
- Floor, air gap, standpipe and roof drains
- Electric heat trace systems

6.3.2 Materials

Table 6-1. Plumbing and Fire Protection Materials of Construction

Area	Atmosphere ⁽¹⁾	Equipment or System	Materials of Construction
Dunner	Companies	Piping	SS/GS/CU/AL/HCI/CU/CPVC
Process	Corrosive	Equipment	Coated GS/AI/SS/CU
Dunnan	Nan aannaina	Piping	CU/BS/CI/DI
Process	Non-corrosive	Equipment	Coated GS/AI
A dualitation at the co	Nanananaina	Piping	GS/BS/CU/DI/PVC
Administration	Non-corrosive	Equipment	GS/CS
Administration -	Nanananaina	Piping	CU/BS/CI/PVC
Toilet Rooms	Non-corrosive	Equipment	CU/DI/CI
Table Notes and Abbreviations:		CU - Co	onner

Table Notes and Abbreviations:

CU - Copper

(1) Corrosive areas are areas that have elevated levels of moisture, hydrogen sulfide or chemical vapors.

CI – Cast Iron
DI – Ductile Iron

PVC – Polyvinyl Chloride

BS – Black Steel

SS - Stainless Steel (Type 316)

HCI - High Silicon Cast Iron

GS – Galvanized Steel

CS - Carbon Steel

Al – Aluminum

CPVC – Chlorinated Polyvinyl Chloride

6.4 Design Criteria

6.4.1 Potable Water System

Water Source: City Water
Minimum Pressure: 30 psi
Maximum Pressure: 80 psi
Maximum Velocity: 8 fps

Hydrostatic Test Pressure: 100 psi minimum

6.4.2 Service Water System

Water Source: City Water
Minimum Pressure: 20 psi
Maximum Pressure: 100 psi
Maximum Velocity: 8 fps

Hydrostatic Test Pressure: 150 psi minimum

6.4.3 Sanitary Drainage System

Type: Gravity

Minimum Pipe Slope: 1/8-in. per ft.

Minimum Velocity: 4 fps

6.4.4 Storm Drainage System

Type: Gravity

• Minimum Pipe Slope: 1/8-in. per ft.

Minimum Cover: 4 ft.Minimum Velocity: 4 fps

6.5 References

6.5.1 Codes

The design of this project will be governed by the Connecticut State Building Code 2016 Edition, Connecticut State Fire Safety Code 2005 (with amendments) and all adopted International Codes including the International Plumbing and International Fire Codes.

6.5.2 Standards

The following standards and guides will be used for the plumbing and fire protection design of this project:

- ANSI (American National Standard Institute)
- ASPE (American Society of Plumbing Engineers)
- ASTM (American Society for Testing and Materials)
- AWWA (American Water Works Association)
- CISPI (Cast Iron Soil Pipe Institute)
- IBC (International Building Code)
- IFC (International Fire Code)
- IPC (International Plumbing Code)
- NFPA (National Fire Protection Association)

Electrical

7.1 Introduction

The electrical work at Union pump station will consist of adding a generator and automatic transfer switch to supply backup power to the facility as well as new electrical service equipment, MCCs and switchgear. The existing switchgear is over 55 years old, and will be replaced in its entirety. New pump motors will be compatible with and controlled by adjustable frequency drives to provide precise control, improve efficiency, and reduce power factor losses.

Architectural improvements to the site will be made so that the motor room is sealed and is not exposed to Class I, Division 1 or 2 atmospheres. Most electrical equipment including the MCC, PLC, and adjustable frequency drives (AFDs) will be placed in a climate controlled electrical room.

The sequence of construction will be scheduled in order to minimize down time and allow suitable pumps to be available at all times, except for 4- to 8-hour shutdowns to transfer power and swap out individual pumps.

Close coordination with the local utility United Illuminating (UI) will be required throughout this project, as a new utility service will be provided for this facility.

The work required for this station is described in further detail below.

7.2 Codes and Standards

The following codes and standards will apply to the design, and may be referenced in this document:

- 1. National Fire Protection Association (NFPA): 70, National Electrical Code, 2014 Edition.
- 2. NFPA: 820, Standard for Fire Protection in Wastewater Treatment and Collection Facilities, 2016 Edition.
- 3. National Electrical Manufacturer's Association (NEMA)
- 4. Underwriter's Laboratory (UL)

7.3 Utility Service

The power provider to the Union Pump Station is United Illuminating (UI), which is based locally in New Haven. The UI transformer is enclosed in a separate above ground brick building on the south side of the pump station. The transformer could not be accessed during the site walk inspection.

CH2M contacted UI to discuss this service. UI indicated that the existing service is 300 kilovolt-amperes (kVA) (three 100 kVA single phase can-type transformers). The new load flow for this station is expected to be approximately 600 kVA, so the existing transformers must be replaced with new. The existing primary service voltage is 13.8 kV, and UI will need to provide an adequately sized transformer with a 480 volt secondary. UI indicated that they need to start an extensive study on how to provide this service at this location, as the existing service is underground, and space is limited. UI asked CH2M to formally request an engineering study be done in order to provide this service, and CH2M has made this request.

Arrangements will be made to keep existing equipment running from the existing service during construction. The new power feed from UI will not be installed until generator power is established to the new equipment.

7.4 Equipment and Sequence of Equipment Replacement

7.4.1 Existing Equipment

The existing switchgear and some of the motor controls were installed with the original station that was designed in 1959. The switchgear has outlived its useful life, and will be replaced. Existing motor controls are also contained within the existing switchgear. An external controller with an interface to a fiber cabinet was added at a later date.

All switchgear and motor controls will be demolished and replaced as a part of this project. Lighting panels, disconnects, cable, and exposed conduit will be replaced.

The existing generator manual transfer switch is rated 240 volts, and is being used to connect a portable 480-volt generator to the existing 480 volt MCC.

7.4.2 New Electrical Equipment

A new electrical room will be constructed in order to provide a conditioned space for most electrical equipment. The electrical equipment room will be located in the same area as the existing MCC, bounded by the stairwell, start of pump grating, west wall, and partial north wall where the existing generator disconnect is mounted.

The room is not large enough to house all of the electrical equipment. For this reason, two adjustable frequency drives, the automatic transfer switch, generator batteries and controls, and miscellaneous panelboards will need to be mounted outside of the conditioned space.

7.4.2.1 Generator and Related Equipment

A new 1000kVA generator is required to provide full backup power to this pump station. The generator will need to be located outdoors in the yard, to the west of the pump station. The recommended location is to the west of the existing screen room, as it is more accessible for maintenance than locations to the south of the building. The generator will be mounted in a weatherproof enclosure with top of floor elevation of 14.00 feet, to meet sea level rise criteria, so that the generator will be protected from flooding.

The generator diesel fuel tank will be located outdoors near the generator. It is also recommended that the diesel fuel tank be mounted on a pad with a pad elevation of 14.00 feet. It would also be acceptable to mount the tank lower and seal the tank so that water could not penetrate the tank below elevation 14.00. A 3000-gallon tank will provide at least 48 hours of run time under fully loaded conditions. This quantity of fuel storage will also be sufficient for 96 hours of run time at normal load.

Generator batteries and controls will be mounted in the generator enclosure.

7.4.2.2 Automatic Transfer Switch

An automatic transfer switch, rated 1200A, will be located in the motor room to automatically transfer power from the utility to the generator, then back to the utility upon return of generator power.

7.4.2.3 Motor Control Center

A 1200A motor control center, designated MCC-1, will distribute power to the station. The 1200A MCC will not be of an arc resistant configuration, because there is not room available in this building to provide the arc resistant configuration. The MCC will be located in the new electrical room. Low voltage switchgear will not be used for power distribution, as switchgear is wider and deeper, and there is no room available for low voltage switchgear at this facility.

7.4.2.4 Adjustable Frequency Drives

The MCC will feed five AFDs: three rated 250 horsepower (hp), and two rated 50 hp. One of the 250 hp AFDs are standby, while the others can be expected to run at the same time. All five AFDs can fit within the conditioned room. The 250hp AFDs will be eighteen pulse. Allen-Bradley drives may be too large to fit within the motor room, and they could be excluded from bidding Union Station if the current arrangement goes to bid. Allen-Bradley 250 hp AFDs are 65 inches wide and 26-32 inches deep, while the Cutler-Hammer offering is 48-60 inches wide and 26 inches deep. The exact dimensions of the PLC will be determined during detailed design, and this will determine whether or not the Allen-Bradley AFDs will fit in the conditioned room. The reason for the variation in the Cutler Hammer AFD sizing is that the lower value is for the selected horsepower number at variable torque. If a horsepower increase occurs, or a constant torque drive is required, the higher value would be required. The larger Cutler-Hammer enclosure is shown on the layout drawings. Most manufacturers other than Allen-Bradley will be able to fit their 18-pulse AFDs within this footprint. The 50hp AFDs will be six pulse, will be wall mounted, and their size is not of consequence to the design of the room (approximately 9" wide and 8" deep).

7.4.3 Sequence of Equipment Replacement

Existing equipment must remain in service to keep the pump station running during construction, with down time being limited to eight hours or less, preferably four or less. The following construction sequence will be used to accomplish this goal:

- 1. Install new motor control center.
- 2. Install automatic transfer switch, generator, generator batteries and associated controls.
- 3. Verify generator can power new switchgear.
- 4. Work with UI to determine optimal sequence to transition to new power feed. If a new feed can be brought to the pump station while existing feed powers existing equipment, establish new power feed to new gear while existing power is in place to existing gear. If this is not possible, new gear can be powered from the generator, or temporarily fed via a jumper from the existing gear. If UI must replace the transformer in place, the pump station will need to run on generator power during this time. If existing gear is still feeding equipment, the existing MCC will need to be temporarily fed from the generator.
- 5. Install AFD-1, AFD-3, and AFD-5, as these AFDs are not in locations occupied by the existing MCC. Terminate wiring to PLC in these AFDs.
- 6. Install Pump 5. Connect power cable from new MCC to AFD-5, and from AFD-5 to Pump 5. Run this pump in manual as it is required.
- 7. Swap out Pumps 1 and 3, one at a time. Connect power wire from the MCC to each AFD and connect power wire from the pumps to the AFD, and run them in manual as they are required.
- 8. De-energize and remove power feed to existing MCC. Remove the first column of this MCC. Temporarily feed existing MCC from new MCC.
- 9. Transfer miscellaneous feeds, from existing MCC to new MCC.
- 10. Repeat Steps 5 and 7 for Pump/AFDs 3 and 4.
- 11. Remove remnants of existing switchgear.
- 12. Install PLC and establish control of new equipment.
- 13. Demo existing equipment and remove temporary feeds.

7.5 Design Criteria

7.5.1 Energy Efficient Design

All pump motors are currently started across the line, and run at full speed. The new design will include AFD controllers for each pump motor. These AFDs will allow the pump to run at an optimum speed and higher efficiencies with lower power factor losses.

Existing pump station lighting will be replaced with more efficient LED type lighting wherever possible.

7.5.2 Area Classification

The existing facility was designed with the intent of the motor room and pump level below being unclassified. The screen room was designed to be a Class I, Division 1 area. Access hatches and vent pipes outside the building allow wastewater gasses to escape into the atmosphere near the building, per Figure 7-1.



Figure 7-1. Building Access Hatches and Vent Pipes

The boarded window in the photograph is not a properly sealed window. Since the gasses from the wet well below can escape into the motor room through this boarded window, the motor room, and therefore the pump room, is classified as Class I, Division 1, and the equipment is not rated for this environment.

Although the room is technically classified, it is not of immediate concern since the window is boarded up, the wet well access hatches are usually closed, and very little if any air is getting in through the boarded window. It is satisfactory to address this issue as a part of the upcoming project.

The solution is to replace the boarded up window with a concrete masonry unit wall.

Note the vent pipe shown in the lower left corner of the photo above. Per NFPA 820, Figure A.4.2.(c), the area is classified Class I, Division 1 within three feet of the vent outlet, and is classified Class I, Division 2 between a three and five foot radius of the vent. Fortunately, the west entrance to the motor room is six feet from the vent, so the gasses expelled through this vent will not reach the door and affect the classification of the room per NFPA 820.

The motor room, pump room, stairwell, and all new rooms created within motor room are unclassified per NFPA 820.

The wet well is a Class I, Division 1 area. The screenings room above the wet well is a Class I, Division 1 area if it is ventilated at less than 12 ACH. The screenings room will be classified as Class I, Division 2 if the room is ventilated at 12 or more ACH. There is a wet well vent near the north screenings room door. However, the vent does not affect the area classification of the screenings room, as this room as already classified.

7.5.3 Design Flood Elevation and Electrical Equipment Elevation

The new electrical equipment described below shall be mounted on an equipment pad 1 foot, 1 inch above the finished floor, to meet the criteria of design flood elevation (DFE) with one foot freeboard. It is not possible to meet the design criteria of DFE with sea level rise (SLR) of three feet above the base flood elevation. The bottom of the beams are only 10 feet above the floor. Equipment manufacturers will be required to manufacture their equipment such that all switches in their highest position are no more than 7 feet, 6 inches above the finished floor. If this is not possible, a stick will be provided per NEC to reach switches that are above that height. The motor control room and dry well will be additionally protected from flooding by dry floodproofing the exterior of the building.

Motor control centers are approximately 7½ feet tall. To meet the DFE with SLR criteria, the electrical equipment would be mounted on a pad 3 feet above finished floor (AFF). This would put the top of the MCC against the bottom of the beams. Even if the MCCs could be located in areas that are not below beams, other equipment such as AFDs would be located against the wall, and not be able to fit underneath the beam. Even in areas not under the beams, clearance required for conduit turns is inadequate.

All floor-mounted electrical equipment will be mounted on equipment pads 13 inches AFF. Existing equipment pads will be completely removed and reinstalled, and new pads will be installed where required.

The outdoor generator and fuel tank can be mounted above elevation 14.00 to meet DFE with SLR criteria, since it is outdoors. An elevated walkway will be required to access the generator weatherproof enclosure. The fuel tank may be mounted lower, if it is flood proofed below elevation 14.00.

7.5.4 Single Line Diagrams and Preliminary Equipment Layout

Refer to attached drawings for single line diagram and preliminary equipment layout.

7.5.5 Lighting

Existing lighting will be replaced with state-of-the-art LED type fixtures in all areas, including Class I, Division 1 and Class I, Division 2 areas. LED frog-eye type emergency lighting fixtures will also be provided.

Existing outdoor lighting fixtures will be replaced with metal halide or LED type fixtures. Where existing lighting is insufficient, new lighting will be added.

Instrumentation and Controls

8.1 Introduction

This section documents the instrumentation and control (I&C) design concepts for the Union Pump Station. A state-of-art I&C system will be provided to ensure continuous and reliable process control and monitoring for the pump station, including remote monitoring and control from the East Shore WPAF.

8.1.1 Existing Instrumentation and Control System

The existing control system for the Union Pump Station is housed in two panels. The panels are mounted in the pump motor room.

The level based control logic for the pumps is executed in a pump control panel that receives the wet well level signal and turns the constant speed pumps on and off based on preset level setpoints. This panel also displays the wet well level, pump status and alarm signals, and provides the means to manually operate the pumps via HAND/OFF/AUTO and LEAD/LAG selector switches.

The second panel contains a Modicon Momentum PLC system that receives the pump status and alarm signals, and wet well level signals from the pump control panel, and communicates them to the East Shore WPAF plant SCADA system via a radio link. The radio antenna for communication with the East Shore WPAF is mounted on the building across from the pump station. The radio link does not provide equipment control from the plant.

There is no permanently mounted Operator Interface Terminal (OIT) or human-machine interface (HMI) computer at the pump station.

The level in the wet well is monitored by pressure transducers. The pump station flow is locally monitored by an electromagnetic flow meter. The pump station gates are manually operated.

There is no onsite generator at the pump station. A transfer switch provides means to hook up a portable generator in case of an emergency.

The pump station does not have an odor control system.

8.2 Design Approach

The existing instrumentation and control system at the Union Pump Station is out-of-date. It lacks the modern hardware and software, as well as instrumentation required for reliable operation. The overall goal is to remove obsolete control system equipment and to take advantage of the current technology for improved operational reliability and process optimization.

A new climate controlled electrical/control room will be provided at the pump station. The proposed location and layout of the room are detailed in the Architectural and Electrical Sections.

To bring the pump station to the same platform as the East Shore WPAF, a new control panel with redundant (hot backup) Allen-Bradley ControlLogix PLC system will be provided in the control room.

The PLC control panel will be equipped with an Allen-Bradley PanelView Plus 6 1500 OIT to provide means for local monitoring and control (e.g., LEAD/LAG/ALTERNATE selection, PLC AUTO/ PLC MANUAL mode selection, setpoints, etc.). A desktop HMI work station, loaded with Factory Talk View SE Standalone Client software, be also provided in the control room. All features available at the OIT will also be available at the HMI work station.

As detailed in the Process Mechanical Section, the new pumps at the Union Street Pump Station will be adjustable speed. The AFDs for the pumps will be installed in the electrical/control room.

Power monitors will be provided in the new MCC for monitoring power consumption and quality.

In addition to hardwired signals, device level rings (DLRs) will be used for Pump Station PLC communication with AFDs and power monitors to manage traffic on the control network.

Control system equipment will be powered from a true online double-conversion-type uninterruptable power supply (UPS) unit to maintain reliable operation during power system disturbances and outages. UPS unit will power the PLCs, operator interface terminals, and HMI operator workstation. UPS battery backup will have enough capacity to energize the control system for 30 minutes after a power failure. The low-battery alarm will be hardwired to the Plant PLC input/output (I/O) for monitoring. The panel will be designed to automatically switch over to the line power upon UPS failure.

For powering loop powered instruments, redundant 24 V DC power supplies will be provided in the PLC panel. The power supply failure alarm will be hardwired to the plant PLC I/O.

Electric or hydraulic actuation will be provided for all valves and gates. In general, electric actuators, rated for the environment, will be used. If the actuator can potentially be submerged, hydraulic actuation will be considered. Based on field observations, all gates and valves at the Union Pump Station can be electrically actuated.

To complement process redundancy, the monitoring and control signals for redundant equipment (e.g., pumps, grinders, etc.) will be split between separate I/O modules and racks (if necessary)

The control systems for the new odor control system and the new generator system will be PLC/OIT based. The package control systems will not be customized to use Allen-Bradley hardware if the system vendor's "standard" operating platform is different. Instead, gateways and/or protocol convertors will be provided for digital connection to the Pump Station PLC System. The system supplier will program the package PLCs. Hardwired I/O will be used for connecting critical monitoring and control signals from the package systems to the Pump Station PLC System. The digital interface will be used for monitoring of additional signals. Digital data interface requirements between the package systems and the Pump Station PLC System will be further developed during design development and coordinated with the package system vendors.

The sump pump control panel will be replaced. If new sump pumps are provided, a new control panel will be specified. The panel will be mounted above the flood plain or in the control room

The existing pressure transducers for wet well level monitoring will be replaced with new non-fouling, hydrostatic pressure type transmitters, designed specifically for wastewater applications. The transmitters will be installed in stilling wells. As a backup to the level transmitters, high and low level switches will be provided to operate the pumps upon failure of a transmitter.

A new electromagnetic flow meter will be provided for pump station flow monitoring. The meter will be located in a vault outside the pump station and will provide analog flow signal to the Pump Station PLC.

Detailed change-out procedure will be developed so that the new I&C equipment can be installed and tested prior to being put into operation. The design will allow the new Pump Station PLC System and the existing control system to coexist for some time as the new system is brought online and the old system is decommissioned. The pump station will remain operational during switchover.

Security camera system with DVR will be provided at the pump station. The location and quantity of cameras will be determined during design development.

8.3 Control System Design Philosophy

The following summarizes the control system design philosophy for the Union Pump Station.

8.3.1 Equipment Control

All equipment to be controlled by the Pump Station PLC System will have a local ON/OFF/AUTO selector switch located on or very close to the equipment. With this selector switch in the ON position, the equipment will operate. In the OFF position, the equipment will not run. When the selector switch is in the REMOTE position, the equipment will be controlled by the Pump Station PLC. AUTO status of the selector switch, and the ON, OFF, and FAIL status of the equipment, will be monitored by the Pump Station PLC. Process interlock and permissive functions will be programmed in the PLC. However, personnel and equipment safety functions (for example, pump low-low level and high-discharge-pressure shutdown) will use conventional control hardware, such as electromechanical relays. These interlocks will be hardwired to the equipment starter or AFD. The hardwired failure conditions will also be transmitted to the Pump Station PLC for alarming.

8.3.2 Valve and Gate Control

Modulating valves/gates will be electrically actuated with integral controllers. LOCAL/OFF/AUTO selector switches, OPEN/STOP/CLOSE pushbuttons, and 4-to-20-mA DC position transmitters will be provided locally. When the selector switch is in the LOCAL position, the valve/gate will be operated via the local OPEN/STOP/CLOSE pushbuttons. In AUTO position, the valve/gate will be controlled by the Pump Station PLC based on a 4-to-20-mA DC control signal from the PLC. The AUTO status of the selector switch and the valve position will be monitored by the Pump Station PLC.

OPEN/CLOSE service process valves/gates will be electrically actuated. LOCAL/OFF/AUTO selector switches and OPEN/CLOSE pushbuttons will be provided locally. When the selector switch is in the LOCAL position, the valve/gate will be operated via the local OPEN/CLOSE pushbuttons. In AUTO position, the valve will be controlled by the Pump Station PLC based on OPEN and CLOSE command signals from the PLC. Both OPEN and CLOSED limit switches will close the circuit at the end of travel and transmit a signal to the Pump Station PLC.

Reversing starters, control-power transformers, and all auxiliary controls required for electrically operated valve/gates will be part of the valve actuator package.

8.3.3 Motor Control Centers

Each MCC starter bucket will have a separate 120 V AC control power transformer. RUNNING and OFF status pilot lights, FAIL alarms pilot lights, and RESET pushbuttons will be provided on each bucket. Auxiliary contacts will be provided to connect to the Pump Station PLC System. As mentioned earlier, local control stations with ON/OFF/AUTO selector switches will normally be provided in the field. In some instances, these devices may be mounted on the MCCs. The local controls will be provided at only one location (MCC or field).

All motor-driven equipment that is energized by an MCC starter and controlled from the Pump Station PLC System will have the following features:

- All control devices, such as START/STOP pushbuttons and LOCAL/OFF/AUTO selector switches, regardless of their location, will be energized from the MCC's control power transformer.
- All solenoid-operated valves that are unique to the specific equipment will be powered from the MCC's control power transformer.

The following monitoring and control functions will be hardwired:

- AUTO status of the ON/OFF/AUTO selector switch to the Pump Station PLC
- RUN status to the Pump Station PLC
- START and STOP control signals from the Pump Station PLC when the selector switch is in the AUTO position
- Motor OVER LOAD alarm to the Pump Station PLC
- Individual FAIL alarms for the interlock signals that are hardwired to the MCC (for example, high temperature, low-low level, high-pressure shutdown) to the Pump Station PLC, as required for the specific application

8.3.4 Adjustable Frequency Drives

All AFDs that are 50 hp or smaller will be installed in the MCCs. Larger AFDs will have a standalone enclosure located in the electrical room.

RUNNING and OFF status pilot lights, FAIL alarms pilot lights, and RESET pushbuttons will be provided on each AFD. Auxiliary contacts will be provided to connect to the Pump Station PLC System. As mentioned earlier, local control stations with ON/OFF/AUTO switches will normally be provided in the field. In some instances, these devices may be mounted on the AFD enclosure. The local controls will only be provided at one location (AFD or field).

With the selector switch in the ON position, the equipment will operate, and its speed will be controlled via the HMI module at the AFD. In the OFF position, the equipment will not run. When the selector switch is in the AUTO position, the equipment will be controlled by the Pump Station PLC System based on START and STOP commands and the SPEED CONTROL signal from the PLC. The following monitoring and control functions will be hardwired:

- AUTO status of the ON/OFF/AUTO selector switch to the Pump Station PLC
- RUN status to the Pump Station PLC
- START and STOP control signals from the Pump Station PLC when the selector switch is in the AUTO position
- 4-to-20-mA DC SPEED CONTROL signal from the Pump Station PLC when the selector switch is in the AUTO position
- 4-to-20-mA DC SPEED FEEDBACK signal to the Pump Station PLC
- AFD FAIL alarm to the Pump Station PLC
- Individual FAIL alarms for the interlock signals that are hardwired to the AFD (for example, high temperature, low-low level, high-pressure shutdown) to the Pump Station PLC, as required for the specific application

As mentioned earlier, AFDs will also have an Ethernet DLR connection to the Pump Station PLC System. This will be used for monitoring purposes only. Smaller AFDs that are installed in the MCC will not be networked.

8.3.5 Power Monitors

Power monitors will be provided for the new MCCs. Power monitoring will be provided for each main feeder to the MCC and for major equipment (>50 hp) that is fed from the MCC.

As mentioned earlier, the power monitors will also have an Ethernet DLR connection to the Pump Station PLC System.

8.3.6 Instruments and Transmitters

"Smart" microprocessor-based field transmitters with HART protocol will be installed wherever possible. For configuring and calibrating instruments and transmitters, two universal hand-held programmers with appropriate software for each type of instrument will be provided. All field transmitters will be provided with a local signal indicator, calibrated in percent or actual engineering units.

Field instrument selection will be in accordance with GNHWPCA preferences.

8.3.7 Surge Suppressors

Surge suppressors will be provided at both ends for all signal and copper Ethernet cables that leave the envelope of the buildings. 120-V AC surge suppressors for all field instruments that require a 120-V AC power source will also be provided. All control panels will be provided with power line surge suppressors.

8.3.8 Pilot-Light Colors

The pilot light colors will follow the existing convention at the plant. RED/GREEN lights will be used to indicate RUNNING/OFF status for motors, OPEN/CLOSE status for valves, and TRIPPED/CLOSED status for circuit breakers. AMBER lights will be used for alarms.

8.3.9 Equipment and Instrument Tag Numbers

The equipment and instrument numbering will follow the existing unit process based convention at the plant.

8.3.10 PLC I/O signals

The following standard signal types will be used to stay compatible with the existing system:

- Digital inputs: 120 VAC rated dry contact in field
- Digital outputs: 120 VDC
- Analog inputs: 4-to-20-mA DC at 24-V DC into 750 ohms, powered from the PLC cabinet or field
- Analog output: 4-to-20-mA DC at 24-V DC into 750 ohms, powered from the PLC output module

A minimum of 20 percent installed spare I/O of each type will be provided. One of each type of I/O module (that is, analog input, analog output, digital input, digital output) will be provided per panel regardless of whether that panel requires that I/O type. Three empty I/O slots will be provided in each panel. Minimum of 20 percent spare terminal blocks will be provided in each panel. The spare PLC I/O will be wired to the terminal blocks

8.4 Control System Operating Philosophy

The system will be designed with four levels of control. Each level will provide progressively more process automation. With the exception of package control system panels, local area control panels will not be provided.

Local Manual Control. Each piece of process equipment will be provided with local control stations
for maintenance and troubleshooting operations. Local control stations will be located on or very
close to the equipment being controlled. Examples are ON/OFF/AUTO and LOCAL/OFF/AUTO
selector switches, START/STOP and OPEN/CLOSE pushbuttons, STOP lockout, and RESET
pushbuttons. Local controls will allow operations and maintenance (O&M) staff to bypass automatic
control. These controls are not intended for long-term equipment operation. Hardwired personnel

and equipment safety interlocks will stay active in this mode of operation. The process interlocks will be bypassed.

- **PLC Manual Control.** This control level will provide the capability to manually control the process equipment at the Pump Station OIT and HMI (for equipment controlled by the Pump Station PLC), or the package system OIT (for equipment controlled by the package system PLC). All of the hardwired equipment and personnel safety interlocks and some of the critical process interlocks with be active in this mode.
- PLC Automatic Control. This will be the normal mode of operation. In this mode, the PLCs will
 control the process equipment based on programmed control algorithms and functions, including
 continuous closed-loop control and sequential control. Operator will select the operating
 parameters and set points at the OITs or the HMI. All of the equipment and personnel safety
 interlocks, as well as process interlocks, will be active in this mode.
- Plant SCADA Control. This supervisory control level will provide control of the pump station from the East Shore WPAF. For example, the plant operators will be able to remotely change the operating mode of the equipment from PLC Auto to PLC Manual. This will allow the operators to Start/Stop the equipment and Open/Close the gates remotely from the plant. The available interlocks in this mode will be the same as the PLC Manual Control mode mentioned above. It is anticipated that this mode will be only be used occasionally if the operations staff is not able to drive to the pump station in a timely manner. Normally, the pump station operation from the East Shore WPAF will be limited to remote setpoints and operating parameter changes. A soft switch at the plant HMI with password security will be provided to enable this mode of operation. The switch to this mode will need to be carefully coordinated with the pump station operators.

8.5 Remote Telemetry System

The existing radio telemetry system at the Union Pump Station will be replaced by a 900 MHz Ethernet radio system for a better data throughput. The antennas at the pump station and at the East Shore WPAF will be replaced. The work will also include addition of Ethernet radios at the East Shore WPAF.

As a backup to the radio telemetry system, T1 line or cellular modems will be considered for communication between the pump station and the treatment plant. The possibility of buying bandwidth on the city's fiber optic network will also be evaluated. The system telemetry system will be configured to automatically fail over to the backup communication path upon primary path failure.

8.6 Codes and Standards

Following is the list of codes and standards that will be followed for the design:

- Institute of Electrical and Electronics Engineers, Inc. (IEEE): C62.41, Recommended Practice on Surge Voltages in Low-Voltage AC Power Circuits.
- International Society of Automation (ISA):
 - RP12.06.01, Recommended Practice for Wiring Methods for Hazardous (Classified) Locations Instrumentation Part 1: Intrinsic Safety.
 - S5.1, Instrumentation Symbols and Identification.
 - S5.4, Instrument Loop Diagrams.
 - S50.1, Compatibility of Analog Signals for Electronic Industrial Process Instruments.

- TR20.00.01, Specification Forms for Process Measurement and Control Instruments, Part 1: General.
- National Electrical Code (NEC).
- National Electrical Manufacturers Association (NEMA):
 - 250, Enclosures for Electrical Equipment (1,000 Volts Maximum).
 - ICS 1, Industrial Control and Systems General Requirements.
- National Fire Protection Association (NFPA): 820, Standard for Fire Protection in Wastewater Treatment and Collection Facilities.

Underwriters Laboratory, Inc. (UL): 508A, Standard for Safety, Industrial Control Panel

Odor Control

9.1 Introduction

The Union Pump Station currently has no odor control. As part of this *Long-Term Control Plan Update*, and as a result of the close proximity of the Union Pump Station to public areas and highly utilized transportation routes, inclusion of odor control is recommended in order to mitigate odor complaints associated with continued operation of the facility.

The Union Pump Station processes that will receive odor control include an inlet chamber, two parallel channels that include grinders, an outlet chamber and two wet wells.

9.2 Basis of Design

This section provides information used as the basis for the odor control system design. The proposed odor control system is based on a "contain-convey-treat" design approach and as such includes design information for each component.

9.2.1 Containment

The existing channels contain sections of grating that allow for comingling of sewage vapors with the overlying room space that can then result in the release of sewage odors to the ambient atmosphere. Containment of foul air to within the process area, i.e., within channels, will be achieved by replacing the grating with solid panels to create a separate controlled headspace within the channels. Panels will be designed using materials of construction resistant to corrosion e.g., fiberglass reinforced plastic (FRP) or aluminum checker plate. Covers will be constructed using flat removable panels. The cover design will facilitate easy removal of individual panels by two people. Each panel will not weight more than 100 lbs and will have an integral nonskid surface. Lifting handles shall be provided on each panel. Each panel will have gasketed joints to prevent fugitive air release.

As a result of the containment of foul air within the process channels, protection of concrete against corrosion using either protective coatings or liners is recommended and will be included during detailed design.

9.2.2 Conveyance

Foul air will be conveyed from within the contained process channels and wet wells by FRP ductwork. It is anticipated that up to four foul air pickup locations will be designed, two associated with channels and one for each wet well. Each foul air pickup location will include a flow balancing damper to facilitate adjustment of flow for each pickup to design values. The foul air duct will connect to the covers through a flanged connection to allow for easy removal. The duct will rise vertically up and then move horizontally at a distance overhead ensuring clearance e.g., min 7 ft. The exact layout will be determined during detailed design.

Allowance for air flow into the covered process channels and wet wells will be included in the design. The relative locations of air entry and foul air extraction will be selected to achieve good overall air movement within the enclosed process area and minimize development of "dead zones" or short-circuiting.

The extraction of foul air will be achieved through use of a single exhaust fan constructed of FRP. A flow balancing damper will be located at the fan inlet to allow for adjustment of overall system air flow. The

fan will convey captured foul air to an odor control system where the odorous compounds, primarily hydrogen sulfide (H_2S), are removed prior to release to the ambient atmosphere.

9.2.3 Odor Control System Sizing

All process areas will be continuously ventilated at 12 ACH. Table 9-1 summarizes ventilation rates required for the Union Pump Station. A plan view containing process areas is shown in the plans. The total system ventilation rate is 5,000 cubic feet per minute (cfm).

Table 9-1. Process Area Ventilation Rates

Source	ID no.	Volume (ft3)	Ventilation Rate (ACH)	Ventilation Rate (cfm)	Design Ventilation Rate (cfm)
Inlet Box	1	1,278	12	255	300
East Channel	2	2,032	12	406	450
West Channel	3	2,032	12	406	450
Outlet Box	4	1,374	12	275	300
South Wetwell	5	10,370	12	2,074	2050
North Wetwell	6	7,205	12	1,441	1,450
Total				4,857	5,000

9.2.4 Anticipated Odor Causing Compounds

CH2M recommends that air sampling be completed at the Union Pump Station in order to definitively establish hydrogen sulfide (H₂S) concentrations and the nature of peaks observed during normal diurnal cycles. It is recommended that an instrument capable of measuring and logging H₂S concentrations (e.g., Odalog) be installed for a week. Based on data previously collected at East Street and Boulevard Pump Stations, and experience from other similar systems, it is anticipated that H₂S concentrations may average on order of 10 parts per million by volume (ppmv) with peaks as high as 100 ppmv. Additionally, it is anticipated that other odorous non- H₂S sulfur bearing compounds will total less than 1 ppmv.

9.3 Control Technology Selection

Due to the anticipated ventilation rates and relatively low H_2S concentrations to be treated, two options have been evaluated; biotowers and carbon scrubbers. Both of these systems have a proven record for odor control, have low operation and maintenance requirements, and have a relative small footprint.

Another biological-based odor control technology, biofilters, is not recommended for consideration due to the relatively large footprint associated with this technology and very limited available site space at Union Pump Station.

Wet chemical scrubbers are another proven technology that may have potential. However, this technology is not recommended for further consideration due to the congested nature of the pump station site and its close proximity to nearby public areas and the need to transport, store and use hazardous chemicals associated with chemical scrubbers, i.e., sodium hypochlorite and sodium hydroxide.

A brief description of biotower and carbon technologies are provided below.

9.3.1 Biotowers

In many ways, a biotower looks externally similar to a wet chemical scrubber, except that no hazardous chemical addition is required. Figure 9-1 depicts a simplified schematic diagram of a biotower system.

Systems are pre-engineered, vendor-supplied systems made of fiberglass-reinforced plastic or high density polyethylene shells. Biotowers use a biologically active media bed to absorb and oxidize odorous compounds from the foul air stream. One of the primary technical advances associated with this technology is the development of engineered inert media on which the biomass attaches. As the media is inert, it is not compromised by the acidic environment within the biotower and has lifespans on the order of 20 years. The media receives either constant recycle spray (bioscrubber) or intermittent oncethrough spray humidification (biotrickling filter), depending on the vendor's approach. The spray is also the source of trace nutrients for the biological system. There are typically two potential sources of water, potable or plant effluent. If potable water is used, then a supplemental nutrient supply containing trace organics, nitrogen, phosphorous, and potassium is required. If plant effluent is available, then supplemental nutrients are usually not required as the plant effluent water will contain sufficient nutrients. For Union Pump Station, potable water and supplemental nutrients would be required as plant effluent is not available.

Biotowers are usually designed in the form of a cylindrical arrangement such as those shown in Figure 9-2.




Figure 9-1. Simplified Schematic of a Biotower System



Figure 9-2. Photograph of a Biotower System

9.3.2 Carbon Scrubbers

Carbon scrubbers are the simplest of the vapor phase treatment technologies. They pass the foul air stream through a bed of dry (no irrigation) activated carbon. Odorous constituents diffuse into the media pore spaces and adsorb onto the media, and are thereby removed from the air stream. There are many types of activated carbon media designed for removal of various types of compounds. A single medium or a mixture of different media can be used. Carbon scrubbers have a small footprint compared to other technologies and can be configured with either vertical upward air flow through single, dual or radial flow beds or with horizontal flow configurations in locations where system height is constrained. Figures 9-3 and 9-4 depict a simplified schematic and photograph of a dual carbon bed system, respectively. Carbon scrubbers are effective at removing a range of compounds with excellent removal efficiency. One potential disadvantage is that under high H_2S loads, the media must be replaced frequently resulting in high annualized media replacement costs. However, the Union Pump Station is anticipated to have relatively low average H_2S concentrations (e.g., ≤ 10 ppmv); therefore, the potential use of carbon scrubbers as a treatment technology is recommended for consideration.

Carbon selection is an important part of designing carbon systems, because different types of carbon can be used depending on the nature of the odorant to be removed. For Union Pump Station, the primary odorant to be designed for is H₂S.

Various types of carbon are available. Virgin activated carbon is the lowest cost but also has the lowest overall capacity for H_2S resulting in relatively high frequency media replacements. Carbon adsorption capacity for H_2S can be increased with media that is impregnated with chemicals, such as sodium hydroxide (NaOH), to enhance contaminant removal. This, however, adds handling complexity because of the potentially hazardous nature of the impregnated carbon and potential for carbon bed fires. The

use of this type of impregnated carbon is not recommended for further consideration. Finally, there are carbons available that have been processed in a manner that results in high selective adsorptive capacity for H_2S (e.g., order of magnitude higher than virgin activated carbon). The use of this type of high capacity carbon is recommended for consideration as it will extend the useful life of the carbon significantly thereby reducing O&M issues and costs associated with frequent media replacement.




Figure 9-3. Schematic Dual Carbon Bed System



Figure 9-4. Photograph of a Dual Bed Carbon Scrubber

9.4 Economic Evaluation

An economic evaluation has been completed in order to compare capital costs, annual O&M costs and a 20-year net present value (NPV) for the carbon and biotower technologies.

Capital construction cost estimates were based on a database of recent vendor quotes for similar technology and were escalated to a midpoint of construction date of 2020. Operation and maintenance costs were estimated and combined with capital costs using a constant discount rate to determine a 20-year net present value. For planning purposes, it was assumed that the vapor phase treatment equipment has a life span of 20 years.

Unit costs and financial factors used in the cost estimate are listed in Table 9-2. As shown in Table 9-2, the inflation rate was assumed to be 6 percent and the discount rate was assumed to be 7 percent. The completion date was assumed to be 2020 and both the equipment life and planning horizon was 20 years. Factors were applied equally to each technology option.

Unit Costs		
Electricity	0.10	\$/kW-hr
Labor	40	\$/hr
Potable Water	4.4	\$/1000 gal
Excavation	15	\$/CY
Backfill	35	\$/CY
Slab on Grade Concrete	525	\$/SF
Support Wall Concrete	525	\$/SF
Allowance Costs		
Equipment Installation	10	%
Field painting/finishes	1	%
Mechanical	8	%
Electrical	8	%
Instrumentation	5	%
Financial Factors		
Discount Rate	7	%
Annual Escalation Rate	3	%
Time Horizon	20	years
Construction Completion Year	2020	
Contractor Markups:		
General Conditions	7	%
Contractor Overhead & Profit	15	%
Bonds and Insurance	2	%
Contingency	30	%

Results of the economic evaluation are provided in Table 9-3.

As can be seen from the results of this evaluation, carbon has the lowest initial capital cost (\$387,000 vs \$655,000) and overall lowest NPV (\$640,000 vs \$804,000) compared to the biotower option, and therefore from a financial perspective, is the initial preferred option. However, given the sensitivity of carbon annual O&M costs and resultant NPV to the H_2S inlet concentration, further evaluations were completed to determine impacts of the assumption of an average 10 ppmv H_2S concentration on the economic results. Specifically, the assessment was repeated with increasingly higher concentrations of H_2S inlet to determine the point at which the biotower option had the lower NPV. This did not occur until inlet H_2S concentrations were 25 ppmv. Given the high ventilation rate included in the odor control design (i.e., 12 ACH), it is anticipated that the frequent turnover of air within the enclosed areas will prevent high concentrations of H_2S from accumulating, thus maintaining an inlet concentration of H_2S to the odor control system well below the 25 ppmv threshold. Therefore, carbon is recommended as the odor control technology of choice.

Table 9-3. Capital, Annual O&M and NPV Evaluation

Technology	Carbon	Biotower
Capital	\$387,000	\$655,000
Annual O&M	\$22,000	\$14,000
20 Yr NPV	\$640,000	\$804,000

9.5 Odor Control System Design Recommendations and Overview

A dual deep bed carbon scrubber utilizing carbon with high adsorptive capacity for H_2S is recommended. The use of the high adsorptive carbon will prolong carbon life and thereby increase the time between media replacements. Based on an average inlet concentration of 10 ppmv H_2S , it is anticipated that media replacement will be on the order of every two years.

As the site has significant space constraints, utilizing a dual deep bed system reduces footprint.

Recommended odor control system process equipment and anticipated design operating conditions are summarized in Table 9-4.

Table 9-4. Major Equipment, Design Criteria and Operating Conditions

Equipment/design criteria	Size/Operating conditions
Carbon Vessel	One (1) 8 ft diameter dual bed FRP vessel
Carbon type and replacement frequency	High adsorptive capacity carbon, e.g., 0.3 g H ₂ S/cc carbon; 24 month media replacement frequency
Carbon bed depth	3 ft each
Carbon bed face velocity	50 fpm
Odorous Air Fan	One (1) fan, FRP construction with sound enclosure; continuous operation
Fan design point	5,000 cfm at 8.5 inches w.c. pressure
Electrical requirements	480V/3-ph/60 Hz; 15 hp

Appendix A Preliminary Design Drawings

INDEX TO DRAWINGS

100 - UNION PUMP STATION

DRAWING NO. TITLE TITLE **GENERAL MECHANICAL** 100-G-001 UNION PUMP STATION INDEX OF DRAWINGS 100-M-201

UNION PUMP STATION 35 MGD CAPACITY LOWER PLAN UNION PUMP STATION ABBREVIATIONS 100-G-002 100-M-202 UNION PUMP STATION 35 MGD CAPACITY UPPER PLAN 100-G-003 UNION PUMP STATION ABBREVIATIONS AND GENERAL LEGEND 100-M-301 UNION PUMP STATION 35 MGD CAPACITY SECTION UNION PUMP STATION INSTRUMENTATION AND CONTROL LEGEND - SHEET 1 100-G-005 100-M-302

UNION PUMP STATION 35 MGD CAPACITY SECTION UNION PUMP STATION INSTRUMENTATION AND CONTROL LEGEND - SHEET 2 UNION PUMP STATION ARCHITECTURAL AND **ELECTRICAL**

UNION PUMP STATION HVAC LEGEND UNION PUMP STATION SINGLE LINE DIAGRAM 100-E-201 ELECTRICAL LEGEND 1 AND MCC ELEVATION ELECTRICAL LEGEND 2 UNION PUMP STATION GROUND FLOOR PLAN 100-E-202

INSTRUMENTATION AND CONTROL

STRUCTURAL

100-S-201 UNION PUMP STATION FLOOD PROOFING FLOOR PLAN 35 MGD CAPACITY

STRUCTURAL LEGEND

ELECTRICAL LEGEND 3

ARCHITECTURAL

100-G-006

100-G-007

100-G-013

100-G-015

100-G-016

100-G-017

100-C-201

UNION PUMP STATION LOWER LEVEL PLAN 35 MGD CAPACITY

UNION PUMP STATION SITE PLAN

UNION PUMP STATION GROUND FLOOR PLAN 35 MGD CAPACITY

UNION PUMP STATION SECTION 35 MGD CAPACITY

UNION PUMP STATION SECTION 35 MGD CAPACITY

<u>HVAC</u>

<u>CIVIL</u>

UNION PUMP STATION 35 MGD CAPACITY EQUIPMENT SCHEDULES 100-H-002

UNION PUMP STATION 35 MGD CAPACITY EQUIPMENT PLATFORM PLAN 100-H-202

UNION PUMP STATION 35 MGD CAPACITY GROUND FLOOR PLAN 100-H-203

\$PWPATH

UNION PUMP STATION PROCESS FLOW DIAGRAM 100-N-601

(35 MGD CAPACITY)

ch2m. RIFY SCALE
IS ONE INCH ON
SINAL DRAWING.

NOVEMBER 2016
664626
100-G-001
of
TIME 146 A DIM

\$PWURL

FILENAME: 100-G-001_664626.dgn

PLOT DATE: 2016\11\04


PLOT TIME: 1:46:40 PM

DWG


BAR IS ONE INCH ON ORIGINAL DRAWING.

		1		2		3	1	4		5		6	
	Λ D	BREVIATIONS	CL	CENTERLINE	ESC	EROSION AND SEDIMENT CONTROL	HDW	HARDWARE	МС	MODULATE-CLOSE	PEP	POLYETHYLENE PIPE	
	AD	BREVIATIONS	CLDI	CEMENT LINED DUCTILE IRON	EP	EXPLOSION PROOF, EDGE OF	HGL	HYDRAULIC GRADE LINE	MCC	MOTOR CONTROL CENTER	PEN.	PENETRATION	
	Δ	AMMETER AMPERES AWNINGS	CLSF	CONTROLLED LOW STRENGTH FILL		PAVING	HK	HOOK	MCJ	MASONRY CONTROL JOINT	PFC	POUNDS PER CUBIC FOOT	
	AB. ABV	ANCHOR BOLT, ABOVE	CLG	CEILING	EQL	EQUAL	HGT	HEIGHT	MDO	MEDIUM DENSITY OVERLAY	PH	PENTHOUSE	
	ABDN	ABANDON	CLR CLSM	CLEAR, CLEARANCE CONTROLLED LOW STRENGTH MATERIAL	EQL SP	EQUALLY SPACED	HH HID	HANDHOLE HIGH INTENSITY DISCHARGE	MECH MFD	MECHANICAL MANUFACTURED	pН	HYDROGEN ION CONCENTRATION	
	AC	ACOUSTICAL, ACOUSTICAL CEILING	CMP	CENTRAL MONITORING PANEL	EQPT ESC	EQUIPMENT EROSION AND SEDIMENT CONTROL	HK	HOOK	MFR	MANUFACTURER	PH Pl	PHASE POINT OF INTERSECTION	
	AC	ALTERNATING CURRENT	CMP	CORRUGATED METAL PIPE	ETM	ELAPSED TIME METER	НМ	HOLLOW METAL	MGD	MILLION GALLONS PER DAY	PIT	PILOT TUBE TEST STATION	
	AC	ASPHALTIC CONCRETE	CMU	CONCRETE MASONRY UNIT	EVC	END OF VERTICAL CURVE	HOA	HAND-OFF-AUTO	MH	MANHOLE, MOUNTING HEIGHT	PJF	PREMOULDED JOINT FILLER	
	ACFL ACI	ACCESS FLOORING AMERICAN CONCRETE INSTITUTE	CNTR	COUNTER	EW	EACH WAY	HOR	HAND-OFF-REMOTE	MIN	MINIMUM	PL	PLATE (STEEL)	
Α	ACMU	ACOUSTICAL CONCRETE MASONRY	COL	CLEANOUT, CARBON MONOXIDE	EWC	ELECTRIC WATER COOLER	HORIZ	HORIZONTAL	MISC	MISCELLANEOUS	PL	PROPERTY LINE	
		UNIT, ACOUSTICAL CMU	COL	COLUMN, COLOR CONCRETE	EXH	EXHAUST	HP HPT	HORSEPOWER	MJ	MECHANICAL JOINT	PLAM	PLASTIC LAMINATE	
	ACP	ACOUSTICAL PANELS	COND	CONDENSATE	EXP	EXPANSION, EXPOSED	HPU	HIGH POINT HYDRAULIC POWER UNIT	MLO	MAIN LUGS ONLY	PLAS	PLASTER, PLASTIC	
	ACST	ACOUSTICAL	CONDTN	CONDITIONED	EXP AB	EXPANSION ANCHOR BOLT	HR	HOSE RACK, HANDRAIL	MMDW MMP	DRY WEATHER MAXIMUM MONTH MECHANICAL MOUNTING PANEL	PLC PLYWD	PROGRAMMABLE LOGIC CONTROLLER PLYWOOD	
	ACT AD	ACOUSTICAL TILE AREA DRAIN	CONN	CONNECTION	EXP JT EXST. EXIST	EXPANSION JOINT EXISTING	HV	HOSE VALVE	MMWW	WET WEATHER MAXIMUM MONTH	PLYWD	PANEL	
	ADDL	ADDITIONAL	CONSTR	CONSTRUCTION	EXT EXIST	EXTERIOR	HVAC	HEATING, VENTILATING AND	MO	MANUAL OPERABLE, MASONRY OPENING	PP	POWER POLE	
	ADDL	ADJACENT	CONT	CONTINUED, CONTINUOUS, CONTINUATION	EXI	EXTERIOR		AIR CONDITIONING	MP	METAL PANEL	P-P	PUSH-PULL	
	ADW	DRY WEATHER AVERAGE	CONTR	CONTRACTOR	°F	DEGREE FAHRENHEIT	HWL	HIGH WATER LEVEL	MPU	MULTIPURPOSE UNIT	PPL	POLYPROPYLENE LINED	
	AFD	ADJUSTABLE FREQUENCY DRIVE	COORD COP	COORDINATE COPPER	FACP	FIRE ALARM CONTROL PANEL	IC	INTERRUPTING CAPACITY	MS	MANUFACTURER'S STANDARD	PR	PAIR	
	AFF	ABOVE FINISHED FLOOR	CP	CENTER PIVOT	FB	FLAT BAR	IC ID	INDUCED DRAFT, INSIDE DIAMETER	MSC	MANUFACTURER SUPPLIED CABLE	PRC	POINT OF REVERSE CURVE	
	AFG	ABOVE FINISHED GRADE	CP-X	CONTROL PANEL NO. X	F, FU F. FX	FUSE FIXED	IE	INVERT ELEVATION	MSR	GROUPED MOTOR CONTROL	PRCST PREFAB	PRECAST PREFABRICATION	
	AG	ACOUSTICAL, ACOUSTICAL GLASS,	CPLG	COUPLING	F, FA	FIRE ALARM PANEL	I.F.	INSIDE FACE	MT	MOUNT	PRES	PRESSURE	
	ACCD	AIR GAP (FIXED)	CPRSR	COMPRESSOR	FC	FLEXIBLE CONDUIT	IG	INSULATING, INSULATING GLASS	MTD MTG	MOUNTED MOUNTING	PRI	PRIMARY	
	AGGR AHR	AGGREGATE ANCHOR	CPT	CONTROL POWER TRANFORMER, CARPET	FCA	FLANGED COUPLING ADAPTER	IN	INCH	MTS	MANUAL TRANSFER SWITCH	PRM	PERMANENT REFERENCED MARKER	
	AISC	AMERICAN INSTITUTE OF	CPVC	CHLORINATED PVC	FCL2	FREE CHLORINE RESIDUAL	INCAND	INCANDESCENT	MTS	MILL TYPE STEEL PIPE	PROJ	PROJECTION	
	,	STEEL CONSTRUCTION	CR	CONTROL RELAY	FCO	FLOOR CLEANOUT	INFL	INFLUENT IN JECTIONS	MU	MULCHING	PROP	PROPERTY	
	AJ	ADJUSTABLE	CRS	COLD ROLLED STEEL	FCTY	FACTORY	INJS	INJECTIONS INSTANTANEOUS	MV	MERCURY VAPOR	PS	PLASTIC SHEET, POLYCARBONATE SHEET	
	AL	ALUMINUM	CRS CT	CONSTRUCTION ROAD STABILIZATION CERAMIC TILE	FD FDN	FLOOR DRAIN	INST INSTM	INSTRUMENT, INSTRUMENTATION	MWS	MAXIMUM WATER SURFACE	PS	PAINT SYSTEM	
	ALKY	ALKALINITY	CT	CURRENT TRANSFORMER	FDN FDR	FOUNDATION FEEDER	INSTM	INSULATION	N	NORTH, NEUTRAL	PSF	POUNDS PER SQUARE FOOT	
	ALTN	ALTERNATE	CTC	COMPUTER TERMINAL CABINET	FEXT	FEEDER FIRE EXTINGUISHER	INVT	INVERT	NA NA	NOT APPLICABLE	PSI PSIG	POUNDS PER SQUARE INCH	
	AM AMRD	AUTO-MANUAL ACOUSTICAL METAL ROOF DECKING	CTR	CENTER	FF	FINISHED FLOOR	IP	INLET PROTECTION, INSTRUMENTATION PANEL	NA	NON-AUTOMATIC	PSIG PT	POUNDS PER SQUARE INCH, GAUGE POINT OF TANGENCY	
В	ANDZ	ANODIZE	CTRD	CENTERED	FG	FINISH GRADE, FLOAT GLASS	IRRIG	IRRIGATION	NC	NORMALLY CLOSED	PT PT	POINT OF TANGENCY POTENTIAL TRANSFORMER	
	APPROX	APPROXIMATE	CTSK	COUNTERSUNK	FH	FLAT HEAD	ITG	INSULATED TEMPERED GLASS	NEUT	NEUTRAL	PT	PRESSURE TREATED	
	APVD	APPROVED	CU	CUBIC	FHY	FIRE HYDRANT	ITX	ISOLATION TRANSFORMER	NG	NATURAL GAS	PTD	PAPER TOWEL DISPENSER	
	ARCH	ARCHITECTURAL	CU FT	CUBIC FOOT	FIG	FIGURE	IU	INTAKE UNIT	NGVD	NATIONAL GEODETIC VERTICAL DATUM	PTN	PARTITION	
	AR	ANALOG RELAY	CU IN	CUBIC INCH	FL	FLOW LINE	IW	IRRIGATION WELL	NIC	NOT IN CONTRACT	PV	PLUG VALVE	
	AS	AS SELECTED	CUH CV	COPPER TUBING, HARD DRAWN CHECK VALVE	FLG FL	FLANGE FLOOR		JALOUSIE	N.O.	NORMALLY OPEN	PVC	POLYVINYL CHLORIDE	
	ASSY	ASSEMBLY	CWR	CABINET DOOR MOUNTED	FLEX	FLEXIBLE	JA	JAL-AWNING	NO., # NOM	NUMBER NOMINAL	PVI	POINT OF VERTICAL INTERSECTION	
	ATS	AUTOMATIC TRANSFER SWITCH	OWIX	WASTE RECEPTACLE	FLH	FLAT HEAD	JB	JUNCTION BOX	NP NP	NON-PROTECTED	PVMT PVT	PAVEMENT	
	AUTO	AUTOMATIC	CY, CU YD		FLTR	FILTER	JAN	JANITOR	NPT	NATIONAL PIPE THREADS	PVI	POINT OF VERTICAL TANGENCY	
	AUX AVG	AUXILIARY AVERAGE	cws	CLEAN WATER SERVICES	FLUOR	FLUORESCENT	JCT	JUNCTION	NS	NON-SHRINK	QAA	AVERAGE FLOW	
	AWW	WET WEATHER AVERAGE			FNSH	FINISH	JT	JOINT	NTS	NOT TO SCALE	QMM	MAXIMUM 30 DAY FLOW	
	@	AT	D	DEEP, DRAIN	FOB	FLAT ON BOTTOM	K	KEY GROUP, KEY INTERLOCK	O2	OXYGEN	QPI	PEAK INSTANTANEOUS FLOW	
	_		d	PENNY NAIL SIZE	FOT	FLAT ON TOP	KIP	THOUSAND POUNDS	0 TO 0	OUT TO OUT	QPP	PEAK PUMPING FLOW	
	B BAL	BELL BALANCE	DA	DUAL ACTION	FP	FIELD PANEL	KIT	KITCHEN	OA	OVERALL, ODOROUS AIR	QT	QUARRY TILE	
			D/ (KICKPLATE		· ·			
	RETW		DAS	DATA ACQUISTION SYSTEM	FPM FR	FEET PER MINUTE	K-PL	IZITCHENI CINIZ	OC	ON CENTER	_		
	BETW BF	BETWEEN	DAS DBA	DEFORMED BAR ANCHOR	FR	FORWARD REVERSE	KSK	KITCHEN SINK	OC OC	ON CENTER OPEN-CLOSE (O)	R B OB BAE	RISER	
			DAS DBA DBL	DEFORMED BAR ANCHOR DOUBLE			KSK KV	KILOVOLTS	OC OCA	OPEN-CLOSE (O) OPEN-CLOSE-AUTO	R OR RAD	RADIUS	
	BF	BETWEEN BLIND FLANGE, BOTTOM FACE	DAS DBA DBL DC	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT	FR FRP	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC	KSK		OC OCA OCR	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE			
	BF BFV BL BFP	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER	DAS DBA DBL DC DEG	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE	FR FRP FSHS FT FTG	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING	KSK KV KVA	KILOVOLTS KILOVOLT AMPERES	OC OCA OCR OD	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN	R OR RAD	RADIUS RETURN AIR	
	BF BFV BL BFP BLDG	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING	DAS DBA DBL DC DEG DET	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL	FR FRP FSHS FT FTG FU	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT	KSK KV KVA KVAR	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT	OC OCA OCR OD O.F.	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE	R OR RAD RA RC	RADIUS RETURN AIR REINFORCED CONCRETE	
	BF BFV BL BFP BLDG BLK	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK	DAS DBA DBL DC DEG	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE	FR FRP FSHS FT FTG FU FVNR	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING	KSK KV KVA KVAR KW	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH	OC OCA OCR OD O.F. OFCI	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED	R OR RAD RA RC RCP RCPT	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE	
С	BF BFV BL BFP BLDG BLK BM	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK	DAS DBA DBL DC DEG DET DF	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN	FR FRP FSHS FT FTG FU FVNR FVR	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING	KSK KV KVA KVAR KW L	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER	OC OCA OCR OD O.F. OFCI OFOI	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED	R OR RAD RA RC RCP RCPT	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN	
С	BF BFV BL BFP BLDG BLK BM BO	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF	DAS DBA DBL DC DEG DET DF DDI DH DI	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET	FR FRP FSHS FT FTG FU FVNR	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING	KSK KV KVA KVAR KW L LA	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY	OC OCA OCR OD O.F. OFCI	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED	R OR RAD RA RC RCP RCPT RD RDCR	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER	
С	BF BFV BL BFP BLDG BLK BM	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK	DAS DBA DBL DC DEG DET DF DDI DH DI DI DIA	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER	FR FRP FSHS FT FTG FU FVNR FVR FWD	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING	KSK KV KVA KVAR KW L	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER	OC OCA OCR OD O.F. OFCI OFOI OL	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY	R OR RAD RA RC RCP RCPT RD RDCR RDW	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD	
С	BF BFV BL BFP BLDG BLK BM BO	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL	FR FRP FSHS FT FTG FU FVNR FVR	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD	KSK KV KVA KVAR KW L LA LAB LAM	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE	R OR RAD RA RC RCP RCPT RD RDCR RDW RECIR	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION	
С	BF BFV BL BFP BLDG BLK BM BO B.O.B.	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND	KSK KV KVA KVAR KW L LA LAB LAB LAT LB LC	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION	R OR RAD RA RC RCP RCPT RD RDCR RDW	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD	
С	BF BFV BL BFP BLDG BLK BM BO B.O.B.	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIR	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED	KSK KV KVA KVAR KW L LA LAB LAM LAT LB LC LD	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR	R OR RAD RA RC RCP RCPT RD RDCR RDW RECIR	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION	
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIR DISCH	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD	KSK KV KVA KVAR KW L LA LAB LAM LAT LB LC LD LDG	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING	R OR RAD RA RC RCP RCPT RD RDCR RDW RECIR REF	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE	
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOD BOT BRG BRK	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIR	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GBB GC	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING	KSK KV KVA KVAR KW L LA LAB LAM LAT LB LC LD LDG LEL	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPPI OPP	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE	R OR RAL RA RC RCP RCPT RD RDCR RDW RECIR REF	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT	
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BEARING BRICK BREAKER	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIR DISCH DN	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROVED COUPLING GLAZED CONCRETE	KSK KV KVA KVAR KW L LA LAB LAM LAT LB LC LD LDG LEL LF	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REGD RESIL	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCE REQUIRED RESILIENT	
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BEARING BRICK BREAKER BLACK STEEL PIPE	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DIR DISCH DN DO	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROVED COUPLING GLAZED CONCRETE MASONRY UNITS	KSK KV KVAR KVAR KW L LA LAB LAM LAT LB LC LD LDG LEL LF LG	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER	
c	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BEARING BRICK BREAKER	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DIR DISCH DN DO DOL	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER	KSK KV KVAR KVAR KW LA LAB LAM LAT LB LC LD LDG LEL LF LG	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPPOSA OSC OSD OWSJ	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND	
С —	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIR DISCH DN DO DOL DP, DPNL DR DS	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROVED COUPLING GLAZED CONCRETE MASONRY UNITS	KSK KV KVAR KVAR KW L LA LAB LAM LAT LB LC LD LDG LEL LF LG	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE	
c	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DISCH DN DO DOL DP, DPNL DR DS DWG	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER	KSK KV KVA KVAR KW L LA LAB LAM LAT LB LC LD LDG LEL LF LG LH	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND LEFT HAND REVERSE	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPPOSA OSC OSD OWSJ	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RHR	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE	2W :
c —	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV BVC	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE	DAS DBA DBL DC DEG DET DF DDI DI DIA DIAG DIP DISCH DN DO DOL DP, DPNL DR DS DWG DWG DBA	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER	KSK KV KVAR KVAR KW L LAB LAM LAT LB LC LD LDG LEL LF LG LH LHR LLHR LLHR LLLV LNTL	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL	OC OCA OCR OD O.F. OFCI OFOI OO OOA OOR OP OPER OPPOSA OSC OSD OWSJ OZ	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RHR	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE	h2m:
c -	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C C C TO C	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DISCH DN DO DOL DP, DPNL DR DS DWG	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING	FR FRP FSHS FT FTG FU FVNR FVN G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GL GPD	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY	KSK KV KVA KVAR KW L LA LAB LAM LAT LB LC LD LDG LEL LF LG LH LHR LLH LHR LLH LLV LNTL LONG	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P P PAVT	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RHR	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER	sh2m.
c	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C CC CTO C CAB	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET	DAS DBA DBL DC DEG DET DF DDI DI DIA DIAG DIP DISCH DN DO DOL DP, DPNL DR DS DWG DWG DBA	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GL GPD GPH	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER DAY GALLONS PER DAY	KSK KV KVA KVAR KW L LA LAB LAM LAT LB LC LD LDG LEL LF LG LH LHR LLH LLH LLV LNTL LONG LOS	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P P PAVT PB	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REJINF REQD RESIL RFS RH RH RHR RL RLS RM RO	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING	ch2m:
c	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C C C TO C CAB CB	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DISCH DN DO DOL DP, DPNL DR DS DWG DWL Δ	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL DELTA	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GALV GB GC GCMU GFA GFI GFR GH GL GPD GPH GPM	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER MINUTE	KSK KV KVA KVAR KW L LA LAB LAM LAT LB LC LD LDG LEL LF LG LH LHR LLH LLV LNTL LONG LOS LP	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL	OC OCA OCR OD O.F. OFCI OFOI OC OOA OOR OP OPER OPPOSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL	R OR RALE RA RC RCP RCPT RD RDCR RESIR REF REFR REINF REQD RESIL RFS RH RH RH RL RLS RM RO ROL	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER	ch2m:
c -	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C °C C TO C CAB CB CC	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DISCH DN DO DOL DP, DPNL DR DS DWG DWL A	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWL DELTA	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GL GPD GPH GPS	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER DAY GALLONS PER HOUR GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM	KSK KV KVAR KVAR KW L LA LAB LAM LAT LB LC LD LDG LEF LG LH LHR LLH LLLV LNTL LONG LOS LP LPT	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P P PAVT PB PC PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE PANEL	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RHR RL RLS RM RO ROL RPM	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE	ch2m:
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C C C TO C CAB CB	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DISCH DN DO DOL DP, DPNL DR DS DWG DWL E EA	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL DELTA EAST, EMPTY EACH, EXHAUST AIR	FR FRP FSHS FT FTG FU FVNR FVNR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GPD GPH GPPM GPS GRTG	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING	KSK KV KVAR KVAR KW L LAB LAM LAT LB LC LD LDG LEF LG LH LHR LLH LLIV LONG LOS LP LPT LR	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC PC PCCP	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE PANEL PRECAST CONCRETE CYLINDER PIPE	R OR RALE RA RC RCP RCPT RD RDCR RESIR REF REFR REINF REQD RESIL RFS RH RH RH RL RLS RM RO ROL	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER	ch2m.
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BSP BV C C C C TO C CAB CB CC	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DISCH DN DO DOL DP, DPNL DR DS DWG DWL A	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWL DELTA	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GL GPD GPH GPS	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER DAY GALLONS PER HOUR GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM	KSK KV KVAR KVAR KW L LA LAB LAM LAT LB LC LD LDG LEF LG LH LHR LLH LLLV LNTL LONG LOS LP LPT	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE PANEL PRECAST CONCRETE CYLINDER PIPE PRESSURE CONTROL VALVE	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RHR RL RLS RM RO ROL RPM	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE	Ch2m.
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C C C TO C CAB CC CCC CCC CCC CCC CCC CCC CCC CCC	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL PANEL	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DISCH DN DO DOL DP, DPNL DR DS DWG DWL A E E EA EB, EBCT	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GL GPD GPH GPM GPS GRTG GSB	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING GYPSUM SOFFIT BOARD	KSK KV KVA KVAR KW L LAB LAM LAT LB LC LD LDG LEL LF LHR LLH LLH LLNTL LONS LP LPT LR	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LOCAL-REMOTE	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE PANEL PRECAST CONCRETE CYLINDER PIPE PRESSURE CONTROL VALVE PLAIN END	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RHR RL RLS RM RO ROL RPM	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE	ch2m.
C	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BVC C C TO C CAB CB CC CCC CCP CCS CDF CE	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL PANEL CONSTRUCTION ENTRANCE	DAS DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DISCH DN DO DOL DP, DPNL DR DS DWG DWL A E EA EB, EBCT ECC	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME ECCENTRIC	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GL GPP GPP GPM GPS GRTG GSB GSP	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRYPSUM SOFFIT BOARD GAYSTELL SEAT TO STATE TO STATE GYPSUM SOFFIT BOARD GALVANIZED STEEL PIPE	KSK KV KVAR KVAR KW L LAB LAM LAT LB LC LD LDG LEL LF LG LHR LLH LLV LNTG LOS LP LPT LR LR	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LONG RADIUS	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE PANEL PRECAST CONCRETE CYLINDER PIPE PRESSURE CONTROL VALVE PLAIN END PEDESTAL, PEDESTRIAN	R OR RALE RA RC RCP RCPT RD RDCR REDW RECIR REF REFR REINF REQD RESIL RFS RH RHR RL RLS RM RO ROL RPM RR	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE	ch2m.
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOT BRG BRK BRKR BSP BV C C C T O C CAB CB CC C C C C C C C C C C C C C C C C	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL SYSTEM CONTROLLED DENSITY FILL CONSTRUCTION ENTRANCE CUBIC FEET PER MINUTE	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DISCH DN DO DOL DP, DPNL DR DS DWG DWL A E E EA EB, EBCT ECC EE EDF EF	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME ECCENTRIC EMERGENCY EYEWASH EGG-SHAPED DIGESTER FACILITY EACH FACE, EXHAUST FAN	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GL GPD GPH GPM GPS GRTG GSB GSP GV	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING GYPSUM SOFFIT BOARD GALVANIZED STEEL PIPE GATE VALVE	KSK KV KVAR KVAR KW L LAB LAM LAT LB LC LD LDG LEL LF LG LH LHR LLHV LNTL LONG LOS LP LPT LR LR LR LR LS LT LTG, LTS	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LOCAL-REMOTE LONG RADIUS LABORATORY SINK LEFT LIGHTS OR LIGHTING	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE PANEL PRECAST CONCRETE CYLINDER PIPE PRESSURE CONTROL VALVE PLAIN END PEDESTAL, PEDESTRIAN	R OR RALE RA RC RCP RCPT RD RDCR REDW RECIR REF REFR REINF REQD RESIL RFS RH RHR RL RLS RM RO ROL RPM RR	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE	Ch2m.
C	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C C TO C CAB CB CC CCP CCS CDF CCS CDF CFM CFS	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BEAM BOTTOM OF BEAM BOTTOM OF PIPE BOTTOM DEARLING BEAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL PANEL CENTRAL CONTROL SYSTEM CONTROLLED DENSITY FILL CONSTRUCTION ENTRANCE CUBIC FEET PER MINUTE CUBIC FEET PER SECOND	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DISCH DN DO DOL DP, DPNL DR DS DWG DWG DWL A E EA EB, EBCT ECC EE EDF EFF	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME ECCENTRIC EMERGENCY EYEWASH EGG-SHAPED DIGESTER FACILITY EACH FACE, EXHAUST FAN EFFICIENCY, EFFICIENT	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GPD GPH GPM GPS GRTG GSB GSP GV GVL	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GLAZED CONCRETE MASONRY UNITS GROVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND SPER HOUR GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING GYPSUM SOFFIT BOARD GALVANIZED STEEL PIPE GATE VALVE GRAVEL	KSK KV KVA KVAR KW L LAB LAM LAT LB LC LD LDG LEL LF LG LH LHR LLH LLV LNTL LONG LOS LP LPT LR LR LR LR LS LT LTG, LTS LTX	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LOCAL-REMOTE LONG RADIUS LABORATORY SINK LEFT LIGHTS OR LIGHTING LIGHTING TRANSFORMER	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE PANEL PRESSURE CONTROL VALVE PLAIN END PEDESTAL, PEDESTRIAN	R OR RALE RA RC RCP RCPT RD RDCR RECIR REF REGIR REF RESIL RFS RH RH RH RL RLS RM RO ROL RPM RR	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE RIPRAP	Ch2M :
C	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C C C TO C CAB CB CC CCC CCP CCS CDF CC CFM CFS CHEM	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL PANEL CENTRAL CONTROL SYSTEM CONTROLLED DENSITY FILL CONSTRUCTION ENTRANCE CUBIC FEET PER MINUTE CUBIC FEET PER SECOND CHEMICAL	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DIR DISCH DN DO DOL DP, DPNL DR DS DWG DWL E EA EB, EBCT ECC EE EDF EFF EFF	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME ECCENTRIC EMERGENCY EYEWASH EGG-SHAPED DIGESTER FACILITY EACH FACE, EXHAUST FAN EFFICIENCY, EFFICIENT EFFLUENT	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GPD GPH GPM GPS GRTG GSB GSP GV GVP H	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING GYPSUM SOFFIT BOARD GALVANIZED STEEL PIPE GATE VALVE GRAVEL GYPSUM WALLBOARD GYPSUM HIGH, HORN OR HOWLER	KSK KV KVAR KVAR KW L LAB LAM LAT LB LC LD LDG LEL LF LG LH LHR LLHV LNTL LONG LOS LP LPT LR LR LR LR LS LT LTG, LTS	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LOCAL-REMOTE LONG RADIUS LABORATORY SINK LEFT LIGHTS OR LIGHTING	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE PANEL PRESSURE CONTROL VALVE PLAIN END PEDESTAL, PEDESTRIAN	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RH RL RLS RM RO ROL RPM RR RT THIS IS A THEREFO	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE RIPRAP RAL NOTES: STANDARD LEGEND SHEET. RE, NOT ALL OF THE INFORMATION	CPSW :
C	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C C TO C CAB CB CC CCP CCS CDF CCS CDF CFM CFS	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BEAM BOTTOM OF BEAM BOTTOM OF PIPE BOTTOM DEARLING BEAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL PANEL CENTRAL CONTROL SYSTEM CONTROLLED DENSITY FILL CONSTRUCTION ENTRANCE CUBIC FEET PER MINUTE CUBIC FEET PER SECOND	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DISCH DN DO DOL DP, DPNL DR DS DWG DWG DWL A E EA EB, EBCT ECC EE EDF EFF	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME ECCENTRIC EMERGENCY EYEWASH EGG-SHAPED DIGESTER FACILITY EACH FACE, EXHAUST FAN EFFICIENCY, EFFICIENT	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GL GPD GPH GPM GPS GRTG GSB GSP GV GVL GWB GYP H H2S	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING GYPSUM SOFFIT BOARD GALVANIZED STEEL PIPE GATE VALVE GRAVEL GYPSUM WALLBOARD GYPSUM HIGH, HORN OR HOWLER HYDROGEN SULFIDE	KSK KV KVA KVAR KW L LAB LAM LAT LB LC LD LDG LEL LF LG LH LHR LLH LLV LNTL LONG LOS LP LPT LR LR LR LR LS LT LTG, LTS LTX	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LOCAL-REMOTE LONG RADIUS LABORATORY SINK LEFT LIGHTS OR LIGHTING LIGHTING TRANSFORMER	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE PANEL PRESSURE CONTROL VALVE PLAIN END PEDESTAL, PEDESTRIAN	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RH RL RLS RM RO ROL RPM RR RT THIS IS A THEREFO	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE RIPRAP RAL NOTES: STANDARD LEGEND SHEET.	VERIF BAR IS G
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BSP BV C C C C TO C CAB CC CCC CCC CCC CCC CCC CCC CCC CCC	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL PANEL CENTRAL CONTROL SYSTEM CONSTRUCTION ENTRANCE CUBIC FEET PER MINUTE CUBIC FEET PER SECOND CHEMICAL CHECKERED	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DISCH DN DO DOL DP, DPNL DR DS DWG DWL E EA EB, EBCT ECC EE EFF EFF EFF EFF EFF EFF	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME ECCENTRIC EMERGENCY EYEWASH EGG-SHAPED DIGESTER FACILITY EACH FACE, EXHAUST FAN EFFICIENCY, EFFICIENT EFFICIENT EXTERIOR INSULATION AND FINISH SYSTEM	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GPD GPH GPM GPS GRTG GSB GSP GVL GWB GYP H H2S H.A.S.	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING GYPSUM SOFFIT BOARD GALVANIZED STEEL PIPE GATE VALVE GRAVEL GYPSUM WALLBOARD GYPSUM HIGH, HORN OR HOWLER HYDROGEN SULFIDE HEADED ANCHOR STUD	KSK KV KVA KVAR KW L LA LAB LAM LAT LB LC LD LDG LEL LF LG LHR LLH LLV LNTL LONG LOS LP LPT LR LR LR LR LS LT LTG, LTS LTX LWL MA MAS	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LOCAL-REMOTE LONG RADIUS LABORATORY SINK LEFT LIGHTS OR LIGHTING LIGHTING TRANSFORMER LOW WATER LEVEL	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE CYLINDER PIPE PRESSURE CONTROL VALVE PLAIN END PEDESTAL, PEDESTRIAN	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RL RLS RM RO ROL RPM RR THIS IS A THEREFO SHOWN N	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE RIPRAP RAL NOTES: STANDARD LEGEND SHEET. RE, NOT ALL OF THE INFORMATION INY BE USED ON THIS PROJECT.	VERIF
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C C T O C CAB CB CC CCP CCAB CC CCP CCS CDF CE CFM CHKD CIP CIP	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL SYSTEM CONSTRUCTION ENTRANCE CUBIC FEET PER MINUTE CUBIC FEET PER SECOND CHEMICAL CHECKERED CAST IRON	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DIR DISCH DN DO DOL DP, DPNL DR DS DWG DWL E EA EB, EBCT ECC EE EDF EFF EFF EFF EFF EFL EIFS EL ELB ELC	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME ECCENTRIC EMERGENCY EYEWASH EGG-SHAPED DIGESTER FACILITY EACH FACE, EXHAUST FAN EFFICIENCY, EFFICIENT EFFLUENT EXTERIOR INSULATION AND FINISH SYSTEM ELEVATION	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GPD GPH GPM GPPS GRTG GSB GSP GV GVL GWB GYP H H2S H.A.S. HC	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING GYPSUM SOFFIT BOARD GALVANIZED STEEL PIPE GATE VALVE GRAVEL GYPSUM WALLBOARD GYPSUM HIGH, HORN OR HOWLER HYDROGEN SULFIDE HEADED ANCHOR STUD HOLLOW CORE WOOD	KSK KV KVAR KVAR KW L LAB LAM LAT LB LC LD LDG LEF LG LH LHR LLV LNTL LONG LOS LP LPT LR LR LR LR LS LT LTG, LTS LTX LWL MAS MATL	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LOCAL-REMOTE LONG RADIUS LABORATORY SINK LEFT LIGHTS OR LIGHTING LIGHTING TRANSFORMER LOW WATER LEVEL MANUAL-AUTO MASONRY MATERIAL	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE CYLINDER PIPE PRESSURE CONTROL VALVE PLAIN END PEDESTAL, PEDESTRIAN	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RL RLS RM RO ROL RPM RR THIS IS A THEREFO SHOWN N	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE RIPRAP RAL NOTES: STANDARD LEGEND SHEET. RE, NOT ALL OF THE INFORMATION TAY BE USED ON THIS PROJECT.	VERIF BAR IS G ORIGIN
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C C C TO C CAB CC	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL PANEL CENTRAL CONTROL SYSTEM CONTROLED DENSITY FILL CONSTRUCTION ENTRANCE CUBIC FEET PER MINUTE CUBIC FEET PER SECOND CHEMICAL CHECKERED CAST IRON CAST IRON PIPE, CAST IN PLACE CULVERT INLET PROTECTION CAST IRON SOIL PIPE	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DIR DISCH DN DO DOL DP, DPNL DR DS DWG DWL E EA EB, EBCT ECC EE EDF EFF EFF EFF EFF EFF EFL EIFS EL ELB ELC ELEC	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME ECCENTRIC EMERGENCY EYEWASH EGG-SHAPED DIGESTER FACILITY EACH FACE, EXHAUST FAN EFFICIENCY, EFFICIENT EFFLUENT EXTERIOR INSULATION AND FINISH SYSTEM ELECTRICA, ELECTRICAL	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GPD GPH GPM GPS GRTG GSB GSP GVL GWB GYP H H2S H.A.S.	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING GYPSUM SOFFIT BOARD GALVANIZED STEEL PIPE GATE VALVE GRAVEL GYPSUM WALLBOARD GYPSUM HIGH, HORN OR HOWLER HYDROGEN SULFIDE HEADED ANCHOR STUD	KSK KV KVAR KVAR KW L LAB LAM LAT LB LC LD LDG LEF LG LH LHR LLH LLV LNTL LONG LOS LP LPT LR LR LR LR LS LT LTG, LTS LTX LWL MA MAS MATL MAX	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LOCAL-REMOTE LONG RADIUS LABORATORY SINK LEFT LIGHTS OR LIGHTING LIGHTING TRANSFORMER LOW WATER LEVEL MANUAL-AUTO MASONRY MATERIAL MAXIMUM	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE CYLINDER PIPE PRESSURE CONTROL VALVE PLAIN END PEDESTAL, PEDESTRIAN	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RL RLS RM RO ROL RPM RR THIS IS A THEREFO SHOWN N	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE RIPRAP RAL NOTES: STANDARD LEGEND SHEET. RE, NOT ALL OF THE INFORMATION INY BE USED ON THIS PROJECT.	VERIF BAR IS CORIGINO ODATE N
С	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOT BRG BRK BRKR BSP BVC C C TO C CAB CC CCP CCS CDF CCS CDF CCE CFM CFS CHEM CHKD CI CIP CIP CISP CJ	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL SYSTEM CONTROLLED DENSITY FILL CONSTRUCTION ENTRANCE CUBIC FEET PER MINUTE CUBIC FEET PER MINUTE CUBIC FEET PER SECOND CHEMICAL CHECKERED CAST IRON PIPE, CAST IN PLACE CULVERT INLET PROTECTION CAST IRON SOIL PIPE CONSTRUCTION JOINT	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DISCH DN DO DOL DP, DPNL DR DS DWG DWL E EA EB, EBCT ECC EE EFF EFF EFF EFF EFL ELB ELC ENGR	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME ECCENTRIC EMERGENCY EYEWASH EGG-SHAPED DIGESTER FACILITY EACH FACE, EXHAUST FAN EFFICIENCY, EFFICIENT EFFLUENT EXTERIOR INSULATION AND FINISH SYSTEM ELEVATION ELEOW ELECTRICAL LOAD CENTER ELECTRICAL ENGINEER	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GPD GPH GPM GPS GRTG GSB GSP GV GVL GWB GYP H H2S H.A.S. HC HCL	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING GYPSUM SOFFIT BOARD GALVANIZED STEEL PIPE GATE VALVE GRAVEL GYPSUM WALLBOARD GYPSUM HIGH, HORN OR HOWLER HYDROGEN SULFIDE HEADED ANCHOR STUD HOLLOW CORE WOOD HYDROCHLORIC ACID	KSK KV KVA KVAR KW L LAB LAM LAT LB LC LD LDG LEL LF LG LH LHR LLHV LNTL LONG LOS LP LPT LR LR LR LT LTG, LTS LTX LWL MA MAS MATL MAX MB	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LOCAL-REMOTE LONG RADIUS LABORATORY SINK LEFT LIGHTS OR LIGHTING LIGHTING TRANSFORMER LOW WATER LEVEL MANUAL-AUTO MASONRY MATERIAL MAXIMUM MACHINE BOLT	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE CYLINDER PIPE PRESSURE CONTROL VALVE PLAIN END PEDESTAL, PEDESTRIAN	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RL RLS RM RO ROL RPM RR THIS IS A THEREFO SHOWN N	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE RIPRAP RAL NOTES: STANDARD LEGEND SHEET. RE, NOT ALL OF THE INFORMATION INY BE USED ON THIS PROJECT.	VERIF BAR IS ORIGIN ORIGIN DATE N PROJ DWG
C D	BF BFV BL BFP BLDG BLK BM BO B.O.B. BOD BOP BOT BRG BRK BRKR BSP BV C C C C TO C CAB CC	BETWEEN BLIND FLANGE, BOTTOM FACE BUTTERFLY VALVE BASELINE BACKFLOW PREVENTER BUILDING BLOCK BEAM, BENCHMARK BOTTOM OF BOTTOM OF BEAM BOTTOM OF DUCT BOTTOM OF PIPE BOTTOM BEARING BRICK BREAKER BLACK STEEL PIPE BALL VALVE, BLOCK VENT BEGINNING OF VERTICAL CURVE CONDUIT, CASEMENT DEGREE CELSIUS CENTER TO CENTER CABINET CATCH BASIN, CIRCUIT BREAKER CENTER OF CIRCLE CONTROL CABLE CENTRAL CONTROL PANEL CENTRAL CONTROL SYSTEM CONTROLED DENSITY FILL CONSTRUCTION ENTRANCE CUBIC FEET PER MINUTE CUBIC FEET PER SECOND CHEMICAL CHECKERED CAST IRON CAST IRON PIPE, CAST IN PLACE CULVERT INLET PROTECTION CAST IRON SOIL PIPE	DAS DBA DBA DBL DC DEG DET DF DDI DH DI DIA DIAG DIP DIR DISCH DN DO DOL DP, DPNL DR DS DWG DWL E EA EB, EBCT ECC EE EDF EFF EFF EFF EFF EFF EFL EIFS EL ELB ELC ELEC	DEFORMED BAR ANCHOR DOUBLE DIRECT CURRENT DEGREE DETAIL DOUGLAS FIR, DRINKING FOUNTAIN DROP INLET DOUBLE HUNG DUCTILE IRON DIAMETER DIAGONAL DUCTILE IRON PIPE DIRECTION DISCHARGE DOWN DISSOLVED OXYGEN DIRECT-ON-LINE DISTRIBUTION PANEL DOOR DOWNSPOUT DRAWING DOWEL DELTA EAST, EMPTY EACH, EXHAUST AIR EMPTY BED CONTACT TIME ECCENTRIC EMERGENCY EYEWASH EGG-SHAPED DIGESTER FACILITY EACH FACE, EXHAUST FAN EFFICIENCY, EFFICIENT EFFLUENT EXTERIOR INSULATION AND FINISH SYSTEM ELECTRICA, ELECTRICAL	FR FRP FSHS FT FTG FU FVNR FVR FWD G, GND GA GAL GALV GB GC GCMU GFA GFI GFR GH GL GPD GPH GPS GRTG GSB GSP GV GVL GWB GYP H H2S H.A.S. HC HCL HDNR	FORWARD REVERSE FIBERGLASS REINFORCED PLASTIC FOLDING SHOWER SEAT FOOT OR FEET FOOTING FIXTURE UNIT FULL VOLTAGE NON-REVERSING FULL VOLTAGE REVERSING FORWARD GROUND GAUGE GALLON GALVANIZED GYPSUM BOARD GROOVED COUPLING GLAZED CONCRETE MASONRY UNITS GROOVED FLANGE ADAPTER GROUND FAULT INTERRUPTER GROUND FAULT INTERRUPTER GROUND FAULT RELAY GREENHOUSE GLASS GALLONS PER DAY GALLONS PER HOUR GALLONS PER HOUR GALLONS PER MINUTE GLOBAL POSITION SYSTEM GRATING GYPSUM SOFFIT BOARD GALVANIZED STEEL PIPE GATE VALVE GRAVEL GYPSUM WALLBOARD GYPSUM HIGH, HORN OR HOWLER HYDROGEN SULFIDE HEADED ANCHOR STUD HOLLOW CORE WOOD HYDROCCHLORIC ACID HARDENER	KSK KV KVAR KVAR KW L LAB LAM LAT LB LC LD LDG LEF LG LH LHR LLH LLV LNTL LONG LOS LP LPT LR LR LR LR LS LT LTG, LTS LTX LWL MA MAS MATL MAX	KILOVOLTS KILOVOLT AMPERES KILOVOLT AMPERES KILOVOLT AMPERES REACTIVE KILOWATT ANGLE, LENGTH LIGHTNING ARRESTER LABORATORY LAMINATE LATITUDE POUND LIGHTING CONTACTOR COMBINATION LOUVER/DAMPER LOADING DOCK LOWER EXPLOSIVE LIMIT LINEAR FEET LONG LEFT HAND LEFT HAND REVERSE LONG LEG HORIZONTAL LONG LEG VERTICAL LINTEL LONGITUDINAL LOCK-OUT STOP PUSHBUTTON LIGHT POLE, LIGHTING PANEL, LOCAL PANEL LOW POINT LATCHING RELAY LOCAL-REMOTE LONG RADIUS LABORATORY SINK LEFT LIGHTS OR LIGHTING LIGHTING TRANSFORMER LOW WATER LEVEL MANUAL-AUTO MASONRY MATERIAL MAXIMUM	OC OCA OCR OD O.F. OFCI OFOI OL OO OOA OOR OP OPER OPNG OPP OSA OSC OSD OWSJ OZ P PAVT PB PC	OPEN-CLOSE (O) OPEN-CLOSE-AUTO OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE OUTSIDE DIAMETER, OVERFLOW DRAIN OUTSIDE FACE OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED OVERLOAD RELAY ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OPAQUE PANEL, OUTLET PROTECTION OPERATOR OPENING OPPOSITE OUTSIDE AIR OPEN-STOP-CLOSE OPEN SITE DRAIN OPEN WEB STEEL JOIST OUNCE PROJECTED PILASTER, PIPE PAVER TILE PUSHBUTTON SWITCH POINT OF CURVE, PHOTOCELL PRECAST CONCRETE CYLINDER PIPE PRESSURE CONTROL VALVE PLAIN END PEDESTAL, PEDESTRIAN	R OR RALE RA RC RCP RCPT RD RDCR RDW RECIR REF REFR REINF REQD RESIL RFS RH RH RH RL RLS RM RO ROL RPM RR THIS IS A THEREFO SHOWN N	RADIUS RETURN AIR REINFORCED CONCRETE REINFORCED CONCRETE PIPE RECEPTACLE ROAD, ROOF DRAIN REDUCER REDWOOD RECIRCULATION REFER OR REFERENCE REFRIGERATE, REFRIGERANT REINFORCED, REINFORCING, REINFORCE REQUIRED RESILIENT ROLL-UP FIRE SHUTTER RIGHT HAND RODHOLE RIGHT HAND REVERSE RAIN LEADER RUBBER LINED STEEL ROOM ROUGH OPENING RAISE-OFF-LOWER REVOLUTIONS PER MINUTE RIPRAP RAL NOTES: STANDARD LEGEND SHEET. RE, NOT ALL OF THE INFORMATION INY BE USED ON THIS PROJECT.	VERIII BAR IS- ORIGIN ORIGIN DATE PROJ

GENERAL UNION PUMP STATION ABBREVIATIONS



SECTION / DETAIL DESIGNATIONS ON DRAWING WHERE SECTION SECTION (LETTER) OR DETAIL (NUMERAL) DESIGNATION DRAWING NUMBER DRAWING NUMBER (REPLACED WITH A LINE ON SAME SHEET) В ON DRAWING WHERE SECTION 65-S-201 DRAWING NUMBER(S) DETAIL ON DRAWING WHERE DETAIL SCALE IS SHOWN: 65-S-201 DRAWING NUMBER(S) WHERE TAKEN DRAWING TITLE ON DRAWING WHERE ONLY A TITLE IS REQUIRED WITH NO REFERENCE (eg: ELEVATIONS) SECTION CALLOUT WHERE SECTION EXTENDS TO A FIXED LIMIT SECTION CALLOUT WHERE SECTION IS ON ANOTHER SHEET AND CUT EXTENDS THROUGHOUT ENTIRE SHEET GRID LINE INDICATOR KEYNOTE NUMBER REVISION / ADDENDA NUMBER NORTH ARROW DESIGN DETAIL DESIGNATION DESIGN DETAIL DESIGNATION (NUMERAL) SHOWN ON DESIGN DETAIL DRAWING(S) NOTES 1. ALL DESIGN DETAILS ARE TYPICAL AND MUST BE USED IF DESIGN



- 1. THIS IS A STANDARD LEGEND SHEET. THEREFORE, NOT ALL OF THE INFORMATION
- 2. CONTACT ENGINEER FOR ABBREVIATIONS



- SHOWN MAY BE USED ON THIS PROJECT.

ch2m.

PLAN

UNION PUMP STATION ABBREVIATIONS AND GENERAL LEGEND

100-G-003

NOT FOR CONSTRUCTION


WG PLOT TIME: 9:42:50 AM

2. THE TERM STANDARD DETAIL, OR A FORM OF IT, IS SYNONYMOUS WITH DESIGN DETAIL.

THE DESIGN DETAILS REPRESENT THE CHARACTER AND NATURE OF THE WORK REQUIRED THROUGHOUT THE PROJECT. ALL ASSOCIATED WORK SHALL BE IN ACCORDANCE WITH THE DESIGN DETAILS SHOWN WHETHER THE DETAILS ARE

INSTRUMENT IDENTIFICATION

EXAMPLE SYMBOLS



DIGITAL SYSTEM INTERFACES

- ANALOG INPUT
- ANALOG OUTPUT
- DISCRETE INPUT
- DISCRETE OUTPUT

	Α	ANALYSIS (+)		ALARM		
Ī	В	BURNER, COMBUSTION		USER'S CHOICE (*)	USER'S CHOICE (*)	USER'S CHOICE (*)
Ī	С	USER'S CHOICE (*)			CONTROL	
	D	DENSITY (S.G.)	DIFFERENTIAL			
	Е	VOLTAGE		PRIMARY ELEMENT, SENSOR		
	F	FLOW RATE	RATIO (FRACTION)			
	G	USER'S CHOICE (*)		GLASS, GAUGE VIEWING DEVICE	GATE	
	Н	HAND (MANUAL)				HIGH
	ı	CURRENT (ELECTRICAL)		INDICATE		
	J	POWER	SCAN			
	K	TIME, TIME SCHEDULE	TIME RATE OF CHANGE		CONTROL STATION	
Ī	L	LEVEL		LIGHT (PILOT)		LOW
	М	MOTION	MOMENTARY			MIDDLE, INTERMEDIATE
	N	TORQUE		USER'S CHOICE (*)	USER'S CHOICE (*)	USER'S CHOICE (*)
	0	USER'S CHOICE (*)		ORIFICE, RESTRICTION		
	Р	PRESSURE, VACUUM		POINT (TEST) CONNECTION		

RECORD OR PRINT

MULTI FUNCTION

WELL

UNCLASSIFIED (*)

TABLE BASED ON THE INSTRUMENTATION, SYSTEMS, AND AUTOMATION SOCIETY (ISA) STANDARD.

INTEGRATE

SAFETY

X AXIS

Y AXIS

Z AXIS

(+) WHEN USED, EXPLANATION IS SHOWN ADJACENT TO INSTRUMENT SYMBOL. SEE ABBREVIATIONS AND LETTER SYMBOLS. (*) WHEN USED, DEFINE THE MEANING HERE FOR THE PROJECT.

FIRST-LETTER

MODIFIER

PROCESS OR INITIATING VARIABLE

QUANTITY

RADIATION

SPEED, FREQUENCY

TEMPERATURE

MULTI VARIABLE

VIBRATION, MECHANICAL ANALYSIS

WEIGHT, FORCE

UNCLASSIFIED (*)

EVENT, STATE OR PRESENCE

POSITION

LETTER

Q

S

U

W

Z

GENERAL INSTRUMENT OR FUNCTIONAL SYMBOLS



FIELD MOUNTED



REAR-OF-PANEL MOUNTED (OPERATOR INACCESSIBLE)



\$PWURL

(OPERATOR ACCESSIBLE) MCC MOUNTED

PANEL MOUNTED

HAND SWITCHES AND INDICATING LIGHTS



ON AND OFF EVENT



ON-OFF HAND SWITCH MAINTAINED CONTACT SWITCH (CONTROLLED DEVICE WILL RESTART ON RETURN OF POWER AFTER POWER FAILURE)



STOP-START HAND SWITCH MOMENTARY CONTACT SWITCHES (CONTROLLED ON RETURN OF POWER AFTER POWER FAILURE).

INSTRUMENT IDENTIFICATION LETTERS TABLE

READOUT OR

PASSIVE FUNCTION

SUCCEEDING-LETTERS

READOUT OR PASSIVE FUNCTION

SWITCH

TRANSMIT

MULTI FUNCTION

VALVE, DAMPER, LOUVER

UNCLASSIFIED (*)

RELAY, COMPUTE, CONVERT

DRIVE, ACTUATOR, UNCLASSIFIED FINAL CONTROL ELEMENT

READOUT OR PASSIVE FUNCTION		
USER'S CHOICE (*)		
	_	
	////	
	-x-x-x-	
HIGH		
	-	
LOW		
MIDDLE, INTERMEDIATE USER'S CHOICE (*)		
COLITO CHOICE ()		
		-
	INTER	F
MULTI FUNCTION	S	_
WISETTI SINGTION		

UNCLASSIFIED (*)

NTERFACE SYMBOLS

LINE LEGEND

PRIMARY PROCESS (CLOSED CONDUIT, DASHED LINE INDICATES

SECONDARY PROCESS

BYPASS PROCESS

ANALOG SIGNAL (4 TO 20 mAdc, ETC.)

(ON/OFF, ETC.)

PNEUMATIC SIGNAL

FILLED SYSTEM SIGNAL

BUILDING OR FACILITY BOUNDARY

PACKAGE SYSTEM

HYDRAULIC SYSTEM SIGNAL

DISCRETE

DATALINK

- - SIMILAR PROCESS

ALTERNATE FLOW STREAM)


PROCESS (OPEN CHANNEL)

PARALLELING LINES

(A) TOTAL OF 2 SIGNALS

CONNECTING LINES

NON-CONNECTING LINES



- INTERFACE LETTER
- DESTINATION DRAWING NO.
- SOURCE DRAWING NO



ABBREVIATIONS & LETTER SYMBOLS

ALTERNATING CURRENT AUTO-MANUAL CHLORINE (TYPICAL: USE STANDARD CHEMICAL CL₂ etc. ELEMENT ABBREVIATIONS) COD CP-X

CHEMICAL OXYGEN DEMAND CONTROL PANEL NO. X (X = FACILITY NUMBER) DIRECT CURRENT DISSOLVED OXYGEN

DC DO FCL₂ FREE CHLORINE RESIDUAL FOS FOSA FAST-OFF-SLOW FAST-OFF-SLOW-AUTO FOSR FP-W-X

FAST-OFF-SLOW-REMOTE FIELD PANEL NO. WX (W = UNIT PROCESS NUMBER X = PANEL NUMBER FORWARD-REVERSE

FR HOA HOR ISR LEL LOS LR MA HAND-OFF-AUTO HAND-OFF-REMOTE INTRINSICALLY SAFE RELAY LOWER EXPLOSIVE LIMIT LOCAL-REMOTE MANUAL-AUTO MC MCC-X MODULATE-CLOSE MOTOR CONTROL CENTER NO. X MANUFACTURER SUPPLIED CABLE NORMALLY CLOSED NORMALLY OPEN

MSC NC NO OCA OCR OO OOA OOR ORP OSC OPEN-CLOSE(D) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE ON-OFF ON-OFF-AUTO ON-OFF-REMOTE OXIDATION REDUCTION POTENTIAL OPEN-STOP-CLOSE

HYDROGEN ION CONCENTRATION PROGRAMMABLE LOGIC CONTROLLER pH PLC RIO RTU-X REMOTE I/O UNIT REMOTE TELEMETRY UNIT NO. X SLOW-OFF-FAST

SOF SS TCL₂ TOC TOD TURB VHC VIB TOTAL CHLORINE RESIDUAL TOTAL ORGANIC CARBON TOTAL OXYGEN DEMAND

VOLATILE HYDROCARBONS VIBRATION

GENERAL NOTES

- COMPONENTS AND PANELS SHOWN WITH A SINGLE ASTERISK (*) ARE TO BE PROVIDED AS PART OF A PACKAGE SYSTEM.
- COMPONENTS AND PANELS SHOWN WITH A DOUBLE ASTERISK (**) ARE TO BE PROVIDED UNDER DIVISION 26, ELÉCTRICAL
- THIS IS A STANDARD LEGEND. THEREFORE, NOT ALL OF THIS INFORMATION MAY BE USED ON THE PROJECT.

ch2m.

UNION PUMP STATION INSTRUMENTATION AND CONTROL LEGEND - SHEET 1

NOT FOR CONSTRUCTION

PLAN

RIFY SCALE
IS ONE INCH ON SINAL DRAWING.

NOVEMBER 2016

664626

100-G-005 VERIFY SCALE BAR IS ONE INCH ON

PROJ WG PLOT TIME: 9:42:46 AM

SELF CONTAINED VALVE & EQUIPMENT TAG NUMBERS

D-UP-LL-UU

AIR RELEASE VALVE AIR AND VACUUM RELEASE VALVE AVRV


GATE MECHANICAL EQUIPMENT

TANK UNIT PROCESS NUMBER

UNIT NUMBER

LOOP NUMBER

HILL




GENERAL ARCHITECTURAL NOTES

UNLESS OTHERWISE INDICATED, PLAN DIMENSIONS ARE TO COLUMN GRID ON CENTERLINES, NOMINAL SURFACE OF MASONRY, FACE OF STUDS AND FACE OF CONCRETE WALLS.

- 2. "FLOOR LINE" REFERS TO TOP ON CONCRETE SLABS. FINISH FLOORING IS INSTALLED ABOVE THE FLOOR LINE. FOR DEPRESSED FLOORS AND CURBS, SEE STRUCTURAL DRAWINGS.
- 3. REPETITIVE FEATURES ARE NOT DRAWN IN THEIR ENTIRETY AND SHALL BE COMPLETELY PROVIDED AS IF DRAWN IN FULL.
- 4. WHERE DOOR IS LOCATED NEAR CORNER OF ROOM AND IS NOT LOCATED BY DIMENSION ON PLAN OR DETAILS, DIMENSION SHALL BE 3-INCHES FROM FACE OF STUD (WALL) TO FACE OF ROUGH OPENING, DIMENSION SHALL BE 6" FROM FACE OF WALL TO EDGE OF ROUGH OPENING AT CONCRETE WALLS, 8" AT CMU WALLS.
- 5. AT SOUND INSULATED WALLS, FULL HEIGHT PARTITIONS SHALL BE SEALED BOTH SIDES WITH ACOUSTIC SEALANT; TOP, BOTTOM, INTERSECTION, DOOR FRAMES, GLAZED OPENING FRAMES, AND OTHER PENETRATIONS.
- 6. LINE OF EXISTING GRADES, AS SHOWN ON THE BUILDING ELEVATIONS AND SECTIONS ARE APPROXIMATE. THEY ARE AT THE BUILDING FACE, OR ON THE SECTION END EXCEPT AS NOTED.
- 7. VERIFY ALL ROUGH-IN DIMENSIONS FOR EQUIPMENT PROVIDED IN THIS
- 8. REFER TO ARCHITECTURAL, STRUCTURAL, MECHANICAL, ELECTRICAL AND OTHER CATEGORIES OR DRAWINGS FOR ADDITIONAL NOTES.
- 9. VERIFY SIZE AND LOCATION OF, AND PROVIDE: REQUIRED OPENINGS THROUGH FLOORS AND WALLS, ACCESS DOORS, FURRING, CURBS, ANCHORS AND INSERTS. PROVIDE ALL BASES AND BLOCKING REQUIRED FOR ACCESSORIES, MECHANICAL, ELECTRICAL AND OTHER EQUIPMENT.

ARCH/STRUCT MATERIAL SYMBOLS




WOOD, FINISHED

ARCHITECTURAL/STF	RUCTURAL LEGEND
SYMBOL	LEGEND
A	NEW REFERENCE GRID INDICATOR
(A)	EXISTING REFERENCE GRID INDICATOR
ROOM NAME ROOM NAME [XX-101] OR 101	ROOM IDENTIFIER
"XX" = FACILITY DOOR LETTER INDICATOR (IF SHOWN) ROOM NUMBER	DOOR IDENTIFIER
XXW-1 OR W-1	WINDOW IDENTIFIER
XXR-1 OR R-1	RELIGHT IDENTIFIER
XXL-1 OR (L-1)	LOUVER IDENTIFIER
A	WALL TYPE INDICATOR
(S-1)	SIGNAGE IDENTIFIER
(P-1)	PRECAST PANEL IDENTIFIER
1 (XX-A-301)	EXTERIOR ELEVATION INDICATOR
QUANTITY AND DIRECTION OF A POINTERS AS REQUIRED D XXX-A-301	INTERIOR ELEVATION INDICATOR
1 XX-A-401	DETAIL INDICATOR - SMALL CONDITION
⊗ 110.50	SPOT ELEVATION INDICATOR
	DIRECTION OF SLOPE DOWN
HINGE SIDE	DOOR/HATCH SWING INDICATOR
ACTIVE INACTIVE	INDICATES PAIR OF DOORS
F.EXT-X	FIRE EXTINGUISHER "X" = NUMBER IN SPECIFICATIONS
	CONTROL JOINT
	EXPANSION JOINT
•	RAILINGS
POST	

UNION PUMP STATION ARCHITECTURAL AND STRUCTURAL LEGEND ch2m. NOT FOR CONSTRUCTION RIFY SCALE
IS ONE INCH ON
SINAL DRAWING
INCH ON
NOVEMBER 2016
664626
100-G-007
of
TIME: 04233 AM VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING.

PROJ WG



HVAC GENERAL NOTES

- NOTES BELOW ARE NOT INTENDED TO REPLACE SPECIFICATIONS. SEE SPECIFICATIONS FOR REQUIREMENTS IN ADDITION TO

- NOTES BELOW ARE NOT INTENDED TO REPLACE SPECIFICATIONS. SEE SPECIFICATIONS FOR REQUIREMENTS IN ADDITION TO GENERAL NOTES.
 CONTRACT OR SHALL VISIT THE SITE AND BECOME INFORMED AS TO THE NATURE AND SCOPE OF WORK REQUIRED BY CONTRACT DOCUMENTS PRIOR TO BIDDING PROJECT.
 PROVIDE ALL REQUIRED MATERIALS, LABOR, EQUIPMENT, AND SERVICES NECESSARY FOR THE INSTALLATION OF THE WORK AS SHOWN ON THESE DRAWNINGS OR SPECIFIED BY THE BASE BUILDING DRAWNING AND SPECIFICATIONS.
 REFER TO AND CAREFULLY CHECK ARCHITECTURAL, ELECTRICAL, PLUMBING, AND FIRE PROTECTION DRAWNINGS AND DETAILS, NOTES, LOCATIONS WHERE WALLS, PARTITIONS, CEILINGS, AND OTHER SURFACES ARE FURRED, LOCATIONS OF SHAFTS, NOTES, LOCATIONS WHERE WALLS, PARTITIONS, CEILINGS, AND OTHER SURFACES ARE FURRED, LOCATIONS OF SHAFTS, SOFFITS, AND CONFLICTS WITH WORK OF OTHER TRADES, AND ARRANGE WORK ACCORDINGLY, FURNISH ALL OFFSETS, DAMPERS, CONNECTORS, ETC., REQUIRED TO MEET SUCH CONDITIONS.

 DUE TO SCALE OF DRAWINGS, ALL REQUIRED OFFSETS, DAMPERS, ETC., MAY NOT BE INDICATED.

 COORDINATE DIFFUSERS LOCATIONS AND DUCT WITH LIGHTING FIXTURES AND SPRINKLER HEADS, SEE ARCHITECTURAL DRAWINGS FOR EXACT LOCATIONS AND DETAILS OF PARTITIONS, SUSPENDED CEILINGS, AND SOFFITS.

- DHAWINGS FOR EXACT LOCATIONS AND DETAILS OF PARTITIONS, SUSPENDED CELLINGS, AND SOFTITS.
 ALL DUCT PASSING THROUGH FIRE, SMOKE RATED DO R SMOKE/FIRE RATED BARRIERS (WALLS, FLOOR) SHALL BE PROVIDED
 WITH FIRE, SMOKE OR SMOKE/FIRE DAMPERS IN ACCORDANCE WITH FINAL CONTRACT DOCUMENTS. ALL REQUIRED SMOKE
 DETECTORS PROVIDED BY DIV 23 SHALL BE CONNECTED TO FIRE ALARM SYSTEM.
 CONTRACTOR SHALL OBTAIN AND PAY FOR ALL REQUIRED PERMITS AND ARRANGE FOR ALL REQUIRED INSPECTIONS IN
 ACCORDANCE WITH STATE AND LOCAL CONVEDING CODES.
- ACCORDANCE WITH STATE AND LOCAL GOVERNING CODES.
- THE TERM "PROVIDE" SHALL MEAN "TO FURNISH, INSTALL, AND CONNECT COMPLETELY"
- THE TERM "PROVIDE" SHALL MEAN "10" PLYNRISH, INSTALL, AND CONNECT COMPLETIELY.
 TURN OVER TO THE OWNER ALL MANUFACTURERS WARRANTIES FOR EQUIPMENT AND MATERIALS PROVIDED.
 WHERE THE CONTRACTOR PROPOSES TO USE AN ITEM OF EQUIPMENT OTHER THAN THAT SPECIFIED OR DETAILED ON THE
 DRAWINGS WHICH REQUIRES ANY REDESIGN OF THE STRUCTURE, PARTITIONS, FOUNDATIONS, PIPING, WIRING OR ANY OTHER
 PART OF THE MECHANICAL, ELECTRICAL OR ARCHITECTURAL LAYOUT, ALL SUCH REDESIGN AND ALL NEW DRAWINGS AND
 DETAILING REQUIRED THEREFORE, SHALL BE PREPARED AT THE CONTRACTOR'S EXPENSE AND ARE SUBJECT TO THE REVIEW AND APPROVAL OF THE OWNER OR HIS AUTHORIZED REPRESENTATIVE, OWNER RESERVES THE RIGHT TO HAVE THE ARCHITECT OR ENGINEER OF HIS CHOICE PREPARE ANY REDESIGN WORK
- AROHIECT OR REGINEER OF HIS CHOICE PREPARE ANY REDESIGN WORK.

 CONTRACTOR SHALL COORDINATE ELECTRICAL REQUIREMENTS OF MECHANICAL EQUIPMENT WITH DIVISION 26.

 ALL WORK SHALL BE DONE WITH LICENSED WORKMEN IN ACCORDANCE WITH STATE AND LOCAL GOVERNING AUTHORITIES.

 BEFORE SELECTING MATERIAL AND EQUIPMENT, AND PROCESSING THE WORK, INSPECT AREAS WHERE MATERIAL AND EQUIPMENT ARE TO BE INSTALLED TO INSURE SUITABILITY AND CHECK NEEDED SPACE FOR PLACEMENT AND CLEARANCES.
- 15. BEFORE CUTTING AND DRILLING INTO BUILDING ELEMENTS, INSPECT AND LAYOUT WORK TO AVOID DAMAGING STRUCTURAL ELEMENTS AND BUILDING UTILITIES.
- ELEMENTS AND BUILDING OTHER S.

 16. CONTRACTOR RESPONSIBLE FOR REPAIR AND PAYMENT FOR ALL LITTLITIES DAMAGE DURING CONSTRUCTION.
- CONTRACTOR TO CONFIRM DUCTWORK LOCATIONS, ELEVATIONS AND SIZES BEFORE ANY WORK IS STARTED. IF ANY DISCREPANCIES ARE FOUNDED, NOTIFY ENGINEER BEFORE PROCEEDING WITH WORK, (SEE PAR. 48 "COORDINATION DRAWINGS").

 18. FOLLOW MANUFACTURER'S RECOMMENDATIONS FOR INSTALLATION OF PROVIDED EQUIPMENT.
- CONTRACTOR TO REPLACE ALL SUSPENDED CEILING TILES DAMAGED AS A RESULT OF HVAC SYSTEM INSTALLATION.
 ALL SHOP DRAWINGS OF INDIVIDUAL COMPONENTS ARE TO BE SUBMITTED AS A COMPLETE PACKAGE.
- 21. HVAC DRAWINGS DO NOT NECESSARY SHOW ALL CONDITIONS OF BUILDING. CONTRACTOR TO USE ALL DRAWINGS AND
- HVAC DRAWINGS DO NOT NECESSARY SHOW ALL CONDITIONS OF BUILDINGS. CONTINACTOR TO USE ALL DRAWINGS AND SPECIFICATIONS OF CONTRACT DOCUMENTS AND INSPECTION OF FIELD CONDITIONS FOR DIVISION 23.

 HVAC PLANS, DETAILS AND ONE LINE DIAGRAMS SHOW THE GENERAL LOCATION AND ARRANGEMENT OF THE SYSTEM. THE ARE DIAGRAMMATIC AND DO NOT SHOW ALL OFFSETS, HANGERS, ACCESS DOORS, ETC. WHICH THE CONTRACTOR MUST
- PROVIDE TO COMPLETE THE SYSTEM. 23. ALL WORK IN INTERIOR FINISHED SPACES EXCEPT INDICATED IS TO BE CONCEALED ABOVE CEILING. PROVIDE ALL NECESSARY CUTTING, PATCHING, REPAINTING AND/OR REPLACEMENT OF FINISHES AS REQUIRED TO PERFORM COORDINATE WITH OTHER
- 25. SUPPORT DUCTWORK ABOVE SUSPENDED CEILING FROM CONSTRUCTION ABOVE AS CLOSE AS POSSIBLE TO BOTTOM OF
- SLABS, BEAMS, MAINTAINING HEADROOM AT ALL TIMES. 26. DO NOT SCALE DRAWINGS, CHECK EXISTING SPACE CONDITIONS AT THE JOB SITE.
- DO NOT PENETRATE STAIR WALLS WITH ANY UTILITIES OR CONDUIT EXCEPT FOR UTILITIES SPECIFICALLY SERVING THAT STAIR.
 CONTROL CONTRACTOR PROVIDE ALL CONTROL DEVICES, EQUIPMENT, ACCESSORIES, VFD DRIVES, OTHER APPARATUS,
 CONTROL VALVES AND DAMPERS, ACTUATORS, SENSORS, ETC, AND ALL CONTROL WIRING RELATED TO FACILITY
 MANAGEMENT SYSTEM (FMS), SEE SPECIFICATION SECTIONS 230900.
- 29. ALL DUCTWORK SHALL BE HUNG FROM STRUCTURE ABOVE. PROVIDE FLEXIBLE JOINTS ON ALL PIPING AND DUCTWORK WHERE PENETRATING ALL BUILDING EXPANSION JOINTS
- 31 PROVIDE ELEXIBLE CONNECTIONS BETWEEN MECHANICAL EQUIPMENT AND DUCTWORK AND PIPING
- PROVIDE FLEXBLE CONNECTIONS BETWEEN MECHANICAL EQUIPMENT AND DUCTWORK AND PIPING.
 PROVIDE MINIMUM OF 3' DUCT LINEAR AT EACH FANCOIL UNIT BRANCH DUCT UNIT CONNECTION AND DUCT LINER FOR DUCT FROM FAN-COIL UNIT TO SUPPLY DIFFUSERS (SEE DETAILS).
 PROVIDE VOLUME DAMPERS ON ALL BRANCHES OF DUCTWORK (SUPPLY, RETURN, EXHAUST).
 PROVIDE FLEXIBLE DUCTWORK CONNECTION TO ALL CEILING SUPPLY DIFFUSERS, (MAXIMUM 3'-0" LONG).
 REFER TO SPECIFICATION SECTION 078413 "THROUGH PENETRATION FIRESTOP SYSTEMS" FOR ALL MATERIALS AND METHODS

- FOR PENETRATION THROUGH FIRE AND SMOKE RATED ASSEMBLIES.
- 36. ALL PENETRATIONS THRU WALLS, ROOF, AND FLOORS TO BE COORDINATED BEFORE SITE WORK EXECUTION WITH
- 30. ALL PENETRALIONS THRU WALLS, ROUF, AND FLOORS TO BE COORDINATED BEFORE SITE WORK EXECUTION WITH STRUCTURAL ENGINEERS.

 37. THERMOSTAT AND TEMPERATURE SENSOR LOCATIONS TO BE COORDINATED WITH INTERIOR WALL LAYOUT, REFER TO ARCHITECTURAL PLANS.

 38. CEILING DIFFUSER AND REGISTER LOCATIONS TO BE COORDINATED WITH CEILING GRID, LIGHTING & SPRINKLER LAYOUT.
- REFER TO ARCHITECTURAL REFLECTED CEILING PLAN.

- REFER TO ARCHITECTURAL REFLECTED CEILING PLAN.

 9. PROVIDED MINIMUM OF 20' DUCT LINER AT EACH AIR HANDLING UNIT (SUPPLY AND RETURN CONNECTIONS).

 40. NO THREADED FITTINGS 2-12" AND LARGER ALLOWED FOR HYDRONIC HVAC PIPING.

 41. CONTRACTOR SHALL SELECT AND PROVIDE EXPANSION JOINTS OR EXPANSION LOOPS AND ANCHORS AS REQUIRED TO PREVENT TEMPERATURE EXPANSION STRESSES OF HYDRONIC PIPES BASED ON ACTUAL INSTALLATION/CONDITIONS.

 2. ELECTRICAL CHARACTERISTICS FOR MECHANICAL EQUIPMENT: EQUIPMENT OF HIGHER LECTRICAL CHARACTERISTICS MAY BE FURNISHED PROVIDED SUCH PROPOSED EQUIPMENT IS APPROVED IN WRITING AND CONNECTING ELECTRICAL SERVICES.
- CIRCUIT BREAKERS, AND CONDUIT SIZES ARE APPROPRIATELY MODIFIED. IF MINIMUM ENERGY RATINGS OR EFFICIENCIES ARE CIRCUIT BREAKERS, AND CONDUIT SIZES ARE APPROFIXE LEY MODIFIED. IF MINIMUM ENERGY RATINGS OR EFFICIENCIES ARE SPECIFIED, EQUIPMENT SHALL COMPLY WITH REQUIREMENTS.

 43. ALL SUPPLY, RETURN, TRANSFER, AND EXHAUST DUCTWORK EXPOSED IN A ROOM WITH NO CEILING(EXCEPT ELECTRICAL AND MECHANICAL ROOMS) SHALL BE DOUBLE WALL INSULATED DUCTWORK WITH PERFORATED INNER LINER.

 44. ALL BASE-MOUNTED PUMPS SHALL BE INSTALLED WITH CONCRETE FILLED INERTIA BASE.

 45. ALL ROOF MOUNTED EXHAUST AND SUPPLY FANS SHALL BE INSTALLED WITH ACOUSTICAL CURB.

 46. ANY MATERIALS EXPOSED WITHIN THE PLENUM MUST BE NONCOMBUSTIBLE OR HAVE A MAXIMUM FLAME SPREAD INDEX OF 25

- AND A MAXIMUM SMOKE-DEVELOPED INDEX OF 50 WHEN TESTED IN ACCORDANCE WITH ASTM E84.
- 47. WINGS: DETAIL MAJOR ELEMENTS, COMPONENTS, AND SYSTEM PF MECHANICAL EQUIPMENT AND MATERIALS IN
 RELATIONSHIPS WITH OTHER SYSTEMS, INSTALLATIONS, AND BUILDING COMPONENTS. SHOW SPACE REQUIREMENTS FOR
 INSTALLATION AND ACCESS, INDICATE IF SEQUENCE AND COORDINATION ARE IMPORTANT TO EFFICIENT FLOW OF THE WORK.
 - PLANNED PIPING LAYOUT, INCLUDING VALVE AND SPECIALTY LOCATIONS AND VALVE-STEM MOVEMENT.
- CLEARANCES FOR INSTALLING AND MAINTAINING INSULATION.
 CLEARANCES FOR SERVING AND MAINTAINING INSULATION.
 CLEARANCES FOR SERVING AND MAINTAINING EQUIPMENT, ACCESSORIES, AND SPECIALTIES, INCLUDING SPACE FOR DISASSEMBLY REQUIRED BY PERIODIC MAINTENANCE.
 EQUIPMENT AND ACCESSORY SERVICE CONNECTIONS AND SUPPORT DETAILS.
- EXTERIOR WALL AND FOUNDATION PENETRATIONS.
- FIRE-RATED WALL AND FLOOR PENETRATION.
- SIZES AND LOCATION OF REQUIRED CONCRETE PADS AND BASES.
- SCHEDULING, SEQUENCING, MOVEMENT, AND POSITIONING OF EQUIPMENT INTO BUILDING DURING
- CONSTRUCTION.
 FLOOR PLANS, ELEVATIONS, AND DETAILS TO INDICATE PENETRATIONS, FLOORS, WALLS, AND CEILINGS AND THEIR
 RELATIONSHIP TO OTHER PENETRATIONS AND INSTALLATIONS.
 REFLECTED CEILING PLANS TO COORDINATE AND INTEGRATE INSTALLATION OF AIR OUTLETS, LIGHT FIXTURES,
 COMMUNICATION SYSTEMS, COMPONENTS, SPRINKLERS, AND OTHER CEILING-MOUNTED ITEMS.
- ACCESS DOOR AND ACCESS PANEL LOCATIONS, WITH FIRE-RATINGS REQUIRED TO MAINTAIN FIRE RATING OF CONSTRUCTION, IN LOCATIONS AS REQUIRED FOR PROPER ACCESS FOR MAINTENANCE ADJUSTMENT, REPAIR AND REMOVAL OF ALL EQUIPMENT AND DEVICES.

 SCALE: MINIMUM 1/4"=1"-0" FOR FLOOR PLAN, 3/8"=1"-0" FOR MECHANICAL ROOMS.
- 48. ALL PENETRATIONS FOR THE INSTALLATION OF THE MECHANICAL SYSTEMS SHALL BE CAULKED AND SEALED FOR SMOKE AND
- 49. LOCATE ROOF MOUNTED HVAC EQUIPMENT MORE 10 FEET FROM ROOF EDGE, PROVIDE HANDRAILS IF EQUIPMENT ON THE
- ECCATE LESS 10 FEET FROM ROOF EDGE (SEE ARCHITECTURAL DRAWINGS)

 CONTROL CONTRACTOR TO PROVIDE ALL CONTROL DEVICES, EQUIPMENT, ACCESSORIES, OTHER APPARATUSES, CONTROL VALVES AND DAMPERS, ACTUATORS, SENSORS, ETC. AND ALL CONTROL WIRING AND LOW VOLTAGE POWER WIRING RELATED TO CENTRAL DDC CONTROL SYSTEM, SEE SPECIFICATION SECTION 230900.


ABBREVIATIONS


	ADDREVIAT	IONS	
AFS	AIR FLOW MEASURING STATION	LWT	LEAVING WATER TEMPERATURE
AC	AIR CONDITIONING	MD	MOTORIZED DAMPER
ACC	AIR COOLED CONDENSER UNIT (NO COMPRESSOR)	MAU	MAKE-UP AIR UNIT
ACCU	AIR COOLED CONDENSING UNIT	MAX	MAXIMUM
AD	ACCESS DOOR	MBH	THOUSAND BTU/HOUR
AHU	AIR HANDLING UNIT	MIN	MINIMUM
AL	ALUMINUM DUCTWORK	MTS	MINUTES
AFF	ABOVE FINISH FLOOR	MUW	MAKE-UP WATER
AMPS	AMPERE	MV	MOTORIZED VALVE
BAL	BALANCE	NEG	NEGATIVE
BD	BAROMETRIC DAMPER	NG	NATURAL GAS
BDD	DAMPER BACK DRAFT	NO	NUMBER
BHP	BREAK HORSEPOWER	NRS	NON-RISING STEM
BMS	BUILDING MANAGEMENT SYSTEM	NTS	NOT TO SCALE
BTU	BRITISH THERMAL UNIT	OA	OUTSIDE AIR
BTUH	BRITISH THERMAL UNIT/HR	OBD	OPPOSED BLADE DAMPER
DWD	DOUBLE WALL DUCTWORK	OCPD	OVER CURRENT PROTECTION DEVICE
C-C	COLUMN ENCLOSURE TO COLUMN ENCLOSRE	OED	OPEN END DUCT, TERMINATE WITH
C-W	COLUMN ENCLOSURE TO WALL		STAINLESS STEEL BIRD SCREEN
CA	COMBUSTION AIR	OS&Y	OUTSIDE STEM & YOKE
CENTRIF	CENTRIFUGAL	P	PUMP
CFM	CUBIC FEET PER MINUTE		
CO	CLEAN OUT	PBD	PARALLEL BLADE DAMPER
cw	DOMESTIC COLD WATER	PEF	PROCESS EXHAUST FAN
CV	CONTROL VALVE	PH	PHASE
CMEU	CEILING MOUNTED EVAPORATOR	PNL	PANEL
CUH	CABINET UNIT HEATER	POS	POSITIVE
DB	DRY BULB	PRESS	PRESSURE
DC	DIRECT CURRENT	PRV	PRESSURE RELIEF VALVE
DIA OR Ø	DIAMETER	PS	PRESSURE SWITCH
DHW	DOMESTIC HOT WATER HEATER	PS I A	POUNDS PER SQUARE INCH
DN	DOWN		ATMOSPHERE
DP	DEW POINT	PSIG	POUNDS PER SQUARE INCH GAUGE
EA	EXHAUST AIR	RA	RETURN AIR
EAT	ENTERING AIR TEMPERATURE	RECIRC	RECIRCULATING
FF	EXHAUST FAN	RH	RELATIVE HUMIDITY
ESP	EXTERNAL STATIC PRESSURE	RPM	REVOLUTIONS PER MINUTE
EWT	ENTERING WATER TEMPERATURE	SA	SUPPLY AIR
EUH	ELECTRIC UNIT HEATER	SATT	SOUND ATTENUATOR
FXH	EXHAUST	SCFM	STANDARD CUBIC FEET/MINUTE
EXP	EXPANSION	SENS	SENSOR
FC	FLEXIBLE CONNECTOR	SF	SUPPLY FAN
		SH	SENSIBLE HEAT
FD/AD	FIRE DAMPER/ACCESS DOOR	SCP	SHORT CIRCUIT CIRCULATION PUMP
FLG	FLANGE	SP	STATIC PRESSURE
FCU	FAN COIL UNIT	STP	STANDARD TEMP & PRESSURE
FMS FPM	FLOW MEASURING STATION	SUP	SUPPLY
°F	FEET PER MINUTE	SV	SOLENOID VALVE
FPS	DEGREES FAHRENHEIT FEET PER SECOND	T&PV	TEMP & PRESSURE RELIEF VALVE
FS	FLOW SWITCH	SFD/AD	COMBINATION SMOKE/FIRE DAMPER
FT	FEET FEET	TC	TEST CONNECTION WITH ACCESS
FTR	FIN-TUBE RADIATION		DOOR
FT3	CUBIC FEET	TEMP	TEMPERATURE
GA	GAUGE	<u>T</u>	THERMOSTAT
GPM	GALLONS PER MINUTE	TH.	TOTAL HEAT
		TRA	TRANSFER AIR
H	HEAT CONTENT (BTU/lb) HUMIDISTAT	TRV	RELIEF VALVE TEMP
H HC	HEATING COIL	TSP	TOTAL STATIC PRESSURE
HD	HEAD HEAD	TS	TEMPERATURE SENSOR
HD HP		TYP	TYPICAL
	HORSEPOWER	UH	UNIT HEATER
HT	HEIGHT CYCLES	UN	UNIT
HZ ID	INSIDE DIAMETER	VD	VOLUME DAMPER
ID IN	INSIDE DIAMETER INCHES	VT	VENT
***		VLV	VALVE
KVA	KILLOVOLT AMPERE	VI	VIBRATION ISOLATOR
KW	KILOWATTS	V	VOLTS
L	LENGTH	W	WATTS
LAT	LEAVING AIR TEMPERATURE	WB	WET BULB
LB	POUNDS	WG	WATER GAUGE
LH	LATENT HEAT	WH	WATER HEATER
		WI	WIDTH
		WT	WEIGHT

DIFFUSER AND GRILLE ABBREVIATIONS

CDE	CEILING DIFFUSER - EXHAUST	SWS	SIDEWALL GRILLE - SUPPLY
TG	TRANSFER GRILLE	SWR	SIDEWALL GRILLE - RETURN
		SWE	SIDEWALL GRILLE - EXHAUST

NOTE: SOME SYMBOLS AND ABBREVIATIONS MAY OR





100-G-015

οf

PLAN

LEGEND

ELECTRICAL

FOR CONSTRUCTION

NOT

	1	2 T	3		4	5	6	1	
SYMBOL	DESCRIPTION	SYMBOL	DESCRIPTION		DESCRIPTION	SYMBOL	DESCRIPTION		
	POWER SYSTEM PLAN-1	100/40	POWER SYSTEM PLAN-2		ARM SYSTEM PLAN AND RISER		OUND SYSTEM PLAN AND RISER		
(A)	CONNECTION POINT TO EQUIPMENT SPECIFIED. RACEWAY, CONDUCTOR, TERMINATION AND CONNECTION IN THIS DIVISION.	100/40	BREAKER, SEPARATELY MOUNTED, CURRENT RATING INDICATED (100/40, 100 = FRAME SIZE; 40 = TRIP RATING)	— — Р	FIRE ALARM STATION, MANUAL	S	SPEAKER, CONE TYPE, RECESSED IN CEILING, SEE ARCHITECTURAL DRAWINGS FOR CEILING TYPE		
MCC-A	MAJOR ELECTRICAL COMPONENT OR DEVICE - NAME	2	3 POLE		FIRE ALARM SYSTEM, AUTOMATIC SMOKE DETECTOR	S	SPEAKER, CONE TYPE, WALL MOUNTED		
	OR IDENTIFYING SYMBOL AS SHOWN.	© ²	CONTACTOR, MAGNETIC, NEMA SIZE INDICATED		FIRE ALARM SYSTEM, AUTOMATIC, HEAT DETECTOR	s	SPEAKER, CONE TYPE, SURFACE MOUNTED	<u> </u>	1 1 101 5
LPXXA	PANELBOARD - SURFACE MOUNTED	L ³⁰	LIGHTING CONTACTOR, CURRENT RATING INDICATED	~	FIRE ALARM BELL	<u> </u>	VOLUME CONTROL, WALL MOUNT 5'-0" AFF		APVE
	PANELBOARD LETTER OR NUMBER FACILITY NUMBER	xx	STARTER, MAGNETIC NEMA SIZE INDICATED		FIRE ALARM HORN	S⊲	INTERIOR PAGING TRUMPET SOUND REPRODUCER		Bd
	LP - LOW VOLTAGE PANEL DP - DISTRIBUTION PANEL	⊕ 2	CONVENIENCE RECEPTACLE - DUPLEX UNLESS NOTED OTHERWISE		FIRE ALARM HORN/STROBE LIGHT		WITH REMOTE AMPLIFIER, SURFACE MOUNTED		
	PANELBOARD - FLUSH MOUNTED		WP-WEATHERPROOF C-CLOCK HANGER TL-TWIST LOCK CRE-CORROSION RESISTANT GFCI-GROUND FAULT CIRCUIT INTERRUPTER	×	FIRE ALARM STROBE LIGHT	M	MICROPHONE OUTLET		A APV
	TERMINAL JUNCTION BOX		SUBSCRIPT NUMBER AT RECEPTACLE INDICATES CIRCUIT	==©	AIR DUCT DETECTOR	s	SOUND SYSTEM RACEWAY		. Revie
M	MOTOR. SQUIRREL CAGE INDUCTION	€	240V RECEPTACLE	FS	FIRE SPRINKLER FLOW SWITCH	SÞ	COMMUNICATION STATION		
	MOTON, OGDINALE OAGE INDOOTION	⊕	CONVENIENCE RECEPTACLE - QUADRUPLEX	TS	FIRE SPRINKLER TAMPER SWITCH	SEC	CURITY SYSTEM PLAN AND RISER		1SION
G	GENERATOR, VOLTAGE AND SIZE AS INDICATED.	φ φ φ	MULTI OUTLET ASSEMBLY	D	DOOR HOLDER	CR	CARD KEY ACCESS		REV CENT
→ LPXXA	HOME RUN - DESTINATION SHOWN		DUPLEX CONVENIENCE RECEPTACLE - FLUSH IN FLOOR	<u>TELEP</u>	HONE SYSTEM PLAN AND RISER	cs	CONTROL STATION		REICH!
or/// _G	EXPOSED CONDUIT AND CONDUCTORS*	₽	CONVENIENCE RECEPTACLE, PEDESTAL, DUPLEX SINGLE FACE UNLESS INDICATED OTHERWISE	TTC	TELEPHONE TERMINAL CABINET	DS 🔯	DOOR SWITCH		
or -/#/_G	CONCEALED CONDUIT AND CONDUCTORS*	L20R 20 🙆			TELEPHONE RECEPTACLE FLOOR BOX	₽ EP	EGRESS PUSHBUTTON		
CONDUCTORS IN 3/4	NDUIT RUNS CONSIST OF TWO NO. 12, ONE NO. 12 GROUND 4" CONDUIT. RUNS MARKED WITH CROSSHATCHES INDICATE		RECEPTACLE, SPECIAL PURPOSE-NEMA CONFIGURATION AND AMPERAGE INDICATED THERMOSTAT		TELEPHONE RECEPTACLE		ELECTRONIC LOCK M = MAGENITIC		MOOW WOO
NUMBER OF NO. 12 GREEN GROUND WI	CONDUCTORS. CROSSHATCH WITH SUBSCRIPT "G" INDICATES			——т——	TELEPHONE SYSTEM RACEWAY	(A)	S = STRIKE		DATE R.
	CROSSHATCHES WITH BAR INDICATE NO.10 CONDUCTOR. SIZE CONDUIT ACCORDING TO SPECIFICATIONS		UTILITY REVENUE METERING FACILITY	COMPUTER	R SYSTEM (DATA) PLAN AND RISER		INTERCOM		NO.
_	AND APPLICABLE CODE.	→	ELECTRIC UNIT HEATER		COMPUTER SYSTEM TERMINAL CABINET		MONITOR		
[A1]	CONDUIT AND CONDUCTOR CALLOUT, SEE LEGEND.		ELECTRIC AID COMPLETICATES	•	COMPUTER NETWORK CONNECTION	»	MOTION SENSOR		PLAN
	CONDUIT DOWN	AC AC	ELECTRIC AIR CONDITIONER (SELF CONTAINED UNIT)		COMPUTER NETWORK CONNECTION, FLUSH IN FLOOR	L)b	VIDEO CAMERA PTZ = PAN/TILT/ZOOM F = FIXED		R POLI
	CONDUIT UP		UTILITY POLE LIGHTING SYSTEM PLAN	D	DATA SYSTEM RACEWAY		0001110 01/07=11 = 1 11		SM CON WATE JTHOR JNNEC
	CONDUIT, STUBBED AND CAPPED	or ①	LUMINAIRE, SEE SCHEDULE	COMBINED) TELEPHONE/COMPUTER SYSTEM	^	GROUND SYSTEM PLAN		NG TEF HAVEN ROL AL
	CONDUIT TERMINATION AT CABLE TRAY	(1)	LUMINAIRE, SEE SCHEDULE		PLAN AND RISER	⊙	GROUND ROD		CA LON I NEW H CONTI
——ЕХ——	EXISTING CONDUIT/ DUCT BANK		LUMINAIRE WITH INTERNAL BATTERY BACKUP, SEE SCHEDULE		COMBINATION TELEPHONE/DATA RECEPTACLE, WALL MOUNTED, NUMBER OF PORTS INDICATED	©	GROUND ROD IN TEST WELL		EATER NE
——ВD——	BUS DUCT - SEE SPECIFICATIONS	<u> </u>	STRIP LUMINAIRE, SEE SCHEDULE		COMBINATION TELEPHONE/DATA RECEPTACLE, FLOOR BOX, NUMBER OF PORTS INDICATED	— —G— —	,		GRE
——СЕ——	CONCRETE ENCASED CONDUIT	□-4 or ○-4	LUMINAIRE AND POLE, SEE SCHEDULE			$\overline{}$	PIGTAIL FOR CONNECTION TO EQUIPMENT CABINET OR FRAME		
————	DIRECT BURIED CONDUIT	15 or 1 − 5	WALL MOUNTED LUMINAIRE, SEE SCHEDULE		IIT/TELEVISION CABLE PLAN AND RISER	G	EQUIPMENT GROUND BUS		
——-FO	FIBER OPTIC CONDUIT	1 -	FLOOD LIGHTS - AIM IN THE DIRECTION SHOWN	l <u>Å</u>	COMBINATION CLOSED CIRCUIT TELEVISION RECEPTACLE (CCTV) AND DUPLEX CONVENIENCE RECEPTACLE IN TWO GANG BOX WITH BARRIER, 12" DOWN FROM CEILING	N	EQUIPMENT NEUTRAL BUS		0 2
xxxx	CONCRETE ENCASED DUCT BANK WHERE XXXX IS THE DUCT BANK NAME. SEE CIRCUIT AND RACEWAY CODING DEFINITION		STANDBY LIGHTING UNIT, SURFACE MOUNTED, SEE SCHEDULE	ے ا	COMBINATION TELEVISION CABLE RECEPTACLE (TV) AND DUPLEX CONVENIENCE RECEPTACLE IN TWO GANG BOX WITH BARRIER, 12" DOWN FROM CEILING			•	l ä
\ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \ \	CONCEALED CONDUIT ROUTING AREA	xx⊗ or 🕏	EXIT LIGHTS - FILLED SECTION INDICATES LIGHTED FACE, ARROW INDICATES EGRESS DIRECTIONAL INDICATORS.		CLOSED CIRCUIT TELEVISION RECEPTACLE, FLOOR BOX			\$	IERAL
	CONDUIT ROUTING AREA	¢ ~	XX = FIXTURE NUMBER, SEE SCHEDULE		TELEVISION CABLE RECEPTACLE, FLOOR BOX			772	GENERAL
	CABLE TRAY	\$ _{a or} 2a	SMALL LETTER SUBSCRIPT AT SWITCH AND LUMINAIRE INDICATES SWITCHING. SUBSCRIPT NUMBER AT LUMINAIRE INDICATES CIRCUIT						CTR
	TRANSFORMER	\$ ₃	WALL SWITCH:						
① or HH	GENERAL CONTROL OR WIRING DEVICE. LETTER SYMBOLS OR ABBREVIATIONS INDICATE TYPE OF DEVICE		2- DOUBLE POLE P- PILOT LIGHT 3- THREE WAY K- KEY OPERATED 4- FOUR WAY D- DIMMER WP- WEATHERPROOF CRE- CORROSION RESISTANT EX- EXPLOSIONPROOF L- MOMENTARY 3-WAY						
cs	CONTROL STATION, SEE CONTROL DIAGRAMS FOR CONTROL DEVICE(S) REQUIRED.		M- MOTOR RATED MS- MANUAL STARTER WITH OVERLOADS						
30 🖳	NONFUSED DISCONNECT SWITCH, CURRENT RATING INDICATED. 3 POLE	os	OCCUPANCY SENSOR						RIFY SCALE IS ONE INCH ON
60/40 🔀	FUSED DISCONNECT SWITCH, CURRENT RATING INDICATED (60/40, 60=SWITCH RATING / 40=FUSE RATING)	LC	LIGHTING CONTACTOR					ORIG 0	SINAL DRAWING. 1"
_ ~	3 POLE	MD	MOTION DETECTOR					DATE PROJ	664626
2 🔀	COMBINATION CIRCUIT BREAKER AND MAGNETIC STARTER, NEMA SIZE INDICATED	©	PHOTOCELL					DWG SHEET PLOT	100-G-016 of

SYMBOL DESCRIPTION ONE LINE PROTECTION RELAYING AND **ELEMENTARY DIAGRAMS-1** DEVICE FUNCTION NUMBER INDICATED, SEE DEVICE TABLE CONTROL SWITCH TRIP (CS) CONTROL SWITCH CLOSE 43-DEVICE FUNCTION NUMBER, SEE DEVICE TABLE 43/CS □ vs VOLTMETER SWITCH AS AMMETER SWITCH Δ INDICATING LAMP-SWITCHBOARD TYPE INDICATING LAMP LENS COLORS INDICATED AS FOLLOWS: A - AMBER R - RED B - BLUE W - WHITE G - GREEN VOLTMETER AMMETER WATTMETER (F)FREQUENCY METER POWER FACTOR METER WH WATT-HOUR METER ETM ELAPSED TIME METER TACHOMETER (W) XD WATTS TRANSDUCER (PF XD) POWER FACTOR TRANSDUCER (TD)TIME DELAY 4 RELAY COIL, DEVICE FUNCTION NUMBER PER ANSI 37.2 - AMERICAN STANDARD MANUAL AND AUTOMATIC STATION CONTROL, SUPERVISORY AND ASSOCIATED TELEMETRY EQUIPMENT NORMALLY OPEN CONTACT NORMALLY CLOSED CONTACT REMOTE DEVICE TEST SWITCH CURRENT ELEMENT TEST SWITCH POTENTIAL ELEMENT NEUTRAL CONNECTION INSTRUMENTATION CABLE, SHIELDED NGR NEUTRAL GROUNDING RESISTOR

PHASE SHIFTING TRANSFORMER

ONE LINE PROTECTION RELAYING AND **ELEMENTARY DIAGRAMS-2**

DEVICE TABLE

DEVICE FUNCTION NO.	DEVICE DESCRIPTION
21	IMPEDANCE/DISTANCE RELAY
25A	AUTOMATIC SYNCHRONIZER
25C	SYNCH CHECK RELAY
27	UNDERVOLTAGE RELAY
32	REVERSE POWER RELAY
40	GENERATOR LOSS OF EXCITATION RELAY
43CSE	AUTOMATIC POWER TRANSFER AND LOAD CONTROL MODE SEL. SWITCH
43CSX	MODE SEL. SWITCH
46	GENERATOR CURRENT UNBALANCE RELAY
49	THERMAL RELAY
50GS	INSTANTANEOUS OVERCURRENT DEVICE, GROUND SENSOR
50	INSTANTANEOUS OVERCURRENT DEVICE,
51	TIME OVERCURRENT RELAY
51G	TIME OVERCURRENT RELAY, GROUND FAULT
51V	TIME OVERCURRENT, VOLTAGE RESTRAINED
52	POWER CIRCUIT BREAKER
52CSX	POWER CIRCUIT BREAKER CONTROL SWITCH
59	OVERVOLTAGE RELAY
60	VOLTAGE OR CURRENT BALANCE RELAY
65A	ENGINE GOVERNOR, SPEED CONTROL
65A, MOP	ENGINE GOVERNOR, SPEED CONTROL MOTOR OPERATED POTENTIOMETER
65A, RL	ENGINE GOVERNOR, SPEED CONTROL RAISE/LOWER SWITCH
65B	ENGINE GOVERNOR, LOAD CONTROL
65B, MOP	ENGINE GOVERNOR, LOAD CONTROL MOTOR OPERATED POTENTIOMETER
65B, RL	ENGINE GOVERNOR, % LOAD RAISE/LOWER SWITCH
65E	AUTOMATIC POWER TRANSFER AND LOAD CONTROL, WOODWARD APTL
65F	AUTOMATIC GENERATOR LOADING CONTROL, WOODWARD AGLC
67	DIRECTIONAL TIME OVERCURRENT RELAY
74	ALARM RELAY
81O/U	FREQUENCY RELAY, OVER/UNDER
86	LOCKOUT RELAY
87	DIFFERENTIAL PROTECTIVE RELAY
90	VOLTAGE REGULATOR
90, MOP	ENGINE EXCITATION, POWER OPERATED POTENTIOMETER
90PF	ENGINE EXCITATION, POWER FACTOR CONTROL
90RL	ENGINE EXCITATION, RAISE/ LOWER SWITCH

X = DEVICE NUMBER, WHEN THERE ARE MULTIPLE UNITS

CIRCUIT AND RACEWAY GENERAL CIRCUIT CONDUCTOR AND CONDUIT IDENTIFICATION


	POWER CIRCUI	MULTICONDUCTOR POWER CABLE CIRCUIT CALLOUTS			
[P1] [P2] [P3] [P4] [P5] [P6] [P7] [P8] [P9] [P10] [P11] [P12] [P13] [P14] [P15] [P16]	[1/2"FLEX, 2#12,#12G] [3/4"C,2#12,1#12G] [3/4"C,3#12,1#12G] [3/4"C,4#12,1#12G] [3/4"C,5#12,1#12G] [3/4"C,6#12,1#12G] [3/4"C,6#12,1#12G] [3/4"C,8#12,1#12G] [3/4"C,8#12,1#12G] [3/4"C,3#12,2#14,1#12G] [3/4"C,3#12,3#14,1#12G] [3/4"C,3#12,5#14,1#12G] [3/4"C,3#12,5#14,1#12G] [3/4"C,3#12,5#14,1#12G] [3/4"C,3#12,6#14,1#12G] [3/4"C,3#12,7#14,1#12G] [3/4"C,3#12,7#14,1#12G] [3/4"C,3#12,7#14,1#12G] [3/4"C,3#12,7#14,1#12G] [3/4"C,3#12,7#14,1#12G]	[P24] [P25] [P26] [P27] [P28] [P29] [P30] [P31] [P32] [P33] [P34] [P35] [P36] [P37] [P38] [P39]	[1"C,3#8,3#14,1#10G] [1"C,3#8,4#14,1#10G] [1"C,3#8,5#14,1#10G] [1"C,2#6, 1#10G] [1"C,3#6, 1#8G] [1"C,3#6, 2#14,1#8G] [1"C,3#6, 3#14,1#8G] [1"C,3#6, 5#14,1#8G] [1"C,3#4,5#14,1#8G] [1"C,3#4,5#14,1#8G] [1"1/4"C,3#4,5#14,1#8G] [1 1/4"C,3#3,1#6G] [1 1/4"C,3#3,1#6G] [1 1/4"C,3#3,3#14,1#6G] [1 1/4"C,3#3,3#14,1#6G] [1 1/4"C,3#3,1#6G]	MULTICOND [PC1] [PC2] [PC3] [PC4] [PC5] [PC1A] [PC2A] [EC-1] [EC-2] [EC-3] [EC-4]	[3/4"C,1 (3C#12,1#12G) TYPE 2] [3/4"C,1 (3C#12,1#12G) TYPE 2] [3/4"C,1 (3C#10,1#10G) TYPE 2] [1"C,1 (3C#8,1#10G) TYPE 2] [1"4"C,2 (3C#12,1#12G) TYPE 2] [1 1/4"C,2 (3C#12,1#12G) TYPE 2] [3/4"C,1 (2C#12,1#12G) TYPE 2] [3/4"C,1 (2C#12,1#10G) TYPE 2] [3/4"C,1 (2C#10,1#10G) TYPE 2] EMPTY CONDUIT [3/4"C,WITH PULL STRING] [1"C,WITH PULL STRING] [1 1/4"C,WITH PULL STRING] [1 1/2"C,WITH PULL STRING]
[P17] [P18] [P19] [P20] [P21] [P22] [P23] After the properties of	[3/4"C,3#10,2#14,1#10G] [3/4"C,3#10,3#14,1#10G] [3/4"C,3#10,4#14,1#10G] [3/4"C,3#10,5#14,1#10G] [1"C,2#8,1#10G] [1"C,3#8,1#10G] [1"C,3#8,2#14,1#10G] NALOG CIRCUIT CALLOUTS	[P40] [P41] [P42] [P43]	[1 1/2"C,3#1, 3#14,1#6G] [1 1/2"C,3#2/0, 1#4G] [2"C,3#3/0, 1#4G] [2"C,3#4/0, 1#3G] TROL CIRCUIT CALLOUTS	[EC-5] [EC-6] [EC-7] [EC-8]	[2"C,WITH PULL STRING] [3"C,WITH PULL STRING] [4"C,WITH PULL STRING] [5"C,WITH PULL STRING] [5"C,WITH PULL STRING] JCTOR CONTROL CABLE CIRCUIT CALLOUTS [3/4"C,1-5C TYPE 1]
[A2] [A3] [A4] [A5] [A6] [A7] [A8] [A9] [A10] [A11] [A12] [A13] [A14] [A15] [A15] [A18] [A19] [A20] [A20] [A21] [A22] [A23] [A24] [A25]	[1"C,2 TYPE 3] [1"C,3 TYPE 3] [1"C,4 TYPE 3] [1 1/4"C,5 TYPE 3] [1 1/4"C,6 TYPE 3] [1 1/2"C,7 TYPE 3] [1 1/2"C,8 TYPE 3] [2"C,10 TYPE 3] [2"C,10 TYPE 3] [2"C,11 TYPE 3] [2"C,12 TYPE 3] [2"C,12 TYPE 3] [2"C,14 TYPE 3] [2"C,14 TYPE 3] [3/4"C,1 TYPE 4] [3/4"C,2 TYPE 4] [1 1/4"C,4 TYPE 4] [1 1/4"C,5 TYPE 4] [1 1/4"C,5 TYPE 4] [1 1/2"C,7 TYPE 4] [1 1/2"C,7 TYPE 4] [1 1/2"C,8 TYPE 4] [1 1/2"C,8 TYPE 4] [3/4"C,1 TYPE 4] [3/4"C,1 TYPE 4] [1 1/2"C,8 TYPE 4] [1 1/2"C,8 TYPE 4] [1 1/2"C,8 TYPE 4] [1 1/2"C,9 TYPE 4]	[C1] [C3] [C4] [C5] [C6] [C7] [C8] [C9] [C10] [C11] [C12] [C13] [C14] [C15] [C16] [C17] [C18] [C19] [C20] [C21] [C22] [C23] [C24] [C25]	[3/4"C,2#14,1#14G] [3/4"C,2#14,1#14G] [3/4"C,3#14,1#14G] [3/4"C,5#14,1#14G] [3/4"C,5#14,1#14G] [3/4"C,6#14,1#14G] [3/4"C,6#14,1#14G] [3/4"C,9#14,1#14G] [3/4"C,9#14,1#14G] [3/4"C,10#14,1#14G] [3/4"C,10#14,1#14G] [3/4"C,12#14,1#14G] [3/4"C,12#14,1#14G] [3/4"C,15#14,1#14G] [3/4"C,15#14,1#14G] [3/4"C,15#14,1#14G] [3/4"C,15#14,1#14G] [3/4"C,15#14,1#14G] [3/4"C,15#14,1#14G] [3/4"C,15#14,1#14G] [3/4"C,15#14,1#14G] [1"C,22#14,1#14G] [1"C,22#14,1#14G] [1"C,22#14,1#14G] [1"C,23#14,1#14G] [1"C,23#14,1#14G] [1"C,24#14,1#14G]	[CC7] [CC9] [CC12] [CC19] [CC25] [CC37] [CCC1]	[3/4"C,1-7C TYPE 1] [1"C,1-9C TYPE 1] [1"C,1-12C TYPE 1] [1 1/2"C, 1-19C TYPE 1] [1 1/2"C,1-25C TYPE 1] [2"C,1-37C TYPE 1] [1-7C #12 TYPE 1]


- 1. FOR CABLE TYPES, SEE SPECIFICATIONS.
- 2. CONDUIT SIZES ARE BASE ON THE AREA OF THW CONDUCTORS.
- 3. SIZING OF CONDUCTORS #1AWG AND SMALLER BASED ON AMPACITIES AT 60 DEGREES C, SIZING OF CONDUCTORS #1/0AWG AND LARGER BASED ON AMPACITIES AT 75 DEGREES C.
- 4. WHERE CIRCUITS ARE UNDERGROUND, DIRECT BURIED OR CONCRETE ENCASED, MINIMUM CONDUIT SIZE SHALL BE 1".

ELECTRICAL LEGEND ch2m.

wzyo	GENERAL	ELECTRICAL LEGE	RELIMINARY - NOT FOR CONSTRUCTION
	2151/ 0	0415	_
	RIFY S		ľ
	IS ONE IN INAL DR		\leq
DATE	NOVI	MBER 2016	≥
PROJ		664626] [
DWG		100-G-017	삤
CHEET		of	1

PST





ACHITECTURAL
UNION PUMP STATION
LOWER LEVEL PLAN
35 MGD CAPACITY

Y - NOT FOR CONSTRUCTION 1/4"=1'-0"

RIFY SCALE

IS ONE INCH ON
SINAL DRAWING.

NOVEMBER 2016

664626


100-A-201


of

TIME: 9:42:30 AM

1/4"=1'-0" VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING. 0 1"

PLOT TIME: 9:42:39 AM






PLOT TIME: 9:42:53 AM

GNHWPCA LONG TERM CONTROL PLAN
GREATER NEW HAVEN WATER POLLUTION
CONTROL AUTHORITY
NEW HAVEN, CONNECTICUT

ARCHITECTURAL
UNION PUMP STATION
SECTION
35 MGD CAPACITY
Y - NOT FOR CONSTRUCTION



ARCHITECTURAL
UNION PUMP STATION
SECTION
35 MGD CAPACITY
Y - NOT FOR CONSTRUCTION 1/4"=1'-0" 1/4"=1'-0"

RIFY SCALE

IS ONE INCH ON
SINAL DRAWING.

NOVEMBER 2016

664626

100-A-302


of

TIME: 9:43:19 AM VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING. 0 1"

GNHWPCA LONG TERM CONTROL PLAN
GREATER NEW HAVEN WATER POLLUTION
CONTROL AUTHORITY
NEW HAVEN, CONNECTICUT

ch2m.

PLOT TIME: 9:43:19 AM




DNION PUMP STATION
35 MGD CAPACITY
LOWER PLAN
Y – NOT FOR CONSTRUCTION

RIFY SCALE
IS ONE INCH ON
SINAL DRAWING.

NOVEMBER 2016
664626
100-D-201
of
TIME: 9:42:52 AM BAR IS ONE INCH ON ORIGINAL DRAWING. 0 1"


PLOT TIME: 9:42:52 AM



PLOT TIME: 9:42:51 AM

RIFY SCALE
IS ONE INCH ON
SINAL DRAWING.

NOVEMBER 2016
664626
100-D-202
of
TIME: 9:42:51 AM





GNHWPCA LONG TERM CONTROL PLAN
GREATER NEW HAVEN WATER POLLUTION
CONTROL AUTHORITY
NEW HAVEN, CONNECTICUT PROCESS MECHANICAL
UNION PUMP STATION
35 MGD CAPACITY
SECTION ch2m. - NOT FOR CONSTRUCTION RIFY SCALE
IS ONE INCH ON
SINAL DRAWING.


NOVEMBER 2016
664626
100-D-301
of
TIME: 9:43:06 AM BAR IS ONE INCH ON ORIGINAL DRAWING. 0 1" DWG

PLOT TIME: 9:43:06 AM

PLOT DATE: 11/4/2016

\$PWURL

pw://projectwise.ch2m.com:DEN001/Documents/664626&space;-&space;GNHWPCA&space;Long&space;Term&space;Control/DESIGN/100&space;-&space;Union&space;PS/PR/DIv/100-M-301_664626.dgn FILENAME: 100-M-301_664626.dgn



PROCESS MECHANICAL
UNION PUMP STATION
35 MGD CAPACITY
SECTION - NOT FOR CONSTRUCTION

ch2m.

DWG

RIFY SCALE
IS ONE INCH ON
SINAL DRAWING.

NOVEMBER 2016
664626
100-D-302
of
TIME: 9:43:23 AM VERIFY SCALE

BAR IS ONE INCH ON ORIGINAL DRAWING.


0 1"

PLOT TIME: 9:43:23 AM

PLOT DATE: 11/4/2016

\$PWURL

pw://projectwise.ch2m.com:DEN001/Documents/664626&space;-&space;GNHWPCA&space;Long&space;Term&space;Control/DESIGN/100&space;-&space;Union&space;PS/PR/DIv/100-M-302_664626.dgn FILENAME: 100-M-302_664626.dgn





PLOT TIME: 9:42:40 AM


RIFY SCALE
IS ONE INCH ON
SINAL DRAWING.

NOVEMBER 2016
664626
100-E-201
W
TIME: 9:42:40 AM VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING.

NOT FOR CONSTRUCTION







Appendix E Boulevard Pump Station Preliminary Design Report

Long-Term Control Plan Update

Boulevard Pump Station – Preliminary Design Report

Prepared for

Greater New Haven Water Pollution Control Authority

November 2016



CH2M HILL Engineers, Inc. 100 Great Meadow Road Suite 707 Wethersfield, CT 06109

Contents

Sectio	n			Page					
Acron	nyms an	d Abbrev	iations	iii					
1	Hydraulics								
	1.1	1.1 Introduction							
	1.2	Basis c	of Design	1-1					
		1.2.1	Hydraulic Design Objectives	1-1					
		1.2.2	Design Flows and Pumping Strategy	1-1					
	Avoid	ling high '	VFD and corresponding pump speed turndown	1-2					
	1.3		ulic Model						
	1.4	Hydra	ulic Analyses	1-2					
		1.4.1	Hydraulic Profile	1-2					
		1.4.2	Pipe Flow Modeling	1-3					
2	Proce	ss Mecha	anical	2-1					
	2.1	Introd	uction	2-1					
	2.2	Pump	Station Existing Conditions	2-1					
		2.2.1	Background and Existing Conditions	2-1					
	2.3	Inlet V	Vorks Facilities Design Criteria	2-3					
		2.3.1	Screening	2-3					
		2.3.2	Grit Removal	2-4					
	2.4	Pumpi	ng Systems Design	2-4					
		2.4.1	Pump Configuration	2-4					
		2.4.2	Pump Operating Criteria	2-6					
		2.4.3	Wet Well Intake Configuration	2-7					
		2.4.4	Effluent Piping	2-7					
		2.4.5	Valves and Flow Meters	2-7					
		2.4.6	Equipment Access and Removal	2-8					
3	Struc	Structural							
	3.1	Introd	uction	3-1					
	3.2	Codes	and Standards	3-1					
	3.3	Structi	ural Condition Assessment	3-1					
		3.3.1	Observations and Recommendations	3-2					
	3.4	Design	Criteria	3-4					
		3.4.1	Loading	3-4					
		3.4.2	Resiliency Planning and Design Basis	3-5					
		3.4.3	Design Loads	3-5					
		3.4.4	Concrete	3-6					
		3.4.5	Masonry	3-7					
		3.4.6	Structural Steel	3-8					
		3.4.7	Cranes	3-8					
4	Archi								
	4.1		uction						
	4.2	Buildir	ng Codes	4-1					
		4.2.1	Authorities Having Jurisdiction	4-1					
		4.2.2	Current Connecticut Codes	4-1					

	4.3	I.3 Boulevard Pump Station							
		4.3.1	Building Code Analysis	4-1					
		4.3.2	Building Condition Assessment	4-2					
		4.3.3	New Rooms and Spaces						
5	Heati	Heating, Ventilation, and Air Conditioning							
	5.1	Introd	uction	5-1					
	5.2	Design	n Approach	5-1					
		5.2.1	General	5-2					
	5.3	Equipr	ment	5-2					
		5.3.1	Heating Equipment	5-2					
		5.3.2	Ventilating Equipment	5-2					
		5.3.3	Air Conditioning Equipment	5-2					
	5.4	Mater	ials	5-3					
	5.5	Design	n Criteria	5-3					
		5.5.1	Outdoor Design Criteria	5-3					
		5.5.2	Mechanical System Criteria	5-4					
		5.5.3	Miscellaneous Design Criteria	5-4					
		5.5.4	Louver Sizing	5-4					
		5.5.5	Ductwork Friction Rate Sizing	5-4					
	5.6	Refere	ences	5-5					
		5.6.1	Codes	5-5					
		5.6.2	Standards	5-5					
		5.6.3	Miscellaneous	5-5					
6	Plum	Plumbing and Fire Protection							
	6.1	1 Introduction							
	6.2	Design	n Approach	6-1					
		6.2.1	General	6-1					
	6.3	Equipr	ment, Materials and Systems	6-1					
		6.3.1	Equipment	6-1					
		6.3.2	Materials	6-1					
	6.4	Design	n Criteria	6-2					
		6.4.1	Potable Water System	6-2					
		6.4.2	Service Water System	6-2					
		6.4.3	Sanitary Drainage System	6-2					
		6.4.4	Storm Drainage System	6-2					
	6.5	Refere	ences	6-3					
		6.5.1	Codes	6-3					
		6.5.2	Standards	6-3					
7	Elect	rical		7-1					
	7.1	Introd	uction	7-1					
	7.2	Codes	and Standards	7-1					
	7.3	Utility	Service and Medium Voltage Switchgear	7-1					
		7.3.1	Why 4160 Volt Distribution is Required	7-2					
	7.4	Equipr	ment and Sequence of Equipment Replacement						
		7.4.1	Existing Equipment						
		7.4.2	New Electrical Equipment						
		7.4.3	Sequence of Equipment Replacement						
	7.5	Design	n Criteria						
		7.5.1	Energy Efficient Design						

		7.5.2	Area Classification	7-5
	•	7.5.3	Design Flood Elevation and Electrical Equipment Elevation	7-6
	•	7.5.4	Flooding of equipment that cannot be relocated Above DFE	7-6
		7.5.5	Single Line Diagrams and Preliminary Equipment Layout	7-6
	•	7.5.6	Lighting	
		7.5.7	Leaking Conduit	7-6
8	Instrum	entatio	on and Controls	8-1
	8.1	Introdu	ıction	8-1
		8.1.1	Existing Instrumentation and Control System	8-1
		_	Approach	
			System Design Philosophy	
			System Operating Philosophy	
			e Telemetry System	
	8.6	Codes a	and Standards	8-3
9	Odor Co	ntrol		9-1
			ıction	
			f Design	
		9.2.1	Containment	
		9.2.2	Conveyance	
		9.2.3	Odor Control System Sizing	
		9.2.4	Anticipated Odor Causing Compounds	
			ontrol Technology Selection	
		9.3.1	Biotowers	
		9.3.2	Carbon Scrubbers	
		9.3.3	Chemical Scrubbers	
			nic Evaluation	
	9.5	Odor C	ontrol System Design Recommendations and Overview	9-0
Apper	ndix			
Α	Prelimin	ary Des	sign Drawings	
Table	S			
Table	1-1. Flow 9	Scenario	os	1-1
Table	1-2. Pump	Operat	tion	1-4
			Force Main Velocities	
			ps	
		_	esign Criteria	
			Pump Selections	
			r Pump Selections	
			uirements for Structural Steel	
			ials of Construction	
			or Design Criteria	
			System Criteria	
			d Fire Protection Materials of Construction	
			Ventilation Rates	
	•	-	1 and NPV Assumptions	
iable	9-4. IVIAJOR	Equipr	ment, Design Criteria and Operating Conditions	9-8

CONTENTS

Figures

Figure 2-1: Existing Grit Channels	2-1
Figure 2-2: Existing Pumps	
Figure 2-3: Existing Surge Suppressor	2-3
Figure 2-4. Dry Weather Pump and System Curves	2-5
Figure 2-5: Wet Weather Pump and System Curves	2-6
Figure 9-1. Simplified Schematic of a Biotower System	9-3
Figure 9-2. Photograph of a Biotower System	9-4
Figure 9-3. Schematic Dual Carbon Bed System	9-5
Figure 9-4. Photograph of a Dual Bed Carbon Scrubber	
Figure 9-5. Photograph of a Chemical Scrubber	

Acronyms and Abbreviations

AASHTO American Association of State Highway and Transportation Officials

ACGIH American Conference of Governmental Industrial Hygienists

ACH air changes per hour

ACI American Concrete Institute
AFD adjustable frequency drive

AISC American Institute of Steel Construction
ANSI American National Standard Institute
ASCE American Society of Civil Engineers

ASHRAE American Society of Heating, Refrigerating, and Air Conditioning

ASPE American Society of Plumbing Engineers
ASTM American Society for Testing and Materials

ATC automatic temperature control

Authority Greater New Haven Water Pollution Control Authority

AWWA American Water Works Association

BEP best efficiency point BFE base flood elevation

CAIECC Connecticut Amendments to the International Energy Conservation Code

CFD computational fluid dynamics

cfm cubic feet per minute cfph cubic feet per hour

CISPI Cast Iron Soil Pipe Institute
CMU concrete masonry unit

CSBC Connecticut State Building Code

CSO combined sewer overflow

DC direct current

DDC direct digital control
DFE design flood elevation
DLR device level ring
DWF dry weather flow

DX direct expansion

FEMA Federal Emergency Management Agency

fps feet per second

FRP fiberglass reinforced plastic

ft² square feet ft³ cubic feet

GNHWPCA Greater New Haven Water Pollution Control Authority

gpm gallon(s) per minute

H₂S hydrogen sulfide HI Hydraulic Institute

HMI human-machine interface

hp horsepower

HSS hollow structural sections

HVAC heating, ventilation, and air conditioning

I&C instrumentation and controls

I/O input/output

IBC International Building Code

ICRI International Concrete Repair Institute, Inc.

IEBC International Existing Building Code
IECC International Energy Conservation Code

IMC International Mechanical CodeIPC International Plumbing Codeksi kilopound(s) per square inch

kV kilovolt

kVA kilovolt-ampere(s)

LTCP long-term control plan

MAU make-up air unit
MCC motor control center
mgd million gallon(s) per day

mph mile(s) per hour

NaOH sodium hydroxide

NAVD 88 North American Vertical Datum of 1988

NEC National Electric Code

NEMA National Electrical Manufacturer's Association (NEMA)

NFPA National Fire Protection Association

NGVD 29 National Geodetic Vertical Datum of 1929

NPV net present value

O&M operations and maintenance OIT operator interface terminal

pcf pound(s) per cubic foot

PLC programmable logic controller
POR preferred operating range
ppmv part(s) per million by volume
psi pound(s) per square inch

RPM revolution(s) per minute

SLR sea level rise

SMACNA Sheet Metal and Air Conditioning Contractors' National Association

SSPC Structural Steel Painting Council

TDH total dynamic head

UI United Illuminating

UL Underwriter's Laboratory

UPS uninterruptable power supply

V volt

VFD variable-frequency drive

WEF Water Environment Federation
WPAF water pollution abatement facility

WSE water surface elevation

WWF wet weather flow

WWTP wastewater treatment plant

Hydraulics

1.1 Introduction

The Long-Term Control Plan (LTCP) Update includes alternatives that control combined sewer overflow (CSO) discharges from all CSO outfalls to meet a 2-year, 6-hour level of CSO control (zero discharges) by 2040. The LTCP Update includes short term, intermediate term, and long term improvements to meet these stated goals. This Preliminary Design Report of the LTCP focuses on long term improvements at the Boulevard (Boulevard) Pump Station. Preliminary Design Drawings are shown in Appendix A of the report.

1.2 Basis of Design

1.2.1 Hydraulic Design Objectives

The hydraulic design objective is to upgrade the Union, East Street and Boulevard Pump Stations to convey the maximum flow to the East Shore Water Pollution Abatement Facility (ESWPAF) resulting in CSO mitigation.

Models were developed to calculate how much flow can be conveyed to the wet well of the pump station using the existing infrastructure and to evaluate improvements to the pump station to allow the station to convey the design flows.

1.2.2 Design Flows and Pumping Strategy

The flow scenarios (Table 1-1) analyzed were developed from the 2015 Hydraulic Model. The model identified the design flows necessary for the system to meet the 2-year, 6-hour level of service. Three flow scenarios were analyzed during the LTCP Update. They are the short-term, intermediate-term, and long-term scenarios.

The short-term improvements do not impact the existing flows from the three pump stations. The total flow conveyed to the East Shore WPAF from the pump stations is 60 mgd split between Boulevard and East Street with each pump station pumping 30 mgd. Union currently pumps 15 mgd to East Street.

The intermediate term improvements increase the total flow conveyed to the ESWPAF. Union will be upgraded to pump 35 MGD capacity under the intermediate improvements, but capacity will be limited to between 15 and 25 MGD. East Street will be upgraded to pump up to 65 MGD, but capacity will be limited to 40 MGD. This is an increase of 10 MGD over existing capacity. Boulevard will be increased to pump up to 45 MGD, but capacity will be limited to 30 MGD.

The long-term improvements increase the total flow conveyed to the East Shore WPAF by the three pump stations to 110 mgd. The flows from the pump stations are 35 mgd from Union (pumping to East Street), 65 mgd from East Street, and 45 mgd from Boulevard.

Table 1-1. Flow Scenarios

Pump Station	Short-Term Flows (mgd)	Intermediate-Term Flows (mgd)	Long-Term Flows (mgd)
Union (to East)	15	25	35
East Street	30	40	65
Boulevard	30	30	45

The design parameters and considerations in selecting pumps for the stations include;

- 1. Create maximum reliability, efficiency and redundancy for flows in the dry weather range since flows in the dry weather range occur 98 percent of the time during a typical year.
- 2. Utilize extended shaft centrifugal pumps.
- 3. Maintain N+1 for dry weather and wet weather pumping conditions.
- 4. Consider space restrictions in existing station footprints.
- 5. Avoid cycling of flows at the East Street and Boulevard Pump Stations since these flows go directly to the ESWPAF.
- 6. Select pumps to operate well within the pump manufacturers' defined allowable operating range (AOR) for both wet and dry weather conditions.
- 7. For high frequency flow capacities, select pumps to operate within the pump's preferred operating range (POR) as defined by the Hydraulic Institute Standards (HIS) to obtain high wire-to-water pump efficiencies for both wet and dry weather conditions. For less frequent lower flow capacities, size pumps for operation well within the candidate pump manufacturers' defined allowable operating range (AOR).
- 8. Maintaining impeller tip speed to prevent accumulation of rags within the volute.
- 9. Maintaining scouring velocities in pump discharges to prevent grit accumulation.

Avoiding high VFD and corresponding pump speed turndown.

1.3 Hydraulic Model

Two models were developed for each pump station to identify the improvements necessary to meet the design flows.

Improvements necessary to convey the design flows by gravity from the sanitary sewer through the pump station's screening and grit systems to the wet well were identified by computing a hydraulic profile using CH2M's proprietary software, WinHydro. The hydraulic model was prepared using available mechanical, structural, and civil plan-and-profile record drawings, site visits and photos.

Improvements to the existing pump station pumping capacity and force mains were identified through incompressible pipe flow modeling using AFT Fathom version 8.0. The hydraulic model was prepared using available mechanical, structural, and civil plan-and-profile record drawings and photos.

Record drawings are in the National Geodetic Vertical Datum of 1929 (NGVD 29) and have been converted to the North American Vertical Datum of 1988 (NAVD 88) by subtracting 1.05 feet from NGVD 29. All elevations referenced in this section are in NAVD 88.

1.4 Hydraulic Analyses

1.4.1 Hydraulic Profile

The hydraulic profile from the influent sewer through the station and into the wet well at Boulevard includes the following:

- Influent Chamber flow split between screening channels
- Screening Channel (three channels)
- Junction Chamber downstream of the screening channels
- Flow Split between grit channels

- Grit channels (four channels)
- Junction Chamber downstream of the grit channels
- Flow split to the divided wet well

The analysis included four alternatives.

- Alternative 1: Three screens installed in screening channels and four grit channels.
- **Alternative 2:** Three screens installed in screening channels and two grit channels with the remaining two grit channels serving as high flow bypass channels.
- **Alternative 3:** Three screens installed in screening channels and zero grit channels. This alternative assumes grit removal is moved to the East Shore WPAF.
- **Alternative 4:** Zero screens and zero grit channels are installed. This assumes screening and grit removal is moved to East Shore WPAF.

The alternatives were run at the proposed long-term flow of 45 mgd. The results of the analysis are as follows:

- Alternative 1: The water surface elevation (WSE) coming into the influent chamber is -2.3. The sewer invert coming into the chamber is -5.1. This shows that at maximum flows, there is 2.8 feet of water depth as the sewer enters the chamber. A model run was performed with a WSE at the influent chamber of -2.3 and the run shows that the upstream infrastructure was able to deliver 44.7 mgd to the pump station under this alternative.
- Alternative 2: The WSE coming into the influent chamber is -3.4. At maximum flow, it is assumed all flow bypasses the grit channels in service and is conveyed through the high flow bypass channels. It was assumed for the bypass that the weir walls at the end of the existing grit channels would be demolished and all grit equipment would be removed. Influent gates would need to be opened during high flows to bypass the grit channels. A model run was performed with a WSE at the influent chamber of -3.4, the run shows that the upstream infrastructure was able to deliver 45 mgd to the pump station through the bypass channels.
- Alternative 3: The WSE coming into the influent chamber is -3.4. It was assumed that the weir walls at the end of the existing grit channels would be demolished and all grit equipment would be removed in all four grit channels. There is a drop in the invert from the screening channels to the grit channels, with the grit equipment removed and weir wall demolished the WSE in the influent chamber is minimally effected by the number of bypass channels at the maximum flow rate of 45 mgd. A model run was performed with a WSE at the influent chamber of -3.4, the run shows that the upstream infrastructure was able to deliver 45 mgd to the pump station through the channels.
- Alternative 4: The WSE coming into the influent chamber is -4.0. It was assumed that the existing screens would be removed, the weir walls at the end of the existing grit channels would be demolished, and all grit equipment would be removed in all four grit channels. A model run was performed with a WSE at the influent chamber of -4.0 and the run shows that the upstream infrastructure was able to deliver 45 mgd to the pump station through the channels.

1.4.2 Pipe Flow Modeling

A pipe flow model was created using AFT Fathom to represent the pressurized system. The model included East Street, Union, and Boulevard Pump Stations, their force mains, the harbor crossings, and force main to East Shore WPAF. The model base was built from existing conditions. Various alternatives were added to the model to identify the improvements necessary to meet the design flows at the short-term, intermediate-term, and long-term scenarios. All scenarios used an N+1 design to meet the design flow rate with the largest pump out of service.

1.4.2.1 Boulevard

Boulevard currently has four pumps installed with no space for additional pumps. The existing pumps have a rated capacity of 17.7 mgd. The stations firm capacity is 53.1 mgd and total capacity is 70.8 mgd. Through conversations with pump station operators, the station pumps approximately 30 mgd during peak flows. The pump station pumps to a 36-inch force main that joins the East Street force main upstream of the harbor crossing.

The long-term flow scenario for Boulevard is 45 mgd. The minimum dry weather flow is 7.4 mgd, the average dry weather flow is 12.5 mgd, and the maximum dry weather flow is 18.2 mgd.

The existing pumps do not have the capacity to meet the long-term pumping scenario with the largest pump out of service (N+1 redundancy criteria). Several scenarios were investigated to meet the design flows.

- Scenario 1: Four identical pumps installed in the existing pump station each rated at 15 mgd. A
 single pump in service would be used for dry weather flows and three pumps in service, with one
 pump in standby, would be used for the maximum wet weather flows. This scenario would have
 trouble pumping the minimum dry weather flows without cycling.
- Scenario 2: Two dry weather pumps and three wet weather pumps. The dry weather pumps were sized to efficiently pump the minimum flows to avoid cycling. To achieve this the dry weather pumps were sized for 12.5 mgd and would require both pumps in service to meet the maximum dry weather flowrate. Pump redundancy would be provided by one of the wet weather pumps which would cycle at the dry weather flows in the event one of the dry weather pumps was out of service. The wet weather pumps would be sized to pump the maximum flows with one pump out of service. Each wet weather pump would be rated at 22.5 mgd. In order to install five pumps in the existing station the two dry weather pumps are installed on a single suction header.
- Scenario 3: Three dry weather pumps and four wet weather pumps. The dry weather pumps are sized similar to scenario 2 but they have a standby pump to meet N+1 redundancy criteria. Installing seven pump requires the addition of a submersible pump station next to the existing station. The dry weather pump would be installed in the submersible pump station and the wet weather pumps would be installed in the existing pump station. Each wet weather pump would be rated at 15.00 mgd.

It was determined that Scenario 3 was the best option to meet the design flows. This scenario allows for N+1 redundancy for both dry weather and wet weather pumping and efficiently handles the minimum dry weather flows without cycling and peak wet weather flows.

Table 1-2 shows the proposed pump operation under several flow regimes for the Intermediate and Long Term Flow Scenario.

Table 1-2. Pump Operation

		Total Flow (mgd)	Dry Weather Pumps	Wet Weather Pumps
Intermediate Term	Min. Dry Weather	7.4	1 pump	0
	Avg. Dry Weather	12.5	1 pump	0
	Max. Dry Weather	18.2	2 pumps	0
	Max. Wet Weather	30	0	2 pumps
Long Term	Min. Dry Weather	7.4	1 pump	0
	Avg. Dry Weather	12.5	1 pump	0
	Max. Dry Weather	18.2	2 pumps	0
	Max. Wet Weather	45	0	3 pumps

1.4.2.2 Force Mains and Harbor Crossing

The existing force main from Boulevard is 36 inches before the junction with East Street.

East Street and Boulevard combine upstream of the harbor crossing. The force main increases to 48 inches downstream of this junction.

The existing twin harbor crossings are each 42 inches in diameter. The model assumed both crossings would be open during minimum dry weather flow and maximum wet weather flows.

The twin harbor crossing join together on the east side of the harbor into a 48-inch force main. The force main terminates at the East Shore WPAF.

Standard practice recommends velocities of 3 feet per second (fps) to provide self-cleaning velocities and limits force main velocities to 8 fps. Under the long-term flow scenario many of the force mains in the system would be below 3 fps during minimum dry weather flows and above 8 fps during maximum wet weather flows.

See Table 1-3 for a summary of force main velocities.

Table 1-3. Summary of Force Main Velocities

Force Main Segment	Min Dry Weather Flow Velocity (fps)	Average Dry Weather Flow Velocity (fps)	Maximum Dry Weather Flow Velocity (fps)	Max Wet Weather Flow Velocity (fps)
Boulevard 36-inch FM	1.5	2.6	3.7	9.3
48-inch FM DS of East and Boulevard Junction	1.6	2.7	4.1	12.8
42-inch Harbor Crossing (both open)	1.2	1.8	2.9	9.1
48-inch FM DS of Harbor Crossing to ESWPAF	1.6	2.7	4.1	12.8

Process Mechanical

2.1 Introduction

This section describes the basis of the process mechanical design associated with improvements to meet the intermediate- and long-term flow scenarios and improve reliability of the station.

2.2 Pump Station Existing Conditions

2.2.1 Background and Existing Conditions

Boulevard was constructed in 1986 next to an existing treatment plant. The plant was abandoned once the pump station was in service. A 48-inch gravity sewer enters the pump station influent chamber. A sluice gate is installed on the incoming sewer. Flow can split between three screen channels. Each channel has a sluice gate on the influent and effluent. As-built drawings show coarse screens followed by fine screens in each channel. The fine screens have since been removed. Mechanically cleaned bar screens manufactured by Duperon Corporation have recently been installed in two of the channels. The screens have a ¾-inch opening.

The channels combine in a junction chamber downstream of the screens and splits into four grit channels. Sluice gates are located on each of the grit channels. An adjustable weir allows the operator to control the depth in the channel. The original grit removal mechanisms are planned to be replaced with a shaftless screw bottom collectors and a bucket removal system. Figure 2-1 shows the air piping entering the grit channels.



Figure 2-1: Existing Grit Channels

The grit channels combine before entering the wet well. There are sluice gates located on the inlet to each side of the wet well and a sluice gate on the wet well dividing wall.

The screenings and grit are conveyed to separate dumpsters in the pump station by belt conveyors. Overhead doors allow for bin removal.

Each side of the wet well has two 30-inch suction wall pipes for total of four. Four pumps are currently installed with no space for additional pumps. All four pumps are identical, as shown in Table 2-1. They are manufactured by Goulds and are extended shaft vertical centrifugal pumps.

Table	e 2-1.	Existing	Pumps
-------	--------	----------	--------------

Pump	Make/Model	Rated Capacity	Motor Size	Speed
1	Goulds NCD 16x16	17.7 mgd	400 HP	710 rpm
2	Goulds NCD 16x16	17.7 mgd	400 HP	710 rpm
3	Goulds NCD 16x16	17.7 mgd	400 HP	710 rpm
4	Goulds NCD 16x16	17.7 mgd	400 HP	710 rpm

Figure 2-2 is a photograph of the pumps.



Figure 2-2: Existing Pumps

Each pump has a gate valve on the suction side and a modulating cone valve on the discharge. There is a flow meter located on each pump discharge. A plug valve isolates the pumps from the discharge manifold downstream of the flow meter. The pumps combine in a 36-inch force main before leaving the station to the north. A surge suppressor is connected to the force main inside the pump station. The surge suppressor drains to the wet well. Figure 2-3 is a photograph of the surge suppressor.



Figure 2-3: Existing Surge Suppressor

2.3 Inlet Works Facilities Design Criteria

2.3.1 Screening

The Boulevard Pump Station currently has two screens installed. The pump station cannot pass the 45 mgd through two screens. The third channel needs to be opened up for peak flows. To protect the pumps a mechanical screen can be provided in the channel. A third mechanical screen provides greater redundancy to the system if a screen needs to be taken offline for maintenance. The screen will match the existing screens.

The existing screening conveyors should be replaced with new conveyors. The new screenings system will include a grinder and compactor washer section. The grinder will have its own motor as will the compactor section, but the system will be operated by a common control panel that will be interlocked with the screen controls such that it is energized whenever the screen is operating.

The grinder section will precondition the screenings allowing a cleaner, drier, and more compact screenings product reducing odors and screenings volume. Spray washwater will be provided to allow organics to be washed back into the channel. The compactor (screw auger) portion of the grinder compactor will compact and convey clean screening into an adjacent screening bin.

Screenings loading is estimated to be 4.7 cubic feet per hour on average with peaks up to 16.9 cubic feet per hour. Screening design criteria are listed in Table 2-2.

Table 2-2. Screening Design Criteria

Design Criteria	
Screenings Capacity	71 cubic feet per hour
Spray Wash Water Capacity	249 gpm
Dry Solids Content	40%
Grinder Motor	5 HP
Compactor Motor	3 HP
Manufacturer	JWC, Franklin Miller

2.3.2 Grit Removal

The Authority is scheduled to replace the grit removal mechanisms on the four grit channels.

The existing grit conveyor should be replaced with new conveyors in the same alignment as the existing conveyor.

Grit loading is based on conservative assumptions of 8 cubic feet of grit for each per million gallons of flow. These values were selected based on review of the Water Environment Federation's (WEF's) *Manual of Practice 8* (MOP 8) and design experience from other Connecticut wastewater treatment plants (WWTPs):

• Grit 4.2 cubic feet per hour on average with peaks up to 15 cubic feet per hour.

2.4 Pumping Systems Design

2.4.1 Pump Configuration

As stated in Section 1, the proposed configuration for the Boulevard Pump Station is to install three dedicated dry weather pumps rated at 12.5 mgd, and four dedicated wet weather pumps rated at 15 mgd. The dry weather pumps would be installed in a submersible pump station and the wet weather pumps would be installed in the same locations as the existing pumps.

Table 2-3 lists the dry weather submersible pump selections.

Table 2-3. Dry Weather Pump Selections

Design Criteria	DWF Avg	DWF Min	DWF Max
Number of pumps	3	3	3
Number of pumps in operation	1	1	2
Design flow (mgd) (each pump)	12.5	7.4	9.1
Design flow (gpm) (each pump)	8,680	5,136	6,285
TDH at design flow (ft)	52	47	64
Efficiency at design flow	71%	75%	80%
NPSHA (ft)	33	33	33
NPSH3	25	15	17
Motor (HP)		215	
Impeller (in)	16.73		
Speed	1200 RPM		
Type of Pump	Submersible		
Model	NP3356.736		
Manufacturer	Flygt		

Table 2-4 lists preliminary wet weather pump selections.

Table 2-4. Wet Weather Pump Selections

Design Criteria	DWF Max	WWF	
Number of pumps installed	4	4	
Number of pumps operating	1	3	
Design flow (mgd) (each pump)	18.2	15	
Design flow (gpm) (each pump)	12,570	10,417	
TDH at design flow (ft)	69	198	
Efficiency at design flow	86%	82%	
NPSHA (ft)	32	31	
NPSH3	17	16	
Motor (HP)	700		
Impeller (in)	32.4	18	
Speed	900 RPM		
Model	12MF29A		
Manufacturer	Flowserve		
Number of pumps installed	4		

Figures 2-4 and 2-5 show the system versus system curves containing the design points for dry and wet weather pumps.




Figure 2-4. Dry Weather Pump and System Curves

Figure 2-4 shows the variable-frequency drive (VFD) curves for two pumps in operation. Under the minimum dry weather flow (DWF), a single pump is operating close to the Best Efficiency Point (BEP). A single pump meets the average DWF just outside preferred operating range (POR), but within the allowable operating range (AOR). Two pumps in operation meet the average DWF within the POR. Two pumps are necessary to meet the DWF maximum flow with both pumps operating within the POR close to the BEP.




Figure 2-5: Wet Weather Pump and System Curves

Figure 2-5 shows that the maximum DWF is within the AOR range of a single wet weather pump. The The figure shows the max DWF is within the AOR and within the POR of two pumps in operation. The WWF is on the POR when three pumps are in operation.

The finish floor elevation of Boulevard is 10.70. The distance from the floor to the ceiling is approximately 17.65 feet or El. 28.60. This does not account for the existing bridge crane, the bridge crane elevation is not shown on existing as-builts and would need to be measured in the field.

The height of the motors would be approximately 6 feet tall. At the existing floor elevation, the top of the motors would be at an elevation of 16.7.

There should be sufficient space to install the motors with the existing bridge crane at the existing floor elevation.

2.4.2 Pump Operating Criteria

The minimum and average dry weather flow can be met with a single dry weather pump in operation. The maximum dry weather flows can be met with two dry weather pumps in operation or a single wet weather pump in operation.

Wet weather flows can be met with two wet weather pumps during the Intermediate Term and three wet weather pumps in operation during the Long Term.

2.4.3 Wet Well Intake Configuration

The existing wet well configuration does not meet Hydraulic Institute (HI) standards in the following areas:

- Anti-rotational baffles are required for pumps larger than 3,000 gpm (4.3 mgd).
- Pump suctions should be located in a confined wet well where each suction inlet bell is located in a confined pocket to isolate the pump from any flow disturbances that might be generated by adjacent pumps.

For retrofit designs, meeting the requirements of HI standards is often not feasible. If designs other than those required by HI standards are shown by prototype or model tests performed in accordance with HI standards the alternative designs are considered to comply with HI standards. During detailed design, the wet wells will be evaluated using computational fluid dynamics (CFD) modeling to verify the hydraulic efficiency and further physical testing may be required to model the existing wet well to identify measures that can be taken to comply with HI standards.

HI also provides recommendations for retrofit designs of rectangular wet wells that would help improve suction conditions. Recommendations are as follows:

- Inclusion of a baffle wall to minimize air entrainment due to falling liquid
- Setting the baffle wall below the maximum wet well level to allow any floatable material to pass over the wall
- Inclusion of fillets below the pump intake
- Inclusion of baffles between the pump intakes
- Inclusion of fillets along the sides of the wet well to eliminate dead zones

2.4.4 Effluent Piping

The proposed effluent piping follows the existing discharge piping layout.

2.4.5 Valves and Flow Meters

Gate valves are recommended for isolation upstream and downstream of each pump. The American Water Works Association (AWWA) C500 double disk metal seated valves are recommended for this application. Resilient seated gate valves (AWWA C509 or 515) are prone to damage from grit, while double disk metal seated valves are more robust than the resilient seated valves and leak less than a solid metal seated disk.

Check valves are provided for prevention of flow reversal on all pumps.

Flow meters are recommended on the discharge of each wet weather pump. It is not recommended to reduce a pipe size upstream and downstream of the flow meter. This is a standard practice to ensure adequate velocities through the flow meter but can cause turbulence reducing the accuracy of the instrument. At the minimum dry weather flow the velocity through the flow meter would be 3.6 fps. According to published literature for ABB mag meters, velocities greater than 1.6 fps result in +/-0.15% and the minimum flow through the meter is 33 gpm. The flow meter will have five upstream diameters and two downstream diameters of straight run.

A single flow meter will be installed on the discharge of the dry weather pump station.

2.4.6 Equipment Access and Removal

The existing monorail has a 5-ton capacity which is sufficient to remove the new extended shaft pumps.

The existing hatches are 7x8 feet. These are sufficient to remove the larger pumps.

Hatches will be provided above the pumps at the new dry weather submersible pump station for removal of the pumps. A hatch will be provided for access to the valve vault for removal of equipment.

Structural

3.1 Introduction

This section is intended to assess the building structure components of the Boulevard Pump Station and identify design criteria for the rehabilitation of the facility. It outlines proposed solutions to address structural deterioration, deficiencies and upgrades to incorporate architectural, process mechanical, and MEP findings.

3.2 Codes and Standards

The current governing code utilized by the City of New Haven and the State of Connecticut are based on the 2016 Connecticut State Building Code.

The following standards shall be used in support of the building code:

Standards:

- ACI 318-11 Building Code Requirements for Structural Concrete
- ACI 530-11 Building Code Requirements for Masonry Structures
- ASCE/SEI 7-10 (Supp 1)—Minimum Design Loads for Buildings and Other Structures.
- ASCE 24 14 Flood Resistant Design and Construction
- CH2M HILL Water Business Group Design Guide.
- International Concrete Repair Institute Technical Guidelines (ICRI)
- ICC-ES Evaluation Reports for specific products.
- Structural Steel Painting Council (SSPC)

Reinforced Concrete:

- Typical Unless Noted Otherwise: ACI 318-11 Building Code Requirements for Structural Concrete.
- Liquid Containment Structures: ACI 350-06 Code Requirements for Environmental Engineering Concrete Structures.

Concrete Repair:

- ICRI GS03130 Guide Specifications for Structural Concrete Repair
- ICRI Technical Guideline No. 03732 -Selecting and Specifying Concrete Surface Preparation for Coatings, Sealers, and Polymer Overlays

Steel:

- AISC 360-10 Specification for Structural Steel Buildings, including Supplement No. 1 dated 2005.
- Manual of Steel Construction, Thirteenth Edition.
- AWS D1.1, Structural Welding Code–Steel Design Loads

3.3 Structural Condition Assessment

The construction of the Boulevard Pump Station structure was completed in 1986. The structure was designed by CE Maguire, Inc. Engineers of Providence, Rhode Island. Original design drawings available for review are dated June 13, 1986.

The Boulevard Pump Station structure is primarily composed of conventionally reinforced cast-in-place concrete. The foundation system is a mat foundation supported by undisturbed soils with 3-foot thick

concrete foundation walls around the below-grade wet well and dry well areas. The above-grade exterior elevations of the pump station structure are clad with brick veneer with a non-structural concrete masonry unit (CMU) backup. An 8-inch CMU partition wall has been provided between each of the five rooms.

3.3.1 Observations and Recommendations

The following observations and recommendations (in italics) are divided into the eight areas of the Boulevard Pump Station:

- 1. Pump Room: The Pump room houses electrical control panels, pump motors and provides access to the dry well area below.
 - a. The concrete floor structure in the Pump Room is in good condition. Some cracking was evident throughout the floor area, but it does not appear to be structural distress cracking. Similar to findings at the East Street Pump Station, we suspect a concrete topping has been provided over the structural slab exacerbating the cracking. A protective traffic bearing floor coating should be placed on the floor to minimize potential deterioration. A flexible polyurethane based coating will span the cracking, improve aesthetics and lighten appearance, and protect the floor system.
 - b. The cast-in-place roof structure above the pump room appears to be in good condition with no observed leaks or distress.
 - c. A new Bridge Crane system is desired in the pump room. Existing drawings for the original Operations building must be analyzed for structural capacity prior to the design and installation of a new bridge crane. Confirming the actual roof framing capacity could allow upsizing of the crane to handle larger pump systems.
 - a. There are two 6-foot-0-inch floor openings provided for access to the pumps in the dry well. Each opening is protected with aluminum grating. Because of the increased loads expected for the new pump system, new heavy duty aluminum access hatches mounted flush with the existing floor will be provided.
- 2. Mechanical Room: The mechanical room is located on the south side of the Inlet Works building and houses motor control panels, chemicals and other mechanical equipment.
 - a. The concrete slab in the mechanical room exhibits significant deterioration totaling approximately 300 square feet (ft²). It is suspected that this is due to the chemicals stored in the room and an unprotected floor surface. All deteriorated concrete on the floor slab should be repaired, a new chemical resistant protective coating should be provided on all concrete and wall surfaces with in the chemical storage area.
 - b. The chemical storage area within the mechanical room does not have walls or a curb for chemical containment in the case of the spill. *Containment walls should be added to this area.*All walls should be protected with a chemical resistant coating.
- 3. Generator Room: The Generator room is located on the south east side of the pump station building and houses a fuel tank and the generator.
 - a. The concrete slab in the generator room exhibits deflection and concrete spalling near the entrance and the generator pad has debonded from the existing base slab. From review of the wet well below, underside cracking was identified.
 - In 2007, CH2M completed an analysis concerning deflection of the floor, cracking and spalling concrete below. The report stated that there is not an immediate structural concern but repairs would need to be completed in the near future to maintain structural capacity in this area. It is

our understanding that the recommended repairs have yet to be incorporated and the conditions may have further deteriorated.

Further structural analysis and field review will be needed for this area. Supplemental supports should be installed below the generator room when repair work is being completed in the wet well below. Concrete repairs should be completed on the top side and underside of the slab.

- 4. Blower Room: The Blower room is located on the west side of the pump station building and houses motor control panels, chemicals and other mechanical equipment.
 - a. The concrete slab in the blower room exhibits significant deterioration totaling approximately 200 ft². We suspect this is due to the chemicals stored in the room and an unprotected floor surface. All deteriorated concrete on the floor slab should be repaired, a new chemical resistant protective coating should be provided on all concrete and wall surfaces with in the chemical storage area.
 - b. The chemical storage area within the blower room does not have walls or a curb for chemical containment in the case of the spill. *Containment walls should be added to this area. All walls should be protected with a chemical resistant coating.*
- 5. Dry Well: The dry well is located approximately 22 feet below the Motor Room and houses the pumps for discharge from the adjacent wet well.
 - a. The dry well area concrete surfaces were in good condition and painted. Some leakage was noted through the foundation walls. *All active leaks should be sealed. Damaged areas shall be re-coated*.
 - b. The drains provided in the dry well floor are corroded. Replace existing drain bodies and grates.
 - c. A steel platform composed of galvanized framing and grating is provided for access to each of the four pumps. Due to leaks at each of the pumps, the platform supports have been subjected to moisture. Corroded stair and platform framing areas should be cleaned and protected with a new coating system.
 - d. The pump pedestals and steel pipe supports are also subjected to moisture due to leaks around the pump mechanism. All deteriorated areas of steel and concrete should be cleaned, repaired and recoated with a protective coating system.
- 6. Screening Room: The screening room is the largest room in the Inlet Works building and provides access to the influent, bar screen and grit collection channels:
 - a. The reinforced concrete floor in the screening room appears to be in good condition. The floor appears to be constantly wet. The floor should be planned for sealants in joints at perimeter walls and a protective coating system. This will protect the concrete structure and perimeter walls.
 - b. At the time of the site visit, the aluminum gratings over channel openings were being replaced with new composite grating. All channels shall receive a protective coating system over concrete surfaces exposed to process fluids and moisture.
- 7. Wet Well: The wet well is located below the generator and blower rooms north of the dry well. Access to the wet well is provided through a stairwell on the east side of the pump station building. The stairs leading down to the wet well are composed of cast-in-place concrete.
 - a. The concrete stairs leading into the wet well were exhibiting deterioration, specifically along embedded nosing plates. All nosing plates shall be removed and concrete steps shall be repaired. A new chemical resistant protective coating should be provided over all steps.

- b. The concrete foundation walls and framing within the wet well could not be reviewed up close. Significant cracking and efflorescence on the ceiling below the generator room was noted.
- c. The existing walls and framing in the wet well were not protected by a coating system. A new protective coating shall be applied to all wet well concrete and steel surfaces.
- d. The grating in the wet well could not be reviewed due to debris in the wet well. *The debris should be cleaned and all grating systems should be replaced in the wet well.*
- e. The railings along the steps were loose. Replace all railing systems in the wet well.
- 8. Garage and Exterior of Building:
 - a. The garage portion of the building is located on the west side of the pump station building, at grade level and appears to be in good condition.
 - b. The exterior entrances and loading dock area on the west side of the pump station building is approximately 4 feet-0 inches above grade. There was concrete deterioration noted at embedded nosing plates on one of the two stairs. No sealants were provided along the brick veneer/concrete interface, in cracks or at construction joints. Existing tread embedment plates should be removed from all exterior stairs and the damaged concrete repaired. New polyurethane sealant shall be provided along all walls, surface cracks and at construction joints.
 - c. The exterior brick veneer appears to be in good condition with the exception of the northwest corner of the building. The brick veneer does not have control joints and has shifted from the corner and cracked the foundation wall below. The damaged concrete wall should be repaired, and the brick veneer should be rebuilt at the corner incorporating a vertical masonry control joint.
 - d. There are three exterior steel framed stairs with metal grating treads and landings. The metal treads are bent in several locations, and the grating at the landing has been covered with wood decking boards. All landing grating and stair treads should be replaced with heavy duty galvanized grating at each of the three locations.

3.4 Design Criteria

3.4.1 Loading

Loads shall be based on the most stringent criteria of the Building Codes and Standards listed above. In some cases, the minimum loads listed in the American Society of Civil Engineers *Minimum Design Loads* for Buildings and other Structures standards (ASCE 7) may be equivalent criteria and may be substituted for the loads listed below. In all cases, the minimum criteria shall conform to the minimum requirements of the IBC as amended by the State of Connecticut.

Design loading criteria was available for the Boulevard Pump Station drawings as follows

Snow Load 40 psf

Live Loads

Stairs 100 psf Inlet Area 150 psf

Heavy Equipment Rooms 300 psf or Weight of Equipment

Slab on Grade 350 psf

3.4.2 Resiliency Planning and Design Basis

As part of its recognition of future coastal resiliency impacts, the State of Connecticut has directed that all projects using State funding, such as the Clean Water Fund (CWF), must include features that address potential sea level rise and coastal resiliency issues within its design. Each of these stations are either within or directly adjacent to the 100-year floodplain, as determined by the Federal Emergency Management Agency (FEMA). The current Flood Insurance Rate Maps (FIRMs) for the New Haven area have recently been updated as a result of documented impacts from Hurricane Sandy, and recent regional evaluations of sea level rise trends and future projections. Due to this revision, the regulatory base flood elevations have risen by 1 foot at both East Street and Boulevard Pump Stations, but remain the same for Union Pump Station.

In accordance with the Public Act Nos. 13-15, the CWF is required to consider the necessity and feasibility of implementing measures designed to mitigate the impact of a rise in sea level over the projected life span of such a project. To further the abilities of municipalities to implement this requirement, the New England Interstate Water Pollution Control Commission (NEIWPCC) updated its Technical Release 16, Guides for the Design of Wastewater Treatment Works (TR-16) and provided guidance on selecting an appropriate protection elevation related to the criticality of each process component and the impact on the environment if that process was impacted during a storm event. The guidance document separates facilities into two types: critical and non-critical. Critical facilities are defined as those systems that are required for the conveyance of wastewater to and through a treatment facility. This includes all electrical, mechanical, and control systems within a pump station. The recommendation in TR-16 is to elevate these critical elements a minimum of 3 feet above the 100-year flood elevation.

As part of the recent Phase 1 Wet Weather Capacity Improvements and Nitrogen Reduction Project at the South Shore WPAF, an evaluation was conducted to establish the resiliency elevation for use during this construction project. This evaluation included consideration of recent regional coastal sea level rise evaluations, along with elevating equipment above the 500-year flood elevation. Combining these two elements resulted in a protection elevation for the East Shore WPAF of 2.95 feet (NAVD 88) above the established 100-year base flood elevation. As part of this Preliminary Design Report, the protection elevation is being set at 3 feet to be consistent with the TR-16 guidance.

The Boulevard Pump Station was evaluated for the feasibility and necessity of elevating critical equipment to maintain operations during a flooding event. It was deemed not feasible or cost-effective to elevate all equipment due to existing space limitations, or overall station configuration. In addition, due to the interconnectivity of the station with existing outfalls adjacent to the stations, certain areas will be inundated without the ability to protect the interior of the facilities from rising flood waters. For this purpose, GNH has taken the approach of providing dry floodproofing where critical equipment must remain below the resiliency protection elevation, and providing wet floodproofing where appropriate to maintain structural stability and allow the facility to quickly regain full operations once the flood waters recede. In general, floodproofing methods include construction of cast-in-place structural walls around the perimeter of each area to be dry floodproofed, with implementation of removable bulkheads at roll up doors and personnel doors as needed. Wet floodproofing methods include installation of flood vents to allow hydrostatic pressures to equalize on either side of facility walls during the flooding event allowing immediate return to service following cessation of flood waters. Specific floodproofing locations are included in the Preliminary Design Drawings included in Appendix A.

3.4.3 Design Loads

In some cases, minimum loads listed in ASCE 7 may be an equivalent criterion and may be substituted for the following loads. The following minimum criteria shall be used for design.

3.4.3.1 Floor Live Loads

In accordance with codes and standards listed above, and the following minimums:

Process Rooms 300 psf on slabs and beams and

200 psf on girders, columns

Electrical Rooms 300 psf Storage Areas 150 psf

Mechanical/HVAC Rooms 150 psf or Equipment weight plus 50 psf

Allow for rolling equipment

Stairs, Walkways and Platforms 100 psf Platforms Only for Access 60 psf

Vehicular Traffic AASHTO HS 20-44

3.4.3.2 Wind Loads

Wind loads will be based on Risk Category III unless otherwise noted, with an ultimate design wind speed (Vult) of 135 mph (3-second gust), Exposure C.

3.4.3.3 Snow Loads

Existing areas requiring analysis and areas of new construction will be analyzed with the following assumptions.

Ground Snow Loads30 psfImportance Factor1.1Snow Exposure Factor1.0

3.4.3.4 Flood Loads

Hydrostatic Loading of 63 pounds per cubic foot (pcf) will be assumed up to the proposed Sea Level Rise (SLR) Elevation. The Boulevard Pump station is located outside of the Coastal A Zone, as identified by the Federal Emergency Management Agency (FEMA) and the ASCE *Flood Resistant Design and Construction* standards (ASCE 24). At this stage of design, it has not been determined if the structures will be designed for Wet or Dry Flood resistance.

The following assumptions apply to the Boulevard Pump Station, all elevations are based on NAVD 88.

Base Flood Elevation (BFE): +12.0'
Design Flood Elevation (DFE): +13.0'
Sea Level Rise Elevation (SLR): +15.0'

3.4.3.5 Liquid Loads

Load cases that will be considered in design of liquid holding structures are:

- A fluid pressure of 62.43 pcf will be used for hydrostatic loads from ground water and flooding.
- A fluid pressure of 63 pcf will be used for process liquid in channels, unless otherwise noted.

3.4.4 Concrete

Materials and design procedures for concrete are described below.

3.4.4.1 Materials

The following minimum requirements apply (concrete compressive strength at 28 days):

•	Typical Concrete, unless otherwise noted	4,500 psi
•	Concrete Fill, unless otherwise noted	3,000 psi
•	Concrete Fill exposed to liquid	4,500 psi
•	Curbs and Sidewalks	3,000 psi
•	Conduit Encasements and pipe	

(encasements not integral with foundation) 4,500 psi

Reinforcement:

Conventional Steel: ASTM A615, Grade 60 (f_y = 60 kilopounds per square inch [ksi])

3.4.4.2 Design Procedures

Strength design will be used for concrete in accordance with ACI 318 unless noted otherwise. Hydraulic structures will be designed in accordance with ACI 350.

Design of concrete hydraulic structures will include use of environmental durability factor (Sd), for anticipated fluid and earth loads during normal operation only. Available capacity of members will be checked for loads that may occur during extreme design events.

Slab thickness will be checked to provide adequate embedment of post installed anchor bolts for mechanical equipment.

3.4.4.3 Details of Steel Reinforcement

Minimum concrete cover over steel reinforcement will be as follows:

Surfaces cast against soil 3 inches Typical unless otherwise noted 2 inches

3.4.5 Masonry

Materials and design procedures for masonry are as follows.

3.4.5.1 Materials

The following requirements apply:

- Hollow concrete masonry units will conform to ASTM C 90 and will be normal- or medium-weight units with a net area compressive strength of 1,900 pounds per square inch (psi).
- Mortar will conform to ASTM C 270, Type S.
- Grout will conform to ASTM C 476. Minimum 28-day compressive strength will be 2,000 psi.
- Steel reinforcement will conform to ASTM A615, Grade 60.
- Horizontal joint reinforcing steel will conform to ASTM A82.

3.4.5.2 Design Procedures

Allowable stress design will be used for masonry in accordance with ACI 530. Compressive strength of masonry, f'm, for masonry assembly will be 1,500 psi. For design, calculated tensile/compressive stress, f_s, of steel reinforcement is 24,000 psi for deformed bars and 30,000 psi for wire in joints.

3.4.5.3 Details of Steel Reinforcement

- 1. Limit maximum spacing of vertical steel reinforcement in bearing walls and partition walls to 4 feet and 8 feet., respectively.
- 2. Provide bond beams at top and bottom of walls.
- 3. Use joint reinforcement at 16 inches maximum vertical spacing.

3.4.6 Structural Steel

Materials and design procedures for structural steel are as follows.

3.4.6.1 Material

The material requirements for structural steel are listed in Table 3-1.

Table 3-1. Material Requirements for Structural Steel

Shape	ASTM	Grade	Fy (ksi)	Fu (ksi)
Rolled Shapes, Plates and Rods	A36	-	36	58
W-shapes & WT-shapes	A992	-	50	65
Pipes	A53	В	35	60
Round Hollow Structural Sections (HSS)	A500	В	42	58
Square and Rectangular Hollow Structural Sections (HSS)	A500	В	46	58
Bolts for Connections (1/2" to 1" diameter)	A325 or F1582	-	-	120
Anchor Rods – Dry Areas Only	F1554	36	36	58
Anchor Rods – Typical	F593	316, Cond. CW	40	80
Welding Electrode	E70XX			70

3.4.6.2 Design Procedures

Structural steel design will be in accordance with American Institute of Steel Construction's (AISC's) *Steel Construction Manual*.

3.4.7 Cranes

Cranes shall meet requirements of AISC Steel Construction Manual and ASCE 7. Unless noted otherwise, vertical impact shall be 25 percent of maximum wheel load. Lateral force on crane runway shall be calculated as 20 percent of sum of rated capacity of crane and weight of hoist and trolley. Lateral force shall be assumed to act horizontally at traction surface of a runway beam, in either direction perpendicular to beam. Longitudinal force on crane runway beams shall be calculated as 10 percent of maximum wheel loads of crane. Longitudinal force shall be assumed to act horizontally at traction surface of a runway beam in either direction parallel to beam.

Architectural

4.1 Introduction

This section assesses the architectural components of the Boulevard Pump Station and presents the design criteria for upgrades to the facility. The architectural assessment consisted of three tasks: interviewing staff, visiting facility site, and reviewing available facility documentation. It outlines proposed solutions to deficiencies found from building and code assessment done. These recommendations are intended to serve as preliminary guidance for the design of facility renovations.

4.2 Building Codes

The 2016 Connecticut State Building Code with amendments will be used as a basis of this review.

4.2.1 Authorities Having Jurisdiction

The Boulevard Pump Station is located in the City of New Haven, Connecticut. The City of New Haven Building Department enforces the Connecticut State Building Code.

4.2.2 Current Connecticut Codes

Per the State of Connecticut Department of Construction Services, the following codes have been adopted and are applicable to this project:

Building Code: 2016 Connecticut State Building Code (CSBC)

2012 International Building Code (IBC) as modified by CSBC.

Existing Building Code: 2012 International Existing Building Code (IEBC) as modified by CSBC.

Accessibility Code: ICC/ANSI A117.1-2003 Accessible and Usable Buildings and Facilities as

modified by CSBC.

Fire Code: Connecticut State Fire Safety Code including all current Amendments to

the fire code.

Energy Code: 2012 International Energy Conservation Code (IECC)

Mechanical Code: 2012 International Mechanical Code International Mechanical Code

(IMC) as modified by CSBC.

Plumbing Code: 2012 International Plumbing Code (IPC) as modified by CSBC.

Electrical Code: 2014 National Electrical Code (NEC) as modified by CSBC.

4.3 Boulevard Pump Station

4.3.1 Building Code Analysis

4.3.1.1 Chemical Storage

There are corrosive chemicals stored in the Blower Room. There appears to be less than the code exempt amount of 500 gallons, so the room would not be an H-4 hazardous occupancy. The floors and walls are damaged from what appears to be chemical leaks. There is electrical equipment in this room with corrosive storage. There is a 4000 gallon above ground Diesel tank at the southwest corner of the

building, and 375-gallon Diesel day tank in the Mechanical Room. No. 2 Diesel Fuel is a Class II Combustible Liquid and irritant. The exempt amount of inside storage of diesel fuel is 120 gallons. Rooms with diesel tanks over the exempt amount would be H-3 hazardous occupancies. This requires fire separation from the rest of the building and sprinkler system. There is no containment for the inside diesel tanks and battery storage. The Diesel day tank blocks required 3 feet-0 inches clear egress width. No safety shower or eyewashes. There is an unused Bioxide tank in the Garage. There are two 55-gallon drums of hydraulic fluid is in the Pump Room at El. 6. Hydraulic fluid is an irritant and not considered hazardous by building code. The design will include the following components:

- Limit the quantity of corrosive to 500 gallons to hazardous occupancy. The recommended odor
 control system will be an activated carbon system to all chemical tanks and pumps related to odor
 control will be demolished.
- 2. Provide containment for any chemical storage area. The containment has to contain largest tank and needs to be resistant to chemical emersion.
- 3. Remove electrical equipment from room with any corrosive chemicals.
- 4. Remove the existing inside Diesel storage tank and provide new day tank integral with the exterior emergency generator system. The emergency generator will be housed in a weatherproof enclosure.
- 5. Provide containment for battery storage.
- 6. Provide leak detection in all chemical containments.
- 7. Provide emergency safety shower and eyewash in Blower Room. Add emergency eyewash at battery storage and hydraulic fluid storage.
- 8. Add NFPA 704 Hazardous Material Signal signs at doors to chemical storage areas. Add Caution Corrosive sign at door to corrosive chemical storage area. Add Warning Diesel Fuel sign at outside Diesel storage tank.
- 9. Seal wall penetrations in Generator and Boiler rooms.
- 10. Demolish Bioxide tank in the Garage.

4.3.1.2 Sprinkler System

Current code requires floors with limited fire fighter access doors and openings to have a sprinkler system. The Pump Room lower levels has limited fire access, so a sprinkler system is required. The design will include the addition of a sprinkler system to Pump Room lower levels.

4.3.2 Building Condition Assessment

4.3.2.1 Roof

The 33-year-old gravel surfaced built-up roof is in need of replacement. The design will include the following components:

- 1. Remove existing roof down to concrete substrate.
- 2. Install vapor retarder on concrete deck.
- 3. Install polyisocyanurate insulation with ¼" per foot slope to drains, R-value of 20 minimum average.
- 4. Add overflow drains to comply with current plumbing code.
- 5. Install gravel surface 4-ply built-up roofing.
- 6. Add treated blocking on top of the parapets and add aluminum coping.
- 7. Modify existing lightning protection system to allow for new coping.
- 8. Add walkway pads from roof hatch to equipment.
- 9. Add stainless steel roof flashings.

- 10. Provide new curbs for new and existing roof top HVAC.
- 11. Replace roof hatch with aluminum roof hatch with safety rails.

4.3.2.2 Skylights and Hatch

The 33-year-old plastic domed skylight and roof hatch in is need of replacement. The design will include the following components:

- 1. Remove 17 existing domed skylights and protective screens.
- 2. Install 17 new translucent panel hip skylights on prefabricated insulated curbs.
- 3. Replace roof hatch with aluminum roof hatch with safety rails.

4.3.2.3 Exterior Masonry

Existing exposed concrete and brick walls are stained and deteriorated. There is some brick spalling. The design will include the following components:

- 1. Clean existing masonry with sand blasting and mild detergent.
- 2. Replace damaged bricks with new matching existing.
- 3. Tuck-point mortar joints.
- 4. Replace joint sealant in masonry joints. Install new sealant joints at outside corners.
- 5. Replace spalled concrete foundation at southwest corner of Garage.
- 6. Seal brick with clear breathable sealer.
- 7. Coat exposed concrete with breathable coating.

4.3.2.4 Doors and Louvers

The hollow metal and FRP doors are deteriorated and need replacement. 3 existing FRP double doors on south side of the building appear to be in good condition. Existing roll-up doors appear to be in good condition. Existing aluminum louvers appear to be in good condition. The design will include the following components:

- 1. Remove 11 single doors and replace with FRP doors and frames with heavy duty stainless steel hardware.
- 2. Remove one double door and replace with FRP doors and frames with heavy duty stainless steel hardware.
- 3. Remove single door between Garage and Screening. Patch CMU walls and floor.
- 4. Remove single door to wet well and install 2 Type 316 stainless steel watertight doors in lower level wet well Stair No. 2 wall openings.
- 5. Provide FRP louvers required for new ventilation.
- 6. Seal around doors and louvers.
- 7. Seal leaking conduit penetrations in Pump Room at El. 6.
- 8. See Control Room for additional door.

4.3.2.5 Grating, Stairs, and Handrails

Grating in screening and wet well is corroded and needs to be replaced. It appears that the existing grating in the screening area is being replaced with FRP grating. Handrails in Stair No. 2, wet well, and around west gates in screening area are corroded and need to be replaced. Three exterior metal stairs on north side and metal stair between Garage and Screening are in need of replacement. The other grating and handrails appear to be in good condition. There is only 1'-10" clear between conveyer support and guard post along egress path to Garage exit stair; code requires a 3-foot egress path. There are several tripping hazards on floor. The design will include the following components:

- 1. Remove all existing metal grating in Stair No. 2, wet well, and around west gates in Screening and replace with FRP grating. Make all grating level with floor.
- 2. Surface prepare and paint grating supports with a chemical resistant epoxy paint system.
- 3. Remove all existing metal handrail in Stair No. 2, wet well and around west gates in Screenings and replace with FRP handrail.
- 4. Remove 3 exterior metal stairs on north side and metal stair between Garage and Screening and replace with FRP stairs and handrails.
- 5. Modify conveyer support and/or guard post at Garage exit stair to provide code required 3-foot egress path.
- 6. Add limited headroom warning sign for low beams in Pump Room at El-12.
- 7. Add wall mounted handrail at south stair in Pump Room at El-12

4.3.2.6 Painting

The walls and ceilings are in need of repainting. Floors of Scrubber Area, Generator Room, Blower Room, Mechanical Room, and Pump Room are cracked and spalling. Bottom of walls are deteriorating in Screening, Stair No. 2 and Scrubber Area. Equipment and piping is in need of painting. The design will include the following components:

- 1. Surface prepare and paint walls and ceilings in all the rooms with a chemical resistant epoxy paint system.
- 2. After surface preparation and before painting the walls, patch holes and the base of the walls in Screening, Stair No. 2 and Scrubber Area with 100% solid epoxy filler.
- 3. Remove spalling concrete and patch Scrubber Area, Generator Room, Blower Room, Mechanical Room, and Pump Room floors.
- 4. Surface prepare and paint existing painted floor and Toilet floor with chemical resistant epoxy non-skid paint system.
- 5. Surface prepare and paint piping, equipment, and supports in all the rooms with a chemical resistant epoxy paint system, including exterior vent pipes.

4.3.2.7 Toilet and Service Sink

The plumbing fixtures and toilet accessories are deteriorated and in need of replacement. The design will include the following components:

- 1. Demolish existing toilet, service sink, and accessories.
- 2. Add toilet, sink, and service sink with stainless steel service sink and faucet.
- 3. Add drinking fountain outside of restroom.
- 4. Since only one Toilet Room is provided, provide privacy lock on door.
- 5. Add commercial grade stainless steel accessories.

4.3.3 New Rooms and Spaces

4.3.3.1 Control and Electrical Rooms

Enclose new electrical equipment so it can be climate controlled. The design will include the following components:

- 1. Add CMU walls to enclose new control and electrical equipment in ground level Pump Room.
- 2. Add double and single FRP doors to both Control Room and Electrical Room.

Heating, Ventilation, and Air Conditioning

5.1 Introduction

Ventilation measures will be established based on the 2012 National Fire Protection Association standard - *Fire Protection in Wastewater Treatment and Collection Facilities* (NFPA 820). NFPA 820 establishes outside air ventilation rate criteria as well as ventilation design recommendations for safeguarding against fire and explosion hazards specific to wastewater treatment plants and associated collection systems.

5.2 Design Approach

Air handling units will be located outside on the roof structure or on an elevated platform adjacent to the structure. Air handling units serving electrically classified areas will be designed to supply tempered 100 percent outside air without recirculation, except where NFPA 820 allows dual ventilation rate during cold weather and the space atmosphere is relatively moisture and corrosive vapor free. Combustible gas detectors will override air handling systems operating in dual mode if combustible gases are detected.

Ventilation will be continuous and at rates adequate to reduce area NFPA 820 electrical classifications one category where required to suit the design. Ventilation systems that are required to reduce electrically classified spaces one category shall be monitored and provided with alarm stations located within and at entrances to these spaces. Air handling units in electrically classified areas will be designed in such a way as to isolate the unit supply air stream from the process area in the event the unit is turned off or loses power. An intermediate damper will open to atmosphere to provide a naturally vented air break space between the unit interior and the process space.

Air will be exhausted via exhaust fans mounted where foul air is not present within the space. Areas containing foul air will be exhausted to an activated carbon treatment system as described in Section 9 – Odor Control in this report. Air will be exhausted low within the space to facilitate removal of hydrogen sulfide that collects along the floor.

Supplemental unit heaters will be provided throughout spaces as required to maintain local heating needs during winter.

Louvers/vents/exhaust fans or supply/exhaust fans will be used to supplement ventilation in areas requiring higher summer ventilation rates or intermittent ventilation.

Staff areas and electrical rooms requiring air conditioning will be provided with packaged rooftop direct expansion (DX) equipment, self-contained DX equipment or ductless split system DX equipment as required to suit the space need. Critical electrical and control rooms will be provided with redundant air conditioning systems if necessary to ensure space temperatures can be met if primary units should fail.

Facilities will be provided with an automatic temperature control (ATC) system for global monitoring and control of heating, ventilation, and air conditioning (HVAC) equipment. The control system will be based on an open architecture (Lon or BACnet) direct digital control (DDC) system or programmable logic controller (PLC) based system, the selection of which will be determined during design. ATC panels will be located in "clean spaces" (e.g., electric room, control room) where possible. Control devices such as sensors and thermostats will be provided with suitable enclosures designed for the associated atmosphere in which they are located.

5.2.1 General

The existing heating and ventilation system in the Screen/Grit Works/Garage/Odor Control Room will be completely demolished and a new make-up air unit (MAU) will be provided for the Screen/Grit Works/Garage/Odor Control. The MAU may be located on the roof and will provide 12 air changes/hour (ACH) with 100 percent outside air that will be provided in order to reduce the NFPA electrical classification from Class 1 Division 1 to Class 1 Division 2. The supply air will be tempered to minimum 55 degrees F during winter in order to protect plumbing and water piping from freezing and ventilation system will be reduced to 6 ACH, as allowed by NFPA 820 and whenever the outside air temperature is 50 degrees F or below, the space is unoccupied and the combustible gas detector is 10 percent below the lower explosive limit of methane. The MAU and exhaust fans will be provided with VFDs and a separate exhaust fan will be provided to maintain proper temperature conditions for the pump motors during the summer months.

The 50 percent exhaust air during summer and 100 percent of exhaust air during winter (ambient temperature is 50 degrees F or below) from the Screen/Grit Works/Garage/Odor Control will be treated by the proposed odor control system.

The existing dual-fuel boiler is recommended to be replaced with a new duel-fuel boiler. The new boiler and the accessories should be sized to meet the new heating requirement.

A split system DX air conditioning system is recommended for the Pump Room to handle the heat dissipation from the VFDs, which will be located in this room.

A new heating and ventilation system will be recommended for the Screening Room to provide tempered air into the space.

5.3 Equipment

The specific type of equipment used on a particular building will be determined during detailed design based on application. Roof mounted equipment will be used where possible to preserve floor space and to minimize equipment exposure to aggressive environments. The following types of HVAC equipment may be utilized on this project.

5.3.1 Heating Equipment

- Air handling units incorporating outside air hoods, filters, Natural Gas HX, hot water heating coils, fans, and air break plenums, as required.
- Hot water and electric unit heaters.
- Gas fired hot water boilers and water circulating pumps.

5.3.2 Ventilating Equipment

- Exhaust fans
- Supply fans
- Wall louvers
- Roof vents

5.3.3 Air Conditioning Equipment

- Packaged roof top air conditioning units
- Split system air conditioning units

5.4 Materials

Table 5-1 provides various material choices that may be used for HVAC systems depending on the type of atmosphere in which equipment is installed. Specific materials will be selected during detailed design to suit the application.

Table 5-1. HVAC Materials of Construction

Area	Atmosphere ⁽¹⁾	Equipment or System	Materials of Construction
Process	Corrosive	Ductwork	SS, FRP
Process	Corrosive	Equipment	HPCS
Process	Non-corrosive	Ductwork	Al
		Equipment	HPCS
Non-Process	Non-corrosive	Ductwork	GS/AI
		Equipment	GS/AI

Table Notes and Abbreviations:

Al – Aluminum

FRP - Fiberglass Reinforced Plastic

GS – Galvanized Steel

HPCS - High Performance Coated Steel

SS - Stainless Steel (Type 316)

5.5 Design Criteria

5.5.1 Outdoor Design Criteria

Table 5-2. HVAC Outdoor Design Criteria

Location	Elevation (ft.)	Cooling Criteria (ASHRAE 0.4%) ⁽¹⁾		Heating Criteria (ASHRAE 99.6%)
New Hoven CT	20	DB (°F)	MCWB (°F)	DB (°F)
New Haven, CT	20 —	90.7	73.2	8.5

Table Notes and Abbreviations:

ASHRAE – American Society of Heating, Refrigeration and Air Conditioning Engineers, 2013 Fundamentals

DB - Dry Bulb Temperature

MCWB - Mean Coincident Wet Bulb Temperature

⁽¹⁾ Corrosive areas are areas that have elevated levels of moisture, hydrogen sulfide or chemical vapors.

 $^{^{(1)}}$ Cooling criteria for critical spaces such as electrical equipment rooms shall be based on extreme conditions (100° F).

5.5.2 Mechanical System Criteria

Table 5-3. Mechanical System Criteria

Space or Area	Cooling (°F)	Cooling Method	Heating (°F)	Heating Method	Ventilation Basis
Process Areas	5-10 °F above ambient	Outside Air Ventilation	55	HW	100% OA
Control Rooms	75	AC	68	G, E	6 ACH min (5 cfm/person and 0.06 cfm/ft ² OA)
Electric Room s	75	AC	55	Е	6 ACH min (0% OA)
Personnel Areas	75	AC	68	G,E	6 ACH min (5 cfm/person and 0.06 cfm/ft ² O.A.)

Table Abbreviations:

AC - Air Conditioning

ACH - Air changes/hour

E – Electric

G - Gas Heating Method

HW - Hot Water

OA – Outside Air

5.5.3 Miscellaneous Design Criteria

Not Used.

5.5.4 Louver Sizing

- 1. Intake Louvers 500 ft. per minute
- 2. Exhaust Louvers 800 ft. per minute

5.5.5 Ductwork Friction Rate Sizing

- 1. Low Pressure: 0.1 in. of water column pressure drop per 100 ft. of ductwork up to an air velocity of 1,500 to 1,800 ft. per minute.
- 2. Medium Pressure: 0.2 in. of water column pressure drop per 100 ft. of ductwork up to an air velocity of 2,000 to 2,500 ft. per minute.
- 3. Transfer Ducts: 0.03-0.05 in. of water column pressure drop per 100 ft. of ductwork.
- 4. Outside Air Intake Shafts: 0.05-0.10 in. of water column pressure drop per 100 ft. of ductwork up to an air velocity of 1,000 ft. per minute.
- 5. Gravity Relief Shafts: 0.03-0.05 in. of water column pressure drop per 100 ft. of ductwork up to an air velocity of 1,000 ft. per minute.

5.6 References

5.6.1 Codes

The HVAC design will follow shall follow all applicable local, state, and federal codes and criteria. The following codes will be used for the mechanical design of this project:

- 2016 Connecticut State Building Code
- 2012 International Building Code
- 2012 International Mechanical Code
- 2012 International Energy Conservation Code
- 2005 Connecticut State Fire Safety Code

5.6.2 Standards

The following standards and guides will be used for the mechanical design of this project:

- 1. ASHRAE (American Society of Heating, Refrigerating and Air Conditioning Engineers)
- 2. SMACNA (Sheet Metal and Air Conditioning Contractors' National Association)
- 3. ACGIH (American Conference of Governmental Industrial Hygienists) Industrial Ventilation Manual of Recommended Practice
- 4. NFPA (National Fire Protection Association)

5.6.3 Miscellaneous

5.6.3.1 Calculation Software

• Heating and Cooling Load Analysis: Carrier E20-II Hourly Analysis Program (HAP)

Plumbing and Fire Protection

6.1 Introduction

Any modification to existing plumbing systems to support the existing or new processes and facilities including potable water piping, service water piping, sanitary drainage piping, storm drainage piping, will be selectively provided for each facility as required by the current building codes or local authority.

6.2 Design Approach

6.2.1 General

Limited existing plumbing system modification has been considered for this project. A summary of the improvements are as follows:

- The existing plumbing the fixtures are recommended to be replaced.
- The existing potable and non-potable water piping is recommended to be replaced with new piping as required.

6.3 Equipment, Materials and Systems

6.3.1 Equipment

The specific type of equipment that will be used on a particular building will be determined during detailed design based on application. Listed below are types of plumbing equipment that may be used for this project.

- Storage type electric or gas-fired water heaters
- Wall-mounted instantaneous electric water heaters
- Backflow preventers
- Emergency eyewash and shower stations
- Sump and sewage ejector pumps
- Plumbing fixtures such as service sink, water closet, lavatory, drinking fountain and kitchen sink
- Hose stations
- Floor, air gap, standpipe and roof drains
- Electric heat trace systems

6.3.2 Materials

Table 6-1. Plumbing and Fire Protection Materials of Construction

Area	Atmosphere (1)	Equipment or System	Materials of Construction
Process	Daniel Committee		SS/GS/CU/AL/HCI/CU/CPVC
Process	Corrosive	Equipment	Coated GS/AI/SS/CU
Process	Non-Corrosive	Piping	CU/BS/CI/DI
	Non-Corrosive	Equipment	Coated GS/AI

Table 6-1. Plumbing and Fire Protection Materials of Construction

Area	Atmosphere ⁽¹⁾	Equipment or System	Materials of Construction
Administration	Non-Corrosive	Piping	GS/BS/CU/DI/PVC
		Equipment	GS/CS
Administration - Toilet Rooms	Non-Corrosive	Piping	CU/BS/CI/PVC
		Equipment	CU/DI/CI

Table Notes and Abbreviations:

evels

⁽¹⁾ Corrosive areas are areas that have elevated levels of moisture, hydrogen sulfide or chemical vapors.

CI – Cast Iron
DI – Ductile Iron

CU - Copper

PVC – Polyvinyl Chloride

BS – Black Steel

SS – Stainless Steel (Type 316)

HCI - High Silicon Cast Iron

GS – Galvanized Steel

CS – Carbon Steel

Al – Aluminum

CPVC – Chlorinated Polyvinyl Chloride

6.4 Design Criteria

6.4.1 Potable Water System

Water Source: City WaterMinimum Pressure: 30 psiMaximum Pressure: 80 psi

• Maximum Velocity: 8 fps

Hydrostatic Test Pressure: 100 psi minimum

6.4.2 Service Water System

Water Source: City Water
 Minimum Pressure: 20 psi
 Maximum Pressure: 100 psi
 Maximum Velocity: 8 fps

Hydrostatic Test Pressure: 150 psi minimum

6.4.3 Sanitary Drainage System

Type: Gravity

• Minimum Pipe Slope: 1/8-in. per ft.

Minimum Cover: 4 ft.Minimum Velocity: 4 fps

6.4.4 Storm Drainage System

Type: Gravity

• Minimum Pipe Slope: 1/8-in. per ft.

Minimum Cover: 4 ft.Minimum Velocity: 4 fps

6.5 References

6.5.1 Codes

The design of this project will be governed by the 2016 Connecticut State Building Code, Connecticut State Fire Safety Code and all adopted International Codes including the International Plumbing and International Fire Codes.

6.5.2 Standards

The following standards and guides will be used for the plumbing and fire protection design of this project:

- ANSI (American National Standard Institute)
- ASPE (American Society of Plumbing Engineers)
- ASTM (American Society for Testing and Materials)
- AWWA (American Water Works Association)
- CISPI (Cast Iron Soil Pipe Institute)
- IBC (International Building Code)
- IFC (International Fire Code)
- IPC (International Plumbing Code)
- NFPA (National Fire Protection Association)

Electrical

7.1 Introduction

The existing electrical service to this facility is 480 volt, 3-phase via a single transformer, terminating at switchgear rated at 2500A. This service will need to be upgraded to a medium voltage service, as four 700 horsepower (hp) wet weather pumps are proposed for this project, and motors above 600 hp generally require medium voltage service. Three 480 volt, 215hp dry weather pumps are also required for this project.

The local electric utility that provides power to this facility is United Illuminating (UI). UI only offers 480 volt and below services and a 13.8kV service to its customers. UI does not provide a 4160-volt service, or any other service between 13.8kV and 480 volts.

The electrical work at Boulevard Pump Station will consist of replacing the incoming distribution switchgear, generator and an automatic transfer switch with 4160 volt rated equipment. A new 1200-amp low voltage switchgear will also be added to feed the dry weather pump motors and 480 volt MCC. The 480-volt motor control centers will also be replaced, as the existing electrical equipment will be over 30 years old by the time this project is implemented, and needs to be replaced in its entirety. New wet weather pump motors will be compatible with and controlled by 4160-volt adjustable frequency drives to provide precise control, improve efficiency, and reduce power factor losses. New dry weather pumps will be controlled by new 480-volt adjustable frequency drives.

The construction sequence will be staggered so that all pumps may remain operable during construction, and only short shutdowns are required to remove and install new pumps.

Electrical distribution equipment will be elevated 4 feet-0 inches above finish floor (AFF) to avoid flooding while accounting for sea level rise concerns.

The work required for this station is described in further detail below.

7.2 Codes and Standards

The following codes and standards will apply to the design, and may be referenced in this document:

- 1. National Fire Protection Association (NFPA): 70, National Electrical Code, 2014 Edition.
- 2. NFPA: 820, Standard for Fire Protection in Wastewater Treatment and Collection Facilities, 2016 Edition.
- 3. National Electrical Manufacturer's Association (NEMA)
- 4. Underwriter's Laboratory (UL)

7.3 Utility Service and Medium Voltage Switchgear

The power provider to the Boulevard Pump Station is UI, which is based locally in New Haven. The existing 480-volt service will need to be removed and replaced with a medium voltage service, as the proposed 700 hp wet weather pump motors will require 4160-volt service.

UI does not offer 4160 volts as a standard service, but does offer 13.8kV as a service voltage. Therefore, the new service voltage to the Boulevard station will be 13.8kV. 13.8kV and 4160-volt switchgear will be arcflash rated. A new medium voltage switchgear room will be created by combining the existing generator room with the northwest corner of the pump room, where an obsolete control panel is

currently located. This room will house all medium voltage switchgear and the automatic transfer switch. Construction of this room will be sequenced so that the existing engine-generator can remain in service as long as possible.

A 3000 kilovolt-amperes (kVA), 13.8 kV-4160 V transformer will be placed outdoors, mounted on a pad near the existing transformer in the northeast corner of the building. Note that the GNHWPCA, not UI, will be responsible for this transformer. The 4160 V secondary feeders will then return to a new 4160 V, 1200A arc flash rated switchgear, also located in the new medium voltage switchgear room. This 4160-volt switchgear will feed the wet weather pump AFDs, and a 750 kVA, 4160-480V, 3-phase, 3-wire transformer which will power a new 1200A low voltage switchgear.

7.3.1 Why 4160 Volt Distribution is Required

It is understood that GNHWPCA would prefer to avoid the use of medium voltage equipment, as their staff is not trained in its use, and they would either need to train their staff or outsource this equipment maintenance.

CH2M evaluated the possibilities of using 13.8 kV or 480 volt, 700hp motors. Although a 13.8kV motor is still medium voltage, it would avoid the addition of 4160-volt switchgear, and the transformers necessary to provide this voltage.

Motors at 13.8kV can be obtained, but they would be custom, and thus difficult to service. AFDs are available at this voltage, but not often used, and are sized for motors no smaller than 2000hp (as a result, custom motors made in the past may not be inverter duty rated). The 13.8kV drives are large, and would take up room saved by not adding 4160-volt distribution equipment.

There are at least three manufacturers that provide AFDs at 700hp, 480 volts, and they are Yasakawa, GE, and ABB. However, CH2M could not find any vertical pump motors at 700hp, 460 volts. Custom 480 volt, 700hp motors may be available, but CH2M does not recommend their use. Each motor could draw up to 1100 amperes at 480 volts, and three 400kcmil cables per phase would need to be run from the low voltage switchgear to the AFD. Due to excessive copper costs end the risks associated with a nonstandard installation, 480 volt, 700hp motors are not recommended.

7.4 Equipment and Sequence of Equipment Replacement

7.4.1 Existing Equipment

The existing service entrance switchgear and automatic transfer switch is located along the east wall of the pump room. The room also includes a motor control center (MCC), MCC-1, that feeds equipment on the east side of the pump station. The equipment in this room sits on the floor level on an equipment pad about 3 inches tall. This equipment was installed in 1988, and will be near the end of its useful life by the time this project is ready to be executed. Since the equipment is near the end of its useful life, and a new service voltage is required for this facility, this equipment will be replaced.

This service entrance switchgear also feeds MCC-2, which is located in the blower room. The blower room is located in the south central portion of the station. The blower room has become increasingly used for chemical storage in recent years. MCC-2 was also installed in 1988, and will be removed as a part of this project. The loads currently fed from MCC-2 will be fed from new MCC-1 in the electrical/control room to keep the electrical distribution equipment away from the chemicals being stored in the blower room.

The existing generator also appears to be late 1980s vintage, and will be due for replacement. The existing generator is 480 volt, 3-phase, 1300 kW/1625 kVA. This generator is also not adequate for the new installation, since a 4160-volt generator will be needed to power the new sewage pump motors. The existing generator fuel tank has a capacity of 4000 gallons and is located above ground and

outdoors, in front of the stairwell area at the east end of the pump station. The existing generator controls and batteries are also located in the generator room.

7.4.2 New Electrical Equipment

Sufficient space is available in the existing pump room to house the medium voltage switchgear, low voltage switchgear, motor control center, medium and low voltage adjustable frequency drives (AFDs), PLC, and operator/control interface. The 13.8 kV, 1200A service entrance switchgear and 4160 V, 1200A power distribution switchgear will be arc flash rated, and located in the new medium voltage switchgear room in the northwest corner of the pump room. The remainder of the equipment, including the medium voltage automatic transfer switch, medium voltage AFDs, low voltage switchgear, 480 V MCC, PLC, controls, and operator interfaces will be located in a new electrical/control room on the east side of the pump room. This pump room will be created by placing a wall on the east edge of the pump access grating to create a conditioned space for this electrical equipment. Electrical distribution equipment will be elevated 4 feet, 0 inches AFF to account for DFE with SLR concerns. Walkways and stairs with sufficient working space will be provided so that the equipment can be properly accessed.

New 3.0 megavolt ampere (MVA), 13.8 kV-4160 V, and 750 kVA 4160-480 V transformers will be pad mounted outdoors to the south of the existing transformer. The top of the pad will be at elevation 15.00, so that it is above the DFE with SLR concern elevation. The existing transformer will remain in service until the new service is commissioned.

The medium and low AFDs are currently shown on the plan drawings as Cutler-Hammer AFD dimensions. Sufficient space is available to accommodate the equipment of other manufacturers. Installation and demolition will be staggered, and temporary equipment provided where necessary to keep critical equipment running during construction, and keeping N+1 pumps available for use, except for a short shutdown to swap out the pumps.

The loads currently powered from MCC-2 will be powered from new MCC-1, located in the conditioned Electrical/Control Room. This will allow MCC-2 to remain in service while MCC-1 is installed and cables to these loads are pulled. This will also get all power distribution equipment away from chemicals and process equipment and into a conditioned space.

7.4.2.1 Generator and Associated Equipment

A new 2.75 MVA, 4160 V generator is required to provide full backup power to this pump station. The existing 480-volt generator will remain in service until the 4160-volt generator and service are commissioned, and all pump motors have been relocated to the 4160-volt switchgear.

Although the new generator may be able to fit into the existing generator room, this cannot be guaranteed for every manufacturer. To guarantee that the generator will fit in its proposed location and also allow more vendors to bid on the generator, the generator will be placed outdoors in a weatherproof enclosure, east of the pump station and south of the new transformers. The top of the pad will also be at elevation 15.00 to meet DFE with SLR criteria. Placing the generator outdoors will allow the existing generator to remain in service longer.

The existing 4000-gallon diesel fuel tank is located above grade, south of the east corner of the pump station. The tank appears to be in good condition, but further analysis will be required during detailed design to determine whether or not the tank can be reused. 7500 gallons of fuel are required to be available to provide 48 hours of run time at full load or 96 hours of run time at normal load. If the tank can be reused, a 3500-4000-gallon subbase tank will be placed under the generator. If the existing tank cannot be reused, it will be replaced in place with a 7500-gallon fuel tank. The subbase tank or new tank may be located below the DFE with SLR criteria elevation, as long as it is floodproofed.

7.4.2.2 Automatic Transfer Switch

A 4160-volt automatic transfer switch, rated 1200A, will be located in the electrical/control room. Construction sequence will allow for installation of the transfer switch after existing AFD is removed to make room for the switch. The transfer switch is recommended at the 4160-volt level rather than the 13.8kV level, so that the 13.8kV-4160V transformer T-1 is not a point of failure when on generator power.

7.4.2.3 Transformers

A new 3.0 MVA, 13.8 kV-4160 V, oil filled transformer and a 750 kVA 4160-480 V transformer will be mounted on pedestals outdoors to the south of the existing transformer. The 750 kVA transformer may be dry type or oil filled, and this will be determined in detailed design. The existing transformer will remain in service until the new service is established.

7.4.2.4 13.8kV Service Entrance Switchgear

A 13.8 kV service entrance switchgear is required, as UI does not offer 4160 volts as a service voltage. This switchgear will include service entrance metering and the main disconnect to the station. UI will provide a 13.8 kV disconnect for their purposes outside of the station. The switchgear will be arc flash rated, and feed the new 13.8kV-4160-volt transformer. The gear will be located in the new MV Switchgear room.

7.4.2.5 4160 Volt Switchgear

The new 4160 volts, 1200A switchgear will also be located in the new MV switchgear room. It will also be arc flash rated, and receive the incoming 4160-volt power from the 13.8kV-4160V transformer, and distribute power to the four 4160 volt AFDs and the 4160 V-480 V transformer located outdoors, which then feeds LVSWGR-1.

7.4.2.6 480 Volt Switchgear

480 Volt 1200A minimum rated switchgear, designated LVSWGR-1, will be located in the electrical and control room. This switchgear will feed the three low voltage dry weather pump AFDs and MCC-1.

7.4.2.7 480 Volt Motor Control Centers

A 480 volt, 600A motor control center, designated MCC-1, will be located in the electrical and control room, and distribute power to all small motor and miscellaneous loads in the pump station, including those loads formerly powered by MCC-2. Relocating these loads to MCC-1 will allow all power distribution equipment to be in a conditioned electrical room.

7.4.2.8 Medium Voltage Adjustable Frequency Drives

The medium voltage switchgear will feed four 700 hp AFDs. One of the AFDs is standby, while the others can be expected to run at the same time. AFDs will be eighteen pulse, and located in the electrical/control room. The AFDs are currently shown on the plan drawings as Cutler-Hammer AFD dimensions. However, there is also enough room to accommodate the medium voltage AFDs of any manufacturer.

7.4.2.9 Low Voltage Adjustable Frequency Drives

The low voltage switchgear will feed three 250hp AFDs. One of the AFDs is standby, while the others can be expected to run at the same time. AFDs will be eighteen pulse, and located in the electrical/control room. The AFDs are currently shown on the plan drawings as Cutler-Hammer AFD dimensions. However, there is also enough room to accommodate the low voltage AFDs of any manufacturer. Motors are designated as 215hp, but the next highest standard AFD size is 250hp.

7.4.3 Sequence of Equipment Replacement

A preliminary sequence of construction is as follows (some steps may overlap during construction):

- 1. Install and wire, transformers, and new medium voltage switchgear (13.8 kV and 4160 V). The 4160 volt transfer switch will initially be bypassed.
- 2. Install new 4160 Volt Generator.
- 2. Obtain new 13.8 kV service from UI, and energize 13.8kV switchgear, transformer and 4160-volt switchgear. Install the automatic transfer switch in a temporary location (southwest area of pump room recommended). Leave enough slack in cables to reuse cable when transfer switch installed at the final location.
- 3. Install two 4160 volt AFDs in a temporary location. (southwest area of pump room recommended) AFDs may need to be run manually to minimize unnecessary control wiring.
- 4. Install two new 4160-volt sewage pumps (one at a time), and power from temporary AFDs.
- 5. Remove the two unused AFDs.
- 6. Install two permanent 4160 V AFDs.
- 7. Replace the other two pump motors (one at a time) with new 4160 V motors.
- 8. Remove the last two existing AFDs.
- 9. Move temporary AFDs to permanent location, one at a time. A spare AFD or across the line temporary starter may be required if the AFD cannot be relocated and rewired fast enough to provide the pump station its required backup pumping capacity (N+1 configuration).
- 10. Install and wire LVSWGR-1, low voltage AFDs, and dry weather pumps.
- 11. Install and provide power to new MCC-1.
- 12. Transfer loads and replace existing MCC loads with new, from existing MCC-1 and MCC-2 to new MCC-1.
- 13. Install new ATS at final location. Reconnect ATS to new generator, 13.8 kV switchgear, and 4160-volt switchgear. Test ATS functionality. Disconnect the pump station from utility power, and run the pump station on the generator.
- 14. Re-energize pump station with utility power through 4160 volt transfer switch.

7.5 Design Criteria

7.5.1 Energy Efficient Design

All pump motors are currently started across the line, and run at full speed. The new design will include AFD controllers for each pump motor. These AFDs will allow the pump to run at an optimum speed and higher efficiencies with lower power factor losses.

Existing pump station lighting will be replaced with more efficient LED type lighting wherever possible.

7.5.2 Area Classification

No changes in area classification are expected for this project. Headworks/screenings areas above ground will be ventilated at 12 ACH so that they are classified as Class I, Division 2. Wet wells are classified as Class I, Division 1. New electrical equipment will be provided per the area classification. Every effort will be made to place electrical equipment outside the classified area.

7.5.3 Design Flood Elevation and Electrical Equipment Elevation

All electrical distribution equipment is going to be relocated four feet above the finished floor, which is above the DFE with SLR criteria, so the equipment will be safe from any flood event.

The new generator will be installed on an equipment pad four feet above the original pump station finished floor, to meet DFE with SLR criteria.

7.5.4 Flooding of equipment that cannot be relocated Above DFE.

Some motors, actuators, local control panels, and other equipment could be in a position to be flooded because it is not practical to locate them above the DFE. Where possible, motors and panelboards should be located above the DFE level. Submersible rated motors are available 200 horsepower and below, but will be considered for critical functions only.

Portions of the facility will be dry floodproofed while other areas will receive wet floodproofing. The extent of floodproofing will be finalized during detailed design. Where panelboards must be elevated four feet above the floor, a platform will be provided with adequate working clearance behind it when required.

Submersible rated control panels, motors (under 200hp) and actuators should be provided for all critical loads that cannot be elevated four feet above the finished floor.

The garage floor is at elevation 8.00, about 3 feet below the pump room floor. It is not practical to raise equipment in this location above the DFE.

7.5.5 Single Line Diagrams and Preliminary Equipment Layout

Refer to attached drawings for single line diagram and preliminary equipment layout.

7.5.6 Lighting

Existing lighting will be replaced with state-of-the-art LED type fixtures in all areas, including Class I, Division 1 and Class I, Division 2 areas. LED frog-eye type emergency lighting fixtures will also be provided.

Existing outdoor lighting fixtures will be replaced with metal halide or LED type fixtures. Where existing lighting is insufficient, new lighting will be added.

7.5.7 Leaking Conduit

During a site inspection, a leaking conduit was observed where a duct bank enters the building, in a lower level in the pump shaft area. The source of this leak will be investigated during detailed design. Corroded conduits will be replaced.

Instrumentation and Controls

8.1 Introduction

This section documents the instrumentation and control (I&C) design concepts for the Boulevard Pump Station. A state-of-art I&C system will be provided to ensure continuous and reliable process control and monitoring for the pump station, including remote monitoring and control from the East Shore WPAF.

8.1.1 Existing Instrumentation and Control System

The overall control system for the Boulevard Pump Station consists of several control panels.

A Modicon Momentum PLC based pump control panel is mounted adjacent to the pump drives in the pump motor room. This panel monitors and controls the pumps based on wet well level. The wet well level transmitters are wired to this panel. The pump control panel does not have a functional Operator Interface Terminal (OIT). The original OITs have been decommissioned. The panel has some status and alarm lights for the pumps.

The pump control panel communicates with an overall pump station control panel, also located in the pump motor room across from the pump drives. The pump station control panel is equipped with Modicon Momentum PLC hardware. The pump station control panel monitors and controls the rest of the equipment at the pump station and communicates with the East Shore WPAF over a T1 line. The communication link allows limited remote control from the plant. This panel is equipped with an OIT.

The generator system includes a PLC based control panel. Limited number of signals from this panel are hardwired to the pump station control panel

The odor control system includes a control panel. The pH and ORP signals for the odor control system are wired to this panel and the chemical feed is paced with the help of a Hach SC200 controller. This panel does not have any interface with the pump station control system.

Screens in both channels have been recently replaced and provided with new PLC based control panels equipped with OITs. Signals from these panels are hardwired to the pump station control panel. The bypass channel has a manual rack. The screenings are conveyed to a dumpster via a belt conveyor.

The bucket and chain style collector mechanisms in the grit channels are being replaced by screw mechanism. The grit is conveyed to a dumpster via a belt conveyor.

The level in the wet well is monitored by two bubbler systems that transmit signals to the pump control panel. The bubbler systems require frequent maintenance.

Each pump is equipped with an electromagnetic flow meter in the discharge line. The signals from these flow meters are wired to the pump station control panel. The location of the existing electromagnetic flow meters is not ideal for a reliable reading.

The pump station gates and some of the valves are hydraulically actuated. The hydraulic system control panels are not in good condition.

The pump station includes a surge control system. The surge control system valves and panels are in poor condition.

8.2 Design Approach

The existing instrumentation and control system at the Boulevard Pump Station is out-of-date. It lacks the modern hardware and software, as well as instrumentation required for reliable operation. The overall goal is to remove obsolete control system equipment and to take advantage of the current technology for improved operational reliability and process optimization.

The existing pump control panel and the pump station control panel in the pump motor room will be demolished. The pump station control will be consolidated in a single new control panel, located in new control room. The proposed location and layout of the room are detailed in the Architectural and Electrical Sections.

To bring the pump station to the same platform as the East Shore WPAF, the new control panel will be based on a redundant (hot backup) Allen-Bradley ControlLogix PLC system.

The PLC control panel will be equipped with an Allen-Bradley PanelView Plus 6 1500 OIT to provide means for local monitoring and control (e.g., LEAD/LAG/ALTERNATE selection, PLC AUTO/ PLC MANUAL mode selection, setpoints, etc.). A desktop human-machine interface (HMI) work station, loaded with Factory Talk View SE Standalone Client software, be also provided in the control room. All features available at the OIT will also be available at the HMI work station.

The AFDs for the new pumps will be installed in the control room.

Power monitors will be provided in the new MCC for monitoring power consumption and quality.

In addition to hardwired signals, device level rings (DLRs) will be used for Pump Station PLC communication with AFDs and power monitors to manage traffic on the control network.

Control system equipment will be powered from a true online double-conversion-type uninterruptable power supply (UPS) unit to maintain reliable operation during power system disturbances and outages. UPS unit will power the PLCs, operator interface terminals, and HMI operator workstation. UPS battery backup will have enough capacity to energize the control system for 30 minutes after a power failure. The low-battery alarm will be hardwired to the Plant PLC input/output (I/O) for monitoring. The panel will be designed to automatically switch over to the line power upon UPS failure.

For powering loop powered instruments, redundant 24 V DC power supplies will be provided in the PLC panel. The power supply failure alarm will be hardwired to the plant PLC I/O.

Electric or hydraulic actuation will be provided for all valves and gates. In general, electric actuators, rated for the environment, will be used. If the actuator can potentially be submerged, hydraulic actuation will be considered. Base on the field investigations, the wet well gate actuators at the Boulevard Pump Station can be submerged during wet weather conditions. For these gates, hydraulic actuation along with new hydraulic equipment, control panels and piping will be provided. The main influent gate will be modulating type to prevent flooding of the wet wells.

To complement process redundancy, the monitoring and control signals for redundant equipment (e.g., pumps, grinders, etc.) will be split between separate I/O modules and racks (if necessary)

The control systems for the new odor control system, the new bar screen in the bypass channel, and the new generator system will be PLC/OIT based. The package control systems will not be customized to use Allen-Bradley hardware if the system vendor's "standard" operating platform is different. Instead, gateways and/or protocol convertors will be provided for digital connection to the Pump Station PLC System. The system supplier will program the package PLCs. Hardwired I/O will be used for connecting critical monitoring and control signals from the package systems to the Pump Station PLC System. The digital interface will be used for monitoring of additional signals. Digital data interface requirements

between the package systems and the Pump Station PLC System will be further developed during design development and coordinated with the package system vendors.

The sump pump control panel will be replaced. If new sump pumps are provided, a new control panel will be specified. The panel will be mounted above the sea level rise protection elevation.

The hydraulic surge control valves will be replaced and a new control panel will be provided.

The existing bubbler systems, along with the associated compressors and receiver tanks will be replaced by non-fouling, hydrostatic pressure type transmitters, designed specifically for wastewater applications. The transmitters will be installed in stilling wells. As a backup to the level transmitters, high and low level switches will be provided to operate the pumps upon failure of a transmitter.

New electromagnetic flow meters will be provided in the discharge line of each pump. The installation will be coordinated with the new piping layout for better locations conforming to the upstream and downstream straight pipe length requirements.

Detailed change-out procedure will be developed so that the new I&C equipment can be installed and tested prior to being put into operation. The design will allow the new Pump Station PLC System and the existing control system to coexist for some time as the new system is brought online and the old system is decommissioned. The pump station will remain operational during switchover.

Security camera system with DVR will be provided at the pump station. The location and quantity of cameras will be determined during design development.

8.3 Control System Design Philosophy

The control system design philosophy at the Boulevard Pump Station will be the same as detailed in the Union and East Street Pump Station Instrumentation and Control Sections for overall consistency.

8.4 Control System Operating Philosophy

The control system operating philosophy at the Boulevard Pump Station will be the same as detailed in the Union and East Street Pump Station Instrumentation and Control Sections for overall consistency.

8.5 Remote Telemetry System

As a backup to the T1 line, a licensed frequency (900 MHz) Ethernet radio telemetry system will be considered for communication between the pump station and the plant. A path study will be conducted to determine the feasibility of utilizing radios. If radio telemetry is feasible, new Ethernet radio equipment and antennas will be installed at the pump station and at the East Shore WPAF.

If the path study is unfavorable, the use of cellular modems will be considered in lieu of radios. The possibility of buying bandwidth on the City's fiber optic network can also be considered. The system will be configured to automatically fail over to the backup communication path upon primary path failure

8.6 Codes and Standards

The Boulevard Pump Station design will follow the same codes and standards as the Union and East Street Pump Stations for consistency.

Odor Control

9.1 Introduction

The Boulevard Pump Station has a crossflow scrubber that was originally designed for a total flow of 15,500 cfm and dual chemistry consisting of both sodium hypochlorite and sodium hydroxide for odor removal. Although the system is in operation, it is unknown how much foul air is actually being ventilated and only sodium hypochlorite is being added. Much of the supporting infrastructure such as the chemical transfer pumps, have deteriorated and are no longer functioning. It is recommended that this system be replaced.

The Boulevard Pump Station processes that require odor control include an inlet chamber, three parallel channels that include bar screens, four aerated grit chambers and two wet wells. There are belt conveyors that convey screenings and grit to two separate dumpsters located in the garage.

9.2 Basis of Design

This section provides information used as the basis for the odor control system design. The proposed odor control system is based on a "contain-convey-treat" design approach and as such includes design information for each component.

9.2.1 Containment

The existing channels contain sections of grating that are covered with mats to contain odors within the channels. The inlet chamber is uncovered and allows for comingling of sewage vapors with the overlying room space that can then result in the release of sewage odors to the ambient atmosphere. It is recommended that all grating be replaced and that the inlet chamber be covered with solid panels to prevent escape of raw sewage vapors into the overlying room space. Covers will be designed using materials of construction resistant to corrosion (e.g., fiberglass reinforced plastic (FRP) or aluminum checker plate). Covers will be constructed using flat removable panels. The cover design will facilitate easy removal of individual panels by two people. Each panel will not weigh more than 100 lbs and will have an integral nonskid surface. Lifting handles shall be provided on each panel. Each panel will have gasketed joints to prevent fugitive air release.

As a result of the containment of foul air within the process channels, protection of concrete against corrosion using either protective coatings or liners is recommended and will be included during detailed design.

Grit and screenings are currently conveyed to the garage where they are discharged into open dumpsters. As a result, the entire volume within the garage requires ventilation and odor control. It is recommended that foul air capture hoods be installed over each dumpster to facilitate focused air capture from the dumpsters thereby allowing for overall reduced foul air extraction rates from the garage.

9.2.2 Conveyance

Foul air will be conveyed from within the contained process channels and wet wells by FRP ductwork. It is anticipated that up to nine foul air pickup locations will be designed, three associated with channels, four associated with the grit chambers and one for each wet well. Each foul air pickup location will include a flow balancing damper to facilitate adjustment of flow for each pickup to design values. The foul air duct will connect to the covers through a flanged connection to allow for easy removal. The duct

will rise vertically straight up and then move horizontally at a distance overhead ensuring clearance (e.g., min. 7 feet). The exact layout will be determined during detailed design.

Allowance for air flow into the covered process channels and wet wells will be included in the design. The relative locations of air entry and foul air extraction will be selected to achieve good overall air movement within the enclosed process area and minimize development of "dead zones" or short-circuiting.

The extraction of foul air will be achieved through use of a single exhaust fan constructed of FRP. A flow balancing damper will be located at the fan inlet to allow for adjustment of overall system air flow. The fan will convey captured foul air to an odor control system where the odorous compounds, primarily hydrogen sulfide (H_2S), are removed prior to release to the ambient atmosphere.

9.2.3 Odor Control System Sizing

All process areas will be continuously ventilated at a rate of least 12 air changes per hour (ACH). Table 9-1 summarizes ventilation rates required for the Boulevard Pump Station. The total system ventilation rate is 17,000 cfm.

Table 9-1. Process Area Ventilation Rates

Source	Volume (ft³)	Ventilation Rate (ACH)	Ventilation Rate (cfm)	Design Ventilation Rate (cfm)
Inlet Box and screen channels	11,400	12	2,280	2,400
Grit Chambers	30,750	12	6,150	6,400
Wet wells	34900	12	6,980	7,200
Screenings dumpster	540	12	108	500
Grit dumpster	540	12	108	500
Total				17,000

9.2.4 Anticipated Odor Causing Compounds

CH2M recommends that air sampling be completed at the Boulevard Pump Station in order to definitively establish current H₂S concentrations and the nature of peaks observed during normal diurnal cycles. It is recommended that an instrument capable of measuring and logging H₂S concentrations, (e.g., Odalog) be installed for a week. Based on data previously collected at East and Boulevard Pump Stations, and experience from other similar systems, it is anticipated that H₂S concentrations may average on order of 10 parts per million by volume (ppmv) with peaks as high as 100 ppmv. Additionally, it is anticipated that other odorous non-H2S sulfur bearing compounds will total less than 1 ppmv.

9.3 Odor Control Technology Selection

Three potential odor control technologies have been evaluated; biotowers, carbon and wet chemical scrubbers. A brief description of each technology is provided below.

9.3.1 Biotowers

In many ways, a biotower looks externally similar to a wet chemical scrubber, except that no hazardous chemical addition is required. Figure 9-1 depicts a simplified schematic diagram of a biotower system.

Systems are pre-engineered, vendor-supplied systems made of fiberglass-reinforced plastic or high density polyethylene shells. Biotowers use a biologically active media bed to absorb and oxidize odorous compounds from the foul air stream. One of the primary technical advances associated with this technology is the development of engineered inert media on which the biomass attaches. As the media is inert, it is not compromised by the acidic environment within the biotower and has lifespans on the order of 20 years. The media receives either constant recycle spray (bioscrubber) or intermittent oncethrough spray humidification (biotrickling filter), depending on the vendor's approach. The spray is also the source of trace nutrients for the biological system. There are typically two potential sources of water, potable or plant effluent. If potable water is used, then a supplemental nutrient supply containing trace organics, nitrogen, phosphorous, and potassium is required. If plant effluent is available, then supplemental nutrients are usually not required as the plant effluent water will contain sufficient nutrients. For Boulevard Pump Station, potable water and supplemental nutrients would be required as plant effluent is not available.

Biotowers are usually designed in the form of a cylindrical arrangement such as the one shown in Figure 9-2.




Figure 9-1. Simplified Schematic of a Biotower System



Figure 9-2. Photograph of a Biotower System

9.3.2 Carbon Scrubbers

Carbon scrubbers are the simplest of the vapor phase treatment technologies. They pass the foul air stream through a bed of dry (no irrigation) activated carbon. Odorous constituents diffuse into the media pore spaces and adsorb onto the media, and are thereby removed from the air stream. There are many types of activated carbon media designed for removal of various types of compounds. A single medium or a mixture of different media can be used. Carbon scrubbers have a small footprint compared to other technologies and can be configured with either vertical upward air flow through single, dual or radial flow beds or with horizontal flow configurations in locations where system height is constrained. Figures 9-3 and 9-4 depict a simplified schematic and photograph of a dual carbon bed system, respectively. Carbon scrubbers are effective at removing a range of compounds with excellent removal efficiency. One potential disadvantage is that under high H_2S loads, the media must be replaced frequently resulting in high annualized media replacement costs. However, the Boulevard Pump Station is anticipated to have relatively low average H_2S concentrations (e.g., \leq 10 ppmv), therefore, the potential use of carbon scrubbers as a treatment technology is recommended for consideration.

Carbon selection is an important part of designing carbon systems, because different types of carbon can be used depending on the nature of the odorant to be removed. For Boulevard Pump Station, the primary odorant to be designed for is H₂S.

Various types of carbon are available. Virgin activated carbon is the lowest cost but also has the lowest overall capacity for H2S resulting in relatively high frequency media replacements. Carbon adsorption capacity for H2S can be increased with media that is impregnated with chemicals, such as sodium hydroxide (NaOH), to enhance contaminant removal. This, however, adds handling complexity because of the potentially hazardous nature of the impregnated carbon and potential for carbon bed fires. The

use of this type of impregnated carbon is not recommended for further consideration. Finally, there are carbons available that have been processed in a manner that results in high selective adsorptive capacity for H2S (e.g., order of magnitude higher than virgin activated carbon). The use of this type of high capacity carbon is recommended for consideration as it will extend the useful life of the carbon significantly thereby reducing O&M issues and costs associated with frequent media replacement.




Figure 9-3. Schematic Dual Carbon Bed System




Figure 9-4. Photograph of a Dual Bed Carbon Scrubber

9.3.3 Chemical Scrubbers

Chemical scrubbers are similar to biotowers in that the foul air stream is passed through a bed of inert media that is continuously irrigated. Rather than using microbes to oxidize odorous compounds, chemicals are added to the irrigation water. Chemical scrubbers can be designed using several different configurations with separate stages using different chemistry. Some include a high pH stage with caustic

soda to facilitate dissolution of hydrogen sulfide into solution. Most have a stage with sodium hypochlorite added to oxidize reduced compounds. Other chemistries can be used to remove compounds, such as ammonia, that are less amenable to oxidation. Chemical scrubbers offer flexible configurations with smaller foot prints than are typical of biofilters and biotowers. Figure 9-5 shows an example. However, chemical scrubbers have the disadvantage that the cost to operate is proportional to the hydrogen sulfide loading. Significant hydrogen sulfide loadings, such as would be present at the headworks, can result in large operating costs. Nevertheless, chemical scrubbers are technically viable for this application and are therefore included in the technology cost comparison. For this application, a two stage dual chemistry chemical scrubber is recommended for consideration.



Figure 9-5. Photograph of a Chemical Scrubber

9.4 Economic Evaluation

An economic evaluation has been completed in order to compare capital costs, annual O&M costs and a 20-year net present value (NPV) for the biotower, carbon, and chemical scrubber technologies.

Capital construction cost estimates were based on a database of recent vendor quotes for similar technology. Operation and maintenance costs were estimated and combined with capital costs using a constant discount rate to determine a 20-year NPV. For planning purposes, it was assumed that the vapor phase treatment equipment has a life span of 20 years.

Unit costs and financial factors used in the cost estimate are listed in Table 9-2. As shown in Table 9-2, the inflation rate was assumed to be 6 percent and the discount rate was assumed to be 7 percent. Both the equipment life and planning horizon was 20 years. Factors were applied equally to each technology option.

Table 9-2. Capital, O&M and NPV Assumptions

	*	
Unit Costs		
Electricity	0.10	\$/kW-hr
Labor	40	\$/hr
Potable Water	4.4	\$/1000 gal

Table 9-2. Capital, O&M and NPV Assumptions

Unit Costs		
Sodium Hydroxide (50% strength)	1.8	\$/gal
Sodium Hypochlorite	0.7	\$/gal
Excavation	15	\$/CY
Backfill	35	\$/CY
Slab on Grade Concrete	525	\$/SF
Support Wall Concrete	525	\$/SF
Allowance Costs		
Equipment Installation	10	%
Field painting/finishes	1	%
Mechanical	8	%
Electrical	8	%
Instrumentation	5	%
Financial Factors		
Discount Rate	7	%
Annual Escalation Rate	3	%
Time Horizon	20	years
Construction Completion Year	2020	
Contractor Markups:		
General Conditions	7	%
Contractor Overhead & Profit	15	%
Bonds and Insurance	2	%
Contingency	30	%

Results of the economic evaluation are provided in Table 9-3.

As can be seen from the results of this evaluation, carbon has the lowest initial capital cost (\$734,000) and overall lowest NPV (\$1,434,000) compared to the biotower and chemical scrubber options, and therefore from a financial perspective, is the initial preferred option. However, given the sensitivity of carbon annual O&M costs and resultant NPV to the H_2S inlet concentration, further evaluations were completed to determine impacts of the assumption of an average 10 ppmv H_2S concentration on the economic results. Specifically, the assessment was repeated with increasingly higher concentrations of H_2S inlet to determine at which point the biotower option had the lower NPV. As chemical scrubber annual O&M costs are also directly related to H_2S inlet concentrations, the chemical scrubber option would not be more financially attractive at higher costs and was therefore not included in this additional analysis.

The biotower option did not have the lowest NPV until inlet H_2S concentrations were on the order of 25 ppmv. Given the high ventilation rate included in the odor control design (i.e., 12 ACH), it is anticipated

that the frequent turnover of air within the enclosed areas will prevent high concentrations of H_2S from accumulating, thus maintaining an inlet concentration of H_2S to the odor control system well below the 25 ppmv threshold. Therefore, carbon is recommended as the odor control technology of choice.

Table 9-3. Capital, Annual O&M and NPV Evaluation

Technology	Carbon	Biotower	Chemical Scrubber
Capital	\$734,000	\$1,662,000	\$1,048,000
Annual O&M	\$66,000	\$29,000	\$92,000
20 Yr NPV	\$1,434,000	\$1,970,000	\$2,023,000

9.5 Odor Control System Design Recommendations and Overview

A dual deep bed carbon scrubber system utilizing carbon with high adsorptive capacity for H_2S is recommended. The use of the high adsorptive carbon will prolong carbon life and thereby increase the time between media replacements. Based on an average inlet concentration of 10 ppmv H_2S , it is anticipated that media replacement will be on the order of every 2 years.

As the site has significant space constraints, utilizing a dual deep bed system reduces footprint

Recommended odor control system process equipment and anticipated design operating conditions are summarized in Table 9-4.

Table 9-4. Major Equipment, Design Criteria and Operating Conditions

Equipment/design criteria	Size/Operating conditions
Carbon Vessel	Two (2) 10 ft diameter dual bed FRP vessels
Carbon type and replacement frequency	High adsorptive capacity carbon, e.g., $0.3~g~H_2S/cc~carbon;$ 24-month media replacement frequency
Carbon bed depth	3 ft each
Carbon bed face velocity	55 fpm
Odorous Air Fan	One (1) fan, FRP construction with sound enclosure; continuous operation
Fan design point	17,000 cfm at 9.5 inches w.c. pressure
Electrical requirements	480V/3-ph/60 Hz; 50 hp

Appendix A Preliminary Design Drawings

INDEX TO DRAWINGS

300 - BOULEVARD PUMP STATION

DRAWING NO. TITLE TITLE **GENERAL ELECTRICAL** 300-G-001 BOULEVARD PUMP STATION INDEX OF DRAWINGS 300-E-201 BOULEVARD PUMP STATION SINGLE LINE DIAGRAM BOULEVARD PUMP STATION ABBREVIATIONS BOULEVARD PUMP STATION MVSWGR-1 AND MCC-1 300-G-002 300-E-202 300-G-003 BOULEVARD PUMP STATION ABBREVIATIONS BOULEVARD PUMP STATION FIRST FLOOR PLAN AND GENERAL LEGEND 300-E-203 BOULEVARD PUMP STATION INSTRUMENTATION AND CONTROL LEGEND - SHEET 1 300-G-005 300-G-006 BOULEVARD PUMP STATION INSTRUMENTATION AND CONTROL LEGEND - SHEET 2 BOULEVARD PUMP STATION ARCHITECTURAL AND 300-G-007 STRUCTURAL LEGEND 300-G-012 BOULEVARD PUMP STATION PROCESS MECHANICAL LEGEND 300-G-015 BOULEVARD PUMP STATION ELECTRICAL LEGEND 1 300-G-016 BOULEVARD PUMP STATION ELECTRICAL LEGEND 2 BOULEVARD PUMP STATION ELECTRICAL LEGEND 3 300-G-017 <u>CIVIL</u> 300-C-201 BOULEVARD PUMP STATION SITE PLAN **STRUCTURAL** BOULEVARD PUMP STATION FLOOD PROOFING PLAN 45 MGD CAPACITY 300-S-201 **ARCHITECTURAL** 300-A-201 BOULEVARD PUMP STATION LOWER PLANS45 MGD CAPACITY BOULEVARD PUMP STATION PLAN 45 MGD CAPACITY 300-A-202 BOULEVARD PUMP STATION ROOF PLAN 45 MGD CAPACITY 300-A-203 **MECHANICAL**

BOULEVARD PUMP STATION INDEX OF DRAWINGS ch2m. NOT FOR CONSTRUCTION

\$PWURL

\$PWPATH

300-M-201

300-M-215

300-M-301

300-M-302

310-M-201

BOULEVARD PUMP STATION 45 MGD CAPACITY PLAN

BOULEVARD PUMP STATION ODOR CONTROL PLAN & SECTIONS BOULEVARD PUMP STATION 45 MGD CAPACITY

BOULEVARD PUMP STATION 45 MGD CAPACITY

BOULEVARD DRY WEATHER PUMP STATION PLAN &

FILENAME: 300-G-001_664626.dgn

PLOT DATE: 2016\11\04

CALE
CH ON
WING.
1"
1"
MBER 2016
664626
300-G-001
of PLOT TIME: 2:00:02 PM


DWG

BAR IS ONE INCH ON ORIGINAL DRAWING.

NOVEMBER 2016

		1	1	2		3		4		5		6		
ſ	۸D	BREVIATIONS	CL	CENTERLINE	ESC	EROSION AND SEDIMENT CONTROL	HDW	HARDWARE	MC	MODULATE-CLOSE	PEP	POLYETHYLENE PIPE		
	AD	DREVIATIONS	CLDI	CEMENT LINED DUCTILE IRON	EP	EXPLOSION PROOF, EDGE OF	HGL	HYDRAULIC GRADE LINE	MCC	MOTOR CONTROL CENTER	PEN.	PENETRATION		
	Α	AMMETER, AMPERES, AWNINGS	CLSF	CONTROLLED LOW STRENGTH FILL		PAVING	HK	HOOK	MCJ	MASONRY CONTROL JOINT	PFC	POUNDS PER CUBIC FOOT		
		ANCHOR BOLT, ABOVE	CLG	CEILING	EQL	EQUAL	HGT	HEIGHT	MDO	MEDIUM DENSITY OVERLAY	PH	PENTHOUSE		
	ABDN	ABANDON	CLR CLSM	CLEAR, CLEARANCE CONTROLLED LOW STRENGTH MATERIAL	EQL SP	EQUALLY SPACED	HH H I D	HANDHOLE HIGH INTENSITY DISCHARGE	MECH MFD	MECHANICAL MANUFACTURED	pН	HYDROGEN ION CONCENTRATION		
	AC	ACOUSTICAL, ACOUSTICAL CEILING	CMP	CENTRAL MONITORING PANEL	EQPT	EQUIPMENT EROSION AND SEDIMENT CONTROL	HK	HOOK	MFR	MANUFACTURER	PH Pl	PHASE POINT OF INTERSECTION		
- 1	AC	ALTERNATING CURRENT	CMP	CORRUGATED METAL PIPE	ESC ETM	ELAPSED TIME METER	HM	HOLLOW METAL	MGD	MILLION GALLONS PER DAY	PIT	PILOT TUBE TEST STATION		
	AC	ASPHALTIC CONCRETE	CMU	CONCRETE MASONRY UNIT	EVC	END OF VERTICAL CURVE	HOA	HAND-OFF-AUTO	MH	MANHOLE, MOUNTING HEIGHT	PJF	PREMOULDED JOINT FILLER		
	ACFL ACI	ACCESS FLOORING	CNTR	COUNTER	EW	EACH WAY	HOR	HAND-OFF-REMOTE	MIN	MINIMUM	PL	PLATE (STEEL)		
ا۵	ACI ACMU	AMERICAN CONCRETE INSTITUTE ACOUSTICAL CONCRETE MASONRY	CO	CLEANOUT, CARBON MONOXIDE	EWC	ELECTRIC WATER COOLER	HORIZ	HORIZONTAL	MISC	MISCELLANEOUS	PL	PROPERTY LINE		Т
Ή	7101110	UNIT, ACOUSTICAL CMU	COL	COLUMN, COLOR	EXH	EXHAUST	HP	HORSEPOWER	MJ	MECHANICAL JOINT	PLAM	PLASTIC LAMINATE		
	ACP	ACOUSTICAL PANELS	CONC COND	CONCRETE CONDENSATE	EXP	EXPANSION, EXPOSED	HPT	HIGH POINT	MLO	MAIN LUGS ONLY	PLAS	PLASTER, PLASTIC		+
	ACST	ACOUSTICAL	CONDTN	CONDITIONED	EXP AB	EXPANSION ANCHOR BOLT	HPU	HYDRAULIC POWER UNIT	MMDW	DRY WEATHER MAXIMUM MONTH	PLC	PROGRAMMABLE LOGIC CONTROLLER		
	ACT	ACOUSTICAL TILE	CONDIN	CONNECTION	EXP JT	EXPANSION JOINT	HR	HOSE RACK, HANDRAIL	MMP	MECHANICAL MOUNTING PANEL	PLYWD	PLYWOOD		+
	AD	AREA DRAIN	CONSTR	CONSTRUCTION	EXST, EXIST	EXISTING	HV HVAC	HOSE VALVE HEATING, VENTILATING AND	MMWW	WET WEATHER MAXIMUM MONTH	PNL	PANEL		
	ADDL	ADDITIONAL	CONT	CONTINUED, CONTINUOUS, CONTINUATION	EXT	EXTERIOR	HVAC	AIR CONDITIONING	MO	MANUAL OPERABLE, MASONRY OPENING	PP P - P	POWER POLE		
	ADJ	ADJACENT	CONTR	CONTRACTOR	°F	DEGREE FAHRENHEIT	HWL	HIGH WATER LEVEL	MP MPU	METAL PANEL MULTIPURPOSE UNIT	P-P PPL	PUSH-PULL POLYPROPYLENE LINED		
	ADW AFD	DRY WEATHER AVERAGE ADJUSTABLE FREQUENCY DRIVE	COORD	COORDINATE	FACP	FIRE ALARM CONTROL PANEL		THO TO THE TEXT OF	MS	MANUFACTURER'S STANDARD	PR	PAIR		
	AFF	ABOVE FINISHED FLOOR	COP	COPPER	FB	FLAT BAR	IC	INTERRUPTING CAPACITY	MSC	MANUFACTURER SUPPLIED CABLE	PRC	POINT OF REVERSE CURVE		
	AFG	ABOVE FINISHED FEOGRA	CP	CENTER PIVOT	F, FU	FUSE	ID	INDUCED DRAFT, INSIDE DIAMETER	MSR	GROUPED MOTOR CONTROL	PRCST	PRECAST		
4	AG	ACOUSTICAL, ACOUSTICAL GLASS,	CP-X	CONTROL PANEL NO. X	F, FX	FIXED	ΙE	INVERT ELEVATION	MT	MOUNT	PREFAB	PREFABRICATION		
		AIR GAP (FIXED)	CPLG	COUPLING	FAP	FIRE ALARM PANEL	I.F.	INSIDE FACE	MTD	MOUNTED	PRES	PRESSURE		
	AGGR	AGGREGATE	CPRSR CPT	COMPRESSOR CONTROL POWER TRANFORMER, CARPET	FC	FLEXIBLE CONDUIT	IG IN	INSULATING, INSULATING GLASS INCH	MTG	MOUNTING	PRI	PRIMARY		
	AHR	ANCHOR	CPVC	CHLORINATED PVC	FCA	FLANGED COUPLING ADAPTER	INCAND	INCANDESCENT	MTS	MANUAL TRANSFER SWITCH	PRM	PERMANENT REFERENCED MARKER		
	AISC	AMERICAN INSTITUTE OF	CPVC	CONTROL RELAY	FCL2 FCO	FREE CHLORINE RESIDUAL FLOOR CLEANOUT	INCAND	INFLUENT	MTS	MILL TYPE STEEL PIPE	PROJ PROP	PROJECTION PROPERTY		
		STEEL CONSTRUCTION	CRS	COLD ROLLED STEEL	FCTY	FACTORY	INJS	INJECTIONS	MU	MULCHING	PROP PS	PLASTIC SHEET. POLYCARBONATE SHEET		
	AJ	ADJUSTABLE	CRS	CONSTRUCTION ROAD STABILIZATION	FD	FLOOR DRAIN	INST	INSTANTANEOUS	MV	MERCURY VAPOR	PS PS	PAINT SYSTEM		
	ALKY	ALUMINUM	CT	CERAMIC TILE	FDN	FOUNDATION	INSTM	INSTRUMENT, INSTRUMENTATION	MWS	MAXIMUM WATER SURFACE	PSF	POUNDS PER SQUARE FOOT		
	ALKY ALTN	ALKALINITY ALTERNATE	CT	CURRENT TRANSFORMER	FDR	FEEDER	INSUL	INSULATION	N	NORTH, NEUTRAL	PSI	POUNDS PER SQUARE INCH		
	ALTN	ALTERNATE AUTO-MANUAL	CTC	COMPUTER TERMINAL CABINET	FEXT	FIRE EXTINGUISHER	INVT	INVERT	NA	NOT APPLICABLE	PSIG	POUNDS PER SQUARE INCH, GAUGE		
٦	AMRD	ACOUSTICAL METAL ROOF DECKING	CTR	CENTER	FF	FINISHED FLOOR	IP	INLET PROTECTION, INSTRUMENTATION PANEL	NA	NON-AUTOMATIC	PT	POINT OF TANGENCY		
R	ANDZ	ANODIZE	CTRD	CENTERED	FG	FINISH GRADE, FLOAT GLASS	IRRIG	IRRIGATION	NC	NORMALLY CLOSED	PT	POTENTIAL TRANSFORMER		
	APPROX		CTSK	COUNTERSUNK	FH	FLAT HEAD	ITG	INSULATED TEMPERED GLASS ISOLATION TRANSFORMER	NEUT	NEUTRAL	PT	PRESSURE TREATED		
	APVD	APPROVED	CU CU FT	CUBIC CUBIC FOOT	FHY	FIRE HYDRANT	ITX IU	INTAKE UNIT	NG	NATURAL GAS	PTD	PAPER TOWEL DISPENSER		Т
	ARCH	ARCHITECTURAL	CU IN	CUBIC INCH	FIG	FIGURE	IW	IRRIGATION WELL	NGVD	NATIONAL GEODETIC VERTICAL DATUM	PTN	PARTITION		
	AR	ANALOG RELAY	CUH	COPPER TUBING, HARD DRAWN	FL FLG	FLOW LINE FLANGE	IVV	INTOATION WELL	NIC	NOT IN CONTRACT NORMALLY OPEN	PV	PLUG VALVE		
	AS	AS SELECTED	CV	CHECK VALVE	FL	FLOOR		JALOUSIE	N.O. NO., #	NUMBER	PVC	POLYVINYL CHLORIDE		+
	ASSY	ASSEMBLY	CWR	CABINET DOOR MOUNTED	FLEX	FLEXIBLE	JA	JAL-AWNING	NO., #	NOMINAL	PVI PVMT	POINT OF VERTICAL INTERSECTION PAVEMENT		
	ATS	AUTOMATIC		WASTE RECEPTACLE	FLH	FLAT HEAD	JB	JUNCTION BOX	NP	NON-PROTECTED	PVIVI	POINT OF VERTICAL TANGENCY		十
	AUTO AUX	AUTOMATIC AUXILIARY	CY, CU YD	CUBIC YARD	FLTR	FILTER	JAN	JANITOR	NPT	NATIONAL PIPE THREADS	FVI	TOWN OF VERTICAL PAROLING		
	AVG	AVERAGE	cws	CLEAN WATER SERVICES	FLUOR	FLUORESCENT	JCT	JUNCTION JOINT	NS	NON-SHRINK	QAA	AVERAGE FLOW		
4	AWW	WET WEATHER AVERAGE			FNSH	FINISH	JT	JOHN	NTS	NOT TO SCALE	QMM	MAXIMUM 30 DAY FLOW		
	@	AT	D	DEEP, DRAIN	FOB	FLAT ON BOTTOM	K	KEY GROUP, KEY INTERLOCK	O2	OXYGEN	QPI	PEAK INSTANTANEOUS FLOW		
	_	25.1	d	PENNY NAIL SIZE	FOT	FLAT ON TOP	KIP	THOUSAND POUNDS	0 TO 0	OUT TO OUT	QPP	PEAK PUMPING FLOW		
	B BAL	BELL BALANCE	DA	DUAL ACTION	FP FPM	FIELD PANEL FEET PER MINUTE	KIT	KITCHEN	OA	OVERALL, ODOROUS AIR	QT	QUARRY TILE		
	BETW	BETWEEN	DAS	DATA ACQUISTION SYSTEM	FPM	FORWARD REVERSE	K-PL	KICKPLATE KITCHEN SINK	ОС	ON CENTER	_			
	BF	BLIND FLANGE, BOTTOM FACE	DBA	DEFORMED BAR ANCHOR	FRP	FIBERGLASS REINFORCED PLASTIC	KSK KV	KITCHEN SINK KILOVOLTS	OC	OPEN-CLOSE (O)	R R OR RAD	RISER		
	BFV	BUTTERFLY VALVE	DBL	DOUBLE	FSHS	FOLDING SHOWER SEAT	KV KVA	KILOVOLTS KILOVOLT AMPERES	OCA	OPEN-CLOSE-AUTO	R OR RAD	RADIUS RETURN AIR		
	BL	BASELINE	DC	DIRECT CURRENT	FT	FOOT OR FEET	KVAR	KILOVOLT AMPERES REACTIVE	OCR	OPEN-CLOSE-REMOTE	RC	REINFORCED CONCRETE		
	BFP	BACKFLOW PREVENTER	DEG DET	DEGREE DETAIL	FTG	FOOTING	KW	KILOWATT	OD	OUTSIDE DIAMETER, OVERFLOW DRAIN	RCP	REINFORCED CONCRETE PIPE		
	BLDG	BUILDING	DF	DOUGLAS FIR. DRINKING FOUNTAIN	FU	FIXTURE UNIT			O.F.	OUTSIDE FACE	RCPT	RECEPTACLE		
٦	BLK	BLOCK	DDI	DROP INLET	FVNR	FULL VOLTAGE NON-REVERSING	L	ANGLE, LENGTH	OFCI	OWNER FURNISHED, CONTRACTOR INSTALLED OWNER FURNISHED, OWNER INSTALLED				
Ч	BM	BEAM, BENCHMARK	DH	DOUBLE HUNG	FVR	FULL VOLTAGE REVERSING	LA	LIGHTNING ARRESTER	OFOI OL	OVERLOAD RELAY	RD	ROAD, ROOF DRAIN		
	ВО	BOTTOM OF	DI	DUCTILE IRON	FWD	FORWARD	LAB LAM	LABORATORY LAMINATE	00	ON-OFF	RDCR	REDUCER		L
	B.O.B.	BOTTOM OF BEAM	DIA	DIAMETER	G, GND	GROUND	LAIVI	LATITUDE	OOA	ON-OFF-AUTO	RDW	REDWOOD		
	BOD	BOTTOM OF DUCT	DIAG	DIAGONAL	G, GND GA	GAUGE	LB	POUND	OOR	ON-OFF-REMOTE	RECIR	RECIRCULATION		
	BOP	BOTTOM OF DOCT	DIP	DUCTILE IRON PIPE	GAL	GALLON	LC	LIGHTING CONTACTOR	OP	OPAQUE PANEL, OUTLET PROTECTION	REF	REFER OR REFERENCE		
	BOT	BOTTOM	DIR	DIRECTION	GALV	GALVANIZED	LD	COMBINATION LOUVER/DAMPER	OPER	OPERATOR	DECD	DEEDICEDATE DEEDICEDANT		
	BRG	BEARING	DISCH	DISCHARGE	GB	GYPSUM BOARD	LDG	LOADING DOCK	OPNG	OPENING	REFR REINF	REFRIGERATE, REFRIGERANT REINFORCED, REINFORCE		
	BRK	BRICK	DN	DOWN DISSOLVED OXYGEN	GC	GROOVED COUPLING	LEL	LOWER EXPLOSIVE LIMIT	OPP	OPPOSITE	REQD	REQUIRED		
	BRKR	BREAKER	DO DOL	DISSOLVED OXYGEN	GCMU	GLAZED CONCRETE	LF	LINEAR FEET	OSA	OUTSIDE AIR	RESIL	RESILIENT		
	BSP	BLACK STEEL PIPE	DOL DP, DPNL	DIRECT-ON-LINE DISTRIBUTION PANEL		MASONRY UNITS	LG	LONG	OSC OSD	OPEN-STOP-CLOSE OPEN SITE DRAIN	RFS	ROLL-UP FIRE SHUTTER	<u> </u>	,
_	BV	BALL VALVE, BLOCK VENT	DP, DPNL DR	DOOR	GFA	GROOVED FLANGE ADAPTER	LH	LEFT HAND	OSD	OPEN SITE DRAIN OPEN WEB STEEL JOIST	RH	RIGHT HAND	2	, [
	BVC	BEGINNING OF VERTICAL CURVE	DR DS	DOWNSPOUT	GFI	GROUND FAULT INTERRUPTER	LHR	LEFT HAND REVERSE	OZ	OUNCE	RH	RODHOLE	~	.
	0	CONDUIT CASEMENT	DWG	DRAWING	GFR	GROUND FAULT RELAY	LLH	LONG LEG VERTICAL			RHR	RIGHT HAND REVERSE	ch2m	ا ا
	°C	CONDUIT, CASEMENT DEGREE CELSIUS	DWL	DOWEL	GH GL	GREENHOUSE GLASS	LLV LNTL	LONG LEG VERTICAL LINTEL	P P	PROJECTED DIDE	RL	RAIN LEADER	"	, [
	СТОС	CENTER TO CENTER	Δ	DELTA	GL GPD	GLASS GALLONS PER DAY	LONG	LINTEL LONGITUDINAL	P PAVT	PILASTER, PIPE PAVER TILE	RLS	RUBBER LINED STEEL	-	
	CAB	CABINET			GPD GPH	GALLONS PER DAY GALLONS PER HOUR	LOS	LOCK-OUT STOP PUSHBUTTON	PAV I PB	PAVER TILE PUSHBUTTON SWITCH	RM RO	ROOM ROUGH OPENING		, [
	CB	CATCH BASIN, CIRCUIT BREAKER			GPM	GALLONS PER MINUTE	LP	LIGHT POLE, LIGHTING PANEL, LOCAL PANEL	PC	POINT OF CURVE, PHOTOCELL	ROL	ROUGH OPENING RAISE-OFF-LOWER		
-	CC	CENTER OF CIRCLE	E	EAST, EMPTY	GPS	GLOBAL POSITION SYSTEM	LPT	LOW POINT	PC	PRECAST CONCRETE PANEL	RPM	REVOLUTIONS PER MINUTE		
-	CC	CONTROL CABLE	EA	EACH, EXHAUST AIR	GRTG	GRATING	LR	LATCHING RELAY	PCCP	PRECAST CONCRETE CYLINDER PIPE	RR	RIPRAP		
-	CCP	CENTRAL CONTROL PANEL	EB, EBCT	EMPTY BED CONTACT TIME	GSB	GYPSUM SOFFIT BOARD	LR	LOCAL-REMOTE	PCV	PRESSURE CONTROL VALVE				
L	CCS	CENTRAL CONTROL SYSTEM	ECC	ECCENTRIC	GSP	GALVANIZED STEEL PIPE	LR	LONG RADIUS	PE	PLAIN END				
٦	CDF CE	CONTROLLED DENSITY FILL CONSTRUCTION ENTRANCE	EE	EMERGENCY EYEWASH	GV	GATE VALVE	LS	LABORATORY SINK	PED	PEDESTAL, PEDESTRIAN				
-	CEM	CUBIC FEET PER MINUTE	EDF EF	EGG-SHAPED DIGESTER FACILITY EACH FACE, EXHAUST FAN	GVL	GRAVEL	LT LTG, LTS	LIGHTS OR LIGHTING		(SENE	RAL NOTES:		
	CFS	CUBIC FEET PER SECOND	EFF	EFFICIENCY, EFFICIENT	GWB GYP	GYPSUM WALLBOARD GYPSUM	LTX	LIGHTS OR LIGHTING LIGHTING TRANSFORMER		-			-	_
	CHEM	CHEMICAL	EFL	EFFLUENT			LWL	LOW WATER LEVEL		1		STANDARD LEGEND SHEET.	17	/ERII
	CHKD	CHECKERED	EIFS	EXTERIOR INSULATION AND FINISH SYSTEM	H H2S	HIGH, HORN OR HOWLER HYDROGEN SULFIDE						RE, NOT ALL OF THE INFORMATION AY BE USED ON THIS PROJECT.		AR IS
	CI	CAST IRON	EL	ELEVATION	H2S H.A.S.	HEADED ANCHOR STUD	MA	MANUAL-AUTO					OR	RIGIN.
	CIP	CAST IRON PIPE, CAST IN PLACE	ELB	ELBOW	HC	HOLLOW CORE WOOD	MAS	MASONRY MATERIAL		2		ENGINEER FOR ABBREVIATIONS NOT SHOWN ON THIS DRAWING.		
	CIP	CULVERT INLET PROTECTION	ELC	ELECTRICAL LOAD CENTER	HCL	HYDROCHLORIC ACID	MATL MAX	MATERIAL MAXIMUM			OSED BUT	NOT SHOWIN ON THIS DRAWING.	DATE	'
	CISP CJ	CAST IRON SOIL PIPE CONSTRUCTION JOINT	ELEC ENGR	ELECTRIC, ELECTRICAL ENGINEER	HDNR	HARDENER	MB	MACHINE BOLT					PROJ	_
-	CKT	CIRCUIT	ENGR	EDGE OF PAVEMENT	HDNS	HARDNESS	MC	MASONRY CLEARANCE					DWG SHEET	
L					HDR	HEADER								
	PWURL							Long&space, Term&space, Control/DESIGN/300&space, -&spa				n PLOT DATE: 11/4/2016	PLO [*]	

GENERAL
BOULEVARD PUMP STATION
ABBREVIATIONS



SECTION / DETAIL DESIGNATIONS ON DRAWING WHERE SECTION SECTION (LETTER) OR DETAIL (NUMERAL) DESIGNATION DRAWING NUMBER DRAWING NUMBER (REPLACED WITH A LINE ON SAME SHEET) В ON DRAWING WHERE SECTION 65-S-201 DRAWING NUMBER(S) DETAIL ON DRAWING WHERE DETAIL SCALE IS SHOWN: 65-S-201 DRAWING NUMBER(S) WHERE TAKEN DRAWING TITLE ON DRAWING WHERE ONLY A TITLE IS REQUIRED WITH NO REFERENCE (eg: ELEVATIONS) SECTION CALLOUT WHERE SECTION EXTENDS TO A FIXED LIMIT SECTION CALLOUT WHERE SECTION IS ON ANOTHER SHEET AND CUT EXTENDS THROUGHOUT ENTIRE SHEET GRID LINE INDICATOR KEYNOTE NUMBER REVISION / ADDENDA NUMBER NORTH ARROW **DESIGN DETAIL DESIGNATION** DESIGN DETAIL DESIGNATION (NUMERAL) SHOWN ON DESIGN DETAIL DRAWING(S)

DRAWING NUMBER DESIGNATION DRAWING NUMBER 100-S-201 **SEQUENTIAL NUMBER** SHEET TYPE 0 GENERAL, DIAGRAMS, SCHEMATICS 1 DEMOLITION DRAWINGS S SECTIONS AND OR ELEVATIONS 4 LARGE SCALED VIEWS 5 DETAILS DISCIPLINE G GENERAL C CIVIL I FROSION CONTROL A ARCHITECTURAL F FIRE PROTECTION P PLUMBING D PROCESS / PIPING M MECHANICAL E ELECTRICAL N INSTRUMENTATION AND CONTROLS **FACILITY** 100 - UNION PUMP STATOIN 200 - EAST STREET PUMP STATION 300 - BOULEVARD PUMP STATION **PROJECT NOTES:** PROJECT ELEVATIONS ARE BASED ON NAVD 88. EXISTING ELEVATIONS ARE BASED ON NGVD 29. EXISTING DRAWINGS WERE USED AS BACKGROUNDS FOR EXISTING BUILDINGS/STRUCTURES. EXISTING ELEVATIONS HAVE BEEN CONVERTED TO NAVD 88, UNLESS NOTED OTHERWISE. TO CONVERT BETWEEN NGVD 29 AND NAVD 88 USE THE FOLLOWING CONVERSIONS: NGVD 29 TO NAVD 88: SUBTRACT 1.04 FEET NAVD 88 TO NGVD 29: ADD 1.04 FEET CONTRACTOR SHALL FIELD VERIFY EXISTING ELEVATIONS AND DIMENSIONS.

NOTES

- 1. ALL DESIGN DETAILS ARE TYPICAL AND MUST BE USED IF DESIGN
- 2. THE TERM STANDARD DETAIL, OR A FORM OF IT, IS SYNONYMOUS WITH DESIGN DETAIL. THE DESIGN DETAILS REPRESENT THE CHARACTER AND NATURE OF THE WORK REQUIRED THROUGHOUT THE PROJECT. ALL ASSOCIATED WORK SHALL BE IN ACCORDANCE WITH THE DESIGN DETAILS SHOWN WHETHER THE DETAILS ARE

- 1. THIS IS A STANDARD LEGEND SHEET. THEREFORE, NOT ALL OF THE INFORMATION
- 2. CONTACT ENGINEER FOR ABBREVIATIONS

SHOWN MAY BE USED ON THIS PROJECT.

WG

300-G-003

VERIFY SCALE

BAR IS ONE INCH ON

BOULEVARD PUMP STATION ABBREVIATIONS AND GENERAL LEGEND


NOT FOR CONSTRUCTION

ch2m

PLAN

INSTRUMENT IDENTIFICATION

EXAMPLE SYMBOLS



DIGITAL SYSTEM INTERFACES

- ANALOG INPUT
- ANALOG OUTPUT
- DISCRETE INPUT
- DISCRETE OUTPUT

INSTRUMENT IDEN	NTIFICATION LETTERS TABLE
FIRST-LETTER	SUCCEEDING-LETT

	FIRST-LETT	ED		SUCCEEDING-LETTERS	
		EK			I
LETTER	PROCESS OR INITIATING VARIABLE	MODIFIER	READOUT OR PASSIVE FUNCTION	READOUT OR PASSIVE FUNCTION	READOUT OR PASSIVE FUNCTION
Α	ANALYSIS (+)		ALARM		
В	BURNER, COMBUSTION		USER'S CHOICE (*)	USER'S CHOICE (*)	USER'S CHOICE (*)
С	USER'S CHOICE (*)			CONTROL	
D	DENSITY (S.G.)	DIFFERENTIAL			
E	VOLTAGE		PRIMARY ELEMENT, SENSOR		
F	FLOW RATE	RATIO (FRACTION)			
G	USER'S CHOICE (*)		GLASS, GAUGE VIEWING DEVICE	GATE	
Н	HAND (MANUAL)				HIGH
I	CURRENT (ELECTRICAL)		INDICATE		
J	POWER	SCAN			
К	TIME, TIME SCHEDULE	TIME RATE OF CHANGE		CONTROL STATION	
L	LEVEL		LIGHT (PILOT)		LOW
М	MOTION	MOMENTARY			MIDDLE, INTERMEDIATE
N	TORQUE		USER'S CHOICE (*)	USER'S CHOICE (*)	USER'S CHOICE (*)
0	USER'S CHOICE (*)		ORIFICE, RESTRICTION		
Р	PRESSURE, VACUUM		POINT (TEST) CONNECTION		
Q	QUANTITY	INTEGRATE, TOTALIZE			
R	RADIATION		RECORD OR PRINT		
S	SPEED, FREQUENCY	SAFETY		SWITCH	
Т	TEMPERATURE			TRANSMIT	
U	MULTI VARIABLE		MULTI FUNCTION	MULTI FUNCTION	MULTI FUNCTION
V	VIBRATION, MECHANICAL ANALYSIS			VALVE, DAMPER, LOUVER	
W	WEIGHT, FORCE		WELL		
Х	UNCLASSIFIED (*)	X AXIS	UNCLASSIFIED (*)	UNCLASSIFIED (*)	UNCLASSIFIED (*)
Y	EVENT, STATE OR PRESENCE	Y AXIS		RELAY, COMPUTE, CONVERT	
Z	POSITION	Z AXIS		DRIVE, ACTUATOR, UNCLASSIFIED FINAL CONTROL ELEMENT	

TABLE BASED ON THE INSTRUMENTATION, SYSTEMS, AND AUTOMATION SOCIETY (ISA) STANDARD.

- (+) WHEN USED, EXPLANATION IS SHOWN ADJACENT TO INSTRUMENT SYMBOL. SEE ABBREVIATIONS AND LETTER SYMBOLS. (*) WHEN USED, DEFINE THE MEANING HERE FOR THE PROJECT.

GENERAL INSTRUMENT OR FUNCTIONAL SYMBOLS



FIELD MOUNTED



REAR-OF-PANEL MOUNTED (OPERATOR INACCESSIBLE)



(OPERATOR ACCESSIBLE) MCC MOUNTED

PANEL MOUNTED

HAND SWITCHES AND INDICATING LIGHTS



ON AND OFF EVENT




ON-OFF HAND SWITCH MAINTAINED CONTACT SWITCH (CONTROLLED DEVICE WILL RESTART ON RETURN OF POWER AFTER POWER FAILURE).




STOP-START HAND SWITCH SWITCHES (CONTROLLED ON RETURN OF POWER AFTER POWER FAILURE).


LINE LEGEND



INTERFACE SYMBOLS



- INTERFACE LETTER
- DESTINATION DRAWING NO.
- SOURCE DRAWING NO



ABBREVIATIONS & LETTER SYMBOLS

ALTERNATING CURRENT AUTO-MANUAL CHLORINE (TYPICAL: USE STANDARD CHEMICAL CL₂ etc. ELEMENT ABBREVIATIONS) COD CP-X CHEMICAL OXYGEN DEMAND CONTROL PANEL NO. X (X = FACILITY NUMBER) DC DO DISSOLVED OXYGEN FCL₂ FREE CHLORINE RESIDUAL FOS FOSA FAST-OFF-SLOW FAST-OFF-SLOW-AUTO

FOSR FP-W-X FAST-OFF-SLOW-REMOTE FIELD PANEL NO. WX (W = UNIT PROCESS NUMBER X = PANEL NUMBER) FORWARD-REVERSE

FR HOA HOR ISR LEL LOS LR MA HAND-OFF-AUTO HAND-OFF-REMOTE INTRINSICALLY SAFE RELAY LOWER EXPLOSIVE LIMIT LOCAL-REMOTE MANUAL-AUTO MC MCC-X MODULATE-CLOSE MOTOR CONTROL CENTER NO. X MANUFACTURER SUPPLIED CABLE NORMALLY CLOSED MSC NC NO OCA OCR OO OOA OOR ORP OSC NORMALLY OPEN OPEN-CLOSE(D) OPEN-CLOSE-AUTO OPEN-CLOSE-REMOTE ON-OFF

ON-OFF-AUTO
ON-OFF-REMOTE OXIDATION REDUCTION POTENTIAL OPEN-STOP-CLOSE HYDROGEN ION CONCENTRATION
PROGRAMMABLE LOGIC CONTROLLER pH PLC RIO RTU-X REMOTE I/O UNIT REMOTE TELEMETRY UNIT NO. X SOF SS TCL₂ TOC TOD TURB VHC VIB

SLOW-OFF-FAST TOTAL CHLORINE RESIDUAL TOTAL ORGANIC CARBON

TOTAL OXYGEN DEMAND VOLATILE HYDROCARBONS VIBRATION

SELF CONTAINED VALVE & EQUIPMENT TAG NUMBERS

D-UP-LL-UU

AIR RELEASE VALVE AIR AND VACUUM RELEASE VALVE AVRV GATE MECHANICAL EQUIPMENT

UNIT PROCESS NUMBER

TANK

LOOP NUMBER HILL UNIT NUMBER

GENERAL NOTES

- COMPONENTS AND PANELS SHOWN WITH A SINGLE ASTERISK (*) ARE TO BE PROVIDED AS PART OF A PACKAGE SYSTEM.
- COMPONENTS AND PANELS SHOWN WITH A DOUBLE ASTERISK (**) ARE TO BE PROVIDED UNDER DIVISION 26, ELÉCTRICAL.
- THIS IS A STANDARD LEGEND. THEREFORE, NOT ALL OF THIS INFORMATION MAY BE USED ON THE PROJECT.


ch2m.

BOULEVARD PUMP STATION INSTRUMENTATION AND CONTROL LEGEND - SHEET 1 NOT FOR CONSTRUCTION

RIFY SCALE
IS ONE INCH ON SINAL DRAWING.

NOVEMBER 2016
664626
300-G-005
of VERIFY SCALE BAR IS ONE INCH ON PROJ

WG PLOT DATE: 11/4/2016 PLOT TIME: 10:08:24 AM



GENERAL ARCHITECTURAL NOTES 1. UNLESS OTHERWISE INDICATED, PLAN DIMENSIONS ARE TO COLUMN GRID ON CENTERLINES, NOMINAL SURFACE OF MASONRY, FACE OF STUDS AND FACE OF CONCRETE WALLS.

"FLOOR LINE" REFERS TO TOP ON CONCRETE SLABS. FINISH FLOORING IS INSTALLED ABOVE THE FLOOR LINE. FOR DEPRESSED FLOORS AND CURBS, SEE STRUCTURAL DRAWINGS.

3. REPETITIVE FEATURES ARE NOT DRAWN IN THEIR ENTIRETY AND SHALL BE COMPLETELY PROVIDED AS IF DRAWN IN FULL.

4. WHERE DOOR IS LOCATED NEAR CORNER OF ROOM AND IS NOT LOCATED BY DIMENSION ON PLAN OR DETAILS, DIMENSION SHALL BE 3-INCHES FROM FACE OF STUD (WALL) TO FACE OF ROUGH OPENING. DIMENSION SHALL BE 6" FROM FACE OF WALL TO EDGE OF ROUGH OPENING AT CONCRETE WALLS, 8" AT CMU WALLS.

 AT SOUND INSULATED WALLS, FULL HEIGHT PARTITIONS SHALL BE SEALED BOTH SIDES WITH ACOUSTIC SEALANT; TOP, BOTTOM, INTERSECTION, DOOR FRAMES, GLAZED OPENING FRAMES, AND OTHER PENETRATIONS.


6. LINE OF EXISTING GRADES, AS SHOWN ON THE BUILDING ELEVATIONS AND SECTIONS ARE APPROXIMATE. THEY ARE AT THE BUILDING FACE, OR ON THE SECTION END EXCEPT AS NOTED.

7. VERIFY ALL ROUGH-IN DIMENSIONS FOR EQUIPMENT PROVIDED IN THIS CONTRACT, OR BY OTHERS

8. REFER TO ARCHITECTURAL, STRUCTURAL, MECHANICAL, ELECTRICAL AND OTHER CATEGORIES OR DRAWINGS FOR ADDITIONAL NOTES.

9. VERIFY SIZE AND LOCATION OF, AND PROVIDE: REQUIRED OPENINGS THROUGH FLOORS AND WALLS, ACCESS DOORS, FURRING, CURBS, ANCHORS AND INSERTS. PROVIDE ALL BASES AND BLOCKING REQUIRED FOR ACCESSORIES, MECHANICAL, ELECTRICAL AND OTHER EQUIPMENT.

ARCH/STRUCT MATERIAL SYMBOLS




WOOD, FINISHED


	ARCHITECTURAL/STR	RUCTURAL LEGEND
	SYMBOL	LEGEND
	A	NEW REFERENCE GRID INDICATOR
	(A)	EXISTING REFERENCE GRID INDICATOR
=	ROOM NAME ROOM NAME XX-101 OR 101	ROOM IDENTIFIER
	"XX" = FACILITY DOOR LETTER INDICATOR (IF SHOWN) ROOM NUMBER	DOOR IDENTIFIER
	XXW-1 OR W-1	WINDOW IDENTIFIER
	XXR-1 OR R-1	RELIGHT IDENTIFIER
	XXL-1 OR (L-1)	LOUVER IDENTIFIER
	A	WALL TYPE INDICATOR
	(\$-1)	SIGNAGE IDENTIFIER
	(P-1)	PRECAST PANEL IDENTIFIER
	(XX-A-301)	EXTERIOR ELEVATION INDICATOR
	QUANTITY AND DIRECTION OF POINTERS AS REQUIRED D XXA-301	INTERIOR ELEVATION INDICATOR
	1 XX-A-401	DETAIL INDICATOR - SMALL CONDITION
	⊗ 110.50	SPOT ELEVATION INDICATOR
	<u>→</u>	DIRECTION OF SLOPE DOWN
	HINGE SIDE	DOOR/HATCH SWING INDICATOR
	ACTIVE INACTIVE	INDICATES PAIR OF DOORS
	F.EXT-X	FIRE EXTINGUISHER "X" = NUMBER IN SPECIFICATIONS
		CONTROL JOINT
		EXPANSION JOINT
	POST	RAILINGS

L		•										
		CAOAA.										
ORIO 0	VE BAR											
ANI	RIF											
L DF		GENERAL	GNHWPCA LONG TERM CONTROL PLAN									
RAWII		BOULEVARD PUMP STATION	GREATER NEW HAVEN WATER POLLUTION									
νG. 1"	E ON	ARCHITECTURAL AND STRUCTURAL	CONTROL AUTHORITY	ġ	DATE		REVISION		ВУ	BY APVD		
		LEGEND	NEW HAVEN, CONNECTICUT	DSGN		DR	CHK	APVD				
					J. OSOSKIE		Z BRYAN QC Review	we		Sealer		
l≧	\ <u>a</u> \	INARY NOT FOR CONSTRICTION REUSE OF	REUSE OF DOCUMENTS: THIS DOCUMENT, AND THE IDEAS AND DESIGNS INCORPORATED HEREIN, AS AN INSTRUMENT OF PROFESSIONAL SERVICE, IS THE PROPERTY OF	SINCORPOF	RATED HEREIN, A	S AN INSTRUMENT OF PROFE	SSIONAL SERVICE, IS THE PROF	PERTY OF		@CH2M F	©CH2M HILL 2016. ALL RIGHTS RESERVE	N.

DATE PROJ DWG NOVEMBER 2016 664626 300-G-007 U

300-G-007 of





300-G-015

οf

PLAN

UMP STATION L LEGEND 1

SOULEVARD PUI ELECTRICAL I

m

NOT FOR CONSTRUCTION

YMBOL	1 2 DESCRIPTION	SYMBOL	3 DESCRIPTION	SYMBOL	4 BESCRIPTION	SYMBOL	6 DESCRIPTION		
	POWER SYSTEM PLAN-1		POWER SYSTEM PLAN-2	FIRE A	ALARM SYSTEM PLAN AND RISER	SOL	UND SYSTEM PLAN AND RISER		
	CONNECTION POINT TO EQUIPMENT SPECIFIED. RACEWAY, CONDUCTOR, TERMINATION AND CONNECTION IN THIS DIVISION.	100/40	BREAKER, SEPARATELY MOUNTED, CURRENT RATING INDICATED (100/40, 100 = FRAME SIZE; 40 = TRIP RATING)	F _P	FIRE ALARM STATION, MANUAL	<u> </u>	SPEAKER, CONE TYPE, RECESSED IN CEILING, SEE ARCHITECTURAL DRAWINGS FOR CEILING TYPE		
MCC-A	MAJOR ELECTRICAL COMPONENT OR DEVICE - NAME OR IDENTIFYING SYMBOL AS SHOWN.	© ²	3 POLE CONTACTOR, MAGNETIC, NEMA SIZE INDICATED		FIRE ALARM SYSTEM, AUTOMATIC SMOKE DETECTOR FIRE ALARM SYSTEM, AUTOMATIC, HEAT DETECTOR	(8)	SPEAKER, CONE TYPE, WALL MOUNTED		
	PANELBOARD - SURFACE MOUNTED	□ 30	LIGHTING CONTACTOR, CURRENT RATING INDICATED	FD	FIRE ALARM BELL	S	SPEAKER, CONE TYPE, SURFACE MOUNTED		
LPXXA	— PANELBOARD LETTER OR NUMBER	≥ 2	STARTER, MAGNETIC NEMA SIZE INDICATED	> F⊲	FIRE ALARM HORN	\bigcirc	VOLUME CONTROL, WALL MOUNT 5'-0" AFF	H	
	FACILITY NUMBER LP - LOW VOLTAGE PANEL	xx ⊜	CONVENIENCE RECEPTACLE - DUPLEX UNLESS NOTED		FIRE ALARM HORN/STROBE LIGHT	S	INTERIOR PAGING TRUMPET SOUND REPRODUCER WITH REMOTE AMPLIFIER, SURFACE MOUNTED	H	
	DP - DISTRIBUTION PANEL PANELBOARD - FLUSH MOUNTED	2	OTHERWISE WP - WEATHERPROOF C - CLOCK HANGER TL - TWIST LOCK CRE - CORROSION RESISTANT GFCI - GROUND FAULT CIRCUIT INTERRUPTER	×	FIRE ALARM STROBE LIGHT	M	MICROPHONE OUTLET		
	TERMINAL JUNCTION BOX		SUBSCRIPT NUMBER AT RECEPTACLE INDICATES CIRCUIT	==	AIR DUCT DETECTOR	s	SOUND SYSTEM RACEWAY		
		€	240V RECEPTACLE	FS	FIRE SPRINKLER FLOW SWITCH	S#D	COMMUNICATION STATION		
(M)	MOTOR, SQUIRREL CAGE INDUCTION	⊕ -	CONVENIENCE RECEPTACLE - QUADRUPLEX	TS	FIRE SPRINKLER TAMPER SWITCH	SECU	JRITY SYSTEM PLAN AND RISER		
G	GENERATOR, VOLTAGE AND SIZE AS INDICATED.	φ φ φ	MULTI OUTLET ASSEMBLY	D	DOOR HOLDER	CR	CARD KEY ACCESS		
→ LPXXA	HOME RUN - DESTINATION SHOWN		DUPLEX CONVENIENCE RECEPTACLE - FLUSH IN FLOOR	<u>TELEF</u>	PHONE SYSTEM PLAN AND RISER	cs	CONTROL STATION		
— or —/// _G	EXPOSED CONDUIT AND CONDUCTORS*	₽	CONVENIENCE RECEPTACLE, PEDESTAL, DUPLEX SINGLE FACE UNLESS INDICATED OTHERWISE	<u>TTC</u>	TELEPHONE TERMINAL CABINET	DS 🔯	DOOR SWITCH		
or -/#/ _G	CONCEALED CONDUIT AND CONDUCTORS*	L20R			TELEPHONE RECEPTACLE FLOOR BOX	₽ EP	EGRESS PUSHBUTTON		
NDUCTORS IN 3/4" MBER OF NO. 12 C	DUIT RUNS CONSIST OF TWO NO. 12, ONE NO. 12 GROUND ' CONDUIT. RUNS MARKED WITH CROSSHATCHES INDICATE ONDUCTORS. CROSSHATCH WITH SUBSCRIPT "G" INDICATES	²⁰ 🙆	RECEPTACLE, SPECIAL PURPOSE-NEMA CONFIGURATION AND AMPERAGE INDICATED THERMOSTAT	I	TELEPHONE RECEPTACLE		ELECTRONIC LOCK M = MAGENITIC S = STRIKE		
EEN GROUND WIR	E.		UTILITY REVENUE METERING FACILITY	т——т	TELEPHONE SYSTEM RACEWAY		INTERCOM		DAT
——————————————————————————————————————	CROSSHATCHES WITH BAR INDICATE NO.10 CONDUCTOR. SIZE CONDUIT ACCORDING TO SPECIFICATIONS AND APPLICABLE CODE.			-	ER SYSTEM (DATA) PLAN AND RISER		MONITOR		N ON
	CONDUIT AND CONDUCTOR CALLOUT, SEE LEGEND.	↓	ELECTRIC UNIT HEATER	CTC _	COMPUTER SYSTEM TERMINAL CABINET	<u> </u>	MOTION SENSOR		z Z
1-/	CONDUIT DOWN	→ AC	ELECTRIC AIR CONDITIONER (SELF CONTAINED UNIT)	•	COMPUTER NETWORK CONNECTION FLUCLING COR	₽	VIDEO CAMERA PTZ = PAN/TILT/ZOOM		COL PLA
	CONDUIT DOWN	——————————————————————————————————————	UTILITY POLE		COMPUTER NETWORK CONNECTION, FLUSH IN FLOOR		F = FIXED		CONTR ATER P
	CONDUIT UP	~ ~ ~	LIGHTING SYSTEM PLAN	——υ——	DATA SYSTEM RACEWAY		GROUND SYSTEM PLAN		TERM (
	CONDUIT, STUBBED AND CAPPED	① or ①	LUMINAIRE, SEE SCHEDULE	COMBINE	ED TELEPHONE/COMPUTER SYSTEM PLAN AND RISER	•	GROUND ROD		LONG:
	CONDUIT TERMINATION AT CABLE TRAY	(1)	LUMINAIRE, SEE SCHEDULE	⊲ ₄	COMBINATION TELEPHONE/DATA RECEPTACLE, WALL MOUNTED. NUMBER OF PORTS INDICATED	0	GROUND ROD IN TEST WELL		WPCA I
——EX———	EXISTING CONDUIT/ DUCT BANK	or Ø	LUMINAIRE WITH INTERNAL BATTERY BACKUP, SEE SCHEDULE	4	COMBINATION TELEPHONE/DATA RECEPTACLE, FLOOR BOX, NUMBER OF PORTS INDICATED	— — G — —	GROUNDING CONDUCTOR, SIZE AS INDICATED		GREA"
—BD——	BUS DUCT - SEE SPECIFICATIONS		STRIP LUMINAIRE, SEE SCHEDULE			<u> </u>	PIGTAIL FOR CONNECTION TO EQUIPMENT CABINET OR FRAME		
——CE——	CONCRETE ENCASED CONDUIT	□-4 or o-4	LUMINAIRE AND POLE, SEE SCHEDULE	CLOSED CIRC	UIT/TELEVISION CABLE PLAN AND RISER	G	EQUIPMENT GROUND BUS		
——DB———	DIRECT BURIED CONDUIT	H 5 or H 5	WALL MOUNTED LUMINAIRE, SEE SCHEDULE	$\overline{\qquad}$	COMBINATION CLOSED CIRCUIT TELEVISION RECEPTACLE (CCTV) AND DUPLEX CONVENIENCE RECEPTACLE IN TWO	N	EQUIPMENT NEUTRAL BUS		NO Z
—FO——	FIBER OPTIC CONDUIT	(1) -	FLOOD LIGHTS - AIM IN THE DIRECTION SHOWN		GANG BOX WITH BARRIER, 12" DOWN FROM CEILING				TATION ND 2
[XXXX]	CONCRETE ENCASED DUCT BANK WHERE XXXX IS THE DUCT BANK NAME. SEE CIRCUIT AND RACEWAY CODING DEFINITION	↓	STANDBY LIGHTING UNIT, SURFACE MOUNTED, SEE SCHEDULE	•	COMBINATION TELEVISION CABLE RECEPTACLE (TV) AND DUPLEX CONVENIENCE RECEPTACLE IN TWO GANG BOX WITH BARRIER, 12" DOWN FROM CEILING			Ż	MP ST
××××××××××××××××××××××××××××××××××××××	CONCEALED CONDUIT ROUTING AREA	xx⊗ or 🕏	EXIT LIGHTS - FILLED SECTION INDICATES LIGHTED FACE, ARROW INDICATES EGRESS DIRECTIONAL INDICATORS, XX = FIXTURE NUMBER, SEE SCHEDULE		CLOSED CIRCUIT TELEVISION RECEPTACLE, FLOOR BOX			<u>୍ବ</u>	PUN
	CONDUIT ROUTING AREA CABLE TRAY	\$ _{a or 2a}	SMALL LETTER SUBSCRIPT AT SWITCH AND LUMINAIRE INDICATES SWITCHING. SUBSCRIPT NUMBER AT LUMINAIRE INDICATES CIRCUIT		TELEVISION CABLE RECEPTACLE, FLOOR BOX			ঠ	VARD CTRIC
	TRANSFORMER	\$ 3	WALL SWITCH:						
(J) or HH	GENERAL CONTROL OR WIRING DEVICE. LETTER SYMBOLS OR ABBREVIATIONS INDICATE TYPE OF DEVICE		2- DOUBLE POLE P- PILOT LIGHT 3- THREE WAY K- KEY OPERATED 4- FOUR WAY D- DIMMER WP- WEATHERPROOF CRE- CORROSION RESISTANT						BOI
cs	CONTROL STATION, SEE CONTROL DIAGRAMS		EX- EXPLOSIONPROOF L- MOMENTARY 3-WAY M- MOTOR RATED MS- MANUAL STARTER WITH OVERLOADS						
30 📑	FOR CONTROL DEVICE(S) REQUIRED. NONFUSED DISCONNECT SWITCH, CURRENT RATING	os	OCCUPANCY SENSOR					VE	ERIFY SCALE
0/40 🗗	INDICATED, 3 POLE FUSED DISCONNECT SWITCH, CURRENT RATING INDICATED	LC	LIGHTING CONTACTOR					BAF ORI 0	R IS ONE INCH ON IGINAL DRAWING. 1"
_	(60/40, 60=SWITCH RATING / 40=FUSE RATING) 3 POLE	MD	MOTION DETECTOR					DATE PROJ	NOVEMBER 2
2 🔟	COMBINATION CIRCUIT BREAKER AND MAGNETIC STARTER, NEMA SIZE INDICATED	<u> </u>	PHOTOCELL					DWG SHEET	300-G- of

SYMBOL DESCRIPTION ONE LINE PROTECTION RELAYING AND **ELEMENTARY DIAGRAMS-1** DEVICE FUNCTION NUMBER INDICATED, SEE DEVICE TABLE CONTROL SWITCH TRIP (CS) CONTROL SWITCH CLOSE 43/CS 43-DEVICE FUNCTION NUMBER, SEE DEVICE TABLE □ vs VOLTMETER SWITCH AS AMMETER SWITCH Δ INDICATING LAMP-SWITCHBOARD TYPE INDICATING LAMP LENS COLORS INDICATED AS FOLLOWS: A - AMBER R - RED B - BLUE W - WHITE G - GREEN VOLTMETER AMMETER WATTMETER (F)FREQUENCY METER POWER FACTOR METER WH WATT-HOUR METER ETM ELAPSED TIME METER TACHOMETER WXD WATTS TRANSDUCER PF POWER FACTOR TRANSDUCER (TD)TIME DELAY 4 RELAY COIL, DEVICE FUNCTION NUMBER PER ANSI 37.2 - AMERICAN STANDARD MANUAL AND AUTOMATIC STATION CONTROL, SUPERVISORY AND ASSOCIATED TELEMETRY EQUIPMENT NORMALLY OPEN CONTACT NORMALLY CLOSED CONTACT REMOTE DEVICE TEST SWITCH CURRENT ELEMENT TEST SWITCH POTENTIAL ELEMENT NEUTRAL CONNECTION INSTRUMENTATION CABLE, SHIELDED

NEUTRAL GROUNDING RESISTOR

PHASE SHIFTING TRANSFORMER

ONE LINE PROTECTION RELAYING AND **ELEMENTARY DIAGRAMS-2**

DEVICE TABLE

DEVICE FUNCTION NO.	DEVICE DESCRIPTION				
21	IMPEDANCE/DISTANCE RELAY				
25A	AUTOMATIC SYNCHRONIZER				
25C	SYNCH CHECK RELAY				
27	UNDERVOLTAGE RELAY				
32	REVERSE POWER RELAY				
40	GENERATOR LOSS OF EXCITATION RELAY				
43CSE	AUTOMATIC POWER TRANSFER AND LOAD CONTROL MODE SEL. SWITCH				
43CSX	MODE SEL. SWITCH				
46	GENERATOR CURRENT UNBALANCE RELAY				
49	THERMAL RELAY				
50GS	INSTANTANEOUS OVERCURRENT DEVICE, GROUND SENSOR				
50	INSTANTANEOUS OVERCURRENT DEVICE,				
51	TIME OVERCURRENT RELAY				
51G	TIME OVERCURRENT RELAY, GROUND FAULT				
51V	TIME OVERCURRENT, VOLTAGE RESTRAINED				
52	POWER CIRCUIT BREAKER				
52CSX	POWER CIRCUIT BREAKER CONTROL SWITCH				
59	OVERVOLTAGE RELAY				
60	VOLTAGE OR CURRENT BALANCE RELAY				
65A	ENGINE GOVERNOR, SPEED CONTROL				
65A, MOP	ENGINE GOVERNOR, SPEED CONTROL MOTOR OPERATED POTENTIOMETER				
65A, RL	ENGINE GOVERNOR, SPEED CONTROL RAISE/LOWER SWITCH				
65B	ENGINE GOVERNOR, LOAD CONTROL				
65B, MOP	ENGINE GOVERNOR, LOAD CONTROL				
00B, MOI	MOTOR OPERATED POTENTIOMETER				
65B, RL	ENGINE GOVERNOR, % LOAD RAISE/LOWER SWITCH				
65E	AUTOMATIC POWER TRANSFER AND LOAD CONTROL, WOODWARD APTL				
65F	AUTOMATIC GENERATOR LOADING CONTROL, WOODWARD AGLC				
67	DIRECTIONAL TIME OVERCURRENT RELAY				
74	ALARM RELAY				
81O/U	FREQUENCY RELAY, OVER/UNDER				
86	LOCKOUT RELAY				
87	DIFFERENTIAL PROTECTIVE RELAY				
90	VOLTAGE REGULATOR				
90, MOP	ENGINE EXCITATION, POWER OPERATED POTENTIOMETER				
90PF	ENGINE EXCITATION, POWER FACTOR CONTROL				
90RL	ENGINE EXCITATION, RAISE/ LOWER SWITCH				

X = DEVICE NUMBER, WHEN THERE ARE MULTIPLE UNITS

CIRCUIT AND RACEWAY GENERAL CIRCUIT CONDUCTOR AND CONDUIT IDENTIFICATION

	POWER CIRC	UIT CALLOUT	S	MULTICONE	DUCTOR POWER CABLE CIRCUIT CALLOUTS
[P1]	[1/2"FLEX, 2#12,#12G]	[P24]	[1"C,3#8,3#14,1#10G]	[PC1]	[3/4"C,1 (3C#12,1#12G) TYPE 2]
[P2]	[3/4"C,2#12,1#12G]	[P25]	[1"C,3#8,4#14,1#10G]	[PC2]	[3/4"C,1 (3C#10,1#10G) TYPE 2]
[P3]	[3/4"C,3#12,1#12G]	[P26]	[1"C,3#8,5#14,1#10G]	[PC3]	[1"C,1 (3C#8,1#10G) TYPE 2]
[P4]	[3/4"C,4#12,1#12G]	[P27]	[1"C,2#6, 1#10G]	[PC4]	[1 1/4"C,2 (3C#12,1#12G) TYPE 2]
[P5]	[3/4"C,5#12,1#12G]	[P28]	[1"C,3#6, 1#8G]	[PC5]	[1 1/2"C,2 (3C#10,1#10G) TYPE 2]
[P6]	[3/4"C,6#12,1#12G]	[P29]	[1"C,3#6, 2#14,1#8G]	[PC1A]	[3/4"C,1 (2C#12,1#12G) TYPE 2]
[P7]	[3/4"C,7#12,1#12G]	[P30]	[1"C,3#6, 3#14,1#8G]	[PC2A]	[3/4"C,1 (2C#10,1#10G) TYPE 2]
[P8]	[3/4"C,8#12,1#12G]	[P31]	[1"C,3#6, 4#14,1#8G]		
[P9]	[3/4"C,3#12,2#14,1#12G]	[P32]	[1"C,3#6, 5#14,1#8G]		
[P10]	[3/4"C,3#12,3#14,1#12G]	[P33]	[1"C,3#4,1#8G]		
[P11]	[3/4"C,3#12,4#14,1#12G]	[P34]	[1 1/4"C,3#4,3#14,1#8G]		
[P12]	[3/4"C,3#12,5#14,1#12G]	[P35]	[1 1/4"C,3#4,5#14,1#8G]		EMPTY CONDUIT
[P13]	[3/4"C,3#12,6#14,1#12G]	[P36]	[1 1/4"C,3#3, 1#6G]		
[P14]	[3/4"C,3#12,7#14,1#12G]	[P37]	[1 1/4"C,3#3, 3#14,1#6G]	[EC-1]	[3/4"C,WITH PULL STRING]
[P15]	[3/4"C,2#10,1#10G]	[P38]	[1 1/4"C,3#2, 1#6G]	[EC-2]	[1"C,WITH PULL STRING]
[P16]	[3/4"C,3#10,1#10G]	[P39]	[1 1/4"C,3#1, 1#6G]	[EC-3]	[1 1/4"C,WITH PULL STRING]
[P17]	[3/4"C,3#10,2#14,1#10G]	[P40]	[1 1/2"C,3#1, 3#14,1#6G]	[EC-4]	[1 1/2"C,WITH PULL STRING]
[P18]	[3/4"C,3#10,3#14,1#10G]	[P41]	[1 1/2"C,3#2/0, 1#4G]	[EC-5]	[2"C,WITH PULL STRING]
[P19]	[3/4"C,3#10,4#14,1#10G]	[P42]	[2"C,3#3/0, 1#4G]	[EC-6]	[3"C,WITH PULL STRING]
[P20]	[3/4"C,3#10,5#14,1#10G]	[P43]	[2"C,3#4/0, 1#3G]	[EC-7]	[4"C,WITH PULL STRING]
[P21]	[1"C,2#8,1#10G]	[]	[2 0,000 000, 0000]	[EC-8]	[5"C,WITH PULL STRING]
[P22]	[1"C,3#8,1#10G]				
[P23]	[1"C,3#8,2#14,1#10G]				
		1			
A	NALOG CIRCUIT CALLOUTS	CON	TROL CIRCUIT CALLOUTS	MULTICONDU	JCTOR CONTROL CABLE CIRCUIT CALLOUT
[A1]	[3/4"C,1 TYPE 3]	[C1]	[3/4"C,MSC]	[CC5]	[3/4"C,1-5C TYPE 1]
[A2]	[1"C,2 TYPE 3]	[C2]	[3/4"C,2#14,1#14G]	[CC7]	[3/4"C,1-7C TYPE 1]
[A3]	[1"C,3 TYPE 3]	[C3]	[3/4"C,3#14,1#14G]	[CC9]	[1"C,1-9C TYPE 1]
[A4]	[1"C,4 TYPE 3]	[C4]	[3/4"C,4#14,1#14G]	[CC12]	[1"C,1-12C TYPE 1]
[A5]	[1 1/4"C,5 TYPE 3]	[C5]	[3/4"C,5#14,1#14G]	[CC19]	[1 1/2"C, 1-19C TYPE 1]
[A6]	[1 1/4"C,6 TYPE 3]	[C6]	[3/4"C,6#14,1#14G]	[CC25]	[1 1/2"C,1-25C TYPE 1]
[A7]	[1 1/2"C,7 TYPE 3]	[C7]	[3/4"C,7#14,1#14G]	[CC37]	[2"C,1-37C TYPE 1]
[8A]	[1 1/2"C,8 TYPE 3]	[C8]	[3/4"C,8#14,1#14G]	[CCC1]	[1-7C #12 TYPE 1]
[A9]	[1 1/2"C,9 TYPE 3]	[C9]	[3/4"C,9#14,1#14G]		
[A10]	[2"C,10 TYPE 3]	[C10]	[3/4"C,10#14,1#14G]		
[A11]	[2"C,11 TYPE 3]	[C11]	[3/4"C,11#14,1#14G]		
[A12]	[2"C,12 TYPE 3]	[C12]	[3/4"C,12#14,1#14G]		
[A13]	[2"C,13 TYPE 3]	[C13]	[3/4"C,13#14,1#14G]		
[A14]	[2"C,14 TYPE 3]	[C14]	[3/4"C,14#14,1#14G]		
[A15]	[3/4"C,1 TYPE 4]	[C15]	[3/4"C,15#14,1#14G]		
[A16]	[3/4"C,2 TYPE 4]	[C16]	[3/4"C,16#14,1#14G]		
[A17]	[1"C,3 TYPE 4]	[C17]	[3/4"C,17#14,1#14G]		
[A18]	[1 1/4"C,4 TYPE 4]	[C17]	[3/4"C,18#14,1#14G]		
[A19]	[1 1/4"C,5 TYPE 4]	[C10]	[3/4"C,19#14,1#14G]		
[A20]	[1 1/4"C,6 TYPE 4]				
[A21]	[1 1/2"C,7 TYPE 4]	[C20]	[1"C,20#14,1#14G]		
[A21]	[1 1/2 C,7 TTPE 4]	[C21]	[1"C,21#14,1#14G]		
[A22] [A23]	[2"C,9 TYPE 4]	[C22]	[1"C,22#14,1#14G]		
[A23] [A24]	[3/4"C,1-4 pr. TYPE 5]	[C23]	[1"C,23#14,1#14G]		
		[C24]	[1"C,24#14,1#14G]		
[A25]	[1"C,2-4 pr. TYPE 5]	[C25]	[1"C,25#14,1#14G]		

- 1. FOR CABLE TYPES, SEE SPECIFICATIONS.
- 2. CONDUIT SIZES ARE BASE ON THE AREA OF THW CONDUCTORS.
- 3. SIZING OF CONDUCTORS #1AWG AND SMALLER BASED ON AMPACITIES AT 60 DEGREES C, SIZING OF CONDUCTORS #1/0AWG AND LARGER BASED ON AMPACITIES AT 75 DEGREES C.
- 4. WHERE CIRCUITS ARE UNDERGROUND, DIRECT BURIED OR CONCRETE ENCASED, MINIMUM CONDUIT SIZE SHALL BE 1".

BOULEVARD PUMP STATION ELECTRICAL LEGEND 3 ch2m.

NOT FOR CONSTRUCTION


RIFY SCALE
IS ONE INCH ON SINAL DRAWING.


NOVEMBER 2016
664626
300-G-017
of VERIFY SCALE BAR IS ONE INCH ON ORIGINAL DRAWING. DATE PROJ DWG


SHEET


NGR


PST











- NOT FOR CONSTRUCTION

BAR IS ONE INCH ON ORIGINAL DRAWING.

1/4"=1'-0"

RIFY SCALE

IS ONE INCH ON
SINAL DRAWING.


NOVEMBER 2016


664626

300-A-203


of

TIME: 10'08'45 AM PLOT TIME: 10:08:45 AM







BLVD PUMP STAION
ODOR CONTROL
PLAN & SECTIONS
- NOT FOR CONSTRUCTION



- NOT FOR CONSTRUCTION



NOT FOR CONSTRUCTION



NOT FOR CONSTRUCTION

ARCFLASH PLENUM 1200AF 150AT MVAFD-1 FEEDER 1200AF 150AT MVAFD-3 FEEDER METERING SPD BREAKER CONTROLS BREAKER CONTROLS BREAKER CONTROLS 1200AF 100AT XFMR-2 & LVSWGR-1 FEEDER 1200AF 150AT MVAFD-4 FEEDER 1200AF 150AT MVAFD-2 FEEDER 1200AF 500AT MAIN BREAKER

MVSWGR-1 ELEVATION

	CABLE COMPARTMENT	METERING	400AF 250AT MCC-1 FEEDER	
,06		1200AF 1000AT MAIN BREAKER	400AF 400AT AFD-1 FEEDER	CABLE
		400AF 400AT AFD-2 FEEDER	400AF 400AT AFD-3 FEEDER	COMPARTMENT
		400AF 400AT SPARE	SPD	
	24"	24"	24"	24"

$\underset{\text{\tiny NTS}}{\underline{\text{LVSWGR-1}}} \; \underline{\text{ELEVATION}}$

15A GATE VALVE 1 15A GATE VALVE 2 15A GATE VALVE 6 15A GATE VALVE 7 SCREENING HVAC FEED GRINDER 15A GATE VALVE 3 15A GATE VALVE 4 15A GATE VALVE 5 15A GATE VALVE 8 15A GATE VALVE 9 15A GATE VALVE 10 LUGS SIZE 1 SCREENING COMPACTOR ODOR CONTROL 15A SUMP PUMP 15A CRANE HOIST 15A SLIDE GATE 11 15A SLIDE GATE 12 15A SLIDE GATE 13 15A SLIDE GATE 14 15A SLIDE GATE 14 15A SLIDE GATE 15 SCREEN 3 208/120V SIZE 1 GRIT PUMP SPACE SPARE SPARE 15A SLIDE GATE 1 15A SLIDE GATE 2 15A SLIDE GATE 3 15A SLIDE GATE 4 15A SLIDE GATE 5 15A SLIDE GATE 6 15A SLIDE GATE 7 15A SLIDE GATE 8 15A SLIDE GATE 9 15A SLIDE GATE 10 15A SLIDE GATE 10 15A SCREEN 2 SIZE 1 GRIT BLOWER 1 GRIT PUMP 2 SIZE 1 SCREENING 25kVA BLOWER 2 180-208/120\ XFMR CONVEYOR SIZE 1 GRIT CONVEYOR SPARE 15A SCREEN 1

MCC-1 ELEVATION

BOULEVARD PUMP STATION MVSWGR-1 AND MCC-1 ELEVATIONS ch2m. NOT FOR CONSTRUCTION RIFY SCALE
IS ONE INCH ON
SINAL DRAWING.


NOVEMBER 2016
664626
300-E-202
W
TIME: 10:08:13 AM BAR IS ONE INCH ON ORIGINAL DRAWING. 0 1"

DWG

PLOT DATE: 11/4/2016

PLOT TIME: 10:08:13 AM

\$PWURL



NOT FOR CONSTRUCTION

Appendix F
Construction Cost Estimate
Breakdown

Intermediate-Term Improvements
Capacity Upgrade of East Street Pump
Station



Job Size:

Facility Summary

Project: East Street Pump Station Estimator: E.B. Smith/GNV, A. Frisch/PGH

1 LS Project No.: 478874 Revision / Date: Rev03/(10-4-2016)

Duration: 1 LS Design Stage: conceptual Estimate Class: 4

Facility	Description	Direct Amount	Grand Total w/Markups	Percent of Total
0200	East Street Pump Station	8,199,409	19,115,106	65.986
0305	Dry Weather Pump Station	4,316,718	9,853,208	34.014

Estimate Totals

Construction Costs	Amount	Totals	Rate	% of Total
Labor	7,826,612			27.02%
Material	12,839,365			44.32%
Subcontract	3,990,129			13.77%
Equipment	4,193,215			14.48%
Other_	118,993			0.41%
Total Prime Contractor Costs	28,968,314	28,968,314		100.00



Project: East Street Pump Station

Project No.: 478874 Revision / Date: Rev03/(10-4-2016)

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Design Stage: conceptual Estimate Class: 4

ac Wor			Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
200		East Street Pump Station											
01.0		General Requirements											
	01.06												
		Startup and Testing											
		General Conditions, Other											
		Startup, Testing, and Contractor Commissioning Allowance	1.00 ls		81,263	0	-	27,976	-	109,238.91 /ls	109,239	233,776.16 /ls	233,77
		General Conditions, Other	1.00 LS		81,263			27,976		109,238.91 /LS	109,239	233,776.16 /LS	233,77
		Startup and Testing	1.00 LS		81,263			27,976		109,238.91 /LS	109,239	233,776.16 /LS	233,77
		01.06 Startup & Commissioning	1.00 LS		81,263			27,976		109,238.91 /LS	109,239	233,776.16 /LS	233,77
		01.0 General Requirements	1.00 LS		81,263			27,976		109,238.91 /LS	109,239	233,776.16 /LS	233,77
02.0		Existing Conditions											
	02.40												
		Selective Demolition											
		Structure/Building Demolition Demolish existing grit equipment and all associated works	1.00 ea	293.1	22,223			3,944	_	26,166.41 /ea	26,166	59,922.25 /ea	59,92
		Demo pumps	4.00 ea	319.7	24,043	205		1,066	-	6,328.49 /ea	25,314	14,492.53 /ea	57,97
		Demo Diesel Tank	1.00 ea	32.0	2,404	-	-	400	-	2,803.97 /ea	2,804	6,421.21 /ea	6,42
		Door demolition, single, remove	1.00 ea	1.3	102	-		-	-	101.58 /ea	102	232.63 /ea	23
	_	Demolition Allowance	5.00 Days 3.00 Days		0	-	12,809 7,686		-	2,561.89 /Days 2,561.89 /Days	12,809 7,686	5,866.84 /Days 5,866.84 /Days	29,33 17,60
		Demo Stair Opening Demo existing roof	4,857.00 bays		12,941	-	7,686	19,411		2,561.89 /Days 6.66 /sf	32,352	5,866.84 /Days 15.25 /sf	74,08
		Structure/Building Demolition	1.00 SF	646.1	61,713	205	20,495			107,233.05 /SF	107,233	245,568.50 /SF	245,56
		Selective Demolition	1.00 LS	646.1	61,713	205	20,495			107,233.05 /LS	107,233	245,568.50 /LS	245,56
		Electrical Facility Demolition			.,.		,	,,,,		,		.,	
		Electrical Facility Demolition											
		Electrical demo, remove misc. electrical equipment, transformers, etc.	9,488.00 sf	9,479.8	776,200	-	-	-	-	81.81 /sf	776,200	187.35 /sf	1,777,53
		Electrical Facility Demolition	9,488.00 SF	9,479.8	776,200					81.81 /SF	776,200	187.35 /SF	1,777,53
		Electrical Facility Demolition	1.00 LS	9,479.8	776,200					776,199.85 /LS	776,200	1,777,532.46 /LS	1,777,53
		02.40 Demolition	1.00 LS	10,125.9	837,913	205	20,495	24,820		883,432.90 /LS	883,433	2,023,100.96 /LS	2,023,10
		02.0 Existing Conditions	1.00 LS	10,125.9	837,913	205	20,495	24,820		883,432.90 /LS	883,433	2,023,100.96 /LS	2,023,10
03.0		Concrete Work											
	03.10												
		Electrical Equipment Pads											
		Cast-in-Place Concrete, Purchase											
		Edge forms, housekeeping pads, up to 6" Concrete, ready mix, 4000 psi	242.00 lf 6.25 CY	17.1	1,278	64 769	-	-	-	5.55 /lf 122.97 /CY	1,343 769	12.71 /lf 281.61 /CY	3,07 1,76
		Add for concrete waste, 4000 psi	0.25 C1		1	38		1	1	122.98 /cy	38	281.67 /cy	1,70
		Finish housekeeping pads	506.25 sf	27.0	1,867	16	-	-	-	3.72 /sf	1,883	8.52 /sf	4,31
		Curing, membrane spray	506.25 sf	1.3	79	21	-	-	-	0.20 /sf	100	0.45 /sf	22
		Cast-in-Place Concrete, Purchase	1.00 CY	45.4	3,225	908				4,132.73 /CY	4,133	9,464.13 /CY	9,46
		Electrical Equipment Pads	1.00 CY	45.4	3,225	908				4,132.73 /CY	4,133	9,464.13 /CY	9,46
		Electrical Equipment Pad - Generator, Xfmrs											
		Cast-In-Place Concrete, Equipment Pads, 24" thick											
		Equipment pad forms, large Reinforcing in place, A615 Gr 60, priced per lbs.	314.00 sf 2,050.00 lb	104.6	7,824	483 1,050	840	-	-	26.46 /sf 0.92 /lb	8,307 1,891	60.58 /sf 2.11 /lb	19,02 4,33
		Concrete, ready mix, 4000 psi	20.00 CY		- :	2,459	040	1	1	122.97 /CY	2,459	281.61 /CY	5,63
		Concrete, ready mix, 4000 psi	7.33 CY		-	902	-	-	-	122.97 /CY	902	281.60 /CY	2,06
		Add for concrete waste, 4000 psi	1.00 cy		-	123	-	-	-	122.98 /cy	123	281.65 /cy	28
		Add for concrete waste, 4000 psi	0.10 cy		-	12	-	-	-	122.90 /cy	12		2
		Add for concrete waste, 4000 psi Finishing floors, monolithic, broom finish	0.27 cy 297.00 sf	11.9	822	33				123.00 /cy 2.79 /sf	33 828	281.61 /cy 6.38 /sf	1,89
		Finishing floors, monolithic, broom finish	72.00 sf	2.9	199	1				2.79 /sf	201	6.38 /sf	45
		Patch & plug tieholes	246.00 sf	4.9	288	5	-		-	1.19 /sf	293	2.73 /sf	67
		Patch & plug tieholes	68.00 sf	1.4		1	-	-	-	1.19 /sf	81	2.73 /sf	18
		Sack rub Curing, water	314.00 sf 369.00 sf	16.7	981 96	10 19	-	-	-	3.15 /sf 0.31 /sf	990	7.22 /sf 0.71 /sf	2,26 26
		Cast-In-Place Concrete, Equipment Pads, 24" thick	1.00 CY	144.0	10,289	5,105	840	_	1	16,234.53 /CY	16,235	37,177.81 /CY	37,17
		Electrical Equipment Pad - Generator, Xfmrs	1.00 LS	144.0		5,105	840			16,234.53 /LS	16,235	37,177.81 /LS	37,17
		Concrete Wall - Floodproof Wall, 8" thick	20	144.0	.5,205	5,105	040			.0,20.100 /20	. 3,200	5., /LO	37,17
		Cast-In-Place Concrete, Straight Walls, 8" thick		1									
		Concrete pumping, subcontract, all inclusive price	31.61 cy		-	-	558	-	-	17.66 /cy	558	40.44 /cy	1,27
		Forms in place, structural walls, to 8' high, hand set	2,560.00 sf	587.7	43,972	3,014		-	-	18.35 /sf	46,986	42.03 /sf	107,6
		Speed Dowels, #5	320.00 ea		-	5,274		-	-	16.48 /ea	5,274	37.75 /ea	12,07
		Reinforcing in place, A615 Gr 60, priced per lbs.	5,688.89 lb	-	-	3,349	2,679	-	-	1.06 /lb	6,028	2.43 /lb	13,80
		Concrete, ready mix, 4000 psi Add for concrete waste, 4000 psi	31.61 CY 2.00 cy			4,205 266	-	1 -		133.04 /CY 133.04 /cy	4,205	304.66 /CY 304.67 /cy	9,62
		Placing concrete, concrete pump, for structural wall to 12" thick	31.61 cy	41.1	2,410	- 200		<u> </u>		76.24 /cy	2,410	174.59 /cy	5,51
		Patch & plug tieholes	2,560.00 sf	58.8	3,443	60				1.37 /sf	3,504	3.13 /sf	8,02



Project: East Street Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03/(10-4-2016)

work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Cast-In-Place Concrete, Straight Walls, 8" thick											
		Sack rub	2,560.00 sf	156.7	9,185 459	90		-	-	3.62 /sf	9,275	8.30 /sf	21,24
		Curing, membrane spray Cast-In-Place Concrete, Straight Walls, 8" thick	2,560.00 sf 31.61 CY	7.8 852.2	59.469	16,379	3.237	-	-	0.23 /sf 2,501.91 /CY	580 79.085	0.52 /sf 5,729.49 /CY	1,328 181,109
		Concrete Wall - Floodproof Wall, 8" thick	31.61 CY	852.2	59,469	16,379	3,237			2,501.91 /CY	79,085	5,729.49 /CY	181,109
		Concrete Wall @ Upper Floor	31.61 C1	032.2	39,409	10,379	3,231			2,301.91 /C1	79,000	3,729.49 /C1	101,103
		Cast-In-Place Concrete, Straight Walls, 12" thick											
		Concrete pumping, subcontract, all inclusive price	50.00 cy				769			15.37 /cy	769	35.20 /cy	1.76
		Forms in place, structural walls, > 8' to 16' high, hand set	2,700.00 sf	719.4	53,823	3,459	709			21.22 /sf	57,282	48.58 /sf	131,17
		Reinforcing in place, A615 Gr 60, priced per lbs.	6,758.64 lb	713.4	30,023	3,463	2,770			0.92 /lb	6,233	2.11 /lb	14,27
		Concrete, ready mix, 4000 psi	50.00 CY		-	6,149		-	-	122.97 /CY	6,149	281.61 /CY	14,08
		Add for concrete waste, 4000 psi	2.50 cy		-	307		-	-	122.97 /cy	307	281.61 /cy	70
		Add amount for Fuel Surcharges - per concrete truck load	6.00 load		-	92		-	-	15.37 /load	92	35.20 /load	21
		Add amount for Environmental Fee - per concrete truck load	6.00 load		-	37		-	-	6.15 /load	37	14.08 /load	8
		Placing concrete, concrete pump, for structural wall to 12" thick	50.00 cy	56.6	3,318	-		-	-	66.36 /cy	3,318	151.97 /cy	7,59 7,36
		Patch & plug tieholes Sack rub	2,700.00 sf 2,700.00 sf	53.9 143.9	3,162 8,432	55 83		-	-	1.19 /sf 3.15 /sf	3,217 8,515	2.73 /sf 7.22 /sf	19,50
		Curing, membrane spray	2,700.00 sf	7.2	422	111		1	-	0.20 /sf	532	0.45 /sf	1,21
		Cast-In-Place Concrete, Straight Walls, 12" thick	50.00 CY	981.0	69.157	13.756	3,539			1,729.03 /CY	86.452	3,959.56 /CY	197.97
		Concrete Wall @ Upper Floor	50.00 CY	981.0	69,157	13,756	3,539			1,729.03 /CY	86,452	3,959.56 /CY	197,97
		SOG @ Door	30.00 C1	301.0	09,137	13,730	3,333			1,729.03 /61	00,432	3,939.30 701	137,37
		Cast-In-Place Concrete, Slabs on Grade, 12" thick	00.00 -/		0.4					0.50 (-1		4.00 //	
		Fine grade, for slab on grade, by hand	63.00 sf 2.33 cy	0.6	34	2	36	-	-	0.58 /sf 15.37 /cy	36	1.32 /sf 35.20 /cy	8 8
		Concrete pumping, subcontract, all inclusive price Slab on grade edge forms, 7" to 12"	55.00 sf	13.2	987	56	30	1	-	18.97 /sf	1,043	43.43 /sf	2,38
		Reinforcing in place, A615 Gr 60, priced per lbs.	315.40 lb	10.2	-	162	129	-	-	0.92 /lb	291	2.11 /lb	66
		Concrete, ready mix, 4000 psi	2.33 CY		-	287	-		-	122.97 /CY	287	281.60 /CY	65
		Add for concrete waste, 4000 psi	0.12 cy		-	14		-	-	123.00 /cy	14	281.71 /cy	3
		Add amount for Fuel Surcharges - per concrete truck load	1.00 load			15		-		15.37 /load	15	35.20 /load	3
		Add amount for Environmental Fee - per concrete truck load	1.00 load		-	6		-	-	6.15 /load	6	14.08 /load	1
		Placing concrete, concrete pump	2.33 cy	2.3	137	-		-	-	58.55 /cy	137	134.08 /cy	31
		Finishing floors, monolithic, trowel finish (machine)	63.00 sf	1.7		1		-	-	1.86 /sf	117	4.27 /sf	26
		Curing, water	63.00 sf	0.3	16	3	405	-	-	0.31 /sf	20	0.71 /sf	4,586
		Cast-In-Place Concrete, Slabs on Grade, 12" thick	2.33 CY	18.1	1,290	547 547	165 165			859.49 /CY	2,003 2,003	1,968.27 /CY 1.968.27 /CY	4,586
		SOG @ Door	2.33 CY	18.1	1,290	547	165			859.49 /CY	2,003	1,968.27 /CY	4,580
		12" SOG											
		Cast-In-Place Concrete, Slabs on Grade, 12" thick											
		Fine grade, for slab on grade, by hand	115.00 sf	1.1	63	4	-	-	-	0.58 /sf	66	1.32 /sf	15 15
		Concrete pumping, subcontract, all inclusive price Slab on grade edge forms, 7" to 12"	4.26 cy 55.00 sf	13.2	987	56	65	-	-	15.37 /cy 18.97 /sf	1,043	35.20 /cy 43.43 /sf	2,38
		Reinforcing in place, A615 Gr 60, priced per lbs.	575.74 lb	13.2	967	295	236	1		0.92 /lb	531	2.11 /lb	2,30
		Concrete, ready mix, 4000 psi	4.26 CY			524	200			122.97 /CY	524	281.61 /CY	1,19
		Add for concrete waste, 4000 psi	0.21 cy		-	26		-	-	122.96 /cy	26	281.55 /cy	6
		Add amount for Fuel Surcharges - per concrete truck load	1.00 load		-	15	-	-	-	15.37 /load	15		3
		Add amount for Environmental Fee - per concrete truck load	1.00 load		-	6		-	-	6.15 /load	6	14.07 /load	1
		Placing concrete, concrete pump	4.26 cy	4.3	249			-	-	58.55 /cy	249		57
		Finishing floors, monolithic, trowel finish (machine)	115.00 sf	3.1	212	2		-	-	1.87 /sf	214		49
		Curing, water	115.00 sf	0.5	30	6			-	0.31 /sf	36	0.71 /sf	8
		Cast-In-Place Concrete, Slabs on Grade, 12" thick	4.26 CY	22.1	1,541	935	301			651.86 /CY	2,777	1,492.79 /CY	6,35
		12" SOG	4.26 CY	22.1	1,541	935	301			651.86 /CY	2,777	1,492.79 /CY	6,35
		03.10 Cast-In-Place Concrete Work	1.00 CY	2,062.7	144,972	37,629	8,083			190,683.70 /CY	190,684	436,674.22 /CY	436,67
		03.0 Concrete Work	1.00 LS	2,062.7	144,972	37,629	8,083			190,683.70 /LS	190,684	436,674.22 /LS	436,67
04.0		Masonry											
	04.00	Masonry											
		CMU WAII											
		Masonry Concrete Masonry Units, 8"											
		Scaffolding, rented, 2 stories	110.00 sf		-		94		-	0.85 /sf	94	1.95 /sf	21
		Grout block cores, solid, 8" thick	110.00 sf		-	-	271		-	2.46 /sf	271	5.63 /sf	62
		Masonry reinforcing per square foot	110.00 sf		-	-	169		-	1.54 /sf	169	3.52 /sf	38
_		Concrete block, back-up, reinforced, 8" thick	110.00 SF		-	-	750		-	6.82 /SF	750	15.61 /SF	1,71
		Waterproof sealer, masonry, 2 coats	220.00 sf 220.00 sf		-	-	225 225		-	1.03 /sf 1.03 /sf	225	2.35 /sf 2.35 /sf	51 51
		Paint exterior masonry walls, latex			-	-	1,734		-		225 1,734	2.35 /st 36.09 /SF	3,97
		Masonry Concrete Masonry Units, 8"	110.00 SF							15.76 /SF			
		CMU WAII	110.00 SF				1,734			15.76 /SF	1,734	36.09 /SF	3,97
		8" CMU WAII @ Stair											
		Masonry Concrete Masonry Units, 8"											
		Scaffolding, rented, 2 stories	480.00 sf		-	-	408	-	-	0.85 /sf	408	1.95 /sf	93
		Grout block cores, solid, 8" thick	480.00 sf		-	-	1,181		-	2.46 /sf	1,181	5.63 /sf	2,7
1	1	Masonry reinforcing per square foot Concrete block, back-up, reinforced, 8* thick	480.00 sf 480.00 SF	-		-	738 3,271		-	1.54 /sf 6.82 /SF	738 3,271	3.52 /sf 15.61 /SF	1,69 7,49



Project: East Street Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03/(10-4-2016)

ac Work	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Masonry Concrete Masonry Units, 8"											
		Waterproof sealer, masonry, 2 coats	960.00 sf		-	-	984	-	-	1.03 /sf	984	2.35 /sf	2,25
_		Paint exterior masonry walls, latex	960.00 sf		-	-	984		-	1.03 /sf	984	2.35 /sf	2,2
		Masonry Concrete Masonry Units, 8"	480.00 SF				7,565			15.76 /SF	7,565	36.09 /SF	17,3
		8" CMU WAII @ Stair	480.00 SF				7,565			15.76 /SF	7,565	36.09 /SF	17,32
		04.00 Masonry	590.00 SF				9,299			15.76 /SF	9,299	36.09 /SF	21,2
		04.0 Masonry	590.00 SF				9,299			15.76 /SF	9,299	36.09 /SF	21,2
05.0		Metals								ı			
	05.00	Metals											
		Railing											
		Metals, Handrailing, 3-Rail											
		Railing, pipe, aluminum, 3 rail, clear anodized	10.00 If	3.1	285	615	-	49	- 1	94.93 /lf	949	217.40 /lf	2,1
		Metals, Handrailing, 3-Rail	10.00 LF	3.1	285	615		49		94.93 /LF	949	217.40 /LF	2,1
		Railing	10.00 LF	3.1	285	615		49		94.93 /LF	949	217.40 /LF	2,1
		05.00 Metals	1.00 LS	3.1	285	615		49		949.31 /LS	949	2,173.98 /LS	2,1
	05.10	Structural Steel	1.00 L3	3.1	203	013		43		343.31 /L3	343	2,173.30 723	2,1
	05.10	Modifications to Existing Monorail Beam											
		•											
		Metals, Structural Steel											
		Allowance to modify the existing monorail beam and all structural related works	1.00 ea				15,371	-	-	15,371.33 /ea	15,371	35,201.00 /ea	35,2
		Metals, Structural Steel	1.00 TN				15,371			15,371.33 /TN	15,371	35,201.00 /TN	35,20
			1.00 LS								15,371		
		Modifications to Existing Monorail Beam	1.00 LS				15,371			15,371.33 /LS	15,371	35,201.00 /LS	35,20
		Miscellaneous Metals Allowance											
		Metals, Structural Steel											
		Misc. Metals Allowance	1.00 LS		0	0	5,124	-	-	5,123.77 /LS	5,124	11,733.68 /LS	11,7
		Metals, Structural Steel	1.00 TN				5,124			5,123.77 /TN	5,124	11,733.68 /TN	11,73
		Miscellaneous Metals Allowance	1.00 LS				5,124			5,123.77 /LS	5,124	11,733.68 /LS	11,73
		05.10 Structural Steel	1.00 LS				20,495			20,495.10 /LS	20,495	46,934.68 /LS	46,93
		05.0 Metals	1.00 LS	3.1	285	615	20,495	49		21,444.41 /LS	21,444	49,108.66 /LS	49,10
06.0		Wood, Plastics and Composites											
	06.00	Wood, Plastics and Composites											
		FRP Grating											
		Wood & Plastics, FRP Fabrications, Gratings											
		Grating fbgls, molded, orange (hi crsv env), 2" sq mesh, 2" thk	854.00 sf	56.9	5,157	21,879	_	_		31.66 /sf	27,035	72.50 /sf	61,91
		Wood & Plastics, FRP Fabrications, Gratings	854.00 SF	56.9	5,157	21,879				31.66 /SF	27,035	72.50 /SF	61,91
		FRP Grating	854.00 SF	56.9	5,157	21,879				31.66 /SF	27.035	72.50 /SF	61.91
_				56.9		,					,		- ,-
		06.00 Wood, Plastics and Composites	1.00 LS		5,157	21,879				27,035.32 /LS	27,035	61,912.11 /LS	61,91
		06.0 Wood, Plastics and Composites	1.00 LS	56.9	5,157	21,879				27,035.32 /LS	27,035	61,912.11 /LS	61,91
07.0		Thermal and Moisture Protection											
	07.50	Membrane Roofing											
		Roofing											
		Thermal & Moisture Protection, Built Up Roofing								ı			
		Roof deck insulation, perlite, 1-1/2" thick R4.17	4,857.00 sf	64.7	4,705	2,389		-	-	1.46 /sf	7,094	3.34 /sf	16,24
		Roof deck insulation, polyisocyanurate 2#/CF density, 2-1/2" thick R16	4,857.00 sf	51.8	3,765	5,027	-	-		1.81 /sf	8,792	4.15 /sf	20,1
		Built up roof, asphalt base sheet, 3-plies #15 felt, mopped w/ gravel	48.57 sq	164.7	11,812	4,106		2,784	-	385.05 /sq	18,702	881.79 /sq	42,8
	-	Coping, aluminum to .019", duranodic finish, 12" wall	265.00 lf	31.1	2,259	2,132	-	-	-	16.57 /lf	4,391	37.95 /lf	10,0
_	-	Roof hatches	1.00 ea	5.3	390	1,537		-	-	1,926.88 /ea	1,927	4,412.64 /ea	4,4
_	_	Skylight, allowance	8.00 ea		-	-	6,149	-	 	768.57 /ea	6,149	1,760.05 /ea	14,0 23,4
	-	Misc. Roofing Drain, roof, 6"	1.00 LS 5.00 ea	20.0	1,763	5,078	10,248		 	10,247.55 /LS 1,368.20 /ea	10,248 6,841	23,467.36 /LS 3,133.23 /ea	23,4
	_	Thermal & Moisture Protection, Built Up Roofing	4,857.00 SF	337.5	24.694	20,269	16,396	2,784	1	13.21 /SF	64,143	30.24 /SF	146,8
	_			337.5	24,694			2,784			64,143		146,8
	-	Roofing	1.00 LS		,	20,269	16,396	, ,		64,143.39 /LS	. , .	146,891.24 /LS	-,-
		07.50 Membrane Roofing	1.00 LS	337.5	24,694	20,269	16,396	2,784	\vdash	64,143.39 /LS	64,143	146,891.24 /LS	146,8
	-	07.0 Thermal and Moisture Protection	1.00 LS	337.5	24,694	20,269	16,396	2,784		64,143.39 /LS	64,143	146,891.24 /LS	146,8
08.0		Openings											
	08.00	Openings											
		Doors											
		Openings, Doors, Frames and Hardware											
		Coml st doors, 316 SST 3'-0" x 7'-0"	2.00 ea	2.5	191	2,121	-			1,156.25 /ea	2,313	2,647.86 /ea	5,:
		Door hardware, average - H.M., wood, or aluminum	30.00 set	159.9	11,835	10,760			-	753.16 /set	22,595	1,724.76 /set	51,
		Frames, steel, knock down, hollow metal, single, 16 ga., up to 5-3/4"	18.00 ea	24.0	1,829	2,859	-	-	-	260.43 /ea	4,688	596.40 /ea	10,
	1	deep, 7'-0" h x 3'-0" w											
			6.00 ea	9.1	697	1,156		1 -	1 -1	308.76 /ea	1,853	707.08 /ea	4,2
		Frames, steel, knock down, hollow metal, double, 16 ga., up to 4-7/8" deep, 7'-0" h x 6'-0" w	6.00 ea	3.1	057	1,100			1		,,,,,,		



Project: East Street Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03/(10-4-2016)

ac Work	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Openings, Doors, Frames and Hardware	28.00 EA	235.3	17,586	30,095				1,702.88 /EA	47,681	3,899.67 /EA	109,19
		Doors	28.00 EA	235.3	17,586	30,095				1,702.88 /EA	47,681	3,899.67 /EA	109,19
		Translucent Panels											
		Entrances, Storefronts and Curtain Walls											
		Translucent panels	112.00 sf	128.3 128.3	9,386 9,386	9,996 9,99 6		-		173.05 /sf	19,382	396.30 /sf	44,38 44.38
		Entrances, Storefronts and Curtain Walls	14.00 EA		-,,,,,,	-,				1,384.43 /EA	19,382	3,170.40 /EA	
		Translucent Panels 08.00 Openings	1.00 LS 1.00 LS	128.3 363.6	9,386 26,972	9,996 40.091				19,382.01 /LS 67,062.60 /LS	19,382 67.063	44,385.66 /LS 153,576.35 /LS	44,380 153,570
	08.30	Specialty Doors and Frames	1.00 LS	363.6	20,972	40,091				67,062.60 /LS	67,063	153,576.35 /LS	153,571
	00.30	Overhead Door											
		Specialty Doors and Frames, Sectional Overhead Doors											
		Doors, rolling service, steel, manual, fire, class A, 20 gauge, 20' x 10'	1.00 ea	26.6	2,415	4,663				7,078.00 /ea	7,078	16,208.94 /ea	16,20
		high, incl. hardware	1.00 00	20.0	2,110	1,000				7,070.00 700	7,070	10,200.01 700	10,20
		Doors, rolling service, steel, manual, motor operators for, to 14' x 14'	1.00 ea	4.3	386	1,204	-	-	-	1,590.54 /ea	1,591	3,642.41 /ea	3,64
		opening											
		Specialty Doors and Frames, Sectional Overhead Doors	1.00 EA	30.9	2,802	5,867				8,668.54 /EA	8,669	19,851.35 /EA	19,851
		Overhead Door	1.00 EA	30.9	2,802	5,867				8,668.54 /EA	8,669	19,851.35 /EA	19,85
	+	08.30 Specialty Doors and Frames	1.00 EA	30.9	2,802	5,867		-		8,668.54 /EA	8,669	19,851.35 /EA	19,85
	+	08.0 Openings	1.00 LS	394.5	29,774	45,957				75,731.14 /LS	75,731	173,427.70 /LS	173,42
09.0	00.15	Finishes						-					
	09.10	Finishes, Special Coatings											
		Special Coating											
		Finishes, Chemical Resistant Coatings Concrete Coating, Chemical Resistant, CRC-2	480.00 sf				9,838			20.50 /sf	9,838	46.93 /sf	22,529
		Finishes, Chemical Resistant Coatings	480.00 SF		-		9,838		-	20.50 /SF	9,838	46.93 /SF	22,529
		Finishes, Chemical Resistant Coatings Finishes, Special Coating	400.00 3F				9,030	1		20.30 /3F	9,030	40.93 /3F	
		Special Coatings, high build epoxy, 50 mil, max, pump room floors and walls	5,120.00 sf	574.4	35,853	52,467	-	-		17.25 /sf	88,320	39.50 /sf	202,25
		Special Coatings, high build epoxy, 50 mil, max, wetwell floor and walls	3,539.00 sf	397.0	24,782	36,266				17.25 /sf	61,048	39.50 /sf	139,80
		Special Coatings, high build epoxy, 50 mil, max, influent channel floor and walls	2,890.00 sf	324.2	20,237	29,615	-	-		17.25 /sf	49,853	39.50 /sf	114,16
		Finishes, Special Coating	11,549.00 SF	1,295.6	80,872	118,349				17.25 /SF	199,221	39.50 /SF	456,225
		Special Coating	9.139.00 SF	1,295.6	80.872	118,349	9.838			22.88 /SF	209.059	52.39 /SF	478.753
		09.10 Finishes, Special Coatings	1.00 LS	1,295.6	80,872	118,349	9,838			209,058.50 /LS	209,059	478,753.35 /LS	478,753
		09.0 Finishes	1.00 LS	1,295.6	80,872	118,349	9,838			209,058.50 /LS	209,059	478,753.35 /LS	478,75
10.0		Specialties											
	10.00	Specialties											
		Toilet Accessories											
		Specialties Toilet & Bath Accessories											
		Partitions, toilet, floor mounted, headrail braced, stainless steel	1.00 ea	3.6	271	1,204			-	1,475.05 /ea	1,475		3,37
		Urinal screens, ceiling or floor mounted, stainless steel	1.00 ea	3.3	247	461	-	-	-	707.66 /ea	708		1,62
		Toilet tissue dispenser, surface mounted, stainless, double roll	1.00 ea 1.00 ea	0.4	34 35	23	-	-	-	56.92 /ea 66.57 /ea	57 67		13i
		Toilet Accessories, grab bars, straight, stainless steel, 24" long Toilet Accessories, grab bars, straight, stainless steel, 36" long	1.00 ea	0.5	41	38				78.56 /ea	79		18
		Toilet Accessories, mirror, 48" x 24", with stainless steel 3/4" square	1.00 ea	1.1	81	156				237.06 /ea	237	542.88 /ea	54
		frame											
		Toilet Accessories, soap dispenser, stainless steel, recessed, liquid	1.00 ea	1.1	81	170	-	-	-	251.40 /ea	251	575.72 /ea	57
		Toilet Accessories, towel dispenser, stainless steel, surface mounted	1.00 ea	0.7	51	49 323	-	-	-	99.47 /ea	99		92 92
		Toilet Accessories, waste receptacle, stainless steel, w/top, 13 gallon Specialties Toilet & Bath Accessories	1.00 ea 9.00 EA	1.1	922	2,455		-	-	404.09 /ea 375.20 /EA	3,377	925.39 /ea 859.22 /EA	7,73
		Toilet Accessories	1.00 LS	12.2	922	2,455				3,376.78 /LS	3,377	7,732.97 /LS	7,73
		10.00 Specialties	1.00 LS	12.2	922	2,455				3,376.78 /LS	3,377	7,732.97 /LS	7,73
		10.00 Specialties 10.0 Specialties	1.00 LS	12.2	922	2,455				3,376.78 /LS	3,377	7,732.97 /LS	7,73
21.0		Fire Suppression	1.00 LO	12.2	322	2,433				0,010.10 /L0	3,377	1,102.01 /20	7,730
21.0	21.00	Fire Suppression											
	200	Sprinkler System											
	1	Mechanical, Fire Sprinklers System											
		Sprinkler System	3,180.00 SF	1,590.0			48,881		-	15.37 /SF	48,881	35.97 /SF	114,383
		Mechanical, Fire Sprinklers System	1.00 LS	1,590.0			48,881			48,880.82 /LS	48,881	114,383.30 /LS	114,38
		Sprinkler System	3,180.00 SF	1,590.0			48,881			15.37 /SF	48,881	35.97 /SF	114,38
		21.00 Fire Suppression	1.00 LS	1,590.0			48,881			48,880.82 /LS	48,881	114,383.30 /LS	114,38
		21.0 Fire Suppression	1.00 LS	1,590.0			48,881			48,880.82 /LS	48,881	114,383.30 /LS	114,38
22.0		Plumbing					,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,						
	22.00	Plumbing											
		Misc. Plumbing											
		Mechanical, Plumbing		1				1					



Project: East Street Pump Station

Project No.: 478874 Revision / Date: Rev03/(10-4-2016)

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Design Stage:	conceptual	Estimate Class:
---------------	------------	-----------------

Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Mechanical, Plumbing											
		Misc. Plumbing Allowance	1.00 LS		33,305		25,619	-	-	58,923.42 /LS	58,923	126,098.75 /LS	126,09
		Mechanical, Plumbing	1.00 LS		33,305		25,619			58,923.42 /LS	58,923	126,098.75 /LS	126,09
		Misc. Plumbing	1.00 LS		33,305		25,619			58,923.42 /LS	58,923	126,098.75 /LS	126,09
		Plumbing Fixtures											
		Mechanical, Plumbing											
		Urinals, wall hung, vitreous china, hanger & self-closing valve, siphon	1.00 ea	7.1		296	-	-	-	910.68 /ea	911	1,948.91 /ea	1,9
		Rough-in water supply, waste & vent for wall hung urinals	1.00 ea	7.5		538	-	-	-	1,189.47 /ea	1,189	2,545.51 /ea	2,5
		Water closet, tank type, vitreous china, floor mounted, close coupled, two piece, includes seat, supply pipe with stop	1.00 ea	4.0		236	-	-	-	583.48 /ea	583	1,248.68 /ea	1,2
		Water closet, tank type, vitreous china, floor mounted, rough-in, supply, waste and vent, one piece	1.00 ea	7.0	605	333	-	-	-	937.55 /ea	938	2,006.40 /ea	2,0
		Lavatory, vanity top, stainless steel, self-rimming, ledge, round, single bowl, 18-3/4*, includes trim	1.00 ea	3.3	288	820	-	-	-	1,107.82 /ea	1,108	2,370.80 /ea	2,3
		Lavatory, vanity top, rough-in, supply, waste and vent	1.00 ea	9.3		223	-	-	-	1,025.02 /ea	1,025	2,193.57 /ea	2,1
		Sink, service, stainless steel, self rimming, triple bowl, 22" x 43", includes	1.00 ea	4.8	419	1,153	-	-	-	1,571.82 /ea	1,572	3,363.77 /ea	3,3
		faucet and drain											
		Sink, service, rough-in, supply, waste and vent	1.00 ea	10.0		253	-	-	-	1,114.67 /ea	1,115	2,385.42 /ea	2,3
		Industrial safety fixture, eyewash station, stainless steel, pedestal	2.00 ea	10.7	922	570		-	-	745.80 /ea	1,492	1,596.06 /ea	3,1
_		mounted, unmounted, excludes rough-in	1.00 LS	63.7	5,510	4,422				9,932.11 /LS	9,932	21,255.18 /LS	21,2
		Mechanical, Plumbing											
	+	Plumbing Fixtures	1.00 LS	63.7		4,422				9,932.11 /LS	9,932	21,255.18 /LS	21,2
		22.00 Plumbing	1.00 LS	63.7	38,815	4,422	25,619			68,855.53 /LS	68,856	147,353.93 /LS	147,3
		22.0 Plumbing	1.00 LS	63.7	38,815	4,422	25,619			68,855.53 /LS	68,856	147,353.93 /LS	147,3
23.0		HVAC											
	23.00	HVAC											
		HVAC Control Components/DDC Systems,											
		Mechanical, HVAC											
		Control Components/DDC Systems,	1.00 ls		-	-	-	-	25,619	25,618.88 /ls	25,619	54,825.55 /ls	54,8
		Mechanical, HVAC	1.00 LS						25,619	25,618.88 /LS	25,619	54,825.55 /LS	54,8
		HVAC Control Components/DDC Systems,	1.00 LS						25,619	25,618.88 /LS	25,619	54,825.55 /LS	54,8
		Misc. HVAC											
		Mechanical, HVAC											
		Misc. HVAC Allowance	1.00 ls						25,619	25,618.88 /ls	25,619	54,825.56 /ls	54,8
		Mechanical, HVAC	1.00 LS				_		25,619	25,618.88 /LS	25,619	54,825.56 /LS	54,8
		Misc. HVAC	1.00 LS						25,619	25,618.88 /LS	25,619	54,825.56 /LS	54,8
	_	23.00 HVAC	1.00 LS						51,238	51,237.76 /LS	51,238	109,651.11 /LS	109,6
		23.00 HVAC 23.0 HVAC							51,238		51,238		
			1.00 LS						51,238	51,237.76 /LS	51,238	109,651.11 /LS	109,6
26.0		Electrical Work											
	26.10	Site Electrical											
		Site Electrical, Buried Conduit											
		Site Electrical, Buried Conduit											
		PVC Sch 40 in Trench 2"	200.00 lf	11.7	945	177	-	-	-	5.61 /lf	1,123	13.42 /lf	2,0
		PVC Sch 40 in Trench 3"	640.00 If	57.1		1,082		-	-	8.89 /lf	5,689	21.24 /lf	13,
		PVC Sch 40 in Trench 3"	100.00 lf	8.9		169	-	-	-	8.89 /lf	889	21.24 /lf	2,
		PVC Sch 40 90 deg Ell 2"	2.00 E	0.7 4.3		8	-		-	30.94 /E	62 444	73.95 /E	
		PVC Sch 40 90 deg Ell 3" PVC Sch 40 90 deg Ell 3"	8.00 E 2.00 E	4.3		100 25	-	-	-	55.51 /E 55.52 /E	111	132.68 /E 132.70 /E	1,
		PVC Coupling 2"	6.00 E	0.4		5			-	6.28 /E	38	15.01 /E	
		PVC Coupling 3"	30.00 E	2.4		73			- 1	8.88 /E	266		
		PVC Female Adaptor 2"	4.00 E	0.7		5				15.26 /E	61	36.48 /E	
		PVC Female Adaptor 3"	16.00 E	3.8		46	-	-	-	22.21 /E	355		
		PVC Female Adaptor 3"	4.00 E	1.0		11	-	-	-	22.21 /E	89		
		PVC Coated GRC in Trench 2"	20.00 lf	3.2		294	-	-	-	27.57 /lf	551	65.89 /lf	1,:
		PVC Coated GRC in Trench 3"	80.00 lf	18.0		2,244	-	-	-	46.21 /lf	3,697	110.44 /lf	8,
1	-	PVC Coated GRC in Trench 3"	20.00 lf	4.5		561	-	-	-	46.21 /lf	924	110.45 /lf	2,
+	+	PVC Coated GRC Elbow 36" Radius 2"	4.00 E	4.0		993	-	-	-	328.90 /E	1,316	786.09 /E	3,
		PVC Coated GRC Elbow 36" Radius 3"	20.00 E	32.0		8,877	-	-	-	572.77 /E	11,455	1,368.96 /E	27,
+	+	PVC Base Spacers < 2" Duct Bank Warning Tane	188.00 E	12.5 19.0		193 146	-	-	-	6.40 /E	1,202 1,677	15.29 /E	2 4
		Duct Bank Warning Tape PVC Solvent Cement - Qt	570.00 lf 0.80 E	0.0		146		·		2.94 /lf 6.25 /E	1,677	7.03 /lf 14.95 /E	4
+	1	PVC Solvent Cement - Qt	3.84 E	0.0		20		-		6.20 /E	24	14.81 /E	
		PVC Solvent Cement - Qt	0.60 E	0.0		3		-		6.17 /E	4	14.72 /E	
		Site Electrical, Buried Conduit	940.00 LF	185.3		15,037				31.90 /LF	29,982	76.23 /LF	71,
		Site Electrical, Duct Bank		100.0	,0-1-1	,							,
1		2500 psi Duct Bank Concrete	7.41 cy	6.4	517	797	-	-		177.44 /cy	1,314	424.08 /cy	3,
		2500 psi Duct Bank Concrete	15.88 cy	13.8		1,709			- 1	177.44 /cy	2,818	424.06 /cy	6,
1		2500 psi Duct Bank Concrete	2.48 cy	2.1		267			1	177.43 /cy	440	424.08 /cy	1,
		Add Color Die for Duct Bank Concrete	23.29 cy	2.1	1	430		-		18.45 /cy	430	44.08 /cy	1,
		Add Color Die for Duct Bank Concrete	2.48 cy			46				18.45 /cy	46		.,



Project: East Street Pump Station

Project No.: 478874 Revision / Date: Rev03/(10-4-2016)

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Design Stage: conceptual Estimate Class	.,		
	Design Stage:	conceptual	Estimate Class

Fac Work		Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Site Electrical, Duct Bank											
		Duct Bank Concrete Forming	1,140.00 sf	455.6	36,741	2,336			-	34.28 /sf	39,077	81.93 /sf	93,396
		Duct Bank Reinforcing Re-bar #4	2,280.00 lf	30.4	2,449	1,171			-	1.59 /lf	3,620	3.79 /lf	8,651
		Duct Bank Reinforcing Re-bar #4 (Ties)	1,265.80 If	42.2	3,400	676		-	-	3.22 /lf	4,075	7.70 /lf	9,740
		Site Electrical, Duct Bank	25.77 CY	550.4	44,389	7,431				2,010.85 /CY	51,820	4,806.03 /CY	123,851
		Site Electrical, Trenching											
		Electrical Trench Excavation - Soil Type C	245.37 cy	107.9	8,702	-		- 2,139	-	44.18 /cy	10,841	105.60 /cy	25,911
		Electrical Trench Bedding - Crushed Gravel	49.07 cy	32.7	2,637	1,509		475	-	94.16 /cy	4,621	225.06 /cy	11,044
		Electrical Trench Backfill - Reuse Trench Spoils Electrical Trench Spoils - Waste on Site	170.53 cy 74.85 cy	61.3 15.0	4,948 1,207	-		2,973		46.45 /cy 27.74 /cy	7,921 2,076	111.02 /cy 66.31 /cy	18,932 4,963
		Site Electrical, Trenching	245.37 CY	216.8	17.494	1.509		6,457		103.76 /CY	25.460	247.99 /CY	60,850
		Site Electrical, Frenching	243.37 61	210.0	17,434	1,303		0,437		103.70 701	25,400	247.99 701	00,030
		CU Bare Stranded #4/0	660.00 If	39.6	3,191	2.713				8.95 /lf	5.904	21.38 /lf	14,111
		Site Electrical, Grounding	660.00 LF	39.6	3,191	2,713			-	8.95 /LF	5,904	21.38 /LF	14,111
-		Site Electrical, Grounding Site Electrical, Buried Conduit	1.00 LS	992.2	80.018	26.690		6.457		113.164.95 /LS	113.165	270.469.30 /LS	270.469
			1.00 LS	992.2	80,018	26,690		6,457		113,164.95 /LS	113,165	270,469.30 /LS	270,469
		Electrical, Grounding											
		Site Electrical, Grounding								"			
		CU Bare Stranded #4/0 CU Bare Stranded #4/0	200.00 lf 70.00 lf	12.0	967 338	822 288		-	-	8.95 /lf 8.95 /lf	1,789 626	21.38 /lf 21.38 /lf	4,276 1,496
		CU Bare Stranded #4/0 CU Bare Stranded #4/0	75.00 lf	4.5	362	308			-	8.94 /lf	671	21.38 /lf	1,496
		Hand Trench and Backfill, includes labor for layout	195.00 lf	52.0	4,190	308				21.49 /lf	4,190	51.35 /lf	10,013
		Copperciad Ground Rod 3/4" x 10'	16.00 E	17.1	1,375	524				118.67 /E	1,899	283.63 /E	4,538
		Compression Lug - 4/0	4.00 E	2.7	215	42			-	64.13 /E	257	153.27 /E	613
		Compression Lug - 4/0	4.00 E	2.7	215	42			-	64.13 /E	257	153.27 /E	613
		Cadweld Cable to Rod - 250 Max	16.00 E	10.7	859	328			-	74.21 /E	1,187	177.36 /E	2,838
		Cadweld Cable to Cable - 250 Max	16.00 E	10.7	859	328		-	-	74.21 /E	1,187	177.36 /E	2,838
		Cadweld Cable to Steel - 250 Max	8.00 E	5.3	430	164		-	-	74.20 /E	594	177.35 /E	1,419
		Grounding Bolt and Nut Set	8.00 E	0.5	43	8		-	-	6.39 /E	51	15.27 /E	122
		Drill and Tap for Ground Connection	8.00 E 12.00 F	5.3 1.6	430 129	2 18		-	-	53.96 /E 12.28 /E	432 147	128.98 /E 29.36 /E	1,032 352
		Above Grade Ground Wire Supports Above Grade Ground Wire Supports	12.00 E	1.6	129	18			1	12.28 /E	147	29.35 /E	352
		Site Electrical, Grounding	345.00 LF	130.7	10,541	2.892				38.94 /LF	13,433	93.06 /LF	32,106
		Electrical, Grounding	345.00 LF	130.7	10,541	2,892				38.94 /LF	13,433	93.06 /LF	32,106
		26.10 Site Electrical	1.00 LS	1.122.9	90.559	29.583		6.457		126,598.16 /LS	126,598	302,575.27 /LS	302,575
-	20.45	Process Electrical	1.00 E3	1,122.3	30,333	23,303		0,437		120,390.10 723	120,330	302,373.27 723	302,373
	26.15												
		Electrical, Conduit and Wire/Cable - Power											
		Process Electrical, Wire/Cable								"			
		THHN-THWN Copper Stranded 1/C # 12 THHN-THWN Copper Stranded 1/C # 12	9,180.00 lf 3,060.00 lf	85.6 28.5	6,907 2,302	933		-	-	0.85 /lf 0.85 /lf	7,840 2,613	2.04 /lf 2.04 /lf	18,737 6,246
		THHN-THWN Copper Stranded 1/C # 12	170.00 lf	2.3	183	44				1.33 /lf	2,013	3.18 /lf	540
		THHN-THWN Copper Stranded 1/C # 6	255.00 lf	4.1	329	100				1.68 /lf	429	4.02 /lf	1,025
		THHN-THWN Copper Stranded 1/C # 2	510.00 If	12.2	986	461			-	2.84 /lf	1,447	6.78 /lf	3,459
		THHN-THWN Copper Stranded 1/C # 1/0	765.00 lf	22.4	1,808	1,064			-	3.76 /lf	2,872	8.97 /lf	6,865
		THHN-THWN Copper Stranded 1/C # 1/0	320.00 lf	9.4	756	445			-	3.76 /lf	1,202	8.97 /lf	2,872
		THHN-THWN Copper Stranded 1/C # 350	960.00 lf	51.2	4,125	4,400		-	-	8.88 /lf	8,526	21.23 /lf	20,377
		XHHW Copper Stranded 1/C # 6	240.00 lf	3.8	309	142		-	-	1.88 /lf	451	4.49 /lf	1,078
		XHHW Copper Stranded 1/C # 1/0 XHHW Copper Stranded 1/C # 1/0	2,000.00 lf 1,800.00 lf	58.6 52.8	4,727 4,254	4,395 3,955		-	-	4.56 /lf 4.56 /lf	9,122 8,210	10.90 /lf 10.90 /lf	21,802 19,622
		5 KV Non Shielded XLP / PVC - 1/C #350 Copper	11,400.00 lf	926.4	74,703	88,318				14.30 /lf	163,020	34.18 /lf	389,626
		Copper XLP 133% Insulated 15 KV #1/0 Copper	720.00 lf	46.0	3,712	4,155				10.93 /lf	7,868	26.12 /lf	18,805
		Stakon Lug #12 - #10	288.00 E	38.4	3,094	74			-	11.00 /E	3,168	26.29 /E	7,571
		Compression Lug - # 8	4.00 E	0.8	64	9			-	18.47 /E	74	44.14 /E	177
		Compression Lug - # 6	10.00 E	2.0	161	22			-	18.36 /E	184	43.87 /E	439
		Compression Lug - # 2	12.00 E	4.0	322	70		-	-	32.67 /E	392	78.09 /E	937
		Compression Lug - 1/0	58.00 E	27.0	2,181	377		-	-	44.11 /E	2,558	105.42 /E	6,114
		Compression Lug - 1/0	4.00 E 30.00 E	1.9 14.0	150			-	-	44.11 /E 44.11 /E	176	105.42 /E	422 3,163
		Compression Lug - 1/0 Compression Lug - 350 MCM	30.00 E	9.6	1,128 773	195				44.11 /E 79.03 /F	1,323	105.42 /E 188.88 /E	2,267
		Motor Hook-up, 3 phase, 10 hp	36.00 E	86.3	6,961	2,094			1	251.53 /E	9,055	601.16 /E	21,642
		Equipmenmt Hook-up, 3 phase, 80A	2.00 E	10.4	838	237				537.48 /E	1,075	1,284.59 /E	2,569
		Motor Hook-up, 3 phase, 90 hp	3.00 E	24.0	1,934	477				803.66 /E	2,411	1,920.78 /E	5,762
		Motor Testing & Commissioning: 10HP / 480V / #12	36.00 E	33.6	2,707	-			-	75.20 /E	2,707	179.73 /E	6,470
		Equipment Testing & Commissioning: 80A / 480V / #4	2.00 E	2.9	236	-		-	-	118.18 /E	236	282.45 /E	565
	-	Motor Testing & Commissioning: 90 HP / 480v / 1/0	3.00 E	13.2	1,064	-		-	-	354.52 /E	1,064	847.33 /E	2,542
	-	600V Megger Testing	209.00 E	69.6	5,613 43	-		-		26.86 /E	5,613	64.19 /E	13,416
	+	Wire Markers Wire Markers	40.00 E 4.00 E	0.5	43	2 0			-	1.13 /E 1.13 /E	45	2.69 /E 2.69 /E	108
		Wire Markers Wire Markers	306.00 E	4.1	329	16				1.13 /E 1.13 /E	344		823
	1	Wire Markers	18.00 E	0.2	19	1				1.13 /E	20	2.69 /E	48
		Wire Markers	4.00 E	0.1	4	0			1	1.13 /E	5	2.69 /E	11
		Wire Markers	12.00 E	0.2	13	1			-	1.12 /E	13	2.68 /E	32
		Wire Markers	4.00 E	0.1		0				1.13 /E	5		11



Project: East Street Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03/(10-4-2016)

Fac Wo		Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
			Process Electrical, Wire/Cable											
	_		Wire Markers	30.00 E	0.4		2	-	-	-	1.13 /E	34		81
	_		5 KV Compression Lug - # 350	210.00 E	251.8	20,304	2,834	-	-	-	110.18 /E	23,138		55,301
	_		15 KV Indoor Termination Kit - 1/C # 1/0 15 KV Outdoor Termination Kit - 1/C # 1/0	6.00 E 6.00 E	16.0 24.0	1,289 1,934	307 461	-	-	-	266.09 /E 399.14 /E	1,597 2,395	635.97 /E 953.96 /E	3,816 5,724
	_		15 KV Compression Lug - # 1/0	12.00 E	8.0	1,934	104		-	-	62.40 /E	749		1,790
			5 KV Motor Connect & Test - 800 HP	5.00 E	53.3	4,297	104			- :	859.42 /E	4,297	2,054.06 /E	10,270
			5 KV Motor Conn Insulating Boot - # 350	45.00 E	209.8	16,920	6,917				529.71 /E	23,837	1,266.03 /E	56,972
			5 KV Megger Testing	105.00 E	139.9	11,280	-	10,760	-	-	209.90 /E	22,040		52,676
			15 KV Hi-Pot Testing	6.00 E	16.0	1,289	-	615	-	-	317.33 /E	1,904	758.43 /E	4,551
			MV Cable Tags	222.00 E	29.6	2,385	227	-	-	-	11.77 /E	2,612	28.13 /E	6,244
			Process Electrical, Wire/Cable	31,380.00 LF	2,394.8	193,122	123,354	11,375			10.45 /LF	327,851	24.97 /LF	783,578
			Process Electrical, Conduit											
			GRC Conduit @ Level 2 3/4"	2,700.00 If	316.5	25,525	4,031		-	-	10.95 /lf	29,556	26.16 /lf	70,640
			GRC Conduit @ Level 2 1-1/4"	150.00 If	21.4	1,724	486	-	-	-	14.74 /lf	2,210	35.22 /lf	5,283
			GRC Conduit @ Level 2 1-1/2"	225.00 lf	35.7	2,876	860	-		-	16.61 /lf	3,736	39.69 /lf	8,930
	_		GRC Conduit @ Level 2 1-1/2"	100.00 lf	15.9	1,278	382	-	-	-	16.61 /lf	1,661	39.69 /lf	3,969
			GRC Conduit @ Level 2 3"	1,000.00 lf	333.1	26,857	10,296	-	-	-	37.15 /lf	37,154	88.80 /lf	88,799
	_		GRC Conduit @ Level 2 3"	160.00 lf	53.3	4,297	1,647				37.15 /lf	5,944		14,208
	-		GRC Conduit @ Level 2 3"	1,500.00 lf	499.6	40,286	15,444		-	-	37.15 /lf	55,731	88.80 /lf	133,199
	-		GRC Elbow 3/4"	108.00 E	36.0	2,901	956	-	-	-	35.71 /E	3,857	85.35 /E	9,218
	_		GRC Elbow 1-1/4" GRC Elbow 1-1/2"	6.00 E 9.00 E	2.8 4.8		112 208	_	_	-	56.23 /E 66.06 /E	337 595	134.39 /E 157.89 /E	806 1,421
	+		GRC Flbow 1-1/2"	6.00 E	3.2		139				66.05 /F	396		947
			GRC Elbow 1"1/2	111.00 E	110.9		9,558			-	166.68 /E	18,501	398.37 /E	44,219
	_		GRC Coupling 3/4"	108.00 E	7.2		275			-	7.92 /E	855		2,044
			GRC Coupling 1-1/4"	6.00 E	0.6						12.24 /E	73		176
			GRC Couplng 1-1/2"	9.00 E	1.0		54		-	-	14.55 /E	131		313
			GRC Coupling 1-1/2"	6.00 E	0.6		36		-	-	14.56 /E	87		209
			GRC Coupling 3"	60.00 E	8.8	709	1,514	-	-	-	37.06 /E	2,223	88.57 /E	5,314
			GRC Couplng 3"	6.00 E	0.9	71	151	-	-	-	37.06 /E	222	88.56 /E	531
			GRC Couplng 3"	45.00 E	6.6	532	1,136	-	-	-	37.06 /E	1,668	88.57 /E	3,986
			Rigid Conduit Hub 3/4"	144.00 E	59.5	4,796	1,908	-	-	-	46.55 /E	6,703	111.26 /E	16,021
			Rigid Conduit Hub 3/4"	6.00 E	2.5		79	-	-	-	46.55 /E	279		668
			Rigid Conduit Hub 1-1/4"	8.00 E	4.8		162	-	-	-	68.54 /E	548		1,311
	_		Rigid Conduit Hub 1-1/2"	12.00 E	7.4		265	-	-	-	71.47 /E	858		2,050
	_		Rigid Conduit Hub 1-1/2"	4.00 E	2.5		88	-	-	-	71.48 /E	286		683
	_		Rigid Conduit Hub 3"	80.00 E	91.7	7,391	4,107				143.73 /E	11,498		27,482
	_		Rigid Conduit Hub 3"	8.00 E	9.2		411			-	143.72 /E	1,150		2,748
			Rigid Conduit Hub 3"	60.00 E	68.7		3,081	-	-	-	143.73 /E	8,624		20,611
	_		Malleable LB Condulet - 3/4" Malleable LB Condulet - 1-1/4"	36.00 E 2.00 E	14.4		460	-	-	-	45.02 /E 72.76 /E	1,621	107.60 /E 173.90 /E	3,874 348
	_		Malleable LB Condulet - 1-1/2"	3.00 E	1.1					-	87.04 /F	261		624
			Malleable TB Condulet - 1-1/2"	2.00 E	1.3		94			-	100.47 /E	201		480
			EYS Seal Fitting 3"	15.00 E	30.0	2,417	1,590				267.11 /E	4,007		9,576
			Unistrut Straps 3/4"	360.00 E	14.4		681		-	-	5.12 /E	1,842		4,402
			Unistrut Straps 1-1/4"	20.00 E	1.1		48				6.72 /E	134		321
			Unistrut Straps 1-1/2"	30.00 E	1.6	129	89	-	-	-	7.27 /E	218	17.37 /E	521
			Unistrut Straps 1-1/2"	14.00 E	0.7	60	42			-	7.27 /E	102	17.37 /E	243
			Unistrut Straps 3"	160.00 E	10.7		623	-	-	-	9.26 /E	1,482	22.14 /E	3,542
			Unistrut Straps 3"	195.00 E	13.0		759	-	-	-	9.26 /E	1,806		4,317
			Unistrut Conduit Hanger Allowance 3/4"	360.00 E	19.2		369	-	-	-	5.32 /E	1,916		4,579
			Unistrut Conduit Hanger Allowance 1-1/4"	20.00 E	1.6		26	-	-	-	7.73 /E	155	18.47 /E	369
	_		Unistrut Conduit Hanger Allowance 1-1/2"	44.00 E	3.5		68	-	-	-	7.98 /E	351	19.08 /E	839
	-		Unistrut Conduit Hanger Allowance 3"	355.00 E	47.3	3,814	728	-	-	-	12.79 /E	4,541	30.57 /E	10,854
	-		EF Sealtite Flex 3/4"	36.00 lf	1.4			-	-	-	5.75 /lf 9.54 /lf	207		495
	-		EF Sealtite Flex 1-1/4" EF Sealtite Flex 1-1/2"	2.00 lf 3.00 lf	0.1		10	-	-	-	9.54 /lf 11.48 /lf	19		46
	+						18	-	-	-				82 55
	_		EF Sealtite Flex 1-1/2" EF Sealtite Flex 3"	2.00 lf 20.00 lf	0.1 2.4			_	-	-	11.46 /lf 27.60 /lf	23 552		1,319
	-		EF Sealtite Flex 3"	20.00 If	0.2		36		1		27.60 /li 27.61 /lf	55	65.98 /lf	1,319
	-		EF Sealtite Flex 3"	15.00 lf	1.8				-	- 1	27.60 /lf	414		989
			LT Flex Connector Straight 3/4"	72.00 E	8.6		372			-	14.83 /E	1,068		2,552
			LT Flex Connector Straight 1-1/4"	4.00 E	0.6		52				25.91 /E	104		248
			LT Flex Connector Straight 1-1/2"	10.00 E	1.9		184	-	-	-	33.41 /E	334		799
			LT Flex Connector Straight 3"	74.00 E	21.7		13,213		-	-	202.19 /E	14,962		35,759
			Conduit Wall Penetration - 1-1/2"	2.00 E	0.7	54	5			-	29.42 /E	59	70.30 /E	141
			Conduit Wall Penetration - 3"	20.00 E	8.0		102	-	-	-	37.35 /E	747		1,785
			Conduit Wall Penetration - 3"	2.00 E	0.8		10	-	-	-	37.34 /E	75		178
			Conduit Wall Penetration - 3"	15.00 E	6.0			-	-	-	37.35 /E	560		1,339
			Fireproof Conduit Wall Penetration - 1-1/2"	2.00 E	1.3		20	-	-	-	63.55 /E	127		304
			Fireproof Conduit Wall Penetration - 3"	20.00 E	16.0		300	-	-	-	79.47 /E	1,589		3,799
	_		Fireproof Conduit Wall Penetration - 3"	2.00 E	1.6		30	-	-	-	79.48 /E	159		380
			Fireproof Conduit Wall Penetration - 3"	15.00 E	12.0	967	225	-	-	-	79.47 /E	1,192	189.93 /E	2,8



Project: East Street Pump Station

Project No.: 478874 Revision / Date: Rev03/(10-4-2016)

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Design Stage: conceptual Estimate Class: 4

Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Process Electrical, Conduit											
		Conduit Floor Penetration - 3"	15.00 E	6.0		77		-	-	37.35 /E	560	89.28 /E	1,3
		Fireproof Conduit Floor Penetration - 3"	15.00 E	6.0	483	128	-	-	-	40.79 /E	612		1,4
		Process Electrical, Conduit	5,835.00 LF	1,963.8	158,364	78,756				40.64 /LF	237,120		566,7
		Electrical, Conduit and Wire/Cable - Power	1.00 LS	4,358.7	351,486	202,110	11,375			564,970.84 /LS	564,971	1,350,305.63 /LS	1,350,3
		Electrical, Conduit and Wire/Cable - Controls											
		Process Electrical, Wire/Cable											
		THHN-THWN Copper Stranded 1/C # 14	5,100.00 If	40.7	3,286	338		-	-	0.71 /lf	3,624	1.70 /lf	8,6
		THHN-THWN Copper Stranded 1/C # 14	1,275.00 If	10.2	822	84	-	-	-	0.71 /lf	906	1.70 /lf	2,1
		THHN-THWN Copper Stranded 1/C # 14	377,740.00 If	3,018.1	243,386	25,021		-	-	0.71 /lf	268,407	1.70 /lf	641,
		THHN-THWN Copper Stranded 1/C # 14	1,360.00 If	10.9	876	90	-	-	-	0.71 /lf	966	1.70 /lf	2,
		Shielded PLTC / Inst Cable 1 Pair #16	595.00 lf	15.9		274	-	-	-	2.61 /lf	1,553		3,
		Unshielded Twisted Pair Cable, 4-Pair CAT 6 350Mhz Ultra II	765.00 lf	17.8	1,438	306	-	-	-	2.28 /lf	1,744		4,
		UTP Cable Connector, RJ45 CAT 6 Mini-Jack TX-5e (568A/B)	18.00 E	6.0		80			-	31.32 /E	564		1,
		UTP Patch Cord, RJ45/RJ45 CAT 6E 350Mhz Data-Patch - 5ft	9.00 E	0.7		49		-	-	11.93 /E	107		:
		UTP Wall Plate, 4-Port, CAT 6 350Mhz, RJ45/110 (568B), White 4 Pair UTP Continuity Test	9.00 E 9.00 E	3.0		18		-	-	28.80 /E 26.85 /E	259 242		
		4 Pair UTP Certification with Documentation	9.00 E	7.6					-	20.05 /E 67.67 /F	609		1,
_		UTP Cable Supports	54.00 E	3.6		28				5.88 /E	318		1,*
		Termination Labor Only - # 16 - #14	1,185.00 E	157.9	12,730	- 20				10.74 /E	12,730	25.68 /E	30,
		Control Wire Testing	589.00 E	78.5	6,328	-		-		10.74 /E	6,328	25.68 /E	15,
		Wire Markers	1,185.00 E	15.8		61				1.13 /E	1,334		3,
		Process Electrical, Wire/Cable	386,835.00 LF	3,389.6	273,341	26,349				0.78 /LF	299,690	1.85 /LF	716,2
		Process Electrical, Conduit	,	0,000.0	2.0,041	20,040				00 /21	200,000		
		GRC Conduit @ Level 2 3/4"	4,425.00 lf	518.7	41,832	6,607		-		10.95 /lf	48,439	26.16 /lf	115,7
		GRC Conduit @ Level 2 3/4"	1,200.00 lf	140.7	11,344	1,792				10.95 /lf	13,136	26.16 /lf	31,
		GRC Elbow 3/4"	45.00 E	15.0		398		-		35.71 /E	1,607	85.35 /E	3,
		GRC Elbow 3/4"	132.00 E	44.0		1,169		-	-	35.71 /E	4,714		11,3
		GRC Elbow 3/4"	21.00 E	7.0		186		-	-	35.71 /E	750		1,7
		GRC Elbow 3/4"	27.00 E	9.0		239		-	-	35.71 /E	964		2,3
		GRC Couplng 3/4"	225.00 E	15.0		573		-	-	7.92 /E	1,782		4,2
		Rigid Conduit Hub 3/4"	30.00 E	12.4		397	-	-	-	46.55 /E	1,396	111.25 /E	3,3
		Rigid Conduit Hub 3/4"	88.00 E	36.3		1,166		-	-	46.55 /E	4,096	111.26 /E	9,7
		Rigid Conduit Hub 3/4"	14.00 E	5.8		185	-	-	-	46.55 /E	652	111.26 /E	1,5
		Rigid Conduit Hub 3/4"	18.00 E	7.4		238	-	-	-	46.55 /E	838		2,0
		Malleable LB Condulet - 3/4"	75.00 E	30.0		959 284				45.02 /E	3,376	107.60 /E	8,0
_		Unistrut Straps 3/4" Unistrut Straps 3/4"	150.00 E 440.00 E	6.0 17.6		833	-	-		5.12 /E 5.12 /E	2,251	12.23 /E 12.23 /E	1,8 5,3
		Unistrut Straps 3/4" Unistrut Straps 3/4"	70.00 E	2.8		132			-	5.12 /E 5.12 /E	358		5,.
		Unistrut Straps 3/4"	90.00 E	3.6		170				5.12 /E	460		1,
		Unistrut Conduit Hanger Allowance 3/4"	750.00 E	40.0		769				5.32 /E	3,992		9,
		EF Sealtite Flex 3/4"	15.00 lf	0.6		38				5.75 /lf	86		
		EF Sealtite Flex 3/4"	44.00 If	1.8		111				5.76 /lf	253		
		EF Sealtite Flex 3/4"	16.00 If	0.6	52	41	-	-	-	5.76 /lf	92		2
		LT Flex Connector Straight 3/4"	30.00 E	3.6	290	155		-	-	14.83 /E	445	35.45 /E	1,0
		LT Flex Connector Straight 3/4"	88.00 E	10.6	851	454	-	-	-	14.83 /E	1,305	35.45 /E	3,1
		LT Flex Connector Straight 3/4"	14.00 E	1.7		72	-	-	-	14.83 /E	208	35.45 /E	4
		LT Flex Connector Straight 3/4"	18.00 E	2.2		93				14.83 /E	267		6
		Process Electrical, Conduit	5,625.00 LF	932.2	75,173	17,062				16.40 /LF	92,235	39.19 /LF	220,4
		Electrical, Conduit and Wire/Cable - Controls	1.00 LS	4,321.8	348,514	43,411				391,924.48 /LS	391,924	936,717.10 /LS	936,7
		Electrical, Grounding											
		Process Electrical, Grounding											
		Miscellaneous Grounding	1.00 ls	79.9	6,446	2,562		-	-	9,007.61 /ls	9,008	21,528.58 /ls	21,5
		Process Electrical, Grounding	1.00 LF	79.9	6,446	2,562				9,007.61 /LF	9,008	21,528.58 /LF	21,5
		Electrical, Grounding	1.00 LF	79.9		2,562				9,007.61 /LF	9.008		21,5
		26.15 Process Electrical	1.00 LS	8,760.4	706,446	248,082	11,375			965,902.93 /LS	965,903	2,308,551.31 /LS	2,308,5
	00.00		1.00 LS	0,700.4	700,440	240,002	11,373			905,902.95 /L5	900,903	2,300,551.51 /L5	2,300,0
_	26.20	Facility Electrical											
_		Facility Electrical, Complete \$/SF Cost											
		Facility Electrical, Complete \$/SF Cost						-					
_		PS Building, Electrical Subcontract, Division 16	9,488.00 sf		-	-	540,884	-	-	57.01 /sf	540,884	136.25 /sf	1,292,
		Facility Electrical, Complete \$/SF Cost	9,488.00 SF				540,884			57.01 /SF	540,884	136.25 /SF	1,292,7
		Facility Electrical, Complete \$/SF Cost	1.00 LS				540,884			540,883.67 /LS	540,884	1,292,736.21 /LS	1,292,7
		26.20 Facility Electrical	1.00 LS				540,884			540,883.67 /LS	540,884	1,292,736.21 /LS	1,292,7
	26.25	Electrical Equipment											
		Electrical Equipment											
		Electrical, Testing											
_		Megger/Check Elec Equipment	1.00 LS	166.5	13,429					13,428.58 /LS	13,429	32,094.93 /LS	32.
+		Electrical, Testing	1.00 LS	166.5	13,429	-				13,428.58 /LS	13,429	32,094.93 /LS	32,0
		Liconical, resulty	1.00 LS	100.5	13,429				1	13,428.38 /LS	13,429	32,094.93 /LS	32,0
		Electrical Equipment, MCCs - General			1								



Project: East Street Pump Station

Project No.: 478874 Revision / Date: Rev03/(10-4-2016)

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Design Stage:	conceptual	Estimate Class: 4

Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Tot w/Markup
		Electrical Equipment, MCCs - General											
		MCC Main Breaker - 600A	1.00 E	6.7		6,328			-	6,865.01 /E	6,865	16,407.70 /E	1
		MCC FVNR Starter w/ Circuit Breaker - Size 1	9.00 E	9.6	774	3,062				426.17 /E	3,835	1,018.55 /E	
		MCC Circuit Breaker - <30A	29.00 E	9.7	779	6,700	-		-	257.89 /E	7,479	616.36 /E	1
		MCC Circuit Breaker - 80A	2.00 E	2.0	161	507	-		-	334.19 /E	668	798.74 /E	
		MCC Circuit Breaker - 150A	3.00 E	5.0	403	1.494				632.32 /E	1.897	1,511.27 /E	
		Switchboard instruments, ground fault protection, ground return path	1.00 ea	3.9		6,917				7,235.39 /ea	7,235	17,292.92 /ea	1
		Voltage monitor systems, AC voltage remote, add-on det only, w/internal modem	1.00 ea		-	4,099	-	-	-	4,099.02 /ea	4,099		
		Transformer, dry-type, ventilated, 3 phase 480 V primary 120/208 V secondary, 30 kVA	1.00 ea	2.4		1,512	-	-	-	1,702.48 /ea	1,702	·	
		Panelboards, 3 phase 4 wire, main lugs, 120/208 V, 100 amp, 30 circuits, NQOD, incl 20 A 1 pole plug-in breakers	1.00 ea	2.0		1,153	-	-	-	1,315.02 /ea	1,315	·	
		Electrical Equipment, MCCs - General Electrical Equipment, Switchgear - 5 KV	1.00 LS	105.2	8,481	45,606				54,087.25 /LS	54,087	129,270.95 /LS	12
		Low Volt Swgr Section NEMA 1 1200A	7.00 E	139.9	11,280	35,866				6,735.20 /E	47,146	16,097.43 /E	1
		Low Volt Swgr Section NEMA 1 1200A	4.00 E	79.9	6,446	20,495				6,735.21 /E	26,941	16,097.45 /E	
		Low Volt Swgr Section NEMA 1 1200A	2.00 E	40.0		10,248				6,735.19 /E	13,470	16,097.39 /E	
		Low Volt Swgr Main Breaker 1200A	3.00 E	8.0		153,713				51,452.61 /E	154,358	122,974.06 /E	3
		Low Volt Swgr Main Breaker 1200A	1.00 E	2.7		51,238			-	51,452.60 /E	51,453	122,974.00 /E	1
		Low Volt Swgr Main Breaker 1200A Low Volt Swgr Main Breaker 1200A	1.00 E	2.7		51,238		<u> </u>	-	51,452.50 /E 51,452.59 /E	51,453	122,974.00 /E 122,974.02 /E	
	+	Low Volt Swgr Nain Breaker 1200A Low Volt Swgr Tie Breaker 1200A	1.00 E	2.7		51,238		<u> </u>	-	51,452.59 /E 51,452.59 /E	51,453	122,974.02 /E 122,973.99 /E	
	+	Low Volt Swgr Netering	1.00 E	2.7		51,238	· ·	<u> </u>	-	51,452.59 /E 214.83 /E	51,453		
	1		1.00 E			51,238	· ·		-	214.83 /E 51,345.16 /E	51,345		
	1	Low Volt Swar Food Breaker 12004	1.00 E	1.3		51,238 51,238		· ·	-				
	1	Low Volt Swgr Feed Breaker 1200A						 	-	51,452.59 /E	51,453		
		Low Volt Swgr Feed Breaker 1200A	6.00 E	16.0		307,427			-	51,452.61 /E	308,716		
		Low Volt Swgr Metering	1.00 E	2.7		51,238			-	51,452.59 /E	51,453		
		Low Voltage Switchgear Breaker Calibration	13.00 E	17.3		666	-	-	-	158.67 /E	2,063	379.24 /E	
		Low Voltage Switchgear Breaker Calibration	2.00 E	2.7		102			-	158.65 /E	317	379.18 /E	
		Switchboard instruments, ground fault protection, ground return path Voltage monitor systems, AC voltage remote, add-on det only, w/internal	1.00 ea 1.00 ea	3.9	318	6,917 4,099	-	-	-	7,235.39 /ea 4,099.02 /ea	7,235 4,099	17,292.92 /ea 9,796.81 /ea	
		modem Electrical Equipment, Switchgear - 5 KV	46.00 EA	325.0	26,208	846,960				18,981.92 /EA	873,169	45,367.65 /EA	2,0
		Electrical Equipment, Switches - General Safety switches, heavy duty, 3 pole, nonfusible, 600 volt, 30 amp, NEMA	34.00 ea	116.9	9,571	5,575	-	-	-	445.45 /ea	15,145	1,064.65 /ea	
		3R Electrical Equipment, Switches - General	1.00 LS	116.9	9,571	5,575				15,145.39 /LS	15,145	36,198.19 /LS	
		Electrical Equipment, VFDs - General Variable frequency drives, enclosed, 460 volt, 90 HP motor size, NEMA	3.00 ea	159.9	13,063	47,959	-	1,174	-	20,731.80 /ea	62,195	49,549.92 /ea	
		1, FBO Variable frequency drives, enclosed, 480 volt, 500 HP motor size, NEMA	5.00 ea	475.8	38,879	1,025	-	2,329	-	8,446.41 /ea	42,232	20,187.29 /ea	
		1, FBO Electrical Equipment, VFDs - General	1.00 LS	635.6	51,942	48,983		3,502		104,427.43 /LS	104,427	249,586.22 /LS	2
		Electrical Equipment, Transformers - General											
		Transformer, liquid-filled, 5 kV primary, 480 V secondary, 3 phase, 500 kVA, pad mounted	1.00 ea	66.6	5,443	21,315	-	489	-	27,246.93 /ea	27,247	65,121.38 /ea	
		Electrical Equipment, Transformers - General	1.00 LS	66.6	5,443	21,315		489		27,246.93 /LS	27,247	65,121.38 /LS	
		Electrical Equipment, Generators - General											
		Generator set, diesel, 1.0 kva, incl battery, charger, enclosure, muffler, day tank, excl conduit, wiring, & concrete	2.00 ea	619.5	49,355	368,912	-	3,314	-	210,790.59 /ea	421,581	503,798.97 /ea	1,
		Electrical Equipment, Generators - General	1.00 LS	619.5	49,355	368,912		3,314		421,581.18 /LS	421,581	1,007,597.95 /LS	1,0
		Electrical Equipment	1.00 LS	2,035.3	164,429	1,337,351		7,305		1,509,085.29 /LS	1,509,085	3,606,781.55 /LS	3,6
	1		1.00 LS	2,035.3				7,305					
	1	26.25 Electrical Equipment				1,337,351				1,509,085.29 /LS	1,509,085	3,606,781.55 /LS	3,
	-	26.0 Electrical Work	1.00 LS	11,918.6	961,434	1,615,016	552,258	13,762		3,142,470.05 /LS	3,142,470	7,510,644.34 /LS	7,
32.0		Exterior Improvements		1									
	32.50	Site, Improvements											
		Site Improvements, Pipe Bollards											
		Site Improvements, Bollards											
		Security vehicle barriers, pipe bollards, steel, concrete filled/painted, 8' L	21.00 ea	67.1	4,346	17,646		1,096		1,099.44 /ea	23,088	2,462.78 /ea	
		x 4' D hole, 8" diam.	21.00 ea	67.1	4,346	17,646	_	1,096	-	1,099.44 /0a	23,088	2,402.70 /ea	
		Site Improvements, Bollards	21.00 EA	67.1	4,346	17,646		1,096		1,099.44 /EA	23,088	2,462.78 /EA	
	+												
	-	Site Improvements, Pipe Bollards	1.00 LS	67.1		17,646		1,096		23,088.14 /LS	23,088	51,718.47 /LS	
		32.50 Site, Improvements	1.00 LS	67.1	4,346	17,646		1,096		23,088.14 /LS	23,088	51,718.47 /LS	
		32.0 Exterior Improvements	1.00 LS	67.1	4,346	17,646		1,096		23,088.14 /LS	23,088	51,718.47 /LS	
40.0		Process Pipe											
	40.00	Exposed Process Pipe											
	40.00			-	-			-			-		
		24" DI Pipe											
		Process Pipe, Ductile Iron, 24"											
		Dresser Coupling, 12"	10.00 ea	33.6	2,858	4,509	-	2,098	-	946.51 /ea	9,465	2,195.95 /ea	
		Dresser Coupling, 14"	1.00 ea	4.5		564		279		1,224.19 /ea	1,224		



Project: East Street Pump Station

Project No.: 478874 Revision / Date: Rev03/(10-4-2016)

Design Stage: conceptual

Estimate Class: 4

Estimator:

E.B. Smith/GNV, A. Frisch/PGH

	rade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Process Pipe, Ductile Iron, 24"											
		Dresser Coupling, 24"	5.00 ea	28.4	2,416	5,073	-	1,773	-	1,852.38 /ea	9,262		21,488
		10" DI, FL, EII, 90	5.00 ea	32.1	2,811	1,825		-	-	927.18 /ea	4,636		10,75
		Install 24" DI, flanged, spool <= 10'	20.00 ea	319.2	27,943	11,324	-	-	-	1,397.13 /ea 2,264.71 /ea	27,943 11,324		64,82
		24" Fabricated DI Spool, FxF, 2' 6" - FURNISH 24" Fabricated DI Spool, FxF, 4' 6" - FURNISH	5.00 ea 5.00 ea		-	11,324		-	-	2,264.71 /ea 2,835.50 /ea	11,324		26,27 32,89
		24" Fabricated DI Spool, FxF, 5' 0" - FURNISH	5.00 ea	-	-	14,177				2,976.91 /ea	14,177		32,69
		24" Fabricated DI Spool, FxF, 5' 6" - FURNISH	5.00 ea			15,592				3.118.33 /ea	15,592		36,17
		24" DI, FL, EII, 90	4.00 ea	63.8	5,589	8,408				3,499.00 /ea	13,996		32,47
		24" DI, FL, EII, 45	5.00 ea	79.8	6,986	7,440			-	2,885.23 /ea	14,426		33,46
		24" DI, FL, reducer, 24" x 12"	5.00 ea	79.8	6,986	6,510		-	-	2,699.15 /ea	13,496		31,31
		24" DI, FL, reducer, 24" x 14"	5.00 ea	79.8	6,986	6,646		-	-	2,726.27 /ea	13,631	6,325.08 /ea	31,62
		Pipe support	15.00 ea	79.9	6,997	17,477	-	-	-	1,631.63 /ea	24,474	3,785.46 /ea	56,78
		FURNISH Gate valve, iron body, solid wedge, Flgd, 250#, HWO, 24"	10.00 ea		-	317,039	-	-	-	31,703.88 /ea	317,039	73,554.42 /ea	735,54
		Process Pipe, Ductile Iron, 24"	87.50 LF	800.9	69,951	431,467		4,151		5,777.94 /LF	505,570	13,405.07 /LF	1,172,94
		24" DI Pipe	87.50 LF	800.9	69,951	431,467		4,151		5,777.94 /LF	505,570	13,405.07 /LF	1,172,94
		Valves				· ·						·	
		Process Pipe, Ductile Iron, 12"											
		Install gate valve, Flgd, DIP, 12"	5.00 ea	40.0	3,403			2.497		1.180.07 /ea	5,900	2,737.81 /ea	13,68
		Install gate valve, Figd, DIP, 12 Install gate valve, Figd, DIP, 24"	10.00 ea	165.2	14,065			10,323	1	2,438.78 /ea	24,388		56,58
		Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 12"	5.00 ea	100.2	14,005	6,343		10,323	1	1,268.65 /ea	6,343		14,71
		Install check valve, Flgd, DIP, 12"	5.00 ea	40.0	3,403	3,343		2,497		1,180.07 /ea	5,900		13,68
		Check valve, iron body, swing check, Flgd, 250#, 12"	5.00 ea	.0.0	0,.00	14,710		2,457		2,942.07 /ea	14,710		34,12
		Install magnetic flow meter, (material FBO), 24"	5.00 ea	82.6	7,231		-	4,130	-	2,272.06 /ea	11,360		26,356
		Cl Valve Box & Cover, w/ Concrete Collar included	5.00 ea	20.0	1,701	769	-	1,249	-	743.75 /ea	3,719		8,628
		Flow Meters 24"	5.00 ea	0.0		122,971	-	-	-	24,594.12 /ea	122,971	57,059.47 /ea	285,297
		Flow Meter: Electrical Hookup Only, 24"	5.00 ea	83.3	6,714				-	1,342.85 /ea	6,714	3,115.47 /ea	15,577
		Process Pipe, Ductile Iron, 12"	1.00 LF	431.0	36,517	144,793		20,696		202,005.98 /LF	202,006	468,662.91 /LF	468,663
		Valves	1.00 LS	431.0	36,517	144,793		20,696		202,005.98 /LS	202,006	468,662.91 /LS	468,663
		40.00 Exposed Process Pipe	87.50 LF	1,231.8	106,469	576,260		24,847		8,086.58 /LF	707,576		1,641,607
		40.0 Process Pipe	87.50 LF	1,231.8	106,469	576,260		24,847		8,086.58 /LF	707,576		1,641,607
40.0		· · · · · · · · · · · · · · · · · · ·	07.50 LF	1,231.0	100,409	570,200		24,041		6,066.36 /LF	101,576	10,701.22 /LF	1,041,007
40.9		Instrumentation & Controls											
40	_	Instrumentation & Controls											
		Instrumentation & Controls											
		I&C, Flow / Mag Meter / Indicators & Transmitters											
		FE - Flow Element - Mag Flowtube (inline)	4.00 ea	10.7	859	205	-		-	266.09 /ea	1,064	635.97 /ea	2,544
		FT / FIT - Flow Transmitter - Magnetic,	4.00 ea	66.6	5,371	73,782	-	-	-	19,788.45 /ea	79,154	47,295.29 /ea	189,18
		I&C, Flow / Mag Meter / Indicators & Transmitters	4.00 EA	77.3	6,231	73,987				20,054.54 /EA	80,218	47,931.26 /EA	191,725
		I&C, Level / Indicators & Transmitters											
		LE - Level Element / Sensor	2.00 ea	0.7	54	102	-	-	-	78.09 /ea	156	186.65 /ea	373
		LT / LIT - Level Transmitter	2.00 ea	6.0	483	2,613			-	1,548.28 /ea	3,097	3,700.45 /ea	7,401
		I&C, Level / Indicators & Transmitters	2.00 EA	6.7	537	2,716				1,626.37 /EA	3,253	3,887.10 /EA	7,774
		I&C, Pressure / Indicators & Transmitters											
		PI - Pressure Indicator - Stem Mounted	8.00 ea	5.3	430	2,664			-	386.76 /ea	3,094	924.38 /ea	7,395
		PE - Diaphragm Seal	8.00 ea	16.0	1,289	3,484			-	596.67 /ea	4,773		11,408
		I&C, Pressure / Indicators & Transmitters	8.00 EA	21.3	1,719	6,149				983.43 /EA	7,867		18,804
	-	I&C, Other / Switches				,,					-	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	-,
		Control Stations	44.00 E	58.6	4,727	4,380		1 .		206.97 /E	9,107	494.68 /E	21,766
		I&C. Other / Switches	1.00 EA	58.6	4,727	4,380		· ·	1	9.106.82 /EA	9,107		21,76
		,	1.00 EA	30.0	4,121	4,300		<u> </u>		3,100.02 /EA	9,107	21,703.71 /EA	21,70
		I&C, Panels & Stands	0.00		0					405 FO /-	4	110.10	
		Instrument Stand-Single, Galv.	6.00 ea	10.0	806	307	-	1	-	185.52 /ea	1,113		2,660
		Instrument Stand-Single, Galv. Instrument Stand-Single, Galv.	2.00 ea 44.00 ea	3.3 73.3	269 5,909	102 2,254	-		-	185.51 /ea 185.52 /ea	371 8.163	443.37 /ea 443.41 /ea	88 19,51
		I&C. Panels & Stands	52.00 EA	86.6	6.983	2,254		·	<u> </u>	185.52 /EA	9,647		23,057
	_		32.00 EA	86.6	0,983	∠,064		1		180.02 /EA	9,647	443.41 /EA	23,05
		I&C, PLC, Control Panels, Network Hardware											
		Network Hardware	1.00 ls	10.7	859	5,124		-	-	5,983.17 /ls	5,983		14,300
		Ethernet Radio [Wireless] - SCADA	1.00 ea	53.3	4,297	25,619	-	-	-	29,916.00 /ea	29,916		71,50
		Local Control Panel, Odor Control, FBO	1.00 ea	20.0	1,611 1,611	205 205	-	1	-	1,816.40 /ea 1,816.40 /ea	1,816	4,341.26 /ea 4,341.29 /ea	4,34 4,34
		Local Control Panel, Sump Pump Controller, FBO Local Control Panel, Screen Control, FBO	3.00 ea	59.9	4,834	615			-	1,816.40 /ea 1,816.37 /ea	5,449		13,02
		Local Control Panel, Screen Control, PBO Local Control Panel, Generator Control, FBO	2.00 ea	40.0	3,223	410		·	<u> </u>	1,816.40 /ea	3,633		8,68
		East Street PS - PLC Cabinet	1.00 ea	53.3	4,297	30,743		1 :		35,039.77 /ea	35,040		83,74
		I&C, PLC, Control Panels, Network Hardware	1.00 EA	257.1	20,734	62,920		<u> </u>	-	83,653.66 /EA	83,654		199,93
			1.00 EA	257.1	20,734	02,920				03,033.00 /EA	03,034	199,933.99 /EA	199,93
		I&C, Sotfware, Programming	100	+				-		0.500.04 /		0.570.05 /	
		SCADA Software Licenses	1.00 ea	0.0	138.744	3,587		-	-	3,586.64 /ea	3,587	8,572.25 /ea	8,57
		PLC / SCADA Software Development	287.00 pts 1.00 EA	1,720.5	138,744	3.587			-	483.43 /pts	138,744 142.331		331,60
		I&C, Sotfware, Programming	1.00 EA	1,720.5	138,744	3,587		-		142,330.56 /EA	142,331	340,176.45 /EA	340,17
		I&C, Instrument Tubing, Piping, etc.		-									8,28
		Press Gauge / Press Sw Installation Materials - Stainless	8.00 ea	27.7	2,234	1,230		-	-	433.02 /ea	3,464	1,034.94 /ea	L



Project: East Street Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03/(10-4-2016)

Fac Wor		Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		I&C, Instrument Tubing, Piping, etc. I&C, Other	1.00 LF	27.7	2,234	1,230				3,464.17 /LF	3,464	8,279.51 /LF	8,280
		Receive & Store Instrument	61.00 ea	28.4	2,294	1				37.61 /ea	2,294	89.89 /ea	5,483
		Identification Tag - SS	6.00 ea	2.0	161	92				42.23 /ea	2,294		5,48
		Identification Tag - SS	2.00 ea	0.7	54	31			-	42.23 /ea	84		20
		Identification Tag - SS	8.00 ea	2.7	215	123	-	-	-	42.23 /ea	338	100.92 /ea	80
		Identification Tag - SS	1.00 ea	0.3	27	15	-		-	42.22 /ea	42		10
		Identification Tag - SS	44.00 ea	14.7	1,182	676	-	-	-	42.23 /ea	1,858		4,44
		Field Calibration - Simple	8.00 ea	5.3	430		-	-	-	53.72 /ea	430		1,02
		Field Calibration - Average	52.00 ea	207.8	16,759 645		-	-	-	322.29 /ea 644.56 /ea	16,759 645		40,054
		Field Calibration - Severe Pre-Operation Check	1.00 ea 61.00 ea	75.6	6,097					99.94 /ea	6,097	1,540.53 /ea 238.87 /ea	1,54°
		Startup - Stand-By (Manhours)	60.00 ea	69.3	5,586				-	93.11 /ea	5,586		13,352
		Loop Check - Average	60.00 ea	138.5	11,173		-		-	186.21 /ea	11,173		26,703
		I&C, Other	1.00 EA	553.3	44,620	938				45,558.67 /EA	45,559		108,887
		Instrumentation & Controls	1.00 LS	2,809.1	226,529	158,570				385,099.39 /LS	385,099		920,405
		40.90 Instrumentation & Controls	1.00 LS	2,809.1	226,529	158,570				385,099.39 /LS	385.099		920,405
		40.9 Instrumentation & Controls	1.00 LS	2.809.1	226,529	158,570				385,099.39 /LS	385.099	,	920,405
41.0		Bulk Material Processing Equipment	1.00 L3	2,003.1	220,323	130,370				303,099.39 723	303,033	320,404.02 /L3	320,400
41.0	41.00	Material Handling Equipment						1					
	41.00			-				-					
		Monorail Crane		-				-					
		Material Handling, Monorail Cranes		1				-					
		Monorail Cranes, under hung hoist, electric operating, 7.5 ton,	1.00 ea	45.3	4,199	51,238	-	198	-	55,634.37 /ea	55,634		124,623
		Material Handling, Monorail Cranes	1.00 EA	45.3	4,199	51,238		198		55,634.37 /EA	55,634		124,623
		Monorail Crane	1.00 EA	45.3	4,199	51,238		198		55,634.37 /EA	55,634		124,623
		41.00 Material Handling Equipment	1.00 LS	45.3	4,199	51,238		198		55,634.37 /LS	55,634		124,623
		41.0 Bulk Material Processing Equipment	1.00 LS	45.3	4,199	51,238		198		55,634.37 /LS	55,634	124,623.49 /LS	124,623
43.0		Process Equipment - Industrial											
	43.05	Furnish and Install Process Equipment											
		Odor Control											
		Cast-In-Place Concrete, Slabs on Grade, 12" thick											
		Fine grade, for slab on grade, by hand	729.00 sf	6.8	399	22				0.58 /sf	421	1.32 /sf	964
		Fill, gravel subbase, under building slab on grade	13.50 cy	9.0	527	484	-		-	74.90 /cy	1,011		2,316
		Concrete pumping, subcontract, all inclusive price	27.00 cy			-	415		-	15.37 /cy	415		950
		Slab on grade edge forms, 7" to 12"	112.00 sf	26.9	2,009	115	-	-	-	18.97 /sf	2,124		4,864
		Reinforcing in place, A615 Gr 60, priced per lbs.	3,510.00 lb		-	1,798	1,439	-	-	0.92 /lb	3,237		7,413
		Concrete, ready mix, 4000 psi	27.00 CY		-	3,320	-	-	-	122.97 /CY	3,320		7,603
		Add for concrete waste, 4000 psi Add amount for Fuel Surcharges - per concrete truck load	1.35 cy 3.00 load		-	166 46	-	-	-	122.97 /cy 15.37 /load	166 46		380
		Add amount for Fuel Surcharges - per concrete truck load Add amount for Environmental Fee - per concrete truck load	3.00 load			18			-	6.15 /load	18		106
		Placing concrete, concrete pump	27.00 cy	27.0	1.581	- 10			-	58.56 /cy	1.581		3,621
		Finishing floors, monolithic, trowel finish (machine)	729.00 sf	19.4	1,344	15				1.87 /sf	1,359		3,113
		Curing, water	729.00 sf	3.2	190	37	-	-	-	0.31 /sf	227		520
		Cast-In-Place Concrete, Slabs on Grade, 12" thick	27.00 CY	92.3	6,050	6,023	1,854			515.80 /CY	13,927	1,181.21 /CY	31,893
		Odor Control Equipment											
		Furnish Scrubber equipment associated accessories	1.00 ea			183,431	-			183,431.18 /ea	183,431	420,065.62 /ea	420,066
		Install Scrubber equipment and all associated accessories	1.00 ea	79.9	6,011	25,619		1 .	-	31,629.69 /ea	31,630		72,433
		30" FRP shop fabricated duct - FURNISH	51.00 LF		-	3,711		-		72.76 /LF	3,711		8,498
		30" FRP shop Ell, 90	1.00 ea		-	604	-	-	-	603.58 /ea	604		1,382
		30" FRP shop Tee	1.00 ea		-	905	-	-	-	905.37 /ea	905		2,073
		30" shop weld	6.00 ea		-	1,814	-	-	-	302.30 /ea	1,814		4,154
		36" FRP shop fabricated duct - FURNISH	20.00 LF	-	-	1,701	-	-	-	85.06 /LF	1,701		3,896
		36" shop weld	2.00 ea			676		-	-	338.17 /ea	676	774.42 /ea	1,549
		Odor Control Equipment	1.00 EA	79.9	6,011	218,461		-		224,471.71 /EA	224,472	. ,	514,050
		Odor Control	1.00 LS	172.2	12,061	224,484	1,854	1		238,398.36 /LS	238,398	545,942.93 /LS	545,943
		500 HP Pumps											
		Vertical Centrifugal Pump: 501hp-1000hp											
		Functional Testing, Pumps, 501-1000 hp	5.00 ea	53.3	4,007	512	-	-	-	903.91 /ea	4,520		10,35
		Align Pump & Motor, 501-1000 hp	5.00 ea	53.3	4,007		7,173		-	2,236.09 /ea	11,180		25,60
		Vibration Testing, Pumps, 501-1000 hp	5.00 ea 5.00 ea	26.6	2,004	-	3,587 2,562		2,562	1,118.05 /ea 1,024.76 /ea	5,590 5,124		12,80 11,73
	_	Witnessed factory test Local panel	5.00 ea 5.00 ea	40.0	3,005	7,686	2,562		2,562	1,024.76 /ea 2,138.21 /ea	5,124 10,691		11,73
		Pressure indicators	10.00 ea	20.0	1,503	2,562				2,136.21 /ea 406.46 /ea	4,065		9,30
		Sleeved anchor bolts - Large	50.00 ea	33.3	2,505	1,435				78.78 /ea	3,939		9,02
		Non-Shrink Machine Grout	60.00 cuft	75.9	5,710	4,550	-	-	-	171.00 /cuft	10,260		23,49
		Grease, Oil, and Lube Pumps, 501-1000 hp	5.00 ea	26.6	2,004	769	-	-	-	554.44 /ea	2,772		6,34
		FURNISH Vertical Centrifugal Pump, 501 - 1000 hp	5.00 EA		-	1,465,400	-	-	-	293,079.99 /EA	1,465,400		3,355,83
		Set pump assembly, 501 - 1000 hp	5.00 ea	479.6	36,065	512		-	-	7,315.45 /ea	36,577	16,752.70 /ea	83,76



Project: East Street Pump Station

Project No.: 478874 Revision / Date: Rev03/(10-4-2016)

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Design Stage: conceptual Estimate Class: 4

Fac Work Trade Pkg Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups

Fac Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Vertical Centrifugal Pump: 501hp-1000hp	5.00 EA	808.6	60,809	1,483,425	13,322		2,562	312,023.69 /EA	1,560,118	714,548.25 /EA	3,572,741
		500 HP Pumps	5.00 EA	808.6	60,809	1,483,425	13,322		2,562	312,023.69 /EA	1,560,118	714,548.25 /EA	3,572,741
		Misc. Equipment											
		Unit Price Code	0.00 F4		13.322	00.405				40,000,40, /54	00.047	00.704.44 /FA	77.44
		55 Gal Hydraulic Fluid Tanks Allowance Unit Price Code	2.00 EA 1.00 LS		13,322	20,495 20,495	-	-	-	16,908.46 /EA 33,816.92 /LS	33,817 33,817	38,721.14 /EA 77,442.27 /LS	77,442 77,442
		Misc. Equipment	1.00 LS		13,322	20,495				33,816.92 /LS	33,817	77,442.27 /LS	77,442
		43.05 Furnish and Install Process Equipment	1.00 LS	980.9	86.192	1.728.404	15.176		2.562	1,832,333.75 /LS	1.832.334	4.196.126.45 /LS	4.196.120
		43.0 Process Equipment - Industrial	1.00 LS	980.9	86,192	1,728,404	15,176		2,562	1,832,333.75 /LS	1,832,334	4,196,126.45 /LS	4,196,126
44.0		Process Equipment - Municipal	1.00 LO	300.3	00,132	1,120,404	10,170		2,302	1,002,000.70 720	1,002,004	4,130,120.43 720	4,130,120
	4.05	Furnish and Install Process Equipment											
	1100	Miscellaneous Euipment											
		Process Equipment											
		Miscellaneous process equipment including, Mechanical Bar Screen, Conveyors, Washer, Grinder & compactor	1.00 ea	599.5	44,961	225,446	-	20,382	-	290,789.71 /ea	290,790	665,921.47 /ea	665,92
		Process Equipment	1.00 EA	599.5	44,961	225,446		20,382		290,789.71 /EA	290,790	665,921.47 /EA	665,92
		Miscellaneous Euipment	1.00 LS	599.5	44,961	225,446		20,382		290,789.71 /LS	290,790	665,921.47 /LS	665,92°
		44.05 Furnish and Install Process Equipment	1.00 EA	599.5	44,961	225,446		20,382		290,789.71 /EA	290,790	665,921.47 /EA	665,92
		44.0 Process Equipment - Municipal	1.00 LS	599.5	44,961	225,446		20,382		290,789.71 /LS	290,790	665,921.47 /LS	665,92
		0200 East Street Pump Station	1.00 LS	33.594.5	2,678,795	4,624,360	726,540	115.915	53.800	8,199,408.91 /LS	8.199.409	19,115,106.38 /LS	19,115,10
305		Dry Weather Pump Station				, ,	,	, i		, ,			, ,
01.0		General Requirements											
	1.06	Startup & Commissioning											
	1100	Startup and Testing											
		General Conditions, Other											
		Startup, Testing, and Contractor Commissioning Allowance	1.00 ls		39,457			13,152	-	52,609.37 /ls	52,609	112,586.44 /ls	112,58
		General Conditions, Other	1.00 LS		39,457			13,152		52,609.37 /LS	52,609	112,586.44 /LS	112,58
		Startup and Testing	1.00 LS		39,457			13,152		52,609.37 /LS	52,609	112,586.44 /LS	112,58
		01.06 Startup & Commissioning	1.00 LS		39,457			13,152		52,609.37 /LS	52,609	112,586.44 /LS	112,58
		01.0 General Requirements	1.00 LS		39,457			13,152		52,609.37 /LS	52,609	112,586.44 /LS	112,580
02.0		Existing Conditions											
0	2.40	Demolition											
		Demolition											
		General Site Demolition											
		Miscellaneous site demo	1.00 ls				25,293	-	-	25,292.96 /ls	25,293	57,922.01 /ls	57,92
		General Site Demolition	1.00 LS				25,293			25,292.96 /LS	25,293	57,922.01 /LS	57,92
		General Site Demolition, Aspalt Pavement											
		Demolish, remove pavement & curb, remove bituminous pavement, 4" to 6" thick, excludes hauling and disposal fees load and haul pavement material for offiste disposal 15 miles	277.78 sy 46.30 cy	34.8	2,330		-	1,204	-	12.72 /sy 24.39 /cy	3,534	29.13 /sy 55.85 /cy	2,58
		Dumping fees	46.30 cy	0.4	423		1,171	700	-	25.29 /cy	1,171	57.92 /cy	2,68
		General Site Demolition, Aspalt Pavement	277.78 SY	41.2	2.759		1,171	1.904		21.00 /SY	5.834	48.09 /SY	13.36
		General Site Demolition, Saw Cutting Asphalt											
		Selective demolition, saw cutting, each additional inch of depth over 3"	750.00 If	64.6	4,516	223		2,184	-	9.23 /lf	6,923	21.14 /lf	15,85
		General Site Demolition, Saw Cutting Asphalt	750.00 LF	64.6	4,516	223		2,184		9.23 /LF	6,923	21.14 /LF	15,85
		Demolition	1.00 LS	105.8	7,275	223	26,464	4,088		38,049.79 /LS	38,050	87,135.71 /LS	87,13
		02.40 Demolition	1.00 LS	105.8	7,275	223	26,464	4,088		38,049.79 /LS	38,050	87,135.71 /LS	87,13
		02.0 Existing Conditions	1.00 LS	105.8	7,275	223	26,464	4,088		38,049.79 /LS	38,050	87,135.71 /LS	87,13
03.0		Concrete Work											
0	3.10	Cast-In-Place Concrete Work											
		36" Slab on Grade: 40' x 20' x 36" Thk											
		Cast-In-Place Concrete, Slabs on Grade, 36" thick											
		Fine grade, for slab on grade, by hand Fill, gravel subbase, under building slab on grade	800.00 sf 29.63 cy	7.4 19.5	432 1,142	1,049	-	-	-	0.57 /sf 73.95 /cy	456 2,191	1.31 /sf 169.35 /cy	1,04 5,01
		Concrete pumping, subcontract, all inclusive price	88.89 cy	19.5	1,142	1,049	1,349			75.95 /cy 15.18 /cy	1,349		3,08
		Slab on grade edge forms, > 24"	360.00 sf	118.4	8,856	455	.,010		-	25.87 /sf	9,312	59.23 /sf	21,32
		Waterstop, PVC, center bulb, 6" wide	160.00 If	16.8	1,260	324	-	-	-	9.90 /lf	1,583	22.66 /lf	3,62
		Reinforcing in place, A615 Gr 60, priced per lbs.	14,222.22 lb		-	7,194	5,756	-	-	0.91 /lb	12,950	2.09 /lb	29,65
		Concrete, ready mix, 4000 psi Add for concrete waste, 4000 psi	88.89 CY 4.44 cy		-	10,792 540	-	-	-	121.41 /CY 121.41 /cy	10,792 540	278.03 /CY 278.02 /cy	24,71
		Placing concrete, concrete pump	88.89 cy	87.7	5,139	- 340				57.81 /cy	5,139		11,76
		Finishing floors, monolithic, trowel finish (machine)	800.00 sf	21.0	1,457	16	-	-	-	1.84 /sf	1,473	4.22 /sf	3,37
		Curing, membrane spray	800.00 sf	2.1	123	32	-	-	-	0.20 /sf	156	0.45 /sf	35
		Polyethelene vapor barrier, 10 mil thick	8.00 sq	2.3	171	86	-	-	-	32.15 /sq	257		58
		Cast-In-Place Concrete, Slabs on Grade, 36" thick	88.89 CY	275.2	18,580	20,513	7,105			519.71 /CY	46,197	1,190.16 /CY	105,793



Project: East Street Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03/(10-4-2016)

Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		36" Slab on Grade: 40' x 20' x 36" Thk	88.89 CY	275.2	18,580	20,513	7,105			519.71 /CY	46,197	1,190.16 /CY	105,79
		12" SOG @ Valve Vault											
		Cast-In-Place Concrete, Slabs on Grade, 12" thick											
		Fine grade, for slab on grade, by hand	378.00 sf	3.5	204	11			-	0.57 /sf	216	1.31 /sf	49
		Concrete pumping, subcontract, all inclusive price	14.00 cy 78.00 sf	18.5	1.382	79	212		-	15.18 /cy 18.72 /sf	212 1,460	34.75 /cy 42.88 /sf	3.34
		Slab on grade edge forms, 7" to 12" Reinforcing in place, A615 Gr 60, priced per lbs.	78.00 st 1,820.00 lb	18.5	1,382	921	737	-	-	18.72 /st 0.91 /lb	1,460	42.88 /st 2.09 /lb	3,34
		Concrete, ready mix, 4000 psi	1,820.00 lb		-	1,700	131		-	121.41 /CY	1,700	278.02 /CY	3,89
		Add for concrete waste, 4000 psi	0.70 cy		1	85				121.41 /C1	85	278.01 /cy	19
		Add amount for Fuel Surcharges - per concrete truck load	2.00 load		-	30				15.18 /load	30	34.77 /load	7
		Add amount for Environmental Fee - per concrete truck load	2.00 load		-	12			-	6.07 /load	12	13.90 /load	2
		Placing concrete, concrete pump	14.00 cy	13.8	809	-	-	-	-	57.81 /cy	809	132.39 /cy	1,85
		Finishing floors, monolithic, trowel finish (machine)	378.00 sf	9.9	688	8	-	-	-	1.84 /sf	696	4.22 /sf	1,59
		Curing, water	378.00 sf	1.7		19		-	-	0.31 /sf	116	0.70 /sf	26
		Cast-In-Place Concrete, Slabs on Grade, 12" thick	14.00 CY	47.4	3,180	2,865	949			499.58 /CY	6,994	1,144.07 /CY	16,01
		12" SOG @ Valve Vault	14.00 CY	47.4	3,180	2,865	949			499.58 /CY	6,994	1,144.07 /CY	16,01
		24" Exterior Concrete Walls: 120' L x 20' H x 24" Thk											
		Cast-In-Place Concrete, Straight Walls, 24" thick											
		Concrete pumping, subcontract, all inclusive price	177.78 cy		-	-	2,698	-	-	15.18 /cy	2,698	34.75 /cy	6,17
		Forms in place, structural walls, > 16' high, hand set	4,800.00 sf	1,073.2	80,297	6,556			-	18.09 /sf	86,853	41.44 /sf	198,89
		Waterstop, PVC, center bulb, 6" wide	240.00 lf	25.3	1,889	486	-	-	-	9.90 /lf	2,375	22.66 /lf	5,43
		Reinforcing in place, A615 Gr 60, priced per lbs.	32,000.00 lb		-	16,187	12,950	-	-	0.91 /lb	29,137	2.09 /lb	66,72
		Concrete, ready mix, 4000 psi	177.78 CY		-	21,583	-	-	-	121.41 /CY	21,583	278.03 /CY	49,42
		Add for concrete waste, 4000 psi	8.89 cy		-	1,079	-	-	-	121.41 /cy	1,079	278.02 /cy	2,47
	-	Placing concrete, concrete pump, for structural wall >12" - 24" thick	177.78 cy	175.4	10,277	-	-	-	-	57.81 /cy	10,277	132.39 /cy	23,53
		Patch & plug tieholes	4,800.00 sf	94.7	5,550	97			-	1.18 /sf	5,647	2.69 /sf	12,93
		Sack rub	4,800.00 sf	252.5	14,800	146	-		-	3.11 /sf	14,945	7.13 /sf	34,22
		Curing, membrane spray	4,800.00 sf	12.6	740	194	-	-	-	0.20 /sf	934	0.45 /sf	2,13 5,56
		Below grade damproofing, Bituminous Asphalt	2,400.00 sf	1,633.7	113.554	2,428	15,648	-	-	1.01 /sf	2,428	2.32 /sf	407,53
		Cast-In-Place Concrete, Straight Walls, 24" thick	177.78 CY			48,757				1,001.00 /CY	177,959	2,292.34 /CY	
		24" Exterior Concrete Walls: 120' L x 20' H x 24" Thk	177.78 CY	1,633.7	113,554	48,757	15,648			1,001.00 /CY	177,959	2,292.34 /CY	407,53
		12" Walls @ Valve Vault											
		Cast-In-Place Concrete, Straight Walls, 12" thick											
		Concrete pumping, subcontract, all inclusive price	23.70 cy		-	-	360	-	-	15.18 /cy	360	34.75 /cy	82
		Forms in place, structural walls, to 8' high, hand set	1,280.00 sf	252.5	18,894	1,295	-	-	-	15.77 /sf	20,189	36.12 /sf	46,23
		Reinforcing in place, A615 Gr 60, priced per lbs.	3,204.10 lb		-	1,621	1,297	-	-	0.91 /lb	2,917	2.09 /lb	6,68
		Concrete, ready mix, 4000 psi	23.70 CY		-	2,878	-	-	-	121.41 /CY	2,878	278.03 /CY	6,59
		Add for concrete waste, 4000 psi	1.19 cy		-	144	-	-	-	121.40 /cy	144	278.01 /cy	32
		Add amount for Fuel Surcharges - per concrete truck load	3.00 load		-	46	-	-	-	15.18 /load 6.07 /load	46	34.76 /load 13.90 /load	10
		Add amount for Environmental Fee - per concrete truck load Placing concrete, concrete pump, for structural wall to 12" thick	3.00 load 23.70 cy	26.5	1 553	18	-	-	-		1,553	13.90 /load 150.04 /cy	3,55
		Patch & plug tieholes	1.280.00 sf	25.3	1,553	26			-	65.52 /cy 1.18 /sf	1,506	2.69 /sf	3,55
		Sack rub	1,280.00 sf	67.3	3,947	39			- 1	3.11 /sf	3,985	7.13 /sf	9,12
		Curing, membrane spray	1,280.00 sf	3.4	197	52			1	0.20 /sf	249	0.45 /sf	57
		Cast-In-Place Concrete, Straight Walls, 12" thick	23.70 CY	375.0	26,071	6,118	1,656			1,428.06 /CY	33,845	3,270.32 /CY	77,50
		12" Walls @ Valve Vault	23.70 CY	375.0		6.118	1,656			1.428.06 /CY	33.845	3.270.32 /CY	77.50
			23.70 C1	373.0	20,071	0,110	1,030			1,420.00 /C1	33,043	3,270.32 701	77,30
		12" Elevated Slab: 40' L x 20' W x 12" Thk											
		Cast-In-Place Concrete, Elevated Decks, 12" thick											
	-	Concrete pumping, subcontract, all inclusive price	29.63 cy	ļ	45	-	450	-	-	15.18 /cy	450	34.75 /cy	1,03
-	1	Forms in place, elevated slab, soffit	800.00 sf	210.4	15,745	1,012	-		-	20.95 /sf	16,756	47.97 /sf	38,37
_		Forms in place, elevated slab, edge form	120.00 sf 16,000.00 cf	39.5 147.4	2,952 11,025	152 809	-	-		25.87 /sf 0.74 /cf	3,104 11,835	59.23 /sf 1.69 /cf	7,10 27,10
	_	Slab shoring Waterstop, PVC, center bulb, 6" wide	16,000.00 cf 240.00 lf	25.3	11,025	809 486	-	_	-	9.90 /lf	11,835	1.69 /cr 22.66 /lf	5,43
		Reinforcing in place, A615 Gr 60, priced per lbs.	6,518.52 lb	25.3	1,089	3,297	2,638	 	-	9.90 /lf 0.91 /lb	5,935	22.66 /lf 2.09 /lb	13,59
		Concrete, ready mix, 4000 psi	29.63 CY			3,597	2,030			121.41 /CY	3,597	278.02 /CY	8,23
		Add for concrete waste, 4000 psi	1.48 cy			180			- 1	121.41 /cr	180	278.04 /cy	41
		Placing concrete, concrete pump, for elevated slab to 12" thick	29.63 cy	19.5	1,142	00		-		38.54 /cy	1,142	88.26 /cy	2,61
		Curing, membrane spray	800.00 sf	2.1	123	32	-	-	-	0.20 /sf	156	0.45 /sf	35
		Cast-In-Place Concrete, Elevated Decks, 12" thick	29.63 CY	444.1	32,877	9,565	3,088			1,536.61 /CY	45,530	3,518.90 /CY	104,26
		12" Elevated Slab: 40' L x 20' W x 12" Thk	29.63 CY	444.1	32.877	9,565	3,088			1,536.61 /CY	45.530	3,518.90 /CY	104,26
		12" Elevated Slab @ Valve Vault	20.00 01	1.4.1	52,577	0,000	5,500			.,	,550	2,210,00 701	,20
			+					 					
		Cast-In-Place Concrete, Elevated Decks, 12" thick	1100					-		45.40 (-		0475 /	
		Concrete pumping, subcontract, all inclusive price	14.00 cy		7.1	-	212	-	-	15.18 /cy	212	34.75 /cy	48
		Forms in place, elevated slab, soffit	378.00 sf	99.4	7,439	478	-	-		20.95 /sf	7,917	47.97 /sf	18,13 4,62
		Forms in place, elevated slab, edge form Slab shoring	78.00 sf 3,024.00 cf	25.6 27.9	1,919 2.084	99 153	-	_	-	25.87 /sf 0.74 /cf	2,018 2,237	59.23 /sf 1.69 /cf	4,62 5,12
		Reinforcing in place, A615 Gr 60, priced per lbs.	1,892.42 lb	21.9	2,004	957	766			0.74 /ci 0.91 /lb	1,723	2.09 /lb	3,94
		Concrete, ready mix, 4000 psi	1,892.42 ID			1,700	700			121.41 /CY	1,700	278.03 /CY	3,89
		Add for concrete waste, 4000 psi	0.70 cy			85	-			121.41 /C1	1,700	278.01 /cy	3,68
_		Add amount for Fuel Surcharges - per concrete truck load	2.00 load			30	-			15.18 /load	30	34.75 /load	7
						30	-		-	15.10 /luau	30	J/ J /IUau	



Project: East Street Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03/(10-4-2016)

Fac Wor			Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
			Cast-In-Place Concrete, Elevated Decks, 12" thick											
	_		Placing concrete, concrete pump, for elevated slab to 12" thick	14.00 cy	9.2	540	-	-	-	-	38.54 /cy	540		1,236
	_		Curing, membrane spray	378.00 sf 14.00 CY	1.0 163.1	58 12.040	3,529	978	-	-	0.20 /sf 1,181.97 /CY	74 16,548	0.45 /sf 2,706.77 /CY	169 37,895
	_		Cast-In-Place Concrete, Elevated Decks, 12" thick	14.00 CY	163.1	12,040		978				16,548		
	_		12" Elevated Slab @ Valve Vault	14.00 CT	103.1	12,040	3,529	9/8			1,181.97 /CY	16,348	2,706.77 /CY	37,895
			8" Baffle Wall @ Wetwell											
			Cast-In-Place Concrete, Straight Walls, 8" thick	3.75 cy				57			15.18 /cy	57	34.76 /cy	100
			Concrete pumping, subcontract, all inclusive price Forms in place, structural walls, > 8' to 16' high, hand set	3.75 cy 304.00 sf	80.0	5,983	384	5/	-	-	15.18 /cy 20.95 /sf	6,367		130 14,582
			Reinforcing in place, A615 Gr 60, priced per lbs.	760.97 lb	80.0	3,503	385	308		- :	0.91 /lb	693		1,587
			Concrete, ready mix, 4000 psi	3.75 CY			456	-	-		121.41 /CY	456	278.03 /CY	1,043
		A	Add for concrete waste, 4000 psi	0.19 cy		-	23		-	-	121.44 /cy	23	278.03 /cy	52
			Add amount for Fuel Surcharges - per concrete truck load	1.00 load		-	15	-	-	-	15.17 /load	15		35
			Add amount for Environmental Fee - per concrete truck load	1.00 load		-	6	-	-	-	6.07 /load	6	13.89 /load	14
	_		Placing concrete, concrete pump, for structural wall to 12" thick	3.75 cy	4.2		-	-	-	-	65.52 /cy	246		563
	_		Patch & plug tieholes Sack rub	304.00 sf 304.00 sf	6.0 16.0		6	-	-	-	1.18 /sf 3.11 /sf	358 947		2,168
			Curing, membrane spray	304.00 sf	0.8		12			-	0.19 /sf	59		2,100
			Cast-In-Place Concrete, Straight Walls, 8" thick	3.75 CY	107.0		1,297	365			2,460.33 /CY	9,226	5,634.27 /CY	21,129
		_	B" Baffle Wall @ Wetwell	3.75 CY	107.0		1,297	365			2,460.33 /CY	9,226	5,634.27 /CY	21,129
		_	03.10 Cast-In-Place Concrete Work	351.75 CY	3,045.5	213.866	92.644	29,789			956.07 /CY	336.298	2,189.45 /CY	770,138
	_		03.0 Concrete Work	351.75 CY 1.00 LS	3,045.5	213,866	92,644	29,789			336,298.25 /LS	336,298	2,189.45 /CY 770,138.09 /LS	770,138
		_		1.00 LS	3,045.5	213,800	92,644	29,789			336,298.25 /LS	330,298	770,138.09 /LS	770,138
08.0	_	_	Openings											
	08.10		Doors and Frames											
			Access Door											
			Specialty Doors and Frames, Access Doors											
			Floor, industrial, steel 300 psf L.L., dbl leaf, 6' x 4' opening, 645#	3.00 opng	63.1	5,723	20,032		-	-	8,585.02 /opng	25,755	19,660.06 /opng	58,980
		_	Specialty Doors and Frames, Access Doors	3.00 EA	63.1	5,723	20,032				8,585.02 /EA	25,755	19,660.06 /EA	58,980
		_	Access Door	3.00 EA	63.1	5,723	20,032				8,585.02 /EA	25,755	19,660.06 /EA	58,980
		(08.10 Doors and Frames	3.00 EA	63.1	5,723	20,032				8,585.02 /EA	25,755	19,660.06 /EA	58,980
		(08.0 Openings	1.00 LS	63.1	5,723	20,032				25,755.05 /LS	25,755	58,980.19 /LS	58,980
26.0		E	Electrical Work											
	26.0	00 E	Electrical											
		E	Electrical and I&C											
		E	Electrical, Other											
		E	Electrical and I&C allowance	1.00 ls		-	-	101,172	-	-	101,171.86 /ls	101,172	241,805.31 /ls	241,805
		E	Electrical, Other	1.00 LS				101,172			101,171.86 /LS	101,172	241,805.31 /LS	241,805
		1	&C, Flow / Mag Meter / Indicators & Transmitters											
		F	FE - Flow Element - Mag Flowtube (inline)	3.00 ea	7.9	636	152	-	-	-	262.70 /ea	788	627.86 /ea	1,884
		F	FT / FIT - Flow Transmitter - Magnetic,	3.00 ea	49.3	3,977	54,633		-		19,536.70 /ea	58,610	46,693.58 /ea	140,081
		1	&C, Flow / Mag Meter / Indicators & Transmitters	3.00 EA	57.2	4,614	54,785				19,799.40 /EA	59,398	47,321.44 /EA	141,964
			Electrical and I&C	1.00 LS	57.2	4,614	54,785	101,172			160,570.05 /LS	160,570	383,769.63 /LS	383,770
		2	26.00 Electrical	1.00 LS	57.2	4,614	54,785	101,172			160,570.05 /LS	160,570	383,769.63 /LS	383,770
		2	26.0 Electrical Work	1.00 LS	57.2	4,614	54,785	101,172			160,570.05 /LS	160,570	383,769.63 /LS	383,770
31.0		E	Earthwork											
	31.1	15 5	Site Preparation											
		_	Site Preparation											
			Site Preparation, Erosion Controls / Pre-construction											
			Silt Fence, Heavy-Duty, Subcontracted	250.00 lf	4.3		-	759	-		3.04 /lf	759	6.80 /lf	1,700
			Erosion control, hay bales, staked, Subcontracted, Install Only	20.00 ea	1.0		-	283	-	-	14.17 /ea	283		635
			Temp Seed	1.00 ls	5.3		-	506		-	505.85 /ls	506		1,133
		1	Temp Mulching	1.00 ls	0.5		-	506	-	-	505.86 /ls	506	1,133.13 /ls	1,133
			Inlet Protection, Subcontracted	8.00 ea	1.2		-	2,023	-	-	252.93 /ea	2,023		4,533
			Stabilized Construction Entrance, Clean Rock, 1-1/2" thru 3"	47.41 tn	12.5		959	-	1,028	-	61.07 /tn	2,895		6,485
	_		Filter Fabric under Stabilized Construction Entrance	88.89 sy	0.2		135			-	1.52 /sy	135	3.40 /sy	302
			Best Management Practice (BMP) Maintenance, Labor & Material Remove erosion control and dispose offsite	20.00 day 1.00 ls	263.0	15,361	3,541	-	-	-	768.04 /day 3,541.02 /ls	15,361 3,541	1,720.44 /day 7,932.03 /ls	34,409 7,932
			Site Preparation, Erosion Controls / Pre-construction	1.00 IS	288.0	16,269	4,635	4,077	1,028		26,009.07 /LS	26,009	58,261.49 /LS	58,261
	_		Site Preparation	1.00 LS	288.0	16,269	4,635	4,077	1,028		26,009.07 /LS 26,009.07 /LS	26,009	58,261.49 /LS	58,261
	_			1.00 LS	288.0	16,269	4,635	4,077	1,028		26,009.07 /LS 26,009.07 /LS	26,009	· · · · · · · · · · · · · · · · · · ·	58,261
	04.5		31.15 Site Preparation	1.00 LS	288.0	16,269	4,635	4,077	1,028		∠0,009.07 /LS	26,009	58,261.49 /LS	58,261
	31.2	_	Earthworks, Structural	1	-							1		
			Structural Excavation		-							-		
			Site Preparation, Dewatering											
			Dewatering, pumping 24 hr, 8 hrs attended, 6" centrifugal pump	120.00 day	3,787.9	271,851	24,281	-	28,823	-	2,707.96 /day	324,955	6,065.95 /day	727,914
			Site Preparation, Dewatering	120.00 Day	3,787.9	271,851	24,281		28,823		2,707.96 /Day	324,955	6,065.95 /Day	727,914
			Earthworks, Sheeting and Shoring											
		5	Shoring, Sheet Piles, subcontracted	3,360.00 sf	1,176.0		-	254,953	-	-	75.88 /sf	254,953	169.97 /sf	571,106



Project: East Street Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03/(10-4-2016)

Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Earthworks, Sheeting and Shoring	3,360.00 SF	1,176.0			254,953			75.88 /SF	254,953	169.97 /SF	571,106
		Earthworks, Structural, Excavation											
		Fine grade, for slab on grade, by machine	900.00 sf	8.3	486	9	-	-	-	0.55 /sf	495	1.23 /sf	1,109
		Backfill from Select (Imported)	575.00 cy	47.3	3,262	20,361	-	3,583	-	47.31 /cy	27,206	105.99 /cy	60,94
		Compaction, vibratory plate, 8" lifts, common fill	575.00 cy	30.3	1,805	-	-	251	-	3.58 /cy	2,056	8.01 /cy	4,60
		Excav, Struct, common earth, hyd backhoe, 2 CY bkt Load Excess Spoils for Off-Site Hauling, Excavator, Cat 320	1,167.00 cy 1,167.00 cy	122.8	8,548 1,221	-	-	34,563 1,871	-	36.94 /cy 2.65 /cy	43,111 3,092	82.75 /cy 5.94 /cy	96,57 6,92
		Haul Excess Spoils Off-Site, 17 yd capacity, 50 miles RT	1,167.00 cy	148.0	9,911	- :		20,112	-	25.73 /cy	30,023	57.63 /cy	67,25
		Excess Spoils (contaminated but not hazardous) Dump Charges for 17 yd end dumps, per cy	1,167.00 cy	140.0	- 3,311	141,681	-	- 20,112	-	121.41 /cy	141,681	271.96 /cy	317,37
		Earthworks, Structural, Excavation	1,167.00 CY	372.0	25,233	162,051		60,380		212.22 /CY	247,664	475.39 /CY	554,77
		Structural Excavation	1,167.00 CY	5,335.8	297,084	186,332	254,953	89,203		709.15 /CY	827,572	1,588.52 /CY	1,853,79
		Concrete Auger Cast Piles											
		Earthworks, Piling, Auger Cast											
		Mobilization for rig, average cost per vlf, add	600.00 vlf	5.9	456		-	2,855	-	5.52 /vlf	3,311	12.36 /vlf	7,4
		Uncasd drilld concrt piers,cast place augered piles,24"dm,priced using 40"lg,unless specifd otherws,excluds pile caps mobiztn,casing rnfrcng	600.00 vlf	315.7	20,597	12,748	-	16,519	-	83.11 /vlf	49,864		111,69
		Cast-in place adds for drilled concrete piers, for reinforcing steel, add	14,000.00 lb		-	17,705	-	-	-	1.27 /lb	17,705	2.83 /lb	39,6
		Pile Caps	15.00 ea		6,905	7,588	-	2,959	-	1,163.48 /ea	17,452	2,606.24 /ea	39,09
		Site Prep and Test Piles	1.00 ls	157.8	10,259	00.044		7,891		18,150.17 /ls	18,150	40,657.22 /ls	40,6
		Earthworks, Piling, Auger Cast	600.00 LF	479.5	38,217	38,041	-	30,224		177.47 /LF	106,482		238,52
		Concrete Auger Cast Piles	15.00 EA	479.5	38,217	38,041		30,224		7,098.82 /EA	106,482	15,901.67 /EA	238,52
		31.25 Earthworks, Structural	1,167.00 CY	5,815.3	335,301	224,373	254,953	119,427		800.39 /CY	934,054	1,792.91 /CY	2,092,32
		31.0 Earthwork	1.00 LS	6,103.2	351,570	229,008	259,030	120,455		960,063.26 /LS	960,063	2,150,584.77 /LS	2,150,58
33.0		Utilities											
	33.05	Buried Process Piping											
		Yard Piping & Structures											
		Buried Pipe, Other											
		Miscellaneous Yard Piping	1.00 ls				101,172	-	-	101,171.86 /ls	101,172	231,688.10 /ls	231,68
		Buried Pipe, Other	1.00 LS				101,172			101,171.86 /LS	101,172	231,688.10 /LS	231,68
		Buried Structure, Concrete Junction Chamber											
		Allowance for concrete junction box including gates	1.00 ea				252,930	-	-	252,929.66 /ea	252,930	579,220.25 /ea	579,22
		Buried Structure, Concrete Junction Chamber	1.00 EA				252,930			252,929.66 /EA	252,930	579,220.25 /EA	579,22
		Yard Piping & Structures	1.00 LS				354,102			354,101.52 /LS	354,102	810,908.35 /LS	810,90
		Utility Relocation											
		Buried Pipe, Other											
		Miscellaneous utilities relocation at foot print of Dry Weather Pump Station	1.00 ls				75,879	-	-	75,878.89 /ls	75,879	173,766.05 /ls	173,76
		Buried Pipe, Other	1.00 LS				75,879			75,878.89 /LS	75,879	173,766.05 /LS	173,76
		Utility Relocation	1.00 LS				75,879			75,878.89 /LS	75,879	173,766.05 /LS	173,76
		Temporary Bypass Pumping											
		Buried Pipe Specials, Temporary Bypasses											
		Allowance for Bypass Pumping, System Operation	12.00 mon	315.7	27,302	48,562	-	1,578,281	-	137,845.47 /mon	1,654,146	315,672.31 /mon	3,788,06
		Buried Pipe Specials, Temporary Bypasses	12.00 EA	315.7	27,302	48,562		1,578,281		137,845.47 /EA	1,654,146	315,672.31 /EA	3,788,06
		Temporary Bypass Pumping	12.00 MO	315.7	27,302	48,562		1,578,281		137,845.47 /MO	1,654,146	315,672.31 /MO	3,788,06
		33.05 Buried Process Piping		315.7	27,302	48,562	429,980	1,578,281		/LF	2,084,126	/LF	4,772,74
		33.0 Utilities	1.00 LS	315.7	27,302	48,562	429,980	1,578,281		2,084,126.04 /LS	2,084,126	4,772,742.10 /LS	4,772,74
40.0		Process Pipe											
	40.00	Exposed Process Pipe											
		12" DI Pipe											
		Process Pipe, Ductile Iron, 12"											
		Install 12" DI, flanged, spool <= 10'	16.00 ea	115.7	10,132					633.26 /ea	10,132	1,469.20 /ea	23,50
		12" Fabricated DI Spool, FxF, 1' 0" - FURNISH	3.00 ea	1		1,733	-	-	-	577.69 /ea	1,733	1,340.26 /ea	4,0
		12" Fabricated DI Spool, FxF, 2' 0" - FURNISH	3.00 ea		-	2,082		-	-	694.04 /ea	2,082	1,610.21 /ea	4,8
		12" Fabricated DI Spool, FxF, 3' 0" - FURNISH	4.00 ea		-	3,238	-	-	-	809.38 /ea	3,238	1,877.79 /ea	7,5
		12" Fabricated DI Spool, FxF, 3' 6" - FURNISH	3.00 ea		-	2,601	-	-	-	867.04 /ea	2,601	2,011.57 /ea	6,0
		12" Fabricated DI Spool, FxF, 8' 0" - FURNISH 12" DI, FL, Ell, 90	3.00 ea 7.00 ea	50.6	4,433	4,176 3,287	-		-	1,392.13 /ea 1,102.85 /ea	4,176 7,720		9,6 17,9
		12" DI, FL, EII, 90 12" DI, FL, tee, 12" x 12"	7.00 ea	9.0	4,433 792	3,287	 	 	1	1,102.85 /ea 1,541.60 /ea	1,542	2,558.67 /ea 3,576.60 /ea	3,5
		12" DI, flanged coupling adapter	3.00 ea	20.2	1,769	801		1	1	856.60 /ea	2,570		5,9
		Process Pipe, Ductile Iron, 12"	59.50 LF	195.6	17,126	18,668				601.58 /LF	35,794	1,395.68 /LF	83,04
		12" DI Pipe	59.50 LF	195.6		18,668				601.58 /LF	35,794		83,0
		24" DI Pipe	55.55 Li	.55.0	,120	.5,000				5555 /EI	30,134	1,000.00 /EI	30,0
		Process Pipe, Ductile Iron, 24"											
		Install 24" DI, flanged, spool <= 10'	2.00 ea	31.5	2,759	_	<u> </u>	<u> </u>		1,379.36 /ea	2,759	3,200.16 /ea	6,4
		24" Fabricated DI Spool, FxF, 2' 0" - FURNISH	1.00 ea	31.3	2,759	2,095				2,095.27 /ea	2,735		4,8
		24" Fabricated DI Spool, FxF, 3' 0" - FURNISH	1.00 ea		-	2,380	-	-	-	2,379.57 /ea	2,380		5,5
		24" DI, FL, tee, red, 24" x 12"	1.00 ea	19.7	1,725	1,976				3,700.63 /ea	3,701		8,58



Project: East Street Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03/(10-4-2016)

Fac Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Process Pipe, Ductile Iron, 24"											
		24" DI, FL, reducer, 24" x 12"	1.00 ea	15.8	1,379	1,285		-		2,664.85 /ea	2,665	6,182.57 /ea	6,18
		Process Pipe, Ductile Iron, 24"	10.00 LF	67.0	5,863	7,736				1,359.90 /LF	13,599	3,155.04 /LF	31,55
		24" DI Pipe	5.00 LF	67.0	5,863	7,736				2,719.81 /LF	13,599	6,310.07 /LF	31,55
		48" DI Pipe											·
		Process Pipe, Ductile Iron, 48"											
		Install 48" DI, flanged, spool <= 10'	1.00 ea	32.7	2,861			_	_	2,861.22 /ea	2,861	6.638.16 /ea	6,63
		48" Fabricated DI Spool, FxF, 2' 0" - FURNISH	1.00 ea	52.7	2,001	9,081				9,081.18 /ea	9,081		21,06
		Process Pipe, Ductile Iron, 48"	10.00 LF	32.7	2.861	9,081				1,194.24 /LF	11,942		27,70
		48" DI Pipe	2.00 LF	32.7	7	9.081				5.971.20 /LF	11,942		27.70
		Valves	2.00 Li	32.1	2,001	3,001				3,971.20 /LI	11,342	13,033.43 /L1	21,10
		Process Pipe, Ductile Iron, 12"											
		Install gate valve, Figd, DIP, 12"	3.00 ea	23.7 5.5		-	-	1,479	-	1,165.04 /ea 815.52 /ea	3,495 816		8,10 1,89
		Install gate valve, MJ, 12" Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 12"	1.00 ea 3.00 ea	5.5	4/0	3.758		345	-	1.252.51 /ea	3,758		1,89
		Gate valve, iron body, dbl disk, Figu, 250#, RVO, 12 Gate valve, iron body, dbl disk, MJ, 250#, NO, 12"	1.00 ea		-	1,253				1,252.51 /ea	1,253		2,90
		Install check valve, Flgd, DIP, 12"	3.00 ea	23.7	2,016	1,233		1,479	1	1,165.04 /ea	3,495		8,10
		Check valve, iron body, swing check, Flgd, 250#, 12"	3.00 ea	20.1		8,714		- 1,110		2,904.64 /ea	8,714		20,21
		Install magnetic flow meter, (material FBO), 24"	1.00 ea	16.3	1,428	-		-		1,427.72 /ea	1,428		3,31:
		CI Valve Box & Cover, w/ Concrete Collar included	1.00 ea	3.9		152	-	247	-	734.29 /ea	734		1,70
		Flow Meters 24"	1.00 ea	0.0		24,281		-	-	24,281.25 /ea	24,281	56,333.60 /ea	56,33
		Flow Meter: Electrical Hookup Only, 24"	1.00 ea	16.4	1,326	-	-	-	-	1,325.82 /ea	1,326	3,075.96 /ea	3,07
		Process Pipe, Ductile Iron, 12"	1.00 LF	89.6	7,591	38,157		3,551		49,298.82 /LF	49,299	114,375.48 /LF	114,37
		Valves	1.00 LS	89.6	7,591	38,157		3,551		49,298.82 /LS	49,299	114,375.48 /LS	114,37
		Miscellaneous Piping				·							
		Process Pipe. Other											
		Miscellaneous Piping	1.00 ls				75.879			75.878.89 /ls	75.879	176.042.42 /ls	176,04
		Process Pipe, Other	1.00 LS				75,879			75.878.89 /LS	75.879	-,	176.04
		Miscellaneous Piping	1.00 LS				75,879			75,878.89 /LS	75.879		176,042
		Odor Control	1.00 L3				13,019			73,070.09 723	13,013	170,042.42 723	170,042
		FRP Duct, Round, 30"											
		Allowance for Odor control	1.00 ls				65,762	-		65,761.71 /ls /LF	65,762		152,57
		FRP Duct, Round, 30"					65,762				65,762		152,570
		Odor Control	1.00 LS				65,762			65,761.71 /LS	65,762	. ,	152,570
		40.00 Exposed Process Pipe	66.50 LF	384.9	33,441	73,642	141,641	3,551		3,793.60 /LF	252,275	8,801.33 /LF	585,28
		40.0 Process Pipe	66.50 LF	384.9	33,441	73,642	141,641	3,551		3,793.60 /LF	252,275	8,801.33 /LF	585,28
44.0		Process Equipment - Municipal											
	44.05	Furnish and Install Process Equipment											
		90 HP Pumps											
		Submersible Pump: 51hp-100hp											
		Functional Testing, Pumps, 51-100 hp	3.00 ea	7.9	593	152		-		248.39 /ea	745	568.82 /ea	1,70
		Align Pump & Motor, 51-100 hp	3.00 ea	11.8	890		1,593	-		827.87 /ea	2,484	1,895.85 /ea	5,68
		Vibration Testing, Pumps, 51-100 hp	3.00 ea	3.9	297	-	531	-	-	275.96 /ea	828	631.96 /ea	1,89
		Witnessed factory test	3.00 ea		-		1,518	-	1,518	1,011.72 /ea	3,035	2,316.88 /ea	6,95
		Local panel	3.00 ea	23.7	1,780	4,553	-	-	-	2,111.00 /ea	6,333	4,834.30 /ea	14,50
		Pressure indicators	6.00 ea	11.8		1,518	-	-	-	401.29 /ea	2,408		5,51
		Sleeved anchor bolts - Medium	24.00 ea	11.0		510	-	-	-	55.86 /ea	1,341		3,07
		Non-Shrink Machine Grout	18.00 cuft	22.5	1,691	1,348	-	-	-	168.83 /cuft	3,039		6,95
	-	Grease, Oil, and Lube Pumps, 51-100 hp	3.00 ea	15.8	1,187	228	-	-	-	471.51 /ea	1,415 373.324		3,23
		FURNISH Submersible Pump, 51 - 100 hp	3.00 EA	157.8	11.869	373,324	-	-	-	124,441.39 /EA			854,92
		Set pump assembly, 51 - 100 hp	3.00 ea			152		<u> </u>	4.510	4,006.81 /ea	12,020		27,52
	-	Submersible Pump: 51hp-100hp	3.00 EA	266.3	20,028	381,783	3,642		1,518	135,657.09 /EA	406,971	310,660.83 /EA	931,98
		90 HP Pumps	3.00 EA	266.3	20,028	381,783	3,642		1,518	135,657.09 /EA	406,971	310,660.83 /EA	931,98
		44.05 Furnish and Install Process Equipment	3.00 EA	266.3	20,028	381,783	3,642	-	1,518	135,657.09 /EA	406,971	310,660.83 /EA	931,98
		44.0 Process Equipment - Municipal	1.00 LS	266.3	20,028	381,783	3,642		1,518	406,971.28 /LS	406,971	931,982.48 /LS	931,98
		0305 Dry Weather Pump Station	1.00 LS	10.341.7	703.276	900.680	991.718	1.719.527	1.518	4.316.717.68 /LS	4.316.718	9.853.207.78 /LS	9.853.20



Project: East Street Pump Station

Project No.: 478874
Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03/(10-4-2016)

Estimate Class: 4

Estimate Totals

Construction Costs	Amount	Totals	Rate	% of Total
Labor	3,382,071			11.68%
Material	5,525,039			19.07%
Subcontract	1,718,258			5.93%
Equipment	1,835,442			6.34%
Other	55,317			0.19%
Subtotal Raw Costs	12,516,127	12,516,127		43.21
Material Sales & Use Tax - %				
Construction Equip Tax - %				
Total Taxes		12,516,127		
Existing Conditions I.OH&P	138.222		15.000 %	0.48%
Concrete Work I.OH&P	79.047		15.000 %	0.27%
Masonry Work I.OH&P	1,395		15.000 %	0.00%
Metals Work I,OH&P	3,217		15.000 %	0.01%
Architectural (Div 6-12)I,OH&P	60,765		15.000 %	0.21%
Mechanical Work I,OH&P	9,776		20.000 %	0.03%
Electrical Work I,OH&P	825,760		25.000 %	2.85%
Site/Civil I,OH&P	98,315		10.000 %	0.34%
Buried Piping I,OH&P	312,619		15.000 %	1.08%
Process Piping I,OH&P	172,773		18.000 %	0.60%
Instruments & Controls I,OH&P	96,275		25.000 %	0.33%
Process Equipment I,OH&P _	379,514		15.000 %	1.31%
Subtotal Subcontractor I,OH&P	2,183,241	14,699,368		7.54
Total Cost To Prime Contractor		14,699,368		
General Conditions	1,469,937		10.000 %	5.07%
Mobilization/Demobilization	646,772		4.000 %	2.23%
Subtotal Indirect Costs	2,116,709	16,816,077	4.000 /0	7.31
Subtotal indirect costs	2,110,709	10,010,077		7.31
Prime Contractor Home OfficeOH	1,345,286		8.000 %	4.64%
Prime Contractor Profit	1,816,136		10.000 %	6.27%
Blder's Risk & Gen Liab Ins -%	362,104		1.250 %	1.25%
Payment & Performance Bonds	362,104		1.250 %	1.25%
Subtotal OH&P	3,885,630	20,701,707		13.41
Design Contingency	6,210,512		30.000 %	21.44%
Subtotal Contingency	6,210,512	26,912,219		21.44
Escal. to Midpoint Const 2020	2,056,094		7.640 %	7.10%
• -	2,056,094	28,968,313	1.040 %	7.10%
Subtotal Escalation				
Total Prime Contractor Costs		28,968,313		

Intermediate-Term Improvements
Capacity Upgrade of Union Pump
Station



Union Pump Station Construction Cost Estimate for Concept Design

Project name GNH Union Pump Station

Estimator E.B. Smith/GNV, A. Frisch/PGH

Project Number 478874
Estimate Class 1-5 4
Design Stage Conceptual

Rev No. / Date Rev02 (10-3-2016)



Job Size:

Facility Summary

Project: GNH Union Pump Station Estimator: E.B. Smith/GNV, A. Frisch/PGH

Project No.: 478874 Revision / Date: Rev02 (10-3-2016)

Duration: Design Stage: Conceptual Estimate Class: 4

Facility	Description	Direct Amount	Grand Total w/Markups	Percent of Total
005	UNION PUMP STATION	4,299,242	10,036,007	71.035
006	FORCEMAIN AND PIPE BRIDGE REPLACEMENT	1,785,290	4,035,797	28.565
007	Submergence Chamber and 42-inch Rehabilitation	25,000	56,515	0.400

Estimate Totals

Construction Costs	Amount	Totals	Rate	% of Total
Labor	2,325,588			16.46%
Material	5,418,965			38.36%
Subcontract	4,866,501			34.45%
Equipment	1,458,848			10.33%
Other_	58,416			0.41%
Total Prime Contractor Costs	14,128,318	14,128,318		100.00



Project: GNH Union Pump Station

Project No.: 478874

Design Stage: Conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev02 (10-3-2016)

Fac Work		Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
005		UNION PUMP STATION										
02.0		Existing Conditions										
	02.40	Demolition										
		Selective Demolition										
		Structure/Building Demolition										
		Demo concrete walls, block, excludes disposal costs and dump fees -	66.67 cy	5,885	-	-	4,116	-	150.00 /cy	10,000	343.41 /cy	22,895
		standard crew	•								·	
		Disposal only, urban buildings w/ salvage value allowed, conc frame	150.00 cy	3,156	-		4,344	-	50.00 /cy	7,500	115.06 /cy	17,25
		Rubbish handling, loading & trucking, hand loading truck, 50' haul	150.00 cy	6,230	-	-	7,685	-	92.76 /cy	13,915	213.29 /cy	31,99
		Demo access hatch	5.00 ea	4,512 2,406	0 25	-	-	-	902.40 /ea	4,512	2,039.95 /ea	10,20 5,49
		Demo small pumps Demo large & Medium pumps	1.00 ea	13.536	150			1	2,431.40 /ea 4.562.00 /ea	2,431 13.686	5,498.13 /ea 10,316.28 /ea	30.94
		Demo Sluice Gates	8.00 ea	16,845	- 130		_		2,105.60 /ea	16,845	4,759.88 /ea	38,07
		Demo Bar Screen	2.00 ea	18,650				-	9,324.80 /ea	18,650	21,079.49 /ea	42,15
		Selective demolition, masonry, veneers, brick, soft old mortar, remove	1,075.00 sf	6,230	-	-	-	-	5.80 /sf	6,230	13.10 /sf	14,08
		Door demolition, single, remove	7.00 ea	209	-		-	-	29.83 /ea	209	67.43 /ea	472
		Door demolition, double, remove	3.00 ea	119	-	-	-	-	39.77 /ea	119	89.91 /ea	27
		Demolition Allowance	5.00 Days		-	12,500	-	-	2,500.00 /Days	12,500	5,651.46 /Days	28,257
		Demo windows	4.00 ea	159	-	-	-	-	39.77 /ea	159	89.90 /ea	360
		Demo Roll-Up Door	1.00 ea	477	-	-	-	-	477.24 /ea	477	1,078.85 /ea	1,079
		Structure/Building Demolition	1.00 SF	78,414	175	12,500	16,144		107,232.83 /SF	107,233	243,551.09 /SF	243,551
		Selective Demolition	1.00 LS	78,414	175	12,500	16,144		107,232.83 /LS	107,233	243,551.09 /LS	243,551
		Electrical Facility Demolition										
		Electrical Facility Demolition										
		Electrical demo, remove misc. electrical equipment, transformers, etc.	3,318.00 sf	203,756	-		-	-	61.41 /sf	203,756	138.82 /sf	460,607
		Electrical Facility Demolition	3,318.00 SF	203,756					61.41 /SF	203,756	138.82 /SF	460,607
		Electrical Facility Demolition	1.00 LS	203,756					203,755.89 /LS	203,756	460,607.15 /LS	460,607
		02.40 Demolition	1.00 LS	282,170	175	12,500	16.144		310.988.72 /LS	310.989	704.158.24 /LS	704.158
		02.0 Existing Conditions	1.00 LS	282,170	175	12,500			310,988.72 /LS	310,989	704,158.24 /LS	704,158
03.0		Concrete Work				,	,		,	0.0,000	101,100.01	
00.0	03.10	Cast-In-Place Concrete Work										
	03.10											
		Electrical Equipment Pads										
		Cast-In-Place Concrete, Equipment Pads, 13" thick										
		Edge forms, housekeeping pads >6" Deep	111.58 sf 334.03 lb	2,087	167 167	-	-	-	20.21 /sf 0.90 /lb	2,255	45.78 /sf 2.07 /lb	5,108
		Reinforcing in place, A615 Gr 60, priced per lbs. Concrete, ready mix, 4000 psi	334.03 ID 4.45 CY		503	134		-	113.00 /CY	301 503	263.35 /CY	1,173
		Add for concrete waste, 4000 psi	0.22 cy		25			1	113.00 /cy	25	263.42 /cy	58
		Finish housekeeping pads	111.00 sf	307	3			-	2.80 /sf	311	6.33 /sf	703
		Curing, membrane spray	111.00 sf	13	4		-	-	0.16 /sf	17	0.36 /sf	40
		Cast-In-Place Concrete, Equipment Pads, 13" thick	4.45 CY	2,407	871	134			766.66 /CY	3,412	1,746.79 /CY	7,773
		Electrical Equipment Pads	4.45 CY	2,407	871	134			766.66 /CY	3,412	1,746.79 /CY	7,773
		Electrical Equipment Pad - Generator		2,107	0				700.00 701	0,1.12	1,1-10110 701	.,
	_											
	_	Cast-In-Place Concrete, Equipment Pads, 24" thick Equipment pad forms, large	102.00 sf	1,908	153				20.21 /sf	2,061	45.78 /sf	4,669
		Reinforcing in place, A615 Gr 60, priced per lbs.	750.00 lb	1,906	375	300	-	- 1	0.90 /lb	675	2.07 /lb	1,552
		Concrete, ready mix, 4000 psi	10.00 CY		1,130	300		1	113.00 /CY	1,130	263.36 /CY	2,634
		Add for concrete waste, 4000 psi	0.50 cy		57				113.00 /cy	57	263.36 /cy	132
		Finishing floors, monolithic, broom finish	135.00 sf	280	3		-	-	2.10 /sf	283	4.74 /sf	640
		Patch & plug tieholes	102.00 sf	90	2	-	-	-	0.90 /sf	92	2.03 /sf	207
		Sack rub	102.00 sf	239	3	-	-	-	2.37 /sf	242	5.37 /sf	548
		Curing, water	135.00 sf	26	7	-	-	-	0.25 /sf	33	0.56 /sf	75
		Cast-In-Place Concrete, Equipment Pads, 24" thick	20.00 CY	2,543	1,729	300			228.62 /CY	4,572	522.87 /CY	10,457
		Electrical Equipment Pad - Generator	20.00 CY	2,543	1,729	300			228.62 /CY	4,572	522.87 /CY	10,457
		12" CIP Wall										
		Cast-In-Place Concrete, Straight Walls, 12" thick										
		Concrete pumping, subcontract, all inclusive price	15.89 cy		-	238	-	-	15.00 /cy	238	33.91 /cy	53
		Forms in place, structural walls, to 8' high, hand set	858.00 sf	9,629	858	-	-	-	12.22 /sf	10,487	27.70 /sf	23,76
		Reinforcing in place, A615 Gr 60, priced per lbs.	2,780.56 lb	-	1,390	1,112	-	-	0.90 /lb	2,503	2.07 /lb	5,75
		Concrete, ready mix, 4000 psi	15.89 CY	-	1,795	-	-	-	113.00 /CY	1,795	263.36 /CY	4,18
	-	Add for concrete waste, 4000 psi	0.79 cy	-	90	-	-	-	113.00 /cy	90	263.36 /cy	20
		Add amount for Fuel Surcharges - per concrete truck load	2.00 load	-	30	-	-	-	15.00 /load	30	34.95 /load	70
	_	Add amount for Environmental Fee - per concrete truck load	2.00 load	-	12	-	-	-	6.00 /load	12	14.00 /load	1.78
	_	Placing concrete, concrete pump, for structural wall to 12" thick	15.89 cy 858.00 sf	792 754	17	-	-	-	49.82 /cy 0.90 /sf	792 771	112.61 /cy 2.03 /sf	1,78
	_	Patch & plug tieholes Sack rub	858.00 st 858.00 sf	2,011	26	-	-	-	0.90 /st 2.37 /sf	2,037	2.03 /sf 5.37 /sf	1,74
		Curing, membrane spray	858.00 sf	101	34	-			0.16 /sf	135	0.36 /sf	4,60
		Cast-In-Place Concrete, Straight Walls, 12" thick	15.89 CY	13,287	4,253	1,351	· ·		1,188.80 /CY	18,890	2,706.12 /CY	43,00
		12" CIP Wall	15.89 CY	13,287	4,253	1,351			1,188.80 /CY	18.890	2,706.12 /CY	43,00
	+	Misc. Concrete Repairs	13.89 CY	13,287	4,253	1,351	-		1,100.00 /CY	18,890	2,100.12 /CY	43,00



Project: GNH Union Pump Station E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Project No.:	478874	Revision / Date: Rev02 (10-3-2016)
Design Stage:	Conceptual	Estimate Class: 4

Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Concrete, Other										
		Misc. Concrete Repairs Allowance	1.00 LS			50,000	-	-	50,000.00 /LS	50,000	113,029.16 /LS	113,029
		Misc. Repair @ Joints Allowance	1.00 LS			25,000	-	-	25,000.00 /LS	25,000	56,514.58 /LS	56,51
_		Concrete, Other	1.00 CY			75,000			75,000.00 /CY	75,000	169,543.74 /CY	169,54
		Misc. Concrete Repairs	1.00 LS			75,000			75,000.00 /LS	75,000	169,543.74 /LS	169,54
		03.10 Cast-In-Place Concrete Work	15.89 CY	18,238	6,852	76,784			6,411.21 /CY	101,874	14,523.25 /CY	230,77
		03.0 Concrete Work	15.89 CY	18,238	6,852	76,784			6,411.21 /CY	101,874	14,523.25 /CY	230,77
04.0		Masonry										
	04.00	Masonry										
		4" Face Brick Veneer										
		Masonry Brick, 4"										
		Brick, standard 4" x 2 2/3" x 8"	1,075.00 SF	-	-	11,825		-	11.00 /SF	11,825	24.87 /SF	26,73
		Masonry Brick, 4"	1,075.00 SF			11,825			11.00 /SF	11,825	24.87 /SF	26,73
		4" Face Brick Veneer	1,075.00 SF			11,825			11.00 /SF	11,825	24.87 /SF	26,73
		8" CMU Wall w/ Brick Veneer	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			,				, , ,		
		Masonry Concrete Masonry Units, 8"										
		Scaffolding, rented, 2 stories	1,305.00 sf			1,083			0.83 /sf	1,083	1.88 /sf	2,44
		Grout block cores, solid, 8" thick	1,305.00 sf			3,132			2.40 /sf	3,132	5.43 /sf	7,08
		Masonry reinforcing per square foot	1,305.00 sf			1.958	-		2.40 /si 1.50 /sf	1,958	3.39 /sf	4.42
		Masonry anchor / ties per square foot	1,305.00 sf		-	1,305	-	-	1.00 /sf	1,305	2.26 /sf	2,95
		Brick, standard 4" x 2 2/3" x 8"	1,305.00 SF	-	-	14,355	-	-	11.00 /SF	14,355	24.87 /SF	32,45
		Concrete block, back-up, reinforced, 8" thick	1,305.00 SF	-		8,678	-	-	6.65 /SF	8,678	15.03 /SF	19,61
		Waterproof sealer, masonry, 2 coats	1,305.00 sf	-	-	1,305	-	-	1.00 /sf	1,305	2.26 /sf	2,95
		Paint exterior masonry walls, latex	1,305.00 sf	-		1,305	-	-	1.00 /sf	1,305	2.26 /sf	2,95
		Masonry Concrete Masonry Units, 8"	1,305.00 SF			33,121			25.38 /SF	33,121	57.37 /SF	74,87
		8" CMU Wall w/ Brick Veneer	1,305.00 SF			33,121			25.38 /SF	33,121	57.37 /SF	74,87
		8" CMU Wall @ Stair										
		Masonry Concrete Masonry Units, 8"										
		Scaffolding, rented, 2 stories	600.00 sf	-		498			0.83 /sf	498	1.88 /sf	1,12
		Grout block cores, solid, 8" thick	600.00 sf	-		1,440	-		2.40 /sf	1,440	5.43 /sf	3,25
		Masonry reinforcing per square foot	600.00 sf	-	-	900		-	1.50 /sf	900	3.39 /sf	2,03
		Concrete block, back-up, reinforced, 8" thick	600.00 SF	-	-	3,990	-	-	6.65 /SF	3,990	15.03 /SF	9,02
		Waterproof sealer, masonry, 2 coats	1,200.00 sf	-		1,200	-		1.00 /sf	1,200	2.26 /sf	2,71
		Paint exterior masonry walls, latex	1,200.00 sf	-		1,200	-	-	1.00 /sf	1,200	2.26 /sf	2,71
		Masonry Concrete Masonry Units, 8"	600.00 SF			9,228			15.38 /SF	9,228	34.77 /SF	20,86
		8" CMU Wall @ Stair	600.00 SF			9,228			15.38 /SF	9,228	34.77 /SF	20,86
		8" Interior CMU Wall										
		Masonry Concrete Masonry Units, 8"										
		Scaffolding, rented, 2 stories	576.00 sf			478			0.83 /sf	478	1.88 /sf	1,08
		Grout block cores, solid, 8" thick	576.00 sf	-		1,382			2.40 /sf	1,382	5.43 /sf	3,12
		Masonry reinforcing per square foot	576.00 sf	-	-	864	-	-	1.50 /sf	864	3.39 /sf	1,9
		Concrete block, back-up, reinforced, 8" thick	576.00 SF	-	-	3,830	-	-	6.65 /SF	3,830	15.03 /SF	8,6
		Waterproof sealer, masonry, 2 coats	1,152.00 sf	-		1,152	-	-	1.00 /sf	1,152	2.26 /sf	2,6
		Paint exterior masonry walls, latex	1,152.00 sf	-		1,152	-	-	1.00 /sf	1,152	2.26 /sf	2,6
		Masonry Concrete Masonry Units, 8"	576.00 SF			8,859			15.38 /SF	8,859	34.77 /SF	20,02
		8" Interior CMU Wall	576.00 SF			8,859			15.38 /SF	8,859	34.77 /SF	20,02
		8" Interior CMU Wall @ Stairwell										
		Masonry Concrete Masonry Units, 8"										
		Scaffolding, rented, 2 stories	276.00 sf	-		229	-		0.83 /sf	229	1.88 /sf	5
		Grout block cores, solid, 8" thick	276.00 sf	-		662		-	2.40 /sf	662	5.43 /sf	1,4
		Masonry reinforcing per square foot	276.00 sf	-	-	414	-	-	1.50 /sf	414	3.39 /sf	9
		Concrete block, back-up, reinforced, 8" thick	276.00 SF			1,835			6.65 /SF	1,835	15.03 /SF	4,1
		Waterproof sealer, masonry, 2 coats	552.00 sf	-		552	-	-	1.00 /sf	552	2.26 /sf	1,2
		Paint exterior masonry walls, latex	552.00 sf	-	-	552	-		1.00 /sf	552	2.26 /sf	1,2
		Masonry Concrete Masonry Units, 8"	276.00 SF			4,245			15.38 /SF	4,245	34.77 /SF	9,5
		8" Interior CMU Wall @ Stairwell	276.00 SF			4,245			15.38 /SF	4,245	34.77 /SF	9,5
		04.00 Masonry	3,832.00 SF			67,278			17.56 /SF	67,278	39.69 /SF	152,0
		04.0 Masonry	3,832.00 SF			67,278			17.56 /SF	67,278	39.69 /SF	152,08
05.0		Metals	0,002.00 01			57,270			17.00 701	57,270	00.00 /01	102,0
05.0	05.00			+ +								
	05.00	Metals										
		Railing										
		Metals, Handrailing, 3-Rail										
		Railing, pipe, aluminum, 3 rail, clear anodized	7.00 lf	150	420	-	19	-	84.07 /lf	589	194.44 /lf	1,3
		Metals, Handrailing, 3-Rail	7.00 LF	150	420		19		84.07 /LF	589	194.44 /LF	1,30
		Railing	7.00 LF	150	420		19		84.07 /LF	589	194.44 /LF	1,36
		05.00 Metals	1.00 LS	150	420		19		588.50 /LS	589	1,361.06 /LS	1,30
	05.10	Structural Steel										



Project: GNH Union Pump Station

Project No.: 478874

Design Stage: Conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev02 (10-3-2016)

Fac	Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
			Modifications to Existing Monorail Beam										
			Metals, Structural Steel										
			Allowance to modify the existing monorail beam and all structural related works	1.00 ea			15,000	-	-	15,000.00 /ea	15,000	33,908.74 /ea	33,90
			Metals, Structural Steel				15,000			/TN	15,000	/TN	33,90
			Modifications to Existing Monorail Beam				15,000			/LS	15,000	/LS	33,90
			Misc. Metals										
			Metals, Structural Steel										
			Misc. Metals Allowance	1.00 LS			5,000	-	-	5,000.00 /LS	5,000	11,302.93 /LS	11,30
_			Metals, Structural Steel Misc. Metals	1.00 TN 1.00 LS			5,000 5,000			5,000.00 /TN 5,000.00 /LS	5,000 5,000	11,302.93 /TN 11,302.93 /LS	11,30 11,30
_			05.10 Structural Steel	1.00 LS			20,000			20,000.00 /LS	20,000	45,211.67 /LS	45,21
			05.0 Metals	1.00 LS	150	420	20,000	19		20,588.50 /LS	20,589	46,572.73 /LS	46,57
	06.0		Wood, Plastics and Composites									15,512.10	,
		06.00	Wood, Plastics and Composites										
			FRP Grating										
			Wood & Plastics, FRP Fabrications, Gratings										
			Grating fbgls, molded, orange (hi crsv env), 2" sq mesh, 2" thk	90.00 sf	408	2,250	-	-	-	29.53 /sf	2,658	68.51 /sf	6,16
			Wood & Plastics, FRP Fabrications, Gratings	90.00 SF	408	2,250				29.53 /SF	2,658	68.51 /SF	6,16
-			FRP Grating	90.00 SF	408	2,250		-		29.53 /SF	2,658	68.51 /SF	6,166
_			06.00 Wood, Plastics and Composites	1.00 LS 1.00 LS	408 408	2,250 2,250				2,657.94 /LS 2,657.94 /LS	2,658 2,658	6,166.00 /LS 6,166.00 /LS	6,16
	07.0		06.0 Wood, Plastics and Composites Thermal and Moisture Protection	1.00 LS	408	2,250				2,057.94 /L5	2,638	6,166.00 /LS	6,16
		07.00	Thermal & Moisture Protection										
		07.00	Fire retardant Insulation										
			Thermal & Moisture Protection, Firerproofing										
			Fireproofing sprayed	2,481.00 sf	1,862	9,552	-	82	-	4.63 /sf	11,496	10.75 /sf	26,66
			Thermal & Moisture Protection, Firerproofing	1.00 LS	1,862	9,552		82		11,496.39 /LS	11,496	26,662.92 /LS	26,663
			Fire retardant Insulation	1.00 LS	1,862	9,552		82		11,496.39 /LS	11,496	26,662.92 /LS	26,663
			07.00 Thermal & Moisture Protection	1.00 LS	1,862	9,552		82		11,496.39 /LS	11,496	26,662.92 /LS	26,663
			07.0 Thermal and Moisture Protection	1.00 LS	1,862	9,552		82		11,496.39 /LS	11,496	26,662.92 /LS	26,663
	0.80		Openings										
		08.00	Openings										
			Openings, Doors, Frames and Hardware										
			Door hardware, average - H.M., wood, or aluminum	13.00 set	3,850	4,550	-			646.12 /set	8,400	1,485.12 /set	19,307
			Frames, steel, knock down, hollow metal, single, 16 ga., up to 5-3/4"	7.00 ea	534	1,085	-	-	-	231.26 /ea	1,619	533.63 /ea	3,73
_			deep, 7'-0" h x 3'-0" w	0.00	261	564				275.16 /ea	005	635.18 /ea	4.00
			Frames, steel, knock down, hollow metal, double, 16 ga., up to 4-7/8" deep, 7'-0" h x 6'-0" w	3.00 ea	261	564	-	-	-	2/5.16 /ea	825	635.18 /ea	1,90
			Fiberglass, exterior, prehung door, 1-3/4", 3'-0" x 7'-0"	13.00 ea	1,057	5,980			-	541.35 /ea	7,037	1,255.96 /ea	16,32
			Openings, Doors, Frames and Hardware	13.00 EA	5,702	12,179				1,375.49 /EA	17,881	3,174.99 /EA	41,27
			Doors	13.00 EA	5,702	12,179				1,375.49 /EA	17,881	3,174.99 /EA	41,275
			08.00 Openings	1.00 LS	5,702	12,179				17,881.40 /LS	17,881	41,274.92 /LS	41,275
		08.30	Specialty Doors and Frames										
			Access Hatch 6' x 6'										
-			Specialty Doors and Frames, Access Doors	5.00	7.050	43,200				40.000.45 /	50.450	20.445.40. /	447.07
			Doors, specialty, access, floor, industrial, aluminum, double leaf, 6' x 6', 645 lb	5.00 opng	7,252	43,200	-	-	-	10,090.45 /opng	50,452	23,415.10 /opng	117,075
			Specialty Doors and Frames, Access Doors	5.00 EA	7,252	43,200				10,090.45 /EA	50,452	23,415.10 /EA	117,075
			Access Hatch 6' x 6'	5.00 EA	7,252	43,200				10,090.45 /EA	50,452	23,415.10 /EA	117,075
			Overhead Door										
			Specialty Doors and Frames, Sectional Overhead Doors										
			Doors, rolling service, steel, manual, fire, class A, 20 gauge, 20' x 10' high, incl. hardware	1.00 ea	1,813	4,550	-	-	-	6,363.06 /ea	6,363	14,702.72 /ea	14,700
			Doors, rolling service, steel, manual, motor operators for, to 14' x 14' opening	1.00 ea	290	1,175	-	-	-	1,465.09 /ea	1,465	3,394.22 /ea	3,394
\rightarrow			Specialty Doors and Frames, Sectional Overhead Doors Overhead Door	1.00 EA 1.00 EA	2,103 2,103	5,725 5,725		 		7,828.15 /EA 7,828.15 /EA	7,828 7,828	18,096.94 /EA 18,096.94 /EA	18,097 18.097
			08.30 Specialty Doors and Frames	1.00 EA 1.00 EA	9,355	5,725 48,925		-		7,828.15 /EA 58,280.39 /EA	7,828 58,280	18,096.94 /EA 135,172.42 /EA	135,172
\rightarrow			08.0 Openings	1.00 EA	15,058	61,104				76,161.79 /LS	76,162	176,447.34 /LS	176,447
	09.0		Finishes	20	.5,000	0.,104					. 3,102	, /20	,44
-1		09.10	Finishes, Special Coatings					1					
			Electrical Equipment Pads										
			Finishes, Chemical Resistant Coatings										
			Concrete Coating, Chemical Resistant, CRC-2	111.00 sf	-	-	333	-	-	3.00 /sf	333	6.78 /sf	753



Project: GNH Union Pump Station

Project No.: 478874

Design Stage: Conceptual Estimate Class: 4

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Revision / Date: Rev02 (10-3-2016)

Fac Work	Trade Pkg	Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Finishes, Chemical Resistant Coatings	111.00 SF			333			3.00 /SF	333	6.78 /SF	753
		Electrical Equipment Pads	1.00 CY			333			333.00 /CY	333	752.78 /CY	753
		Electrical Equipment Pad - Generator										
		Finishes, Chemical Resistant Coatings										
		Concrete Coating, Chemical Resistant, CRC-2	135.00 sf	-	-	405		-	3.00 /sf	405	6.78 /sf	916
		Finishes, Chemical Resistant Coatings	135.00 SF 1.00 CY			405 405			3.00 /SF 405.00 /CY	405 405	6.78 /SF 915.54 /CY	916 916
		Electrical Equipment Pad - Generator Finishes	1.00 CY			405			405.00 /CY	405	915.54 /CY	916
		Finishes, Chemical Resistant Coatings Concrete Coating, @ wetwell	4,988.00 sf			24,940			5.00 /sf	24,940	11.30 /sf	56,379
		Concrete Coating, @ wetwell Concrete Coating, @top of roof	2,481.00 sf	-		12,405		-	5.00 /sf	12,405	11.30 /sf	28,043
		Concrete Coating, @screen room floor	402.00 sf	-	-	2,010		-	5.00 /sf	2,010	11.30 /sf	4,544
		Allowance for misc. coatings, prep & paint piping, equipment	1.00 LS	-		25,000		-	25,000.00 /LS	25,000	56,514.57 /LS	56,515
		Finishes, Chemical Resistant Coatings	7,871.00 SF			64,355			8.18 /SF	64,355	18.48 /SF	145,480
		Finishes	1.00 LS			64,355			64,355.00 /LS	64,355	145,479.82 /LS	145,480
		09.10 Finishes, Special Coatings	1.00 LS			65,093			65,093.00 /LS	65,093	147,148.14 /LS	147,148
		09.0 Finishes	1.00 LS			65,093			65,093.00 /LS	65,093	147,148.14 /LS	147,148
10.0		Specialties										
	10.00	Specialties										
		Toilet Accessories										
		Specialties Toilet & Bath Accessories										
		Partitions, toilet, floor mounted, headrail braced, stainless steel	1.00 ea	203	1,175	-	-	-	1,378.39 /ea	1,378	3,198.23 /ea	3,198
		Toilet tissue dispenser, surface mounted, stainless, double roll	1.00 ea	25	23	-	-	-	47.89 /ea	48	109.82 /ea	110
		Toilet Accessories, grab bars, straight, stainless steel, 24" long	1.00 ea 1.00 ea	27	31 37	-	-	-	57.03 /ea 67.50 /ea	57 68	131.07 /ea 155.18 /ea	131
		Toilet Accessories, grab bars, straight, stainless steel, 36" long Toilet Accessories, mirror, 48" x 24", with stainless steel 3/4" square	1.00 ea	61	152		-	-	213.01 /ea	213	155.18 /ea 492.17 /ea	155 492
		frame	1.00 64	"	102	_			210.01 /64	210	432.17 764	732
		Toilet Accessories, soap dispenser, stainless steel, recessed, liquid	1.00 ea	61	166	-	-	-	227.01 /ea	227	524.79 /ea	525
		Toilet Accessories, towel dispenser, stainless steel, surface mounted	1.00 ea	38	48	-	-	-	85.63 /ea	86	196.89 /ea	197
		Toilet Accessories, waste receptacle, stainless steel, w/top, 13 gallon	1.00 ea	61	315	-	-	-	376.01 /ea	376	872.05 /ea	872
		Specialties Toilet & Bath Accessories	8.00 EA	507	1,946				306.56 /EA	2,452	710.03 /EA	5,680
		Toilet Accessories	1.00 LS	507	1,946				2,452.47 /LS	2,452	5,680.20 /LS	5,680
		10.00 Specialties	1.00 LS	507	1,946				2,452.47 /LS	2,452	5,680.20 /LS	5,680
		10.0 Specialties	1.00 LS	507	1,946				2,452.47 /LS	2,452	5,680.20 /LS	5,680
21.0		Fire Suppression										
	21.00	Fire Suppression										
		Sprinkler System										
		Mechanical, Fire Sprinklers System										
		Sprinkler System	928.00 SF	0	0	3,248	-	-	3.50 /SF	3,248	8.09 /SF	7,505
		Mechanical, Fire Sprinklers System	1.00 LS			3,248			3,248.00 /LS	3,248	7,504.78 /LS	7,505
		Sprinkler System	938.00 SF			3,248			3.46 /SF	3,248	8.00 /SF	7,505
		21.00 Fire Suppression	1.00 LS			3,248			3,248.00 /LS	3,248	7,504.78 /LS	7,505
		21.0 Fire Suppression	1.00 LS			3,248			3,248.00 /LS	3,248	7,504.78 /LS	7,505
22.0		Plumbing										
	22.00	Plumbing										
		Plumbing Fixtures										
		Mechanical, Plumbing										
		Water closet, tank type, vitreous china, floor mounted, close coupled,	1.00 ea	261	230	-	-	-	491.11 /ea	491	1,052.62 /ea	1,053
		two piece, includes seat, supply pipe with stop Water closet, tank type, vitreous china, floor mounted, rough-in, supply,	1.00 ea	454	325	-	-	-	778.73 /ea	779	1,666.33 /ea	1,666
		waste and vent, one piece Lavatory, vanity top, stainless steel, self-rimming, ledge, round, single bowl, 18-3/4", includes trim	1.00 ea	216	800	-	-	-	1,016.23 /ea	1,016	2,200.85 /ea	2,201
		Lavatory, vanity top, rough-in, supply, waste and vent Sink, service, stainless steel, self rimming, triple bowl, 22" x 43", includes	1.00 ea 1.00 ea	602 315	218 1,125	-	-	-	819.69 /ea 1,439.52 /ea	820 1,440	1,745.26 /ea 3,116.99 /ea	1,745 3,117
		faucet and drain	4.00				-		000.00 '		4 000 47 1	
		Sink, service, rough-in, supply, waste and vent Industrial safety fixture, eyewash station, stainless steel, pedestal mounted, unmounted, excludes rough-in	1.00 ea 2.00 ea	647 692	247 556	-	-		893.68 /ea 623.97 /ea	894 1,248	1,903.47 /ea 1,336.40 /ea	1,903 2,673
		Drinking fountain, wall mounted, non-recessed, aluminum, dual bubbler type, for connection to cold water supply	1.00 ea	222	2,475	-	-		2,696.85 /ea	2,697	5,865.18 /ea	5,865
		Mechanical, Plumbing	1.00 LS	3,408	5,976				9,383.75 /LS	9,384	20,223.50 /LS	20,224
		Plumbing Fixtures	1.00 LS	3,408	5,976				9,383.75 /LS	9,384	20,223.50 /LS	20,224
		22.00 Plumbing	1.00 LS	3,408	5,976				9,383.75 /LS	9,384	20,223.50 /LS	20,224
		22.0 Plumbing	1.00 LS	3,408	5,976				9,383.75 /LS	9,384	20,223.50 /LS	20,224
23.0		HVAC		2,130	-,	İ		i	.,	2,201	.,	
	23.00	HVAC										



Project: GNH Union Pump Station

Project No.: 478874

Design Stage: Conceptual Estimate Class: 4

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Revision / Date: Rev02 (10-3-2016)

Fac Wor		Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		HVAC										
		Mechanical, HVAC										
		Condensing Unit, 3.5 ton Fans, exhaust	2.00 ea 1.00 ea	2,801 76	12,000 79	-	_	-	7,400.67 /ea 155.23 /ea	14,801 155	16,039.74 /ea 333.15 /ea	32,079 333
		Fans, wall exhauster, centrifugal, auto damper, direct drive, 1/8" S.P.,	3.00 ea	631	4,650		1	-	1,760.20 /ea	5,281	3,823.54 /ea	11,471
		3307 CFM, 3/4 H.P.			·				·	·	·	
		Louver	16.00 sf	318	664	-	-	-	61.36 /sf	982	132.42 /sf	2,119
		AC-1 & AC2 Allowance Misc. HVAC Allowance	2.00 ea 1.00 LS	6,151	41,800	25,000	-	-	23,975.27 /ea 25,000.00 /LS	47,951 25,000	52,064.81 /ea 52,764.58 /LS	104,130 52,765
		Mechanical, HVAC	1.00 LS	9,977	59,193	25,000			94,169.53 /LS	94,170		202,896
		HVAC	1.00 LS	9,977	59,193	25,000			94,169.53 /LS	94,170	202,896.15 /LS	202,896
		HVAC Control Components/DDC Systems,	1100 =0									
		Mechanical, HVAC										
		Control Components/DDC Systems,	1.00 ls	-		-	-	25,000	25,000.00 /ls	25,000	52,764.58 /ls	52,765
		Mechanical, HVAC	1.00 LS					25,000	25,000.00 /LS	25,000	52,764.58 /LS	52,765
		HVAC Control Components/DDC Systems,	1.00 LS					25,000	25,000.00 /LS	25,000	52,764.58 /LS	52,765
		23.00 HVAC	1.00 LS	9,977	59,193	25,000		25,000	119,169.53 /LS	119,170	255,660.73 /LS	255,661
		23.0 HVAC	1.00 LS	9,977	59,193	25,000		25,000	119,169.53 /LS	119,170	255,660.73 /LS	255,661
26.0		Electrical Work										
	26.10	Site Electrical										
		Electrical, Grounding										
		Site Electrical, Grounding										
		CU Bare Stranded #4/0	100.00 lf	363	401	-	-	-	7.64 /lf	764	18.32 /lf	1,832
		Hand Trench and Backfill, includes labor for layout	60.00 lf 4.00 E	968 258	128	-	-	-	16.13 /lf 96.45 /E	968	38.07 /lf 229.91 /E	2,284 920
		Copperclad Ground Rod 3/4" x 10' Compression Lug - 4/0	2.00 E	81	20				50.49 /E	101	119.90 /F	240
		Cadweld Cable to Rod - 250 Max	4.00 E	161	80	-	-	-	60.32 /E	241	143.79 /E	575
		Cadweld Cable to Cable - 250 Max	4.00 E	161	80	-	-	-	60.32 /E	241	143.79 /E	575
		Cadweld Cable to Steel - 250 Max	2.00 E	81	40	-	-	-	60.32 /E	121	143.80 /E	288
		Grounding Bolt and Nut Set Drill and Tap for Ground Connection	2.00 E 2.00 E	8 81	2	-	-	-	5.03 /E 40.57 /E	10		24 192
		Above Grade Ground Wire Supports	6.00 E	48	9				9.56 /E	57		136
		Site Electrical, Grounding	100.00 LF	2,210	761				29.70 /LF	2.970		7.065
		Electrical, Grounding	1.00 LS	2,210	761				2,970.30 /LS	2,970	7,064.90 /LS	7,065
		26.10 Site Electrical	1.00 LS	2,210	761				2,970.30 /LS	2,970	7,064.90 /LS	7,065
	26.15	Process Electrical										
		Electrical, Conduit and Wire/Cable - Power										
		Process Electrical, Wire/Cable										
		THHN-THWN Copper Stranded 1/C # 12	10,880.00 If	6,142	1,079	-	-	-	0.66 /lf	7,221	1.57 /lf	17,120
		THHN-THWN Copper Stranded 1/C # 8	425.00 lf	343	106	-	-	-	1.06 /lf	449	2.51 /lf	1,067
		THHN-THWN Copper Stranded 1/C # 6 THHN-THWN Copper Stranded 1/C # 2	85.00 lf 1.530.00 lf	82 2,221	1,350	-	-	-	1.35 /lf 2.33 /lf	115 3,571	3.22 /lf 5.57 /lf	274 8,524
		THHN-THWN Copper Stranded 1/C # 2/0	255.00 lf	494	434			- 1	3.64 /lf	928	8.71 /lf	2,220
		THHN-THWN Copper Stranded 1/C # 3/0	1,200.00 If	2,613	2,609	-	-	-	4.35 /lf	5,222	10.42 /lf	12,510
		THHN-THWN Copper Stranded 1/C # 350	3,600.00 If	11,612	16,103	-	-	-	7.70 /lf	27,715	18.49 /lf	66,551
		THHN-THWN Copper Stranded 1/C # 500	765.00 If	3,023	4,833	-	-	-	10.27 /lf	7,856	24.68 /lf	18,883
		Stakon Lug #12 - #10 Compression Lug - # 8	256.00 E 10.00 E	2,064	64 23		1	-	8.31 /E 14.40 /E	2,128 144	19.64 /E 34.15 /E	5,029 341
		Compression Lug - # 6	2.00 E	24	4		_	-	14.29 /E	29		68
		Compression Lug - # 2	36.00 E	726	204	-	-	-	25.83 /E	930	61.37 /E	2,209
		Compression Lug - 2/0	6.00 E	194	45	-	-	-	39.78 /E	239		567
		Compression Lug - 3/0	24.00 E 72.00 E	774	220	-	-	-	41.42 /E 62.61 /E	994 4,508	98.41 /E 148.78 /E	2,362
		Compression Lug - 350 MCM Compression Lug - 500 MCM	72.00 E 18.00 E	3,484 1,016	1,024 370	-	-	-	76.99 /E	1,386	148.78 /E 183.18 /E	10,712 3,297
		Motor Hook-up, single phase, 100 hp	1.00 E	645	135		_	-	780.38 /E	780	1,851.63 /E	1,852
		Motor Hook-up, 3 phase, 10 hp	32.00 E	4,645	1,816	-	-	-	201.90 /E	6,461	480.58 /E	15,379
		Motor Hook-up, 3 phase, 50 hp	2.00 E	629	231	-	-	-	430.15 /E	860	1,023.49 /E	2,047
		Equipmenmt Hook-up, 3 phase, 80A	3.00 E	944	347		-	-	430.15 /E	1,290	1,023.50 /E	3,070
		Motor Hook-up, 3 phase, 250 hp Motor Testing & Commissioning: 10HP / 480V / #12	3.00 E 32.00 E	3,387 1,806	531	-		-	1,305.82 /E 56.45 /E	3,917 1,806	3,094.89 /E 133.25 /E	9,285 4,264
		Motor Testing & Commissioning: 10111 / 480V / #12 Motor Testing & Commissioning: 50HP / 480V / #4	2.00 E	177	-			-	88.71 /E	177	209.39 /E	419
		Equipment Testing & Commissioning: 80A / 480V / #4	3.00 E	266		-	-	-	88.71 /E	266	209.40 /E	628
		Motor Testing & Commissioning: 100 HP / 480v / 2/0	1.00 E	266	-	-	-	-	266.12 /E	266	628.22 /E	628
		Motor Testing & Commissioning: 250 HP / 480v / 500 600V Megger Testing	3.00 E 212.00 E	1,427 4,274	-	-	-	-	475.78 /E 20.16 /E	1,427 4,274	1,123.12 /E 47.59 /E	3,369 10,089
		Wire Markers	424.00 E	342	21		1		0.86 /E	363	2.03 /E	859
		Process Electrical, Wire/Cable	18,740.00 LF	53,740	31,583				4.55 /LF	85,323	10.87 /LF	203,623
		Process Electrical, Conduit	.,	,	. ,000							
		GRC Conduit @ Level 2 3/4"	2,400.00 lf	17,031	3,497	-	-	-	8.55 /lf	20,528	20.29 /lf	48,703
		GRC Conduit @ Level 2 1-1/4"	375.00 lf	3,236	1,186			-	11.79 /lf	4,422	28.06 /lf	10,522



Project: GNH Union Pump Station

Project No.: 478874

Design Stage: Conceptual Estimate Class: 4

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Revision / Date: Rev02 (10-3-2016)

Fac Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Process Electrical, Conduit										
		GRC Conduit @ Level 2 2"	75.00 lf	907	333	-		-	16.54 /lf	1,240	39.35 /lf	2,951
		GRC Conduit @ Level 2 3"	1,225.00 lf	24,696	12,308	-	-	-	30.21 /lf	37,004	72.01 /lf	88,214
		GRC Flbow 1-1/4"	96.00 E 15.00 F	1,935	829				28.80 /E 46.40 /F	2,765	68.59 /E 110.80 /E	6,584 1,662
		GRC Elbow 1-1/4"	3.00 E	106	273 98		-	-	46.40 /E 68.01 /E	204	110.80 /E 162.83 /E	1,662
		GRC Elbow 2"	45.00 E	2,722	3,781			-	144.51 /E	6,503	347.01 /E	15,615
		GRC Couplng 3/4"	96.00 E	387	239	<u> </u>		1	6.52 /E	626	15.56 /E	1,494
		GRC Coupling 1-1/4"	15.00 E	85	69				10.25 /E	154		368
		GRC Coupling 2"	3.00 E	22				-	14.94 /E	45	35.79 /E	107
		GRC Coupling 3"	45.00 E	399	1,108			-	33.50 /E	1,508	80.81 /E	3,636
		Rigid Conduit Hub 3/4"	130.00 E	3,250	1,680			-	37.93 /E	4,930	90.43 /E	11,756
		Rigid Conduit Hub 1-1/4"	20.00 E	726	394	-		-	56.00 /E	1,120	133.57 /E	2,671
		Rigid Conduit Hub 2"	4.00 E	168	92	-	-	-	64.83 /E	259	154.63 /E	619
		Rigid Conduit Hub 3"	36.00 E	2,497	1,804	-	-	-	119.45 /E	4,300	285.49 /E	10,277
		Malleable LB Condulet - 3/4"	32.00 E	774	399	-	-	-	36.67 /E	1,174	87.44 /E	2,798
		Malleable LB Condulet - 1-1/4"	5.00 E	161	145		-	-	61.32 /E	307	146.78 /E	734
		Malleable LB Condulet - 2"	1.00 E	44	63 488	-	-	-	107.47 /E	107	258.08 /E	258
		Malleable LB Condulet - 3"	3.00 E	266		-	-	-	251.53 /E	755	605.15 /E	1,815
		Unistrut Straps 3/4"	320.00 E	774 161	591 118	 		 	4.27 /E 5.59 /E	1,365	10.20 /E 13.36 /E	3,264 668
		Unistrut Straps 1-1/4" Unistrut Straps 2"	50.00 E 10.00 E	32	31	 		 	5.59 /E 6.29 /E	279	13.36 /E 15.06 /E	151
		Unistrut Straps 2" Unistrut Straps 3"	160.00 E	645	608			+ + + + + + + + + + + + + + + + + + + +	6.29 /E 7.83 /E	1,253	15.06 /E 18.75 /E	3,000
		Unistrut Conduit Hanger Allowance 3/4"	320.00 E	1,032	320				4.23 /E	1,352	10.04 /E	3,214
		Unistrut Conduit Hanger Allowance 1-1/4"	50.00 E	242	63			-	6.09 /E	304	14.46 /E	723
		Unistrut Conduit Hanger Allowance 2"	10.00 E	48				-	6.34 /E	63	15.07 /E	151
		Unistrut Conduit Hanger Allowance 3"	160.00 E	1,290	320			-	10.06 /E	1,610	23.90 /E	3,824
		EF Sealtite Flex 3/4"	32.00 If	77	79			-	4.89 /lf	156		375
		EF Sealtite Flex 1-1/4"	5.00 If	16	26			-	8.33 /lf	42	20.01 /lf	100
		EF Sealtite Flex 2"	1.00 lf	5	7	-		-	12.24 /lf	12	29.41 /lf	29
		EF Sealtite Flex 3"	11.00 lf	80	193	-		-	24.76 /lf	272		656
		LT Flex Connector Straight 3/4"	64.00 E	464	322	-	-	-	12.30 /E	787	29.38 /E	1,880
		LT Flex Connector Straight 1-1/4"	10.00 E	97	127	-	-	-	22.38 /E	224	53.72 /E	537
		LT Flex Connector Straight 2"	2.00 E	24	66	-	-	-	45.02 /E	90	108.57 /E	217
		LT Flex Connector Straight 3"	22.00 E	390	3,833			-	191.98 /E	4,224	465.38 /E	10,238
		Conduit Wall Penetration - 3"	8.00 E	194	40		-	-	29.19 /E	234	69.26 /E	554
		Fireproof Conduit Wall Penetration - 3"	8.00 E	387	117	-	-	-	63.04 /E	504	149.83 /E	1,199
		Process Electrical, Conduit	4,075.00 LF	65,796	35,686				24.90 /LF	101,482	59.40 /LF	242,054
		Electrical, Conduit and Wire/Cable - Power	1.00 LS	119,537	67,268				186,804.71 /LS	186,805	445,676.85 /LS	445,677
		Electrical, Conduit and Wire/Cable - Controls			<u> </u>				<u> </u>			
		Process Electrical, Wire/Cable			i		'		l .			
		THHN-THWN Copper Stranded 1/C # 14	323,170.00 lf	156,365	20,889			-	0.55 /lf	177,254	1.30 /lf	419,884
		Shielded PLTC / Inst Cable 1 Pair #16	595.00 If	960	268		-	-	2.06 /lf	1,227	4.90 /lf	2,916
		Unshielded Twisted Pair Cable, 4-Pair CAT 6 350Mhz Ultra II	680.00 If	960	265	-	-	-	1.80 /lf	1,225	4.28 /lf	2,910
		UTP Cable Connector, RJ45 CAT 6 Mini-Jack TX-5e (568A/B)	16.00 E	323			-	-	24.51 /E	392	58.16 /E	931
		UTP Patch Cord, RJ45/RJ45 CAT 6E 350Mhz Data-Patch - 5ft	8.00 E	39			-	-	10.19 /E	82	24.43 /E	195
		UTP Wall Plate, 4-Port, CAT 6 350Mhz, RJ45/110 (568B), White	8.00 E	161	15		- '	-	22.06 /E	176	52.21 /E	418
		4 Pair UTP Continuity Test	8.00 E	161		-		-	20.16 /E	161	47.59 /E	381
		4 Pair UTP Certification with Documentation	8.00 E	406					50.80 /E	406	119.93 /E	959
		UTP Cable Supports	48.00 E 979.00 E	194 7,895	24			-	4.53 /E	218 7,895	10.73 /E	515 18,636
		Termination Labor Only - # 16 - #14 Control Wire Testing	979.00 E 486.00 E	3,919		 		 	8.06 /E 8.06 /F	3,919	19.04 /E 19.04 /F	9,251
		Wire Markers	979.00 E	789	49	 		 	0.86 /E	3,919	19.04 /E 2.03 /E	9,251
		Process Electrical, Wire/Cable	324,445.00 LF	172,171	21,623		<u> </u>	1	0.60 /LF	193,794	1.41 /LF	458,979
	_	1	324,443.00 LF	172,171	21,023		+	+	U.OU /LF	193,794	1.41 /LF	400,979
		Process Electrical, Conduit	4.050.00 "	1 00			+	+	0.55 %		20.00 "	0:
	-	GRC Conduit @ Level 2 3/4"	4,650.00 lf	32,998	6,775		+	-	8.55 /lf	39,773	20.29 /lf	94,363
		GRC Elbow 3/4"	186.00 E	3,750	1,607 462			+	28.80 /E 6.52 /E	5,357	68.59 /E 15.56 /E	12,757
		GRC Couplng 3/4" Rigid Conduit Hub 3/4"	186.00 E 124.00 E	750 3,100	1,603	 		 	6.52 /E 37.93 /E	1,212 4,703	90.43 /E	2,894 11,213
		Malleable LB Condulet - 3/4"	62.00 E	1,500	774			 	37.93 /E 36.67 /E	2,274	90.43 /E 87.44 /E	5,421
		Unistrut Straps 3/4"	620.00 E	1,500	1,145			1	4.27 /E	2,274	10.20 /E	6,324
		Unistrut Conduit Hanger Allowance 3/4"	620.00 E	2,000	620			1	4.27 /E 4.23 /E	2,620	10.20 /E	6,228
		EF Sealtite Flex 3/4"	62.00 lf	150	153	·			4.89 /lf	303	11.71 /lf	726
		LT Flex Connector Straight 3/4"	124.00 E	900	625			-	12.30 /E	1,525	29.38 /E	3,643
		Process Electrical, Conduit	4,650.00 LF	46,648	13,764				12.99 /LF	60,411	30.88 /LF	143,570
		Electrical, Conduit and Wire/Cable - Controls	1.00 LS	218.819	35.386				254.204.89 /LS	254,205	602.548.84 /LS	602,549
		Electrical, Grounding	1.00 LO	210,019	55,560			 	204,204.00 /20	204,203	002,040.04 723	002,043
				+			+	1				
		Process Electrical, Grounding	100 1	1000	2.555	-	+		7,000 10 1	+	47 100 04 10	4
		Miscellaneous Grounding	1.00 ls	4,838	2,500			-	7,338.46 /ls	7,338	17,498.04 /ls	17,498
		Barrier Florida Company	4.00 : -	4.000					7 000 40 " -	h	47 400 04 7 7	
		Process Electrical, Grounding Electrical, Grounding	1.00 LF 1.00 LS	4,838 4,838	2,500 2,500		-		7,338.46 /LF 7,338.46 /LS	7,338 7,338	17,498.04 /LF 17,498.04 /LS	17,498 17,498



Project: GNH Union Pump Station

Project No.: 478874

Design Stage: Conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev02 (10-3-2016)

	Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
			26.15 Process Electrical	1.00 LS	343,194	105,155				448,348.06 /LS	448,348	1,065,723.73 /LS	1,065,724
		26.20	Facility Electrical										
			Facility Electrical, Complete \$/SF Cost										
			Facility Electrical, Complete \$/SF Cost										
			PS Building, Electrical Subcontract, Division 16	3,318.00 sf	-	-	61,527	-	-	18.54 /sf	61,527	43.77 /sf	145,23
			Facility Electrical, Complete \$/SF Cost	3,318.00 SF			61,527			18.54 /SF	61,527	43.77 /SF	145,23
			Facility Electrical, Complete \$/SF Cost	1.00 LS			61,527			61,526.78 /LS	61,527	145,239.09 /LS	145,23
			26.20 Facility Electrical	1.00 LS			61,527			61,526.78 /LS	61,527	145,239.09 /LS	145,23
		26.25	Electrical Equipment										
			Electrical Equipment										
			Electrical, Testing										
_			Megger/Check Elec Equipment	1.00 LS	4,838		-	-	-	4,838.46 /LS	4,838	11,421.61 /LS	11,42
_			Electrical, Testing	1.00 LS	4,838					4,838.46 /LS	4,838	11,421.61 /LS	11,42
-			Electrical Equipment, MCCs - General	0.00 F	5 000	04.750				0.005.40 /5	00.550	0.000.00 /F	70.00
-			LV MCC Vertical Sections - 1200A MCC Main Breaker - 1200A	9.00 E 1.00 E	5,806 564	24,750 8,625	-	-	-	3,395.13 /E 9,189.49 /E	30,556 9,189	8,206.98 /E 22,296.29 /E	73,86 22,29
			MCC FVNR Starter w/ Circuit Breaker - Size 1	7.00 E	452	2,324	-		- :	396.51 /E	2,776	959.24 /E	6,71
			MCC Circuit Breaker - <30A	25.00 E	504	5,636			-	245.61 /E	6,140	595.57 /E	14,88
			MCC Circuit Breaker - 80A	1.00 E	60	248			-	307.98 /E	308	744.33 /E	74
_			MCC Circuit Breaker - 90A	3.00 E	181	743	-	-	-	307.98 /E	924	744.34 /E	2,23
-			MCC Circuit Breaker - 175A MCC Circuit Breaker - 400A	1.00 E 4.00 E	101	486 18.800	-	-	-	586.80 /E 5.022.57 /E	587 20.090	1,419.20 /E 12.185.19 /E	1,41 48.74
			Switchboard instruments, ground fault protection, ground return path	1.00 E	1,290	6,750		-	-	5,022.57 /E 6,988.94 /ea	6,989	12,185.19 /E 16,970.46 /ea	48,74 16,97
			Voltage monitor systems, AC voltage remote, add-on det only, w/internal	1.00 ea	239	4,000			- :	4,000.00 /ea	4,000	9,722.34 /ea	9,72
-			modem Transformer, dry-type, ventilated, 3 phase 480 V primary 120/208 V	1.00 ea	143	1,475	-	-	-	1,618.38 /ea	1,618	3,923.57 /ea	3,92
			secondary, 30 kVA Panelboards, 3 phase 4 wire, main lugs, 120/208 V, 100 amp, 30	1.00 ea	122	1,125	-	-	-	1,246.69 /ea	1,247	3,021.67 /ea	3,02
			circuits, NQOD, incl 20 A 1 pole plug-in breakers Electrical Equipment, MCCs - General	1.00 LS	9,463	74,961				84,424.48 /LS	84,424	204,538.30 /LS	204,53
			Electrical Equipment, Switches - General										
			Safety switches, heavy duty, 3 pole, nonfusible, 600 volt, 30 amp, NEMA 3R	25.00 ea	5,283	4,000	-	-	-	371.30 /ea	9,283	887.69 /ea	22,19
			Safety switches, heavy duty, 3 pole, nonfusible, 600 volt, 30 amp, NEMA 3R HVAC	12.00 ea	2,536	1,920	-	-	-	371.30 /ea 753.91 /ea	4,456 754	887.69 /ea	10,65
			Safety switches, heavy duty, 3 pole, nonfusible, 600 volt, 100 amp, NEMA 3R Safety switches, heavy duty, 3 pole, nonfusible, 600 volt, 200 amp,	1.00 ea	364 546	475	-	-	-	1,020.86 /ea	1,021	1,806.98 /ea	2,44
			NEMA 3R Electrical Equipment, Switches - General	1.00 Ea	8,728	6,785	_		-	15,512.91 /LS	15,513	37,094.46 /LS	37,09
			Electrical Equipment, VFDs - General	1.00 LO	0,720	0,700				10,012.01 /20	10,010	31,034.40 720	37,03
			Variable frequency drives, enclosed, 460 volt, 50 HP motor size, NEMA	2.00 ea	4,944	400				2,671.82 /ea	5,344	6,321.07 /ea	12,64
_			1, FBO Variable frequency drives, enclosed, 460 volt, 200 HP motor size, NEMA	3.00 ea	11,674	600	-	771	-	4,348.24 /ea	13,045	10,296.36 /ea	30,88
			1, FBO Electrical Equipment, VFDs - General	1.00 LS	16,617	1,000		771		18,388.35 /LS	18,388	43,531.21 /LS	43,53
			Electrical Equipment, Generators - General Generator set, diesel 1000 kva, incl battery, charger, enclosure, muffler, day	1.00 ea	12,394	298,000		915		311,308.25 /ea	311,308	755,793.08 /ea	755,79
			tank, excl conduit, wiring, & concrete Automatic transfer switches, enclosed, 3 pole, 480 volt, 1200 amp	1.00 ea	1,872	19,400				21,271.52 /ea	21,272	51,571.20 /ea	51,57
			Electrical Equipment, Generators - General	1.00 LS	14,265	317,400		915		332,579.77 /LS	332,580	807,364.28 /LS	807,364
			Electrical Equipment	1.00 LS	53,912	400,146		1,686		455,743.97 /LS	455,744	1,103,949.86 /LS	1,103,95
			26.25 Electrical Equipment	1.00 LS	53,912	400,146		1,686		455,743.97 /LS	455,744	1,103,949.86 /LS	1,103,95
			26.0 Electrical Work	1.00 LS	399,315	506,062	61,527	1,686		968,589.11 /LS	968,589	2,321,977.58 /LS	2,321,97
	32.0		Exterior Improvements			,	0.,0=1	.,,,,,,		,			_,,
		32.45	Fencing										
		02.10	Fencing										
			Fencing, Security										
			Fence, security fence	16.00 If	1,573	1.088	-	709		210.65 /lf	3,370	473.53 /lf	7,57
			Fence, double swing gates	1.00 opng	1,873	1,350	-	341	-	3,563.67 /opng	3,564	7,996.16 /opng	7,99
			Fencing, Security	16.00 LF	3,446	2,438		1,051		433.38 /LF	6,934	973.29 /LF	15,57
			Fencing	16.00 LF	3,446	2,438		1,051		433.38 /LF	6,934	973.29 /LF	15,57
			32.45 Fencing	16.00 LF	3,446	2,438		1,051		433.38 /LF	6,934	973.29 /LF	15,57
		32.50	Site, Improvements		.,	,		,,,,,			.,		.,
			Site Improvements, Pipe Bollards										
			Site Improvements, Bollards										
			Pipe bollards, steel, concrete filled/paint, 8' L x 4' D hole, 12" dia	13.00 ea	2,129	4,420	-			503.76 /ea	6,549	1,137.40 /ea	14,786



Project: GNH Union Pump Station

Project No.: 478874

Design Stage: Conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev02 (10-3-2016)

ac Pkg	rk Trade g Pkg	Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Site Improvements, Bollards	13.00 EA	2,129	4,420				503.76 /EA	6,549	1,137.40 /EA	14,786
		Site Improvements, Pipe Bollards	1.00 LS	2,129	4,420				6,548.85 /LS	6,549	14,786.19 /LS	14,786
		32.50 Site, Improvements	1.00 LS	2,129	4,420				6,548.85 /LS	6,549	14,786.19 /LS	14,78
		32.0 Exterior Improvements	1.00 LS	5,574	6,858		1,051		13,482.97 /LS	13,483	30,358.82 /LS	30,35
33.0		Utilities									-	
	33.05	Buried Process Piping										
		Temporary Bypass Pumping										
		Buried Pipe Specials, Temporary Bypasses										
		Allowance for Bypass Pumping, System Operation	6.00 mon	10,379	24,000		600,000	-	105,729.86 /mon	634,379	246,291.15 /mon	1,477,74
		Buried Pipe Specials, Temporary Bypasses	6.00 EA	10,379	24,000		600,000		105,729.86 /EA	634,379	246,291.15 /EA	1,477,74
		Temporary Bypass Pumping	6.00 MO	10,379	24,000		600,000		105,729.86 /MO	634,379	246,291.15 /MO	1,477,74
		33.05 Buried Process Piping	1.00 LS	10,379	24,000		600,000		634,379.16 /LS	634,379	1,477,746.91 /LS	1,477,74
		33.0 Utilities	1.00 LS	10,379	24,000		600,000		634,379.16 /LS	634,379	1,477,746.91 /LS	1,477,74
40.0		Process Pipe										
	40.00	Exposed Process Pipe										
		12" DI Pipe										
		Process Pipe, Ductile Iron, 12"										
		Install gate valve, Figd, DIP, 12"	2.00 ea	1,022	-		507	-	764.54 /ea	1,529	1,769.00 /ea	3,53
		Gate valve, iron body, dbl disk, Flgd, 250#, NO, 12"	2.00 ea	-	2,888		-	-	1,444.00 /ea	2,888	3,408.68 /ea	6,8
		Install check valve, Flgd, DIP, 12"	2.00 ea	1,022	-	-	507	-	764.54 /ea	1,529	1,769.01 /ea	3,53
	_	Check valve, iron body, swing check, Flgd, 250#, 12" Install magnetic flow meter, 12"	2.00 ea 2.00 ea	1,051	5,742		-	-	2,871.00 /ea 525.25 /ea	5,742 1,051	6,777.23 /ea 1,203.13 /ea	13,55 2,40
		Install 12" DI, flanged, spool <= 10'	10.00 ea	4,815	-		-	-	525.25 /ea 481.48 /ea	4,815	1,203.13 /ea 1,102.87 /ea	11,02
		12" Fabricated DI Spool, FxF, 1' 6" - FURNISH	4.00 ea	4,615	2,516		1		629.00 /ea	2,516	1,484.81 /ea	5,93
		12" Fabricated DI Spool, FxF, 4' 0" - FURNISH	1.00 ea	-	914			-	914.00 /ea	914	2,157.57 /ea	2,15
		12" Fabricated DI Spool, FxF, 5' 0" - FURNISH	5.00 ea	-	5,165		-	-	1,033.00 /ea	5,165	2,438.48 /ea	12,19
		12" DI, FL, EII, 90	4.00 ea	1,926	1,857	-	-	-	945.64 /ea	3,783	2,198.56 /ea	8,79
		12" DI, flanged coupling adapter	4.00 ea	1,793	1,056		-	-	712.22 /ea	2,849	1,649.87 /ea	6,59
		Pipe stand support, CS, 12"	2.00 ea	525	666		-	-	595.63 /ea	1,191	1,387.66 /ea	2,77
		Flow Meters 12" Flow Meter: Electrical Hookup Only, 12"	2.00 ea 2.00 ea	1,532	24,000	<u>-</u>	-	-	12,000.00 /ea 766.09 /ea	24,000 1,532	28,326.99 /ea 1,754.78 /ea	56,65 3,51
		Process Pipe, Ductile Iron, 12"	35.00 LF	13.685	44.804		1.015	-	1.700.10 /LF	59.503	3.985.85 /LF	139.50
		12" DI Pipe	35.00 LF	13,685	44,804		1,015		1,700.10 /LF	59,503	3,985.85 /LF	139,50
		16" DI Pipe	35.00 LF	13,005	44,004		1,015		1,700.10 /LF	39,303	3,903.03 /LF	139,30
		Process Pipe, Ductile Iron, 16"										
		Install gate valve, Flgd, DIP, 16"	4.00 ea	2,963			1,471	_	1,108.58 /ea	4,434	2,565.05 /ea	10,26
		Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 16"	4.00 ea	2,303	31,352		1,471	-	7,838.00 /ea	31,352	18,502.24 /ea	74.00
		Install check valve, Flgd, DIP, 16"	3.00 ea	2,222			1,103	-	1,108.58 /ea	3,326	2,565.05 /ea	7,69
		Check valve, iron body, swing check, Flgd, 250#, 16"	3.00 ea	-	17,226	-	-	-	5,742.00 /ea	17,226	13,554.47 /ea	40,66
		Install magnetic flow meter, 16"	3.00 ea	2,285	-		-	-	761.62 /ea	2,285	1,744.55 /ea	5,23
		Install 16" DI, flanged, spool <= 10'	15.00 ea	11,332	6,114		-	-	755.49 /ea	11,332	1,730.51 /ea	25,95
		16" Fabricated DI Spool, FxF, 1' 0" - FURNISH										
			6.00 ea	-		-	-		1,019.00 /ea	6,114	2,405.44 /ea	
		16" Fabricated DI Spool, FxF, 4' 0" - FURNISH	6.00 ea	-	9,174	-	-	-	1,529.00 /ea	9,174	3,609.33 /ea	14,43 21,65
		16" Fabricated DI Spool, FxF, 4' 0" - FURNISH 16" Fabricated DI Spool, FxF, 4' 6" - FURNISH	6.00 ea 3.00 ea	5.288	9,174 4,842	-	-	-	1,529.00 /ea 1,614.00 /ea	9,174 4,842	3,609.33 /ea 3,809.98 /ea	21,65 11,43
		16" Fabricated DI Spool, FxF, 4' 0" - FURNISH	6.00 ea	- - - 5,288 755	9,174	-	-	-	1,529.00 /ea	9,174	3,609.33 /ea	21,65 11,43 24,54
		16" Fabricated DI Spool, FxF, 4' 0" - FURNISH 16" Fabricated DI Spool, FxF, 4' 6" - FURNISH 16" DI, FL, Ell, 90	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea	755 3,939	9,174 4,842 5,265 652 2,112	-	-	-	1,529.00 /ea 1,614.00 /ea 1,507.70 /ea	9,174 4,842 10,554 1,407 6,051	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea	21,65 11,45 24,54 3,26 14,00
		16" Fabricated DI Spool, FxF, 4' 0" - FURNISH 16" Fabricated DI Spool, FxF, 4' 6" - FURNISH 16" DI, FL, El, 90 16" DI, FL, reducer, 16" x 12" 16" DI, flanged coupling adapter Pipe stand support, CS, 16"	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea	755	9,174 4,842 5,265 652 2,112 1,386	-	-	-	1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea	9,174 4,842 10,554 1,407 6,051 2,437	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea	21,68 11,43 24,54 3,26 14,00 5,67
		16" Fabricated DI Spool, FxF, 4' 0" - FURNISH 16" Fabricated DI Spool, FxF, 4' 6" - FURNISH 16" DI, FL, Ell, 90 16" DI, FL, reducer, 16" x 12" 16" DI, flanged coupling adapter Pipe stand support, CS, 16" Flow Meters 16"	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea	755 3,939 1,051	9,174 4,842 5,265 652 2,112	-	-	-	1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea	9,174 4,842 10,554 1,407 6,051 2,437 48,000	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 37,769.34 /ea	21,6t 11,4t 24,5t 3,2t 14,0t 5,6t 113,3t
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° Fabricated DI Spool, FxF, 4' 6° - FURNISH 16° DI, FL_EII, 90 16° DI, FL_EII, 90 16° DI, FL_EII, 90 16° DI, FL_Teducer, 16° x 12° 16° DI, flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters 16°	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea	755 3,939 1,051 2,540	9,174 4,842 5,265 652 2,112 1,386 48,000	-	-	-	1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 37,769.34 /ea 1,939.50 /ea	21,68 11,43 24,55 3,28 14,00 5,66 113,30 5,8
		16' Fabricated DI Spool, FxF, 4' 0' - FURNISH 16' Fabricated DI Spool, FxF, 4' 6' - FURNISH 16' DI, FL, Ell, 90 16' DI, FL, reducer, 16' x 12' 16' DI, flanged coupling adapter Pipe stand support, CS, 16' Flow Meters 16' Flow Meters Electrical Hookup Only, 16' Process Pipe, Ductile Iron, 16"	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 43.50 LF	755 3,939 1,051 2,540 32,376	9,174 4,842 5,265 652 2,112 1,386 48,000	-	- - - - - - - - - - - - - - - - - - -	-	1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075	3,609,33 /ea 3,809,98 /ea 3,506,16 /ea 3,269,36 /ea 2,334,84 /ea 1,892,67 /ea 37,769,34 /ea 1,939,50 /ea 8,688.82 /LF	21,68 11,43 24,5- 3,26 14,00 5,66 113,30 5,8
		16" Fabricated DI Spool, FxF, 4' 0" - FURNISH 16" Fabricated DI Spool, FxF, 4' 6" - FURNISH 16" DI, FL, El, 90 16" DI, FL, reducer, 16" x' 12" 16" DI, Rianged coupling adapter Pipe stand support, CS, 16" Flow Meters 16" Flow Meter: Electrical Hookup Only, 16" Process Pipe, Ductile Iron, 16" 16" DI Pipe	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea	755 3,939 1,051 2,540	9,174 4,842 5,265 652 2,112 1,386 48,000				1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 37,769.34 /ea 1,939.50 /ea	21,65 11,43 24,54 3,26
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, Ell, 90 16° DI, FL, reducer, 16° X 12° 16° DI, FL, reducer, 16° X 12° 16° DI, flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters: Electrical Hookup Only, 16° Process Pipe, Ductile Iron, 16° 16° DI Pipe 20° DI Pipe	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 43.50 LF	755 3,939 1,051 2,540 32,376	9,174 4,842 5,265 652 2,112 1,386 48,000				1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075	3,609,33 /ea 3,809,98 /ea 3,506,16 /ea 3,269,36 /ea 2,334,84 /ea 1,892,67 /ea 37,769,34 /ea 1,939,50 /ea 8,688.82 /LF	21,68 11,43 24,5- 3,26 14,00 5,66 113,30 5,8
		16' Fabricated DI Spool, FxF, 4' 0' - FURNISH 16' Fabricated DI Spool, FxF, 4' 6' - FURNISH 16' DI, FL, Ell, 90 16' DI, FL, educer, 16' x 12' 16' DI, flanged coupling adapter Pipe stand support, CS, 16' Flow Meters 16' Flow Meters Electrical Hookup Only, 16'' Process Pipe, Ductile Iron, 16'' 16' DI Pipe 20' DI Pipe Process Pipe, Ductile Iron, 20''	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 43.50 LF	755 3,939 1,051 2,540 32,376 32,376	9,174 4,842 5,265 652 2,112 1,386 48,000		2,575	-	1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075	3,609,33 /ea 3,809,98 /ea 3,506,16 /ea 3,269,36 /ea 2,334,84 /ea 1,892,67 /ea 37,769,34 /ea 1,939,50 /ea 8,688,82 /LF 8,688,82 /LF	21,6i 11,4: 24,5: 3,2: 14,0i 5,6i 113,3i 5,8 377,96
		16* Fabricated DI Spool, FxF, 4' 0* - FURNISH 16* Fabricated DI Spool, FxF, 4' 6* - FURNISH 16* DI, FL, Ell. 90 16* DI, FL, reducer, 16* X 12* 16* DI, FL, reducer, 16* X 12* 16* DI, flanged coupling adapter Pipe stand support, CS, 16* Flow Meters 16* Flow Meters 16* Flow Meters Electrical Hookup Only, 16* Process Pipe, Ductile Iron, 16* 16* DI Pipe 20* DI Pipe Process Pipe, Ductile Iron, 20* Install gate valve, Flgd, DIP, 20*	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 3.00 ea 43.50 LF 43.50 LF	755 3,939 1,051 2,540 32,376	9,174 4,842 5,265 652 2,112 1,386 48,000 - 126,123				1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 1,337.95 /ea	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 3,7769.34 /ea 1,939.50 /ea 8,688.82 /LF 8,688.82 /LF	21,6i 11,4: 24,5: 3,2i 14,0i 5,6i 113,3i 5,8 377,96
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° Fabricated DI Spool, FxF, 4' 6° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, Ell, 90 16° DI, FL, reducer, 16° x 12° 16° DI, flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters 16° Tell Meters Electrical Hookup Only, 16° Process Pipe, Ductile Iron, 16° 16° DI Pipe 20° DI Pipe Process Pipe, Ductile Iron, 20° Install gate valve, Figd, DIP, 20° Install gate valve, Figd, DIP, 20° Gate valve, iron body, did lisk, Figd, 250#, HWO, 20°	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 3.00 ea 3.00 EF 43.50 LF	755 3,939 1,051 2,540 32,376 32,376	9,174 4,842 5,265 652 2,1112 1,386 45,000 - 126,123 126,123		2,575		1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 37,769.34 /ea 1,939.50 /ea 8,688.82 /LF 8,688.82 /LF	21,6: 11,4: 24,5: 3,2: 14,0: 5,6: 113,3: 5,8: 377,9: 6,1: 5,6:
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° Fabricated DI Spool, FxF, 4' 6° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, educer, 16° x 12° 16° DI, FL, reducer, 16° x 12° 16° DI, Flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters 16° Flow Meters Electrical Hookup Only, 16° Process Pipe, Ductile Iron, 16° 16° DI Pipe 20° DI Pipe Process Pipe, Ductile Iron, 20° Install gate valve, Flgd, DIP, 20° Gate valve, Flgd, DIP, 20° Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 20° 20° DI, FL, Ell, 90	6.00 ea 3.00 ea 7.00 ea 1.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 43.50 LF 43.50 LF	755 3,939 1,051 2,540 32,376 32,376	9,174 4,842 5,265 652 2,1112 1,336 48,000 - 126,123 126,123 - 24,750 2,489		2,575		1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,407.39 /ea 1,08.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF 1,337.95 /ea 12,375.00 /ea 2,122.35 /ea	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075 2,676 24,750 4,245	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 37,769.34 /ea 1,939.50 /ea 8,688.82 /LF 8,688.82 /LF 3,095.75 /ea 29,212.21 /ea 4,948.51 /ea	21,6: 11,4: 24,5: 3,2: 14,0: 5,6: 113,3: 377,9: 377,9: 6,1: 58,4: 9,8:
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, Ell, 90 16° DI, FL, reducer, 16° x 12° 16° DI, FL, reducer, 16° x 12° 16° DI, Flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters 16° Flow Meters Electrical Hookup Only, 16° Process Pipe, Ductille Iron, 16° 16° DI Pipe 20° DI Pipe Process Pipe, Ductille Iron, 20° Install gate valve, Figd, DIP, 20° Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 20° 20° DI, FL, Ell, 90 20° DI, FL, Fl, reducer, 20° x 12°	6.00 ea 3.00 ea 7.00 ea 1.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 43.50 LF 43.50 LF	755 3,939 1,051 2,540 32,376 32,376	9,174 4,842 5,265 652 2,1112 1,386 45,000 - 126,123 126,123		2,575		1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 37,769.34 /ea 1,939.50 /ea 8,688.82 /LF 8,688.82 /LF	21,6: 11,4: 24,5: 3,2: 14,0; 5,6: 113,3: 5,8: 377,9: 6,1: 58,4: 9,8:
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° Fabricated DI Spool, FxF, 4' 6° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, educer, 16° x 12° 16° DI, FL, reducer, 16° x 12° 16° DI, Flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters 16° Flow Meters Electrical Hookup Only, 16° Process Pipe, Ductile Iron, 16° 16° DI Pipe 20° DI Pipe Process Pipe, Ductile Iron, 20° Install gate valve, Flgd, DIP, 20° Gate valve, Flgd, DIP, 20° Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 20° 20° DI, FL, Ell, 90	6.00 ea 3.00 ea 7.00 ea 1.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 43.50 LF 43.50 LF	755 3,939 1,051 2,540 32,376 32,376 1,788 - 1,756 878	9,174 4,842 5,265 662 2,1112 1,386 48,000 126,123 126,123 24,750 2,489		2,575		1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF 1,337.95 /ea 12,375.00 /ea 2,122.35 /ea	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075	3,609,33 /ea 3,809,98 /ea 3,506,16 /ea 3,269,36 /ea 2,334,84 /ea 1,892,67 /ea 37,769,34 /ea 1,939,50 /ea 8,688,82 /LF 8,688,82 /LF 3,095,75 /ea 29,212,21 /ea 4,948,51 /ea 4,167,79 /ea	21,68 11,43 24,5- 3,26 14,00 5,66 113,30 5,8
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° Fabricated DI Spool, FxF, 4' 6° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, Ell, 90 16° DI, FL, educer, 16° x 12° 16° DI, flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters Electrical Hookup Only, 16° Process Pipe, Ductile Iron, 16° 16° DI Pipe 20° DI Pipe Process Pipe, Ductile Iron, 20° Install gate valve, Flgd, DIP, 20° Cate valve, iron body, dbl disk, Flgd, 250#, HWO, 20° 20° DI, FL, Ell, 90 20° DI, FL, reducer, 20° x 16°	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 3.00 ea 2.00 ea 2.00 ea 2.00 ea 1.00 ea 1.00 ea	755 3,939 1,051 2,540 32,376 32,376 1,788 - 1,756 878	9,174 4,842 5,265 652 2,1112 1,386 48,000 - 126,123 126,123 - 24,750 2,489 914 1,032		2,575 888 - -		1,529.00 /ea 1,614.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF 1,337.95 /ea 12,375.00 /ea 2,122.35 /ea 1,791.61 /ea 1,910.24 /ea	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075 2,676 24,750 4,245 1,792 1,910	3,609,33 /ea 3,809,98 /ea 3,506,16 /ea 3,269,36 /ea 2,334,84 /ea 1,892,67 /ea 37,769,34 /ea 1,939,50 /ea 8,688.82 /LF 8,688.82 /LF 3,095,75 /ea 29,212,21 /ea 4,948,51 /ea 4,167,79 /ea 4,447.83 /ea	21,61 11,4,4 24,5, 3,2(14,0) 5,61 113,3(5,8, 377,9(377,9(6,1) 5,8,4, 9,88 4,1(4,4,4
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, Ell, 90 16° DI, FL, Ell, 90 16° DI, FL, reducer, 16° x 12° 16° DI, Flaged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters 16° Flow Meters Electrical Hookup Only, 16° Process Pipe, Ductille Iron, 16° 16° DI Pipe 20° DI Pipe Process Pipe, Ductille Iron, 20° Install gate valve, Flgd, DIP, 20° Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 20° 20° DI, FL, Ell, 90 20° DI, FL, Educer, 20° x 16° Process Pipe, Ductile Iron, 20° 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20° 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20° 20° DI Pipe	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 3.00 ea 43.50 LF 43.50 LF 2.00 ea 2.00 ea 2.00 ea 1.00 ea 1.00 ea	755 3,939 1,051 2,540 32,376 32,376 1,788 1,756 878 878 878 5,300	9,174 4,842 5,265 652 2,1112 1,366 48,000 126,123 126,123 126,123 24,750 2,489 914 1,032 29,184		2,575 888 		1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF 1,337.95 /ea 12,375.00 /ea 2,122.35 /ea 1,791.61 /ea 1,910.24 /ea 35,372.43 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075 2,676 24,750 4,245 1,792 1,910 35,372	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 3,7769.34 /ea 1,939.50 /ea 8,688.82 /LF 3,095.75 /ea 29,212.21 /ea 4,948.51 /ea 4,167.79 /ea 4,447.83 /ea 83,128.56 /LF	21.6 11.4 24.5 3.2 14.0 5.6 113.3 5.8 377.9 6.1 56.4 9.8 4.1 4.4 4.4 83.1;
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° Fabricated DI Spool, FxF, 4' 6° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, Ell, 90 16° DI, FL, educer, 16° x 12° 16° DI, flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters 16° Flow Meters Electrical Hookup Only, 16° Process Pipe, Ductile Iron, 16" 16° DI Pipe 20° DI Pipe Process Pipe, Ductile Iron, 20" Install gate valve, Figd, DIP, 20° Gate valve, iron body, dib disk, Figd, 250#, HWO, 20° 20° DI, FL, Ell, 90 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20" 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20" 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20" 20° DI Pipe	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 3.00 ea 43.50 LF 43.50 LF 2.00 ea 2.00 ea 2.00 ea 1.00 ea 1.00 ea	755 3,939 1,051 2,540 32,376 32,376 1,788 1,756 878 878 878 5,300	9,174 4,842 5,265 652 2,1112 1,366 48,000 126,123 126,123 126,123 24,750 2,489 914 1,032 29,184		2,575 888 		1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF 1,337.95 /ea 12,375.00 /ea 2,122.35 /ea 1,791.61 /ea 1,910.24 /ea 35,372.43 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075 2,676 24,750 4,245 1,792 1,910 35,372	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 3,7769.34 /ea 1,939.50 /ea 8,688.82 /LF 3,095.75 /ea 29,212.21 /ea 4,948.51 /ea 4,167.79 /ea 4,447.83 /ea 83,128.56 /LF	21.6 11.4 24.5 3.2 14.0 5.6 113.3 5.8 377.9 6.1 56.4 9.8 4.1 4.4 4.4 83.1;
		16' Fabricated DI Spool, FxF, 4' 0' - FURNISH 16' Fabricated DI Spool, FxF, 4' 6' - FURNISH 16' DI, FL, Ell. 90 16' DI, FL, reducer, 16' x 12' 16' DI, Flanged coupling adapter Pipe stand support, CS, 16' Flow Meters 16' Flow Meters 16' Flow Meters Electrical Hookup Only, 16' Process Pipe, Ductile Iron, 16'' 16' DI Pipe 20' DI Pipe Process Pipe, Ductile Iron, 20'' Install gate valve, Flgd, DIP, 20' Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 20' 20' DI, FL, reducer, 20' x 12' 20' DI, FL, reducer, 20' x 16' Process Pipe, Ductile Iron, 20'' 20' DI Pipe	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 3.00 ea 43.50 LF 43.50 LF 2.00 ea 2.00 ea 2.00 ea 1.00 ea 1.00 ea	755 3,939 1,051 2,540 32,376 32,376 1,788 1,788 878 878 5,300 5,300	9,174 4,842 5,265 652 2,1112 1,366 48,000 126,123 126,123 126,123 24,750 2,489 914 1,032 29,184		2,575 888 		1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF 1,337.95 /ea 12,375.00 /ea 2,122.35 /ea 1,791.61 /ea 1,910.24 /ea 35,372.43 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075 2,676 24,750 4,245 1,792 1,910 35,372	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 3,7769.34 /ea 1,939.50 /ea 8,688.82 /LF 3,095.75 /ea 29,212.21 /ea 4,948.51 /ea 4,167.79 /ea 4,447.83 /ea 83,128.56 /LF	21.6 11.4 24.5 3.2 14.0 5.6 113.3 5.8 377.9 377.9 6.1 58.4 4.4 4.4 4.3 83.1
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° Fabricated DI Spool, FxF, 4' 6° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, Ell, 90 16° DI, FL, educer, 16° x 12° 16° DI, flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters 16° Flow Meters Electrical Hookup Only, 16° Process Pipe, Ductile Iron, 16" 16° DI Pipe 20° DI Pipe Process Pipe, Ductile Iron, 20" Install gate valve, Figd, DIP, 20° Gate valve, iron body, dib disk, Figd, 250#, HWO, 20° 20° DI, FL, Ell, 90 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20" 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20" 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20" 20° DI Pipe	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 3.00 ea 3.00 ea 2.00 ea 2.00 ea 2.00 ea 1.00 ea 1.00 ea 1.00 ea	755 3,939 1,051 2,540 32,376 32,376 1,788 1,756 878 878 878 5,300	9,174 4,842 5,265 652 2,1112 1,366 48,000 126,123 126,123 126,123 24,750 2,489 914 1,032 29,184		2,575 888 - - - - - - - - - - - - -		1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF 1,337.95 /ea 12,375.00 /ea 2,122.35 /ea 1,910.24 /ea 1,910.24 /ea 35,372.43 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075 2,676 24,750 4,245 1,792 1,910 35,372	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 3,7769.34 /ea 1,939.50 /ea 8,688.82 /LF 3,095.75 /ea 29,212.21 /ea 4,948.51 /ea 4,167.79 /ea 4,447.83 /ea 83,128.56 /LF	21.6 11.4 24.5 3.2 14.0 5.6 113.3 5.8 377.9 6.1 56.4 9.8 4.1 4.4 4.4 83.1;
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, Ell, 90 16° DI, FL, reducer, 16° x 12° 16° DI, FL, reducer, 16° x 12° 16° DI, Flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters 16° Flow Meters 16° Process Pipe, Ductile Iron, 18° 16° DI Pipe 20° DI Pipe 20° DI Pipe Process Pipe, Ductile Iron, 20° Install gate valve, Figd, DIP, 20° Gate valve, iron body, dbl disk, Figd, 250#, HWO, 20° 20° DI, FL, Ell, 90 20° DI, FL, Educer, 20° x 16° Process Pipe, Ductile Iron, 20° 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20° 20° DI Pipe 24° DI Pipe 24° DI Pipe Process Pipe, Ductile Iron, 24″ Install gate valve, Figd, DIP, 24°	6.00 ea 3.00 ea 7.00 ea 1.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 3.00 ea 43.50 LF 43.50 LF 2.00 ea 2.00 ea 1.00 ea 1.00 LF 1.00 LF	755 3,939 1,051 2,540 32,376 32,376 1,788 1,788 878 878 5,300 5,300	9,174 4,842 5,265 662 2,1112 1,386 48,000 126,123 126,123 24,750 2,489 914 1,032 29,184 29,184		2,575 888 - - - - - - - - - - - - -		1,529.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF 1,337.95 /ea 12,375.00 /ea 2,122.35 /ea 1,791.61 /ea 1,910.24 /ea 35,372.43 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075 2,676 24,750 4,245 1,792 1,910 35,372 35,372	3,609,33 /ea 3,809,98 /ea 3,506,16 /ea 3,269,36 /ea 2,334,84 /ea 1,892,67 /ea 37,769,34 /ea 1,939,50 /ea 8,688,82 /LF 8,688,82 /LF 3,095,75 /ea 29,212,21 /ea 4,948,51 /ea 4,167,79 /ea 4,447,83 /ea 83,128,56 /LF 83,128,56 /LF	21.6 11.4 24.5 3.2 14.0 5.6 113.3 5.8 377.9 377.9 6.1 58.4 9.8 4.1 4.4 83.1:
		16° Fabricated DI Spool, FxF, 4' 0° - FURNISH 16° Fabricated DI Spool, FxF, 4' 6° - FURNISH 16° DI, FL, Ell, 90 16° DI, FL, Ell, 90 16° DI, FL, educer, 16° x 12° 16° DI, flanged coupling adapter Pipe stand support, CS, 16° Flow Meters 16° Flow Meters Electrical Hookup Only, 16° Process Pipe, Ductile Iron, 16° 16° DI Pipe 20° DI Pipe Process Pipe, Ductile Iron, 20° Install gate valve, Figd, DIP, 20° Cate valve, iron body, dib disk, Figd, 250#, HWO, 20° 20° DI, FL, Ell, 90 20° DI, FL, Educer, 20° x 12° 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20° 20° DI, FL, reducer, 20° x 16° Process Pipe, Ductile Iron, 20° 20° DI, FL, Fuelucer, 20° x 16° Process Pipe, Ductile Iron, 20° 20° DI, FL, Fuelucer, 20° x 16° Process Pipe, Ductile Iron, 20° 21° DI Pipe 24° DI Pipe Process Pipe, Ductile Iron, 24° Install gate valve, Figd, DIP, 24° Install gate valve, Figd, DIP, 24° Install gate valve, Figd, DIP, 24°	6.00 ea 3.00 ea 7.00 ea 1.00 ea 6.00 ea 3.00 ea 3.00 ea 3.00 ea 3.00 ea 2.00 ea 2.00 ea 1.00 ea 1.00 LF 1.00 LF	755 3,939 1,051 2,540 32,376 32,376 1,788 - 1,786 878 5,300 5,300	9,174 4,842 5,265 662 2,1112 1,386 48,000 126,123 126,123 24,750 2,489 914 1,032 29,184 29,184		2,575 888 - - - - - - - - - - - - -		1,529.00 /ea 1,614.00 /ea 1,614.00 /ea 1,507.70 /ea 1,407.39 /ea 1,008.57 /ea 812.17 /ea 16,000.00 /ea 846.73 /ea 3,702.86 /LF 3,702.86 /LF 1,337.95 /ea 12,375.00 /ea 2,122.35 /ea 1,791.61 /ea 1,910.24 /ea 35,372.43 /LF 35,372.43 /LF	9,174 4,842 10,554 1,407 6,051 2,437 48,000 2,540 161,075 161,075 2,676 24,750 4,245 1,792 1,910 35,372 35,372 3,160 33,000	3,609.33 /ea 3,809.98 /ea 3,506.16 /ea 3,269.36 /ea 2,334.84 /ea 1,892.67 /ea 37,769.34 /ea 1,939.50 /ea 8,688.82 /LF 8,688.82 /LF 3,095.75 /ea 29,212.21 /ea 4,948.51 /ea 4,167.79 /ea 4,447.83 /ea 83,128.56 /LF 83,655.92 /ea 36,949.62 /ea	21.6 11.4 24.5 3.2 14.0 5.6 113.3 5.8 377.9 377.9 6.1 5.8 4.1 4.4 83.1: 83.1



Project: GNH Union Pump Station

Project No.: 478874 Revision / Date: Rev02 (10-3-2016)

Design Stage: Conceptual Estimate Class: 4

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

ac Work	Trade Pkg	Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Process Pipe, Ductile Iron, 24"										
		24" Fabricated DI Spool, FxF, 9' 6" - FURNISH	1.00 ea	-	4,152	-	-	-	4,152.00 /ea	4,152	9,801.14 /ea	9,80
		24" DI, FL, EII, 90	2.00 ea	2,098	4,102	-	-	-	3,099.86 /ea	6,200	7,244.05 /ea	14,48
		24" DI, FL, wye, red, 24" x 12" 24" DI, FL, wye, red, 24" x 16"	2.00 ea 3.00 ea	2,623 3,934	6,350 15,005		-	-	4,486.58 /ea 6.313.04 /ea	8,973 18,939	10,499.16 /ea 14.810.66 /ea	20,99
		24" DI, FL, Wye, red, 24" x 16 24" DI, FL, blind flange	1.00 ea	985	963			-	1,948.19 /ea	1,948	4,529.92 /ea	44,43
		24" DI, FL, reducer, 24" x 16"	2.00 ea	2,098	2,780			-	2,438.96 /ea	4,878	5,683.94 /ea	11,36
		Process Pipe, Ductile Iron, 24"	34.50 LF	19.092	79.363		1.048		2.884.17 /LF	99.504	6.769.59 /LF	233.55
		24" DI Pipe	34.50 LF	19,092	79,363		1,048		2,884.17 /LF	99,504	6,769.59 /LF	233,55
		40.00 Exposed Process Pipe	35.00 LF	70,454	279,475		5,526		10,155.84 /LF	355,454	23,832.79 /LF	834,14
		40.0 Process Pipe	1.00 LF	70,454	279,475		5,526		355,454.26 /LF	355,454	834,147.62 /LF	834,14
40.9		Instrumentation & Controls		,								
10.0	40.90	Instrumentation & Controls										
	10.00	Instrumentation & Controls										
		I&C, Flow / Mag Meter / Indicators & Transmitters										
		FE - Flow Element - Mag Flowtube (inline)	5.00 ea	806	250				211.28 /ea	1,056	502.25 /ea	2,51
		FT / FIT - Flow Transmitter - Magnetic, 12"	2.00 ea	1,532	18,000			-	9,766.09 /ea	19,532	23,683.67 /ea	47,36
		FT / FIT - Flow Transmitter - Magnetic, 16"	3.00 ea	2,540	36,000	-	-	-	12,846.73 /ea	38,540	31,165.77 /ea	93,49
		I&C, Flow / Mag Meter / Indicators & Transmitters	10.00 EA	4,879	54,250				5,912.88 /EA	59,129	14,337.59 /EA	143,37
		I&C, Level / Indicators & Transmitters										
		LE - Level Element / Sensor	2.00 ea	40	100			-	70.16 /ea	140	169.12 /ea	33
		LT / LIT - Level Transmitter	2.00 ea	363	2,550		-	-	1,456.44 /ea	2,913	3,527.30 /ea	7,05
		I&C, Level / Indicators & Transmitters	4.00 EA	403	2,650				763.30 /EA	3,053	1,848.21 /EA	7,39
		I&C, Pressure / Indicators & Transmitters										
		PI - Pressure Indicator - Stem Mounted	5.00 ea	202	1,625	-	-	-	365.32 /ea	1,827	885.12 /ea	4,42
		PE - Diaphragm Seal	5.00 ea	605	2,125	-	-	-	545.96 /ea	2,730	1,318.54 /ea	6,59
		I&C, Pressure / Indicators & Transmitters	10.00 EA	806	3,750				455.64 /EA	4,556	1,101.83 /EA	11,01
		I&C, Other / Switches										
		Control Stations	37.00 E	2,984	16,544		-	-	527.78 /E	19,528	1,277.17 /E	47,25
		I&C, Other / Switches	37.00 EA	2,984	16,544				527.78 /EA	19,528	1,277.17 /EA	47,25
		I&C, Panels & Stands										
		Instrument Stand-Single, Galv.	44.00 ea	4,435	2,200		-	-	150.80 /ea	6,635	359.48 /ea	15,81
		I&C, Panels & Stands	44.00 EA	4,435	2,200				150.80 /EA	6,635	359.48 /EA	15,81
		I&C, PLC, Control Panels, Network Hardware										
		Network Hardware Ethernet Radio [Wireless] - SCADA	1.00 ls 1.00 ea	645 3,226	5,000 25,000		-	-	5,645.13 /ls 28,225.64 /ea	5,645 28,226	13,675.82 /ls 68,378.95 /ea	13,67 68,37
		Local Control Panel, Odor Control, FBO	1.00 ea	1,210	25,000				1,409.62 /ea	1,410	3,341.54 /ea	3,34
		Local Control Panel, Sump Pump Controller, FBO	1.00 ea	1,210	200			-	1,409.62 /ea	1,410	3,341.53 /ea	3,34
		Local Control Panel, Generator Control, FBO	1.00 ea	1,210	200		-	-	1,409.62 /ea	1,410	3,341.53 /ea	3,34
		Union PS - PLC Cabinet	1.00 ea	3,226	30,000	-	-	-	33,225.64 /ea	33,226	80,531.88 /ea	80,53
		I&C, PLC, Control Panels, Network Hardware	6.00 EA	10,725	60,600				11,887.55 /EA	71,325	28,768.54 /EA	172,61
		I&C, Sotfware, Programming										
		SCADA Software Licenses	1.00 ea		3,500		-	-	3,500.00 /ea	3,500	8,507.05 /ea	8,50
		PLC / SCADA Software Development	184.00 pts	66,771		-	-	-	362.89 /pts	66,771	856.62 /pts	157,61
		I&C, Sotfware, Programming	184.00 EA	66,771	3,500				381.91 /EA	70,271	902.85 /EA	166,12
		I&C, Instrument Tubing, Piping, etc.										
		Press Gauge / Press Sw Installation Materials - Stainless	5.00 ea	1,048	750		-	-	359.67 /ea	1,798	859.52 /ea	4,29
		I&C, Instrument Tubing, Piping, etc.	1.00 LF	1,048	750				1,798.33 /LF	1,798	4,297.59 /LF	4,29
		I&C, Other										
		Receive & Store Instrument	50.00 ea	1,411	1		-	-	28.23 /ea	1,412	66.65 /ea	3,33
		Identification Tag - SS Field Calibration - Simple	50.00 ea 5.00 ea	1,008	750		-	-	35.16 /ea 40.32 /ea	1,758 202	84.05 /ea 95.18 /ea	4,20 47
		Field Calibration - Average	44.00 ea	10,645				1	241.92 /ea	10,645	571.08 /ea	25,12
		Field Calibration - Severe	1.00 ea	484			1 -		483.85 /ea	484	1,142.18 /ea	1,14
		Pre-Operation Check	50.00 ea	3,770			-	-	75.40 /ea	3,770	177.99 /ea	8,89
		Startup - Stand-By (Manhours)	49.00 ea	3,468			-	-	70.77 /ea	3,468	167.05 /ea	8,18
	-	Loop Check - Average	49.00 ea	6,935		-	-	-	141.53 /ea	6,935	334.10 /ea	16,37
		I&C, Other	50.00 EA	27,922	751				573.45 /EA	28,672	1,354.72 /EA	67,73
		Instrumentation & Controls	1.00 LS	119,974	144,995		1		264,968.35 /LS	264,968	635,629.49 /LS	635,62
		40.90 Instrumentation & Controls	1.00 LS	119,974	144,995				264,968.35 /LS	264,968	635,629.49 /LS	635,62
		40.9 Instrumentation & Controls	1.00 LS	119,974	144,995				264,968.35 /LS	264,968	635,629.49 /LS	635,62
41.0		Bulk Material Processing Equipment										
	41.00	Material Handling Equipment										
		Monorail Crane										
		Material Handling, Monorail Cranes										
		Monorail Cranes, under hung hoist, electric operating, 7.5 ton,	1.00 ea	3,152	30,000		1,360	-	34,511.73 /ea	34,512	78,486.25 /ea	78,48
		Material Handling, Monorail Cranes	1.00 EA	3,152	30.000		1,360		34,511.73 /EA	34.512		78.48



Project: GNH Union Pump Station

Project No.: 478874

Design Stage: Conceptual Estimate Class: 4

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Revision / Date: Rev02 (10-3-2016)

Design Grage. Conceptual Estimate Class

Work Pkg		Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Monorail Crane	1.00 EA	3,152	30,000		1,360		34,511.73 /EA	34,512	78,486.25 /EA	78,48
		41.00 Material Handling Equipment	1.00 LS	3,152	30,000		1,360		34,511.73 /LS	34,512	78.486.25 /LS	78,48
		41.0 Bulk Material Processing Equipment	1.00 LS	3,152	30.000		1,360		34.511.73 /LS	34.512	78.486.25 /LS	78,48
43.0		Process Equipment - Industrial					1,000				13,1222	
10.0	43.05	Furnish and Install Process Equipment										
	43.03	Wet Weather - 250 HP Flowserve Pump										
		Vertical Centrifugal Pump: 101hp-500hp										
	_	Functional Testing, Pumps, 101-500 hp	3.00 ea	902	300				400.80 /ea	1,202	913.04 /ea	2.73
		Align Pump & Motor, 101-500 hp	3.00 ea	1,354	300	3,150		-	1,501.20 /ea	4,504	3,393.59 /ea	10,18
		Vibration Testing, Pumps, 101-500 hp	3.00 ea	451	-	1,050		-	500.40 /ea	1,501	1,131.20 /ea	3,39
		Witnessed factory test	3.00 ea	-		1,500		1,500	1,000.00 /ea	3,000	2,260.58 /ea	6,78
		Local panel	3.00 ea	1,354	4,500		-	-	1,951.20 /ea	5,854	4,515.86 /ea	13,54
		Pressure indicators	6.00 ea	677	1,500		-	-	362.80 /ea	2,177	837.64 /ea	5,02
		Sleeved anchor bolts - Medium	24.00 ea	632	504		-	-	47.32 /ea	1,136	108.44 /ea	2,60
		Non-Shrink Machine Grout	24.00 cuft	1,715	1,776	-	-	-	145.44 /cuft	3,491	333.96 /cuft	8,01
		Grease, Oil, and Lube Pumps, 101-500 hp	3.00 ea	902	225	-		-	375.80 /ea	1,127	854.78 /ea	2,56
		FURNISH Vertical Centrifugal Pump, 101 - 500 hp	3.00 EA	13,536	450,000	-	-	-	150,000.00 /EA	450,000	349,587.49 /EA	1,048,76
		Set pump assembly, 101 - 500 hp Vertical Centrifugal Pump: 101hp-500hp	3.00 ea 3.00 EA	21,522	150 458,955	5,700	-	1,500	4,562.00 /ea 162,559.08 /EA	13,686 487,677	10,316.28 /ea 378,187.29 /EA	30,94 1,134,56
	_	Wet Weather - 250 HP Flowserve Pump	3.00 EA	21,522	458,955	5,700		1,500	162,559.08 /EA	487,677	378,187.29 /EA	1,134,56
		Dry Weather - 50 HP Flowserve Pump										
		Vertical Centrifugal Pump: 21hp-50hp										
		Functional Testing, Pumps, 21-50 hp	2.00 ea	301	100	-	-	-	200.40 /ea	401	456.53 /ea	91
		Align Pump & Motor, 21-50 hp	2.00 ea	451	-	1,050	-	-	750.60 /ea	1,501	1,696.80 /ea	3,39
		Vibration Testing, Pumps, 21-50 hp	2.00 ea 2.00 ea	150	-	350 1,000	-	1,000	250.20 /ea 1,000.00 /ea	500 2,000	565.59 /ea 2,260.60 /ea	1,13 4,52
		Witnessed factory test Local panel	2.00 ea	902	3.000	1,000		1,000	1,951.20 /ea	3,902	2,260.60 /ea 4.515.84 /ea	9,03
		Pressure indicators	4.00 ea	451	1,000				362.80 /ea	1,451	837.65 /ea	3,35
		Sleeved anchor bolts - Small	12.00 ea	271	144			-	34.56 /ea	415	78.96 /ea	94
		Non-Shrink Machine Grout	8.00 cuft	572	592			-	145,44 /cuft	1,164	333.96 /cuft	2,67
		Grease, Oil, and Lube Pumps, 21-50 hp	2.00 ea	301	150	-	-	-	225.40 /ea	451	514.79 /ea	1,03
		FURNISH Vertical Centrifugal Pump, 21 - 50 hp	2.00 EA	-	250,000	-	-	-	125,000.00 /EA	250,000	291,322.91 /EA	582,64
		Set pump assembly, 21 - 50 hp	2.00 ea	4,813	50		-	-	2,431.40 /ea	4,863	5,498.14 /ea	10,99
		Vertical Centrifugal Pump: 21hp-50hp	2.00 EA	8,212	255,036	2,400		1,000	133,323.92 /EA	266,648	310,316.09 /EA	620,63
		Dry Weather - 50 HP Flowserve Pump	2.00 EA	8,212	255,036	2,400		1,000	133,323.92 /EA	266,648	310,316.09 /EA	620,63
		Channel Grinders										
		Channel Grinders										
		Channel Grinders	2.00 ea	8,000	182,000			-	95,000.00 /ea	190,000	221,125.41 /ea	442.25
		Channel Grinders	2.00 EA	8,000	182,000				95,000.00 /EA	190,000	221,125.41 /EA	442,25
		Channel Grinders	2.00 EA	8.000	182,000				95.000.00 /EA	190,000	221,125.41 /EA	442,25
		42" x 42" Sluice Gate	2.00 2/1	0,000	.02,000				00,000.00 /2/1	100,000	221,120111 /211	112,20
		Sluice Gates, Rectangular, 42"										
		42" Wide Rectangular Sluice Gate - FURNISH	5.00 ea		32,500				6,500.00 /ea	32,500	15,148.80 /ea	75,74
		42" Wide Rectangular Sluice Gate - PORNISH 42" Wide Rectangular Sluice Gate - Installation	5.00 ea	10,528	32,500	-		-	2,105.60 /ea	10,528	4,759.88 /ea	23,79
		Grout Behind Gate Frame	4.19 cf	472	151			- 1	2,103.00 /ea 148.80 /cf	623	338.90 /cf	1,41
		Sluice Gate Anchor Bolts	185.00 ea	2,782	1,388		_	-	22.54 /ea	4,170	51.48 /ea	9,52
		Sluice Gates, Rectangular, 42"	5.00 EA	13,783	34.038				9,564.22 /EA	47,821	22,097.24 /EA	110,48
		42" x 42" Sluice Gate	5.00 EA	13,783	34,038				9,564.22 /EA	47,821	22,097.24 /EA	110,48
		36" x 36" Sluice Gate	0.00 2/1	10,700	0.,000				0,001122 /2/1	17,021	22,007121 7271	110,10
		Sluice Gates, Rectangular, 36"										
		36" Wide Rectangular Sluice Gate - FURNISH	2.00 ea		10,400				5,200.00 /ea	10,400	12,119.04 /ea	24,23
		36" Wide Rectangular Sluice Gate - PORNISH 36" Wide Rectangular Sluice Gate - Installation	2.00 ea	3,610	10,400	-		-	1,804.80 /ea	3,610	4,079.90 /ea	8,16
		Grout Behind Gate Frame	1.45 cf	164	52			-	1,804.80 /cf	216	338.90 /cf	49
		Sluice Gate Anchor Bolts	64.00 ea	963	480			-	22.54 /ea	1,443	51.48 /ea	3,29
		Sluice Gates, Rectangular, 36"	2.00 EA	4.736	10.932				7,833.96 /EA	15.668	18,091.95 /EA	36.18
		36" x 36" Sluice Gate	2.00 EA	4,736	10,932				7,833.96 /EA	15,668	18,091.95 /EA	36,18
		Odor Control	2.00 EA	4,700	10,332				1,000.00 /LA	10,000	10,031.33 724	30,10
		Cast-In-Place Concrete, Slabs on Grade, 12" thick										
			700.00 -/	200					244 /-/	201	4.00 ///	70
	+	Fine grade, for slab on grade, by hand Fill, gravel subbase, under building slab on grade	729.00 sf 13.50 cy	299 396	22 398	-	 	-	0.44 /sf 58.80 /cy	321 794	1.00 /sf 134.99 /cy	72 1,82
	_	Concrete pumping, subcontract, all inclusive price	27.00 cy	396	398	405	 		58.80 /cy 15.00 /cy	405	134.99 /cy 33.91 /cy	1,82
	_	Slab on grade edge forms, 7" to 12"	112.00 cy	1,508	112	405	 		15.00 /cy 14.47 /sf	1,620	32.77 /sf	3,67
		Reinforcing in place, A615 Gr 60, priced per lbs.	3,510.00 lb	1,308	1,755	1,404	1		0.90 /lb	3,159	2.07 /lb	7,26
		Concrete, ready mix, 4000 psi	27.00 CY		3,051	1,404	-		113.00 /CY	3,051	263.36 /CY	7,1
		Add for concrete waste, 4000 psi	1.35 cy	-	153				113.00 /cy	153	263.36 /cy	35
		Add amount for Fuel Surcharges - per concrete truck load	3.00 load	-	45		-	-	15.00 /load	45	34.96 /load	11
		Add amount for Environmental Fee - per concrete truck load	3.00 load	-	18		-	-	6.00 /load	18	13.98 /load	
		Placing concrete, concrete pump	27.00 cy	1,187	-		-	-	43.95 /cy	1,187	99.36 /cy	2,6
		Finishing floors, monolithic, trowel finish (machine)	729.00 sf	1,009	15			-	1.40 /sf	1.024		2.3



Project: GNH Union Pump Station

Project No.: 478874

Design Stage: Conceptual Estimate Class: 4

E.B. Smith/GNV, A. Frisch/PGH

Estimator:

Revision / Date: Rev02 (10-3-2016)

Fac Work		Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Cast-In-Place Concrete, Slabs on Grade, 12" thick										
		Curing, water	729.00 sf	142	36	-	-	-	0.25 /sf	179	0.56 /sf	407
		Cast-In-Place Concrete, Slabs on Grade, 12" thick	27.00 CY	4,541	5,605	1,809			442.78 /CY	11,955	1,015.47 /CY	27,418
		Odor Control Equipment										
		Furnish Scrubber equipment associated accessories	1.00 ea	0	179,000	-	-	0	179,000.00 /ea	179,000	417,174.42 /ea	417,174
		Install Scrubber equipment and all associated accessories	1.00 ea	4,512	25,000		-	-	29,512.00 /ea	29,512	68,464.33 /ea	68,464
		30" FRP shop fabricated duct - FURNISH	51.00 LF	-	3,621		-	-	71.00 /LF	3,621	165.47 /LF	8,439
		30" FRP shop Ell, 90	1.00 ea	-	589	-	-	-	589.00 /ea	589	1,372.71 /ea	1,373
		30" FRP shop Tee 30" shop weld	1.00 ea 6.00 ea	-	884 1.770		-	-	883.50 /ea 295.00 /ea	884 1,770	2,059.07 /ea 687.52 /ea	2,059
		36" FRP shop fabricated duct - FURNISH	20.00 LF		1,770		-	-	83.00 /LF	1,770	193.44 /LF	3.869
		36" shop weld	2.00 ea		660				330.00 /ea	660	769.09 /ea	1,538
		Odor Control Equipment	1.00 EA	4.512	213.184				217.695.50 /EA	217.696	507.041.65 /EA	507.042
		Odor Control	1.00 LS	9.053	218,788	1,809			229.650.60 /LS	229.651	534,459,47 /LS	534.459
		43.05 Furnish and Install Process Equipment	1.00 LS	65,306	1,159,750	9,909		2.500	1.237.464.68 /LS	1.237.465	2.878.574.44 /LS	2.878.574
		43.0 Process Equipment - Industrial	1.00 LS	65,306	1,159,750	9,909		2,500	1,237,464.68 /LS	1,237,465	2.878.574.44 /LS	2,878,574
		005 UNION PUMP STATION	1.00 LS	1.005.931	2.298.606	341,339	625.867	27.500	4.299.242.06 /LS	4,299,242	10.036.006.89 /LS	10.036.007
006		FORCEMAIN AND PIPE BRIDGE REPLACEMENT	1.00 LO	1,000,001	2,230,000	341,333	023,007	21,500	4,233,242.00 /20	7,233,242	10,030,000.03 /20	10,030,007
33.0		Utilities Utilities										
55.0	33.05	Buried Process Piping										
	33.03	Forcemain and Pipe Bridge Replacement (Lochner)										
		Buried Pipe, Other										
		Forcemain and pipe bridge replacement cost provided by (Lochner	1.00 ls			1,785,290	-	-	1,785,290.00 /ls	1,785,290	4,035,796.75 /ls	4,035,797
		\$2.5M less 30% contingency) Buried Pipe, Other	1.00 LS			1.785,290			1.785,290.00 /LS	1.785.290	4.035.796.75 /LS	4.035.797
		Forcemain and Pipe Bridge Replacement (Lochner)	1.00 LS			1,785,290			1,785,290.00 /LS	1,785,290	4,035,796.75 /LS	4,035,797
		, , , , , ,	1.00 LS			1,785,290			1,785,290.00 /LS	1,785,290		4,035,797
		33.05 Buried Process Piping				1,785,290			1,785,290.00 /LS 1.785,290.00 /LS	1,785,290	4,035,796.75 /LS 4.035.796.75 /LS	4,035,797
		33.0 Utilities	1.00 LS			,,			,,	,,	7,	,,,,,
		006 FORCEMAIN AND PIPE BRIDGE	1.00 LS			1,785,290			1,785,290.00 /LS	1,785,290	4,035,796.75 /LS	4,035,797
		REPLACEMENT										
007		Submergence Chamber and 42-inch Rehabilitation										
33.0		Utilities										
00.0	33.15	Buried Structures										
	00.10	Submergence Chamber and 42-inch RCP Rehabilitation										
		Pipeline Specials. Other										
		Submergence Chamber and 42" RCP Rehabilitation	1.00 ls			25,000			25.000.00 /ls	25,000	56.514.56 /ls	56,515
	1	Pipeline Specials, Other	1.00 IS			25,000			25,000.00 /ls	25,000	56,514.56 /LS	56,515
	1	Submergence Chamber and 42-inch RCP Rehabilitation	1.00 EA			25,000			25,000.00 /EA	25,000	56.514.56 /EA	56.515
	+	33.15 Buried Structures	1.00 EA			25,000			25,000.00 /EA 25.000.00 /EA	25,000	56,514.56 /EA 56.514.56 /EA	56,515
		33.0 Utilities	1.00 EA			25,000			25,000.00 /EA	25,000	56.514.56 /LS	56,515
	+					-,			-,	-,		
		007 Submergence Chamber and 42-inch Rehabilitation	1.00 LS			25,000			25,000.00 /LS	25,000	56,514.56 /LS	56,515



Project: GNH Union Pump Station

Project No.: 478874
Design Stage: Conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev02 (10-3-2016)

Estimate Class: 4

Estimate Totals

Construction Costs	Amount	Totals	Rate	% of Tota
Labor	1,005,931			7.12%
Material	2,298,606			16.27%
Subcontract	2,151,629			15.23%
Equipment	625,867			4.43%
Other	27,500			0.19%
Subtotal Raw Costs	6,109,533	6,109,533		43.24
Material Sales & Use Tax - %	160.902		7.000 %	1.14%
Construction Equip Tax - %			7.000 %	
Total Taxes	204,713	6,314,246		1.4
Existing Conditions I,OH&P	46,648		15.000 %	0.33%
Concrete Work I,OH&P	15,281		15.000 %	0.119
Masonry Work I,OH&P	10,092		15.000 %	0.07%
Metals Work I,OH&P	3,088		15.000 %	0.02%
Architectural (Div 6-12)I,OH&P	23,679		15.000 %	0.179
Mechanical Work I,OH&P	650		20.000 %	0.00%
Electrical Work I,OH&P	242,147		25.000 %	1.719
Site/Civil I,OH&P	1,348		10.000 %	0.019
Process Piping I,OH&P	63,982		18.000 %	0.45%
Instruments & Controls I.OH&P	66.242		25.000 %	0.479
Process Equipment I.OH&P	185,620		15.000 %	1.319
Subtotal Subcontractor I,OH&P	1,028,928	7,343,174		7.2
Total Cost To Prime Contractor		7,343,174		
General Conditions	734,317		10.000 %	5.20%
Mobilization/Demobilization	220,295		3.000 %	1.569
Subtotal Indirect Costs	954,612	8,297,786		6.7
Prime Contractor Home OfficeOH	663,823		8.000 %	4.70%
Prime Contractor Profit	829,779		10.000 %	5.879
Blder's Risk & Gen Liab Ins -%	141,283		1.000 %	1.00%
	163,888		1.160 %	1.169
Payment & Performance Bonds		40.000.550	1.100 %	
Subtotal OH&P	1,798,773	10,096,559		12.7
Design Contingency	3,028,968		30.000 %	21.44%
Subtotal Contingency	3,028,968	13,125,527		21.4
E	4 000 ====		7040 **	
Escal. to Midpoint Const 2020	1,002,790		7.640 %	
Subtotal Escalation	1,002,790	14,128,317		7.1
Total Prime Contractor Costs		14,128,317		

Intermediate-Term Improvements
Capacity Upgrade of Boulevard Pump
Station



Job Size:

Duration:

Facility Summary

Boulevard Pump Station Project:

E.B. Smith/GNV, A. Frisch/PGH Estimator:

Project No.:

478874

Revision / Date: Rev03, (10-4-2016)

Estimate Class: 4 Design Stage: conceptual

Facility	Description	Direct Amount	Grand Total w/Markups	Percent of Total
0300	Boulevard Pump Station	8,205,212	19,095,658	66.664
0305	Dry Weather Pump Station	4,179,720	9,549,065	33.336

Estimate Totals

Construction Costs	Amount	Totals	Rate	% of Total
Labor	8,021,852			28.00%
Material	12,429,999			43.39%
Subcontract	3,874,229			13.53%
Equipment	4,199,798			14.66%
Other_	118,846			0.41%
Total Prime Contractor Costs	28,644,724	28,644,724		100.00



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

	ork Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
0300			Boulevard Pump Station											
01	.0		General Requirements											
	- (01.06	Startup & Commissioning											
			Startup and Testing											
			General Conditions, Other											
			Startup, Testing, and Contractor Commissioning Allowance	1.00 ls		81,998			28,229	-	110,227.17 /ls	110,227	235,803.65 /ls	235,804
			General Conditions, Other	1.00 LS		81,998			28,229		110,227.17 /LS	110,227	235,803.65 /LS	235,804
			Startup and Testing	1.00 LS		81,998			28,229		110,227.17 /LS	110,227	235,803.65 /LS	235,804
			01.06 Startup & Commissioning	1.00 LS		81,998			28,229		110,227.17 /LS	110,227	235,803.65 /LS	235,804
			01.0 General Requirements	1.00 LS		81,998			28,229		110,227.17 /LS	110,227	235,803.65 /LS	235,804
02	2.0		Existing Conditions											
	(02.40	Demolition											
			Selective Demolition											
			Structure/Building Demolition											
			Roofing and siding demolition, roofing, built-up, 5-ply, excluding gravel	10,918.00 sf	366.8	22,115	-			-	2.03 /sf	22,115	4.64 /sf	50,627
			Door demolition, single, remove	15.00 ea	10.1	601	-	-	-	-	40.09 /ea	601		1,377
			Demo 17 skylights	17.00 ea	91.4	5,453	-	-	-	-	320.76 /ea	5,453		12,483
	-		Misc. Demo allowance	5.00 Days		10,082	7,755	12,925	-	-	2,585.07 /Days	12,925		29,589
	_		Misc. Concrete demo	1.00 LS		10,082	7,755		-		17,836.94 /LS	17,837		40,833
	\rightarrow		Demo Tank	1.00 Days			2,585	2,585	-	-	2,585.08 /Days	2,585 2,585		5,918
	-		Repair cracked concrete	1.00 LS 1.00 Days			2,585	2,585	-	-	2,585.06 /LS 2,585.06 /Days	2,585		5,918 5,918
	_		Demo grating, railings and exterior metal stair Remove spalling concrete and patch surfaces Allowance	1.00 Days			-	15,510	1	1	15,510.39 /LS	15,510		35,507
			Demo toilet, service sink and accessories	1.00 LS	21.5	1,440		- 10,010			1,440.11 /LS	1,440		3,297
			Structure/Building Demolition	1.00 SF	489.8	39.691	10.340	33,606			83,637.54 /SF	83,638		191,467
			Pipe Demolition					,				30,000		101,101
	_		Miscellaneous piping demolition and disposal	1.00 ls	1,075.4	94,527					94,526.52 /ls	94,527	216,394.98 /ls	216,395
			Pipe Demolition	1.00 LS	1,075.4	94,527					94,526.52 /LS	94,527	216,394.98 /LS	216,395
			Process Equipment Demolition		.,	- 1,0-1					0 1,0-0.00- 7-0			
			Demolish existing pump and all associated works	4.00 ea	430.2	32,617			10,611		10,806.99 /ea	43,228	24,739.91 /ea	98,960
			Demolish existing grit equipment and all associated works	1.00 ea	295.7	22,424		-	3,979		26,403.11 /ea	26,403		60,443
			Demolish existing existing sluice gates and all associated works	8.00 ea	258.1	19,570		-	15,917	-	4,435.87 /ea	35,487	10,154.83 /ea	81,239
			Demolish existing grit equipment and all associated works	1.00 ea	295.7	22,424		-	3,979	-	26,403.11 /ea	26,403	60,443.37 /ea	60,443
			Process Equipment Demolition	4.00 EA	1,279.7	97,034			34,487		32,880.29 /EA	131,521	75,271.25 /EA	301,085
			Selective Demolition	1.00 LS	2,844.9	231,252	10,340	33,606	34,487		309,685.21 /LS	309,685	708,947.40 /LS	708,947
			Electrical Facility Demolition											
			Electrical Facility Demolition											
			Electrical demo, remove misc. electrical equipment, transformers, etc.	8,855.00 sf	8,927.3	730,962	-	-	-	-	82.55 /sf	730,962	188.97 /sf	1,673,356
			Electrical Facility Demolition	8,855.00 SF	8,927.3	730,962					82.55 /SF	730,962	188.97 /SF	1,673,356
			Electrical Facility Demolition	1.00 LS	8,927.3	730,962					730,962.11 /LS	730,962	1,673,356.21 /LS	1,673,356
			02.40 Demolition	1.00 LS	11,772.3	962,214	10,340	33,606	34,487		1,040,647.32 /LS	1,040,647	2,382,303.61 /LS	2,382,304
			02.0 Existing Conditions	1.00 LS	11,772.3	962,214	10,340	33,606	34,487		1,040,647.32 /LS	1,040,647	2,382,303.61 /LS	2,382,304
03	3.0		Concrete Work								7	7	, , , , , , , , , , , , , , , , , , , ,	,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,
	_		Cast-In-Place Concrete Work											
			Electrical Equipment Pads											
	_		Cast-In-Place Concrete, Equipment Pads, 10" thick											
			Edge forms, housekeeping pads, up to 6"	242.00 lf	17.2	1,290	65		l .		5.60 /lf	1,355	12.82 /lf	3,102
			Concrete, ready mix, 4000 psi	6.25 CY	17.2	.,230	776				124.08 /CY	776		1,776
			Add for concrete waste, 4000 psi	0.31 cy		-	39	-	-	-	124.07 /cy	39		89
			Finish housekeeping pads	506.25 sf	27.2	1,884	16		-	-	3.75 /sf	1,900		4,349
			Curing, membrane spray	506.25 sf	1.4	80	21	-	-	-	0.20 /sf	101		230
			Cast-In-Place Concrete, Equipment Pads, 10" thick	6.25 CY	45.8	3,254	916				667.18 /CY	4,170	7	9,546
			Electrical Equipment Pads	6.25 CY	45.8	3,254	916				667.18 /CY	4,170	1,527.36 /CY	9,546
			Electrical Equipment Pad - Generator, Xfmrs											
			Cast-In-Place Concrete, Equipment Pads, 24" thick											
			Equipment pad forms, large	212.00 sf	71.2	5,330	329	-	-	-	26.69 /sf	5,659		12,955
			Reinforcing in place, A615 Gr 60, priced per lbs.	1,300.00 lb		-	672	538	-	-	0.93 /lb	1,210		2,769
	-		Concrete, ready mix, 4000 psi	10.00 CY		-	1,241	-	-	-	124.08 /CY	1,241		2,841
			Concrete, ready mix, 4000 psi	2.00 CY		-	248 662		-		124.08 /CY 124.08 /CY	248		568 1,515
	-		Concrete, ready mix, 4000 psi Add for concrete waste, 4000 psi	5.33 CY 0.87 cy		-	108				124.08 /CY 124.10 /cy	108		1,515
	_		Finishing floors, monolithic, broom finish	135.00 sf	5.4	377	100			<u> </u>	2.81 /sf	380		869
	_		Finishing floors, monolithic, broom finish	27.00 sf	1.1	75	1				2.82 /sf	76		174
			Finishing floors, monolithic, broom finish	72.00 sf	2.9	201	1	-	-	-	2.81 /sf	202		464
			Patch & plug tieholes	212.00 sf	4.3	251	4		-		1.20 /sf	255		584
			Sack rub	212.00 sf	11.4		7				3.18 /sf	675		1,54
			Curing, water	234.00 sf	1.0	62	12	-	-		0.32 /sf	74	0.72 /sf	16



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

ac Work		Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Cast-In-Place Concrete, Equipment Pads, 24" thick	17.33 CY	97.4	6,964	3,287	538			622.54 /CY	10,789	1,425.15 /CY	24,698
		Electrical Equipment Pad - Generator, Xfmrs	17.33 CY	97.4	6,964	3,287	538			622.54 /CY	10,789	1,425.15 /CY	24,698
		Concrete Wall - Floodproof Wall, 8" thick											
		Cast-In-Place Concrete, Straight Walls, 8" thick											
		Concrete pumping, subcontract, all inclusive price Forms in place, structural walls, to 8' high, hand set	31.61 cy 2,560.00 sf	516.2	38,619	2,647	490	-	-	15.51 /cy 16.12 /sf	490 41,266	35.51 /cy 36.90 /sf	1,122 94,469
		Speed Dowels, #5	320.00 si	510.2	30,019	4,632			-	14.48 /ea	4,632		10,60
		Reinforcing in place, A615 Gr 60, priced per lbs.	5,688.89 lb			2,941	2,353	-	-	0.93 /lb	5,294		12,120
		Concrete, ready mix, 4000 psi	31.61 CY		-	3,693	-	-	-	116.85 /CY	3,693		8,454
		Add for concrete waste, 4000 psi	2.00 cy		-	234	-	-	-	116.84 /cy	234		538
		Placing concrete, concrete pump, for structural wall to 12" thick	31.61 cy	36.1	2,116	-		-	-	66.96 /cy	2,116		4,84
		Patch & plug tieholes Sack rub	2,560.00 sf 2,560.00 sf	51.6 137.7	3,025 8,067	53 79		-		1.20 /sf 3.18 /sf	3,078 8,147		7,04 18,65
		Curing, membrane spray	2,560.00 sf	6.9		106			- :	0.20 /sf	509		1,16
		Cast-In-Place Concrete, Straight Walls, 8" thick	31.61 CY	748.4	52,231	14,386	2,843			2,197.39 /CY	69,459		159,01
		Concrete Wall - Floodproof Wall, 8" thick	31.61 CY	748.4		14,386	2,843			2,197.39 /CY	69,459		159,010
		Misc. Concrete & Brick repairs	31.01 31	140.4	32,231	14,500	2,040			2,137.33 701	03,403	3,030.37 701	100,011
		Concrete. Other											
		Allowance for concrete and brick repairs	1.00 LS				77,552			77,551.95 /LS	77,552	177,535.93 /LS	177,53
		Concrete, Other	1.00 CY				77.552			77.551.95 /CY	77,552	177.535.93 /CY	177,530
		Misc. Concrete & Brick repairs	1.00 LS				77,552			77,551.95 /LS	77,552	177,535.93 /LS	177,530
		03.10 Cast-In-Place Concrete Work	6.25 CY	891.7	62.448	18.589	80,933			25,915.18 /CY	161,970	59,326.37 /CY	370,790
	+	03.0 Concrete Work	23.58 CY	891.7	62,448	18,589	80,933			6,868.95 /CY	161,970	15,724.76 /CY	370,790
05.0		Metals	23.30 01	091.7	02,440	10,309	00,933			0,000.95 /С1	101,970	15,724.76 761	370,790
05.0	05.40												
	05.10	Structural Steel											
		Modifications to Existing Monorail Beam											
		Metals, Structural Steel	1.00 ea				45.540			15.510.39 /ea	15.510	35.507.19 /ea	35.507
		Allowance to modify the existing monorail beam and all structural related works	1.00 ea				15,510		-	15,510.39 /ea	15,510	35,507.19 /ea	35,507
		Metals, Structural Steel	1.00 LS				15,510			15,510.39 /LS	15,510	35,507.19 /LS	35,507
		Modifications to Existing Monorail Beam	1.00 LS				15,510			15,510.39 /LS	15,510		35,507
										· · · · · · · · · · · · · · · · · · ·	-,	,	
		05.10 Structural Steel	1.00 LS				15,510			15,510.39 /LS	15,510	35,507.19 /LS	35,507
		05.0 Metals	1.00 LS				15,510			15,510.39 /LS	15,510	35,507.19 /LS	35,507
06.0		Wood, Plastics and Composites											
	06.00	Wood, Plastics and Composites											
		FRP Grating											
		Wood & Plastics, FRP Fabrications, Gratings											
		Grating fbgls, molded, orange (hi crsv env), 2" sq mesh, 2" thk	2,405.00 sf	161.6	14,653	62,171	-	-	-	31.94 /sf	76,824	73.13 /sf	175,869
		Wood & Plastics, FRP Fabrications, Gratings	2,405.00 SF	161.6	14,653	62,171				31.94 /SF	76,824	73.13 /SF	175,869
		FRP Grating	2,405.00 SF	161.6	14,653	62,171				31.94 /SF	76,824	73.13 /SF	175,869
		Misc. FRP Allowance											
		Wood & Plastics, FRP Fabrications, Gratings											
		Misc. FRP Allowance	1.00 LS		6,721	10,340	-	-	-	17,061.41 /LS	17,061	39,057.84 /LS	39,058
		Wood & Plastics, FRP Fabrications, Gratings	1.00 SF		6,721	10,340				17,061.41 /SF	17,061	39,057.84 /SF	39,058
		Misc. FRP Allowance	1.00 LS		6,721	10,340				17,061.41 /LS	17,061	39,057.84 /LS	39,058
		06.00 Wood, Plastics and Composites	1.00 LS	161.6	21,374	72,511				93,885.39 /LS	93,885	214,927.28 /LS	214,927
		06.0 Wood, Plastics and Composites	1.00 LS	161.6	21,374	72,511				93,885.39 /LS	93,885	214,927.28 /LS	214,927
07.0		Thermal and Moisture Protection											
	07.50	Membrane Roofing											
		Roofing											
		Thermal & Moisture Protection, Built Up Roofing											
		Roof deck insulation, perlite, 1-1/2" thick R4.17	10,918.00 sf	146.7	10,672	5,419			-	1.47 /sf	16,090	3.37 /sf	36,835
		Roof deck insulation, polyisocyanurate 2#/CF density, 2-1/2" thick R16	10,918.00 sf	117.5	8,544	11,402	-	-	-	1.83 /sf	19,946	4.18 /sf	45,661
		Built up roof, asphalt base sheet, 3-plies #15 felt, mopped w/ gravel	109.18 sq	373.5	26,791	9,314	-	6,315	-	388.54 /sq	42,421	889.46 /sq	97,11
		Coping, aluminum to .019", duranodic finish, 12" wall	638.00 lf	75.5		5,179		-	-	16.72 /lf	10,667	38.28 /lf 4,450.98 /ea	24,420 4,451
		Roof hatches Skylight, allowance	1.00 ea 17.00 ea	5.4	393	1,551	43,946	-	-	1,944.29 /ea 2,585.07 /ea	1,944	4,450.98 /ea 5,917.87 /ea	100,604
		Misc. Roofing	1.00 Ea		0	0	10,340	-		10,340.25 /LS	10,340	23,671.43 /LS	23,671
		Drain, roof, 6"	16.00 ea	64.5	5,694	16,396	.0,040	-		1,380.57 /ea	22,089		50,568
		Vapor Retarders, building paper, asphalt felt sheathing paper, 15#	109.18 sq	31.7	2,420	598	-		-	27.65 /sq	3,018	63.29 /sq	6,910
		Thermal & Moisture Protection, Built Up Roofing	10,918.00 SF	814.8	60,002	49,859	54,286	6,315		15.61 /SF	170,462	35.74 /SF	390,231
		Roofing	1.00 LS	814.8	60,002	49,859	54,286	6,315		170,462.33 /LS	170,462	390,231.18 /LS	390,231
		07.50 Membrane Roofing	1.00 LS	814.8	60,002	49,859	54,286	6,315		170,462.33 /LS	170,462	390,231.18 /LS	390,231
		07.0 Thermal and Moisture Protection	1.00 LS	814.8	60,002	49,859	54,286	6,315		170,462.33 /LS	170,462	390,231.18 /LS	390,231
	_			2.110	,-52	,	2 .,200	-,0		.,	, 102		222,201
08.0		Openings											



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual Esti

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

ac Work	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Doors											
		Openings, Doors, Frames and Hardware											
		Coml st doors, 316 SST 3'-0" x 7'-0"	2.00 ea	2.5		2,140	-	-	-	1,166.69 /ea	2,333	2,670.85 /ea	5,34
		Door hardware, average - H.M., wood, or aluminum	2.00 set	10.8		724	-	-	-	759.94 /set	1,520	1,739.70 /set	3,47
		Frames, steel, knock down, hollow metal, single, 16 ga., up to 5-3/4" deep, 7'-0" h x 3'-0" w	12.00 ea	16.1	1,230	1,923	·	-	-	262.79 /ea	3,153	601.59 /ea	7,21
		Frames, steel, knock down, hollow metal, double, 16 ga., up to 4-7/8* deep, 7'-0" h x 6'-0" w	4.00 ea	6.1	469	778	-	-	-	311.58 /ea	1,246	713.28 /ea	2,85
		Fiberglass, exterior, prehung door, 1-3/4", 3'-0" x 7'-0"	20.00 ea	28.7	2,187	9,513			-	585.00 /ea	11,700	1,339.21 /ea	26,78
		Seal around doors & louvers	1.00 ea	1.1		0	5,170	-	-	5,170.13 /ea	5,170		11,8
		Openings, Doors, Frames and Hardware	22.00 EA	65.3	4,875	15,078	5,170			1,141.96 /EA	25,123	2,614.23 /EA	57,51
		Doors	22.00 EA	65.3	4,875	15,078	5,170			1,141.96 /EA	25,123	2,614.23 /EA	57,5
		08.00 Openings	1.00 LS	65.3	4,875	15,078	5,170			25,123.11 /LS	25,123	57,513.12 /LS	57,51
	08.30	Specialty Doors and Frames											
		Access Hatch 6' x 6'											
		Specialty Doors and Frames, Access Doors											
		Doors, specialty, access, floor, industrial, aluminum, double leaf, 6' x 6', 645 lb	2.00 opng	43.0	3,899	17,868	-	-	-	10,883.71 /opng	21,767	24,915.54 /opng	49,8
		Specialty Doors and Frames, Access Doors	2.00 EA	43.0	3,899	17,868				10,883.71 /EA	21,767	24,915.54 /EA	49,83
		Access Hatch 6' x 6'	2.00 EA	43.0		17.868				10.883.71 /EA	21,767	24.915.54 /EA	49.83
		08.30 Specialty Doors and Frames	2.00 EA	43.0		17,868				10,883.71 /EA	21,767	24,915.54 /EA	49,83
		08.0 Openings	1.00 LS	108.3		32,946	5,170			46,890.52 /LS	46.891	107,344.21 /LS	107,34
09.0		Finishes	20	100.0	0,	02,010	5,1.0			10,000.02 720	10,001	101,011121 720	,
	09.00	Finishes											
	03.00	Misc. Finishes											
		Finishes, Chemical Resistant Coatings											
		Misc. Finishes Allowance	1.00 LS		33,606	25,851				59,456.50 /LS	59.457	136,110.86 /LS	136,1
		Finishes, Chemical Resistant Coatings	1.00 ES		33,606	25.851		_	-	59,456.50 /SF	59,457	136,110.86 /SF	136,11
		Misc. Finishes	1.00 LS		33,606	25,851				59,456.50 /LS	59,457	136,110.86 /LS	136,11
		Special Coating	1.00 L3		33,000	23,031				39,430.30 /L3	33,437	130,110.00 723	130,11
		Finishes, Chemical Resistant Coatings											
		Concrete Coating, Chemical Resistant, CRC-2	641.25 sf				13,261			20.68 /sf	13,261	47.34 /sf	30,35
		Concrete Coating, Chemical Resistant, CRC-2	27.00 sf				558		- :	20.68 /sf	558	47.34 /sf	1,27
		Concrete Coating, Chemical Resistant, CRC-2	200.00 sf		-	-	4,136		-	20.68 /sf	4,136	47.34 /sf	9,4
		Finishes, Chemical Resistant Coatings	868.25 SF				17,956			20.68 /SF	17,956	47.34 /SF	41,10
		Finishes, Special Coating											
		Special Coatings, high build epoxy, 50 mil, max, pump room floors and walls	5,824.00 sf	659.3	41,153	60,222	-	-	-	17.41 /sf	101,375	39.85 /sf	232,0
		Special Coatings, high build epoxy, 50 mil, max, wetwell floor and walls	3,731.00 sf	422.3	26,364	38,580		-	-	17.41 /sf	64,943	39.85 /sf	148,67
		Finishes, Special Coating	5,824.00 SF	1,081.6	67,517	98,801				28.56 /SF	166,318	65.38 /SF	380,74
		Special Coating	6,692.25 SF	1,081.6	67,517	98,801	17,956			27.54 /SF	184,274	63.04 /SF	421,85
		09.00 Finishes		1,081.6	101,123	124,652	17,956			/LS	243,731	/LS	557,96
		09.0 Finishes	1.00 LS	1,081.6	101,123	124,652	17,956			243,730.81 /LS	243,731	557,961.15 /LS	557,96
10.0		Specialties											
	10.00	Specialties											
		Toilet Accessories											
		Specialties Toilet & Bath Accessories											
		Partitions, toilet, floor mounted, headrail braced, stainless steel	1.00 ea	3.6	273	1,215				1,488.38 /ea	1,488	3,407.27 /ea	3,4
		Toilet tissue dispenser, surface mounted, stainless, double roll	1.00 ea	0.4		23	-	-	-	57.43 /ea	57		1;
		Toilet Accessories, grab bars, straight, stainless steel, 24" long	1.00 ea	0.5		32	-	-	-	67.15 /ea	67		1
		Toilet Accessories, grab bars, straight, stainless steel, 36" long	1.00 ea	0.5		38	-	-	-	79.20 /ea	79		1
		Toilet Accessories, mirror, 48" x 24", with stainless steel 3/4" square frame	1.00 ea	1.1	82	157	-	-	-	239.24 /ea	239	547.69 /ea	5
		Toilet Accessories, soap dispenser, stainless steel, recessed, liquid	1.00 ea	1.1	82	172			-	253.70 /ea	254	580.79 /ea	5
		Toilet Accessories, towel dispenser, stainless steel, surface mounted	1.00 ea	0.7		49		· -	-	100.37 /ea	100		2
		Toilet Accessories, waste receptacle, stainless steel, w/top, 13 gallon	1.00 ea	1.1		326	-	-	-	407.78 /ea	408		9
		Specialties Toilet & Bath Accessories	8.00 EA	8.9		2,012				336.66 /EA	2,693	770.69 /EA	6,1
		Toilet Accessories	1.00 LS	8.9		2,012				2,693.25 /LS	2,693	6,165.54 /LS	6,10
		10.00 Specialties	1.00 LS	8.9		2,012				2,693.25 /LS	2,693	6,165.54 /LS	6,1
		10.0 Specialties	1.00 LS	8.9	682	2,012				2,693.25 /LS	2,693	6,165.54 /LS	6,1
21.0		Fire Suppression											
	21.00	Fire Suppression											
		Sprinkler System											
		Mechanical, Fire Sprinklers System											
		Sprinkler System	3,180.00 SF	1,590.0			18,085	-	-	5.69 /SF	18,085	13.30 /SF	42,3
		Mechanical, Fire Sprinklers System	1.00 LS	1,590.0			18,085			18,085.12 /LS	18,085	42,305.62 /LS	42,30



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

	Vork Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
			Sprinkler System	3,180.00 SF	1,590.0			18,085			5.69 /SF	18,085	13.30 /SF	42,306
			21.00 Fire Suppression	1.00 LS	1,590.0			18,085			18,085.12 /LS	18,085	42,305.62 /LS	42,306
			21.0 Fire Suppression	1.00 LS	1,590.0			18,085			18,085.12 /LS	18,085	42,305.62 /LS	42,306
22	2.0		Plumbing											
		22.00	Plumbing											
			Misc. Plumbing											
			Mechanical, Plumbing											
			Misc. Plumbing Allowance	1.00 LS		33,606		25,851	-	-	59,456.49 /LS	59,456	127,192.42 /LS	127,192
			Mechanical, Plumbing	1.00 LS		33,606		25,851			59,456.49 /LS	59,456	127,192.42 /LS	127,192
			Misc. Plumbing	1.00 LS		33,606		25,851			59,456.49 /LS	59,456	127,192.42 /LS	127,192
			Plumbing Fixtures											
			Mechanical, Plumbing											
			Water closet, tank type, vitreous china, floor mounted, close coupled, two piece, includes seat, supply pipe with stop	1.00 ea	4.1		238	-	-	-	588.82 /ea	589	1,259.64 /ea	1,260
			Water closet, tank type, vitreous china, floor mounted, rough-in, supply, waste and vent, one piece	1.00 ea	7.1	610	336	-	-	-	946.01 /ea	946		2,024
			Lavatory, vanity top, stainless steel, self-rimming, ledge, round, single bowl, 18-3/4*, includes trim	1.00 ea	3.4	291	827	-	-	-	1,117.86 /ea	1,118	2,391.37 /ea	2,391
			Lavatory, vanity top, rough-in, supply, waste and vent	1.00 ea	9.4		225	-	-	-	1,034.29 /ea	1,034		2,213
			Sink, service, stainless steel, self rimming, triple bowl, 22" x 43", includes	1.00 ea	4.9	423	1,163	-	-	-	1,586.06 /ea	1,586	3,392.96 /ea	3,393
			faucet and drain	4.00	10.1	869	255				4.404.75 /:-	4.405	0.400.40. /	2,406
			Sink, service, rough-in, supply, waste and vent Industrial safety fixture, eyewash station, stainless steel, pedestal	1.00 ea 3.00 ea	10.1	1,395	255 862	-		-	1,124.75 /ea 752.50 /ea	1,125 2,258	2,406.13 /ea 1,609.79 /ea	4,829
			mounted, unmounted, excludes rough-in	3.00 ea	10.1	1,393	002]	732.30 /ea	2,230	1,009.79 /ea	4,029
			Mechanical, Plumbing	1.00 LS	54.9	4,748	3,908				8,655.30 /LS	8,655	18,515.86 /LS	18,516
			Plumbing Fixtures	1.00 LS	54.9	4,748	3,908				8,655.30 /LS	8,655		18,516
			22.00 Plumbing	1.00 LS	54.9	38,354	3,908	25,851			68,111.79 /LS	68,112		145,708
			22.0 Plumbing	1.00 LS	54.9	38.354	3.908	25.851			68.111.79 /LS	68.112		145,708
23	3.0		HVAC				-,						110,100	,
		23.00	HVAC											
			HVAC Control Components/DDC Systems,											
			Mechanical, HVAC											
			Control Components/DDC Systems,	1.00 ls		-	-		-	25,851	25,850.65 /ls	25,851	55,301.04 /ls	55,301
			Mechanical, HVAC	1.00 LS						25,851	25,850.65 /LS	25.851	55,301.04 /LS	55,301
			HVAC Control Components/DDC Systems,	1.00						25,851	25,850.65	25,851	55,301.04	55,301
			Misc. HVAC							1,11	.,	.,		
			Mechanical, HVAC											
			Misc. HVAC Allowance	1.00 ls		-	-	-	-	25,851	25,850.65 /ls	25,851	55,301.05 /ls	55,301
			Mechanical, HVAC	1.00 LS						25,851	25,850.65 /LS	25,851	55,301.05 /LS	55,301
			Misc. HVAC	1.00 LS						25,851	25,850.65 /LS	25,851	55,301.05 /LS	55,301
			23.00 HVAC	1.00 LS						51,701	51,701.30 /LS	51,701	110,602.09 /LS	110,602
			23.0 HVAC	1.00 LS						51,701	51,701.30 /LS	51,701	110,602.09 /LS	110,602
26	6.0		Electrical Work											
		26.10	Site Electrical											
			Site Electrical, Buried Conduit											
			Site Electrical, Buried Conduit											
			PVC Sch 40 in Trench 2"	100.00 If	5.9		89			-	5.66 /lf	566		1,353
			PVC Sch 40 90 deg Ell 2"	1.00 E	0.3		4	-	-	-	31.22 /E	31		75
			PVC Coupling 2"	3.00 E	0.2		3	-	-	-	6.32 /E	19		45
			PVC Female Adaptor 2"	2.00 E	0.4		3		-	-	15.41 /E	31		74
			PVC Coated GRC in Trench 2" PVC Coated GRC Elbow 36" Radius 2"	10.00 lf 2.00 F	1.6		148 501		- :	-	27.82 /lf 331.87 /E	278	66.46 /lf 792.92 /F	665 1,586
			PVC Base Spacers < 2"	20.00 E	1.3		21	-		-	6.45 /E	129		308
			Duct Bank Warning Tape	100.00 If	3.4	271	26			-	2.97 /lf	297	7.09 /lf	709
			PVC Solvent Cement - Qt	0.40 E	0.0		2	-	-	-	6.28 /E	3	14.95 /E	6
			Site Electrical, Buried Conduit	100.00 LF	15.1	1,221	797				20.18 /LF	2,018	48.20 /LF	4,820
			Site Electrical, Duct Bank											
			2500 psi Duct Bank Concrete	3.70 cy	3.2	261	402	-	-	-	179.05 /cy	663		1,585
	-		Add Color Die for Duct Bank Concrete	3.70 cy	00.7	6 504	69 414		-	-	18.61 /cy	69		165
	\rightarrow		Duct Bank Concrete Forming Duct Bank Reinforcing Re-bar #4	200.00 sf 400.00 lf	80.7 5.4	6,504 434	414 207	-		-	34.59 /sf 1.60 /lf	6,918 641		16,528 1,531
	-		Duct Bank Reinforcing Re-bar #4 Duct Bank Reinforcing Re-bar #4 (Ties)	200.00 lf	6.7	542	108	-			3.25 /lf	650	7.76 /lf	1,553
			Site Electrical, Duct Bank	200.00 1	96.0	7,741	1,200				/CY	8,941	/CY	21,361
			Site Electrical, Trenching		30.0	.,,,,,	.,200				701	3,341	701	21,001
			Electrical, Trenching Electrical Trench Excavation - Soil Type C	37.04 cy	16.4	1,325			326		44.58 /cy	1,651	106.52 /cy	3,945
			Electrical Trench Bedding - Crushed Gravel	7.41 cy	5.0		230	-	72		95.00 /cy	704	226.98 /cy	1,68
			Electrical Trench Backfill - Reuse Trench Spoils	25.93 cy	9.4			-	456	-	46.87 /cy	1,215		2,903
			Electrical Trench Spoils - Waste on Site	11.11 cy	2.2				130		27.99 /cy	311		743



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

Fac Work		Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Site Electrical, Trenching		33.1	2,667	230		984		/CY	3,881	/CY	9,273
		Site Electrical, Grounding											
		CU Bare Stranded #4/0	100.00 lf	6.0	488	415	-	-	-	9.03 /lf	903		2,157
	-	Site Electrical, Grounding		6.0	1	415				/LF	903		2,157
		Site Electrical, Buried Conduit	1.00 LF	150.2	12,116	2,641		984		15,741.74 /LF	15,742	37,610.99 /LF	37,611
		Electrical, Grounding											
		Site Electrical, Grounding											
		CU Bare Stranded #4/0	100.00 lf 70.00 lf	6.0		415 290		-	-	9.03 /lf 9.03 /lf	903		2,157
		CU Bare Stranded #4/0 CU Bare Stranded #4/0	70.00 If	4.2		311			-	9.03 /lf 9.03 /lf	632		1,510
		Hand Trench and Backfill, includes labor for layout	135.00 lf	36.3	2,927	-				21.68 /lf	2,927		6,993
		Copperclad Ground Rod 3/4" x 10'	12.00 E	12.9	1,041	396			-	119.74 /E	1,437		3,433
		Compression Lug - 4/0	6.00 E	4.0		63		-	-	64.71 /E	388		928
		Cadweld Cable to Rod - 250 Max	4.00 E	2.7		83	-	-	-	74.90 /E	300		716
		Cadweld Cable to Rod - 250 Max	4.00 E	2.7		83		-	-	74.90 /E	300		716
		Cadweld Cable to Rod - 250 Max Cadweld Cable to Cable - 250 Max	4.00 E 4.00 E	2.7		83 83		-	-	74.90 /E 74.90 /E	300		716
		Cadweld Cable to Cable - 250 Max	4.00 E	2.7		83				74.90 /E	300		716
		Cadweld Cable to Cable - 250 Max	4.00 E	2.7	217	83	-		-	74.90 /E	300		716
		Cadweld Cable to Steel - 250 Max	6.00 E	4.0		124			-	74.87 /E	449		1,073
		Grounding Bolt and Nut Set	4.00 E	0.3		4	-	-	-	6.43 /E	26		61
	-	Grounding Bolt and Nut Set	2.00 E	0.1		2		-	-	6.44 /E	13		31
		Drill and Tap for Ground Connection	6.00 E	4.0		2		-	-	54.45 /E	327		780
	_	Above Grade Ground Wire Supports Site Electrical, Grounding	18.00 E	2.4 95.1	7,667	28 2,132		-	-	12.40 /E	9,799		533 23,411
	-			95.1	7,667	2,132				/LF	9,799		23,411
	-	Electrical, Grounding	4.00.1.6					984					
	00.45	26.10 Site Electrical	1.00 LS	245.3	19,783	4,773		984		25,540.25 /LS	25,540	61,022.09 /LS	61,022
	26.15	Process Electrical											
		Electrical, Conduit and Wire/Cable - Power											
		Process Electrical, Wire/Cable											
		THHN-THWN Copper Stranded 1/C # 12	9,180.00 lf	86.4	6,966	941		-	-	0.86 /lf	7,907		18,893
		THHN-THWN Copper Stranded 1/C # 12 THHN-THWN Copper Stranded 1/C # 8	3,060.00 lf 170.00 lf	28.8	2,322 184	314 44			-	0.86 /lf 1.34 /lf	2,636		6,298 545
		THHN-THWN Copper Stranded 1/C # 2	510.00 lf	12.3		465				2.86 /lf	1,461		3,490
		THHN-THWN Copper Stranded 1/C # 2	330.00 lf	8.0		301			-	2.86 /lf	945		2,258
		THHN-THWN Copper Stranded 1/C # 1/0	170.00 lf	5.0		239			-	3.79 /lf	644	9.05 /lf	1,539
		THHN-THWN Copper Stranded 1/C # 2/0	180.00 If	5.8		317	-		-	4.36 /lf	785		1,876
		THHN-THWN Copper Stranded 1/C # 350	510.00 lf	27.4		2,359			-	8.96 /lf	4,570		10,919
	-	THHN-THWN Copper Stranded 1/C # 500	1,530.00 lf	100.8	8,127	9,995		-	-	11.85 /lf	18,122		43,298
		XHHW Copper Stranded 1/C # 6 XHHW Copper Stranded 1/C # 1/0	240.00 lf 1,760.00 lf	3.9 52.0	312 4,197	143 3,903			-	1.90 /lf 4.60 /lf	455 8,099		1,087 19,351
		XHHW Copper Stranded 1/C # 1/0 XHHW Copper Stranded 1/C # 1/0	1,920.00 lf	56.8	4,578	4,257				4.60 /lf	8,836		21,111
		5 KV Non Shielded XLP / PVC - 1/C #350 Copper	11,040.00 lf	905.3	73,003	86,302				14.43 /lf	159,305		380,620
		Copper XLP 133% Insulated 15 KV #1/0 Copper	720.00 lf	46.5	3,746	4,193			-	11.03 /lf	7,939	26.35 /lf	18,969
		Stakon Lug #12 - #10	288.00 E	38.7		74		-	-	11.10 /E	3,197		7,637
		Compression Lug - # 8	4.00 E	0.8		10	-	-	-	18.65 /E	75		178
		Compression Lug - # 6	4.00 E	0.8		9		-	-	18.54 /E	74		177
	+	Compression Lug - # 2 Compression Lug - 1/0	18.00 E 64.00 E	6.0 30.1	488 2,428	106 420	-	1 -	 	32.96 /E 44.51 /E	593 2,848		1,418
	_	Compression Lug - 1/0 Compression Lug - 1/0	4.00 E	1.9		26				44.51 /E 44.53 /E	2,040		426
		Compression Lug - 2/0	6.00 E	3.2		47		-	-	51.14 /E	307		733
		Compression Lug - 350 MCM	12.00 E	9.7	780	176				79.74 /E	957	190.52 /E	2,286
		Compression Lug - 500 MCM	36.00 E	33.9		765	-		-	97.12 /E	3,496		8,353
		Motor Hook-up, 3 phase, 10 hp	36.00 E	87.1	7,024	2,113			-	253.80 /E	9,137		21,830
		Equipmenmt Hook-up, 3 phase, 80A	2.00 E	10.5	846	239	-	-	-	542.39 /E	1,085		2,592
		Motor Hook-up, 3 phase, 250 hp	3.00 E	56.5 33.9	4,553 2,732	549		-	-	1,700.47 /E	5,101 2,732		12,189
		Motor Testing & Commissioning: 10HP / 480V / #12 Equipment Testing & Commissioning: 80A / 480V / #4	36.00 E 2.00 E	3.0					-	75.88 /E 119.23 /E	2,732		570
		Motor Testing & Commissioning: 250 HP / 480v / 500	3.00 E	23.8		-				639.56 /E	1,919		4,584
		600V Megger Testing	218.00 E	73.3	5,908	-	-		-	27.10 /E	5,908		14,115
		Wire Markers	32.00 E	0.4	35	2			-	1.14 /E	36	2.72 /E	87
		Wire Markers	4.00 E	0.1		0	-	-	-	1.13 /E	5		11
	+	Wire Markers	336.00 E	4.5		17	-	-	-	1.14 /E	381		911
	+	Wire Markers Wire Markers	12.00 E 4.00 E	0.2		1	-	-	-	1.14 /E 1.13 /E	14		33
	1	Wire Markers Wire Markers	4.00 E 32.00 E	0.1		2			 	1.13 /E 1.14 /E	36		87
	+	Wire Markers	12.00 E	0.4		1				1.14 /E	14		3:
		Wire Markers	4.00 E	0.1	4	0				1.13 /E	5	2.69 /E	1
		5 KV Compression Lug - # 350	192.00 E	232.3	18,732	2,615			-	111.18 /E	21,346		51,00
		15 KV Indoor Termination Kit - 1/C # 1/0	6.00 E	16.1	1,301	310	-		-	268.49 /E	1,611	641.49 /E	3,84
		15 KV Outdoor Termination Kit - 1/C # 1/0	6.00 E	24.2		465	-	-	-	402.75 /E	2,417		5,77
		15 KV Compression Lug - # 1/0	12.00 E	8.1	650	105	-	-	-	62.97 /E	756	150.44 /E	1,80



Project: Boulevard Pump Station

Project No.: 478874
Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

eac Work	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Process Electrical, Wire/Cable											
		5 KV Motor Connect & Test - 1000 HP	4.00 E	53.8	4,336		-	-	-	1,084.02 /E	4,336	2,589.99 /E	10,360
		5 KV Motor Conn Insulating Boot - # 350	48.00 E	225.8	18,211	7,445	-	-	-	534.51 /E	25,656	1,277.07 /E	61,299
		5 KV Megger Testing	96.00 E	129.0	10,406	-	9,927	-	-	211.80 /E	20,333	506.05 /E	48,58
		15 KV Hi-Pot Testing	6.00 E	16.1	1,301		620			320.19 /E	1,921	765.01 /E	4,590
		MV Cable Tags	204.00 E	27.4	2,211	211	-	-	-	11.87 /E	2,422		5,788
		Process Electrical, Wire/Cable		2,493.1	201,044	129,480	10,547			/LF	341,071	/LF	814,904
		Process Electrical, Conduit											
		GRC Conduit @ Level 2 3/4"	2,700.00 lf	319.4	25,755	4,068	-	-	-	11.05 /lf	29,823	26.39 /lf	71,255
_		GRC Conduit @ Level 2 1-1/4"	150.00 lf	21.6	1,740	491	-	-	-	14.87 /lf	2,230	35.53 /lf	5,32
		GRC Conduit @ Level 2 1-1/2"	200.00 lf	32.0	2,580	771	-	-	-	16.76 /lf 37.49 /lf	3,351	40.03 /lf	8,00° 143,31
		GRC Conduit @ Level 2 3" GRC Conduit @ Level 2 3"	1,600.00 lf 150.00 lf	537.7	43,360 4,065	16,623 1,558	-	-	-	37.49 /lf 37.49 /lf	59,983 5,623	89.57 /lf 89.57 /lf	143,31
		GRC Conduit @ Level 2 3"	1,900.00 lf	638.5	51,490	19,740				37.49 /lf	71,230		170,18
		GRC Conduit @ Level 2 3"	1,900.00 If	50.4		1,558			-	37.49 /lf	5,623	89.57 /lf	13,436
		GRC Elbow 3/4"	108.00 E	36.3	2,927	965			-	36.03 /E	3,892		9,298
		GRC Elbow 1-1/4"	6.00 E	2.8	228	113			-	56.74 /E	340		813
		GRC Elbow 1-1/2"	6.00 E	3.2		140				66.67 /E	400		956
		GRC Elbow 3"	48.00 E	48.4		4,171	-	-	-	168.19 /E	8,073	401.84 /E	19,288
		GRC Elbow 3"	9.00 E	9.1	732	782	-	-		168.19 /E	1,514		3,617
		GRC Elbow 3"	57.00 E	57.5	4,634	4,953	-		-	168.19 /E	9,587	401.84 /E	22,90
		GRC Elbow 3"	6.00 E	6.0		521	-	-	-	168.20 /E	1,009	401.87 /E	2,411
		GRC Coupling 3/4"	108.00 E	7.3		278	-	-	-	7.99 /E	863	19.09 /E	2,061
		GRC Coupling 1-1/4"	6.00 E	0.6		29	-	-	-	12.34 /E	74		177
		GRC Couplng 1-1/2"	6.00 E	0.6		36	-	-	-	14.70 /E	88		211
		GRC Coupling 3"	48.00 E	7.1	572	1,223	-	-	-	37.39 /E	1,795		4,288
		GRC Coupling 3"	9.00 E	1.3		229	-	-	-	37.39 /E	337	89.33 /E	804
		GRC Coupling 3"	48.00 E	7.1	572	1,223	-	-	-	37.40 /E	1,795		4,289
		GRC Coupling 3"	15.00 E	2.2		382	-	-	-	37.39 /E	561	89.33 /E	1,340
		Rigid Conduit Hub 3/4"	144.00 E	60.0	4,839	1,925	-	-	-	46.97 /E	6,764		16,161
		Rigid Conduit Hub 3/4"	6.00 E 8.00 E	2.5		80 163	-	-	-	46.97 /E	282 553		673 1,322
		Rigid Conduit Hub 1-1/4" Rigid Conduit Hub 1-1/2"	4.00 E	2.5		89				69.17 /E 72.12 /E	288		1,322
_		Rigid Conduit Hub 1-1/2 Rigid Conduit Hub 3"	64.00 E	74.0	5,966	3,316				145.03 /E	9,282		22,177
		Rigid Conduit Hub 3"	12.00 E	13.9	1,119	622			-	145.04 /E	1,740		4,158
		Rigid Conduit Hub 3"	64.00 E	74.0	5.966	3,316				145.03 /F	9,282		22,177
		Rigid Conduit Hub 3"	12.00 E	13.9		622		· .		145.03 /E	1,740		4,158
		Rigid Conduit Hub 3"	4.00 E	4.6		207				145.03 /E	580		1,386
		Malleable LB Condulet - 3/4"	36.00 E	14.5		465		-	-	45.42 /E	1,635		3,907
		Malleable LB Condulet - 1-1/4"	2.00 E	1.1	87	60	-	-	-	73.44 /E	147	175.46 /E	351
		Malleable LB Condulet - 3"	3.00 E	4.4	358	505				287.60 /E	863	687.16 /E	2,061
		Malleable TB Condulet - 1-1/2"	2.00 E	1.3	108	94	-	-	-	101.37 /E	203		484
		EYS Seal Fitting 3"	16.00 E	32.3		1,711	-	-	-	269.53 /E	4,313		10,304
		Unistrut Straps 3/4"	360.00 E	14.5	1,171	688	-	-	-	5.16 /E	1,858		4,440
		Unistrut Straps 1-1/4"	20.00 E	1.1		49	-	-	-	6.78 /E	136		324
		Unistrut Straps 1-1/2"	14.00 E	0.8		42	-	-	-	7.34 /E	103		245
		Unistrut Straps 3"	112.00 E	7.5	607	440 82		-		9.35 /E 9.35 /E	1,047	22.33 /E 22.33 /E	2,501 469
_		Unistrut Straps 3"	21.00 E	14.0		82	-	-	-		1,944		4,645
		Unistrut Straps 3"	208.00 E 39.00 E			153				9.35 /E 9.35 /E	364		
		Unistrut Straps 3" Unistrut Straps 3"	20.00 E	2.6		153 79	·	†	-	9.35 /E 9.35 /E	187		871 447
		Unistrut Conduit Hanger Allowance 3/4"	360.00 E	19.4		372			-	5.37 /E	1,933		4,619
		Unistrut Conduit Hanger Allowance 1-1/4"	20.00 E	1.6		26		· .		7.80 /E	156		373
		Unistrut Conduit Hanger Allowance 1-1/2"	14.00 E	1.1		22		-		8.05 /E	113		269
		Unistrut Conduit Hanger Allowance 3"	400.00 E	53.8		827		-	-	12.91 /E	5,164		12,337
		EF Sealtite Flex 3/4"	36.00 lf	1.5		92	-	-	-	5.81 /lf	209	13.87 /lf	499
		EF Sealtite Flex 1-1/4"	2.00 lf	0.1	9	11	-	-	-	9.63 /lf	19	23.01 /lf	46
		EF Sealtite Flex 1-1/2"	2.00 If	0.1	11	12		-		11.56 /lf	23		55
		EF Sealtite Flex 3"	16.00 lf	1.9	156	290	-	-	-	27.85 /lf	446	66.55 /lf	1,065
		EF Sealtite Flex 3"	3.00 lf	0.4	29	54	-		-	27.85 /lf	84	66.54 /lf	200
		EF Sealtite Flex 3"	16.00 If	1.9		290	-	-	-	27.85 /lf	446		1,065
		EF Sealtite Flex 3"	3.00 lf	0.4		54	-	-	-	27.85 /lf	84		200
		LT Flex Connector Straight 3/4"	72.00 E	8.7		375		-	-	14.97 /E	1,078		2,575
	-	LT Flex Connector Straight 1-1/4"	4.00 E	0.6		53	-	-	-	26.14 /E	105		250
		LT Flex Connector Straight 1-1/2"	4.00 E	0.8		74	-	-	-	33.74 /E	135		322
		LT Flex Connector Straight 3"	32.00 E	9.5		5,765	-	-	-	204.02 /E	6,529		15,59
	-	LT Flex Connector Straight 3"	6.00 E	1.8		1,081		-		204.02 /E	1,224		2,92
		LT Flex Connector Straight 3"	32.00 E	9.5		5,765		-	-	204.02 /E	6,529		15,59
		LT Flex Connector Straight 3"	6.00 E 2.00 E	1.8		1,081	-	-	-	204.01 /E 29.68 /E	1,224		2,92
	_	Conduit Wall Penetration - 1-1/2"		0.7		5	-	 	-		59 603		1,44
		Conduit Wall Penetration - 3" Conduit Wall Penetration - 3"	16.00 E	6.5 7.7		83 98	-	<u> </u>	-	37.69 /E 37.69 /F	716	90.05 /E 90.04 /F	1,441
		Fireproof Conduit Wall Penetration - 1-1/2"	2.00 E	1.3		20				64.12 /E	128		306
	_	Fireproof Conduit Wall Penetration - 3"	16.00 E	12.9		242				80.19 /E	1,283		3,066



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

ac Work	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Process Electrical, Conduit											
		Fireproof Conduit Wall Penetration - 3"	3.00 E	2.4		45		-	-	80.20 /E	241		57
		Fireproof Conduit Wall Penetration - 3"	16.00 E	12.9	1,041	242	-	-	-	80.19 /E	1,283		3,06
		Conduit Floor Penetration - 3"	16.00 E	6.5		83		-	-	37.69 /E	603		1,44
		Fireproof Conduit Floor Penetration - 3"	16.00 E	6.5		138	-	-	-	41.15 /E	658		1,57
		Process Electrical, Conduit	6,850.00 LF	2,358.6	190,197	92,576				41.28 /LF	282,772		675,61
		Electrical, Conduit and Wire/Cable - Power		4,851.6	391,240	222,056	10,547				623,843		1,490,5
		Electrical, Conduit and Wire/Cable - Controls											
		Process Electrical, Wire/Cable											
		THHN-THWN Copper Stranded 1/C # 14	5,100.00 If	41.2	3,319	341		-	-	0.72 /lf	3,660	1.71 /lf	8,7
		THHN-THWN Copper Stranded 1/C # 14	1,275.00 lf	10.3	830	85		-	-	0.72 /lf	915	1.71 /lf	2,1
		THHN-THWN Copper Stranded 1/C # 14	377,740.00 If	3,048.4	245,823	25,247		-	-	0.72 /lf	271,070		647,6
		THHN-THWN Copper Stranded 1/C # 14	1,360.00 lf	11.0	885	91		-	-	0.72 /lf	976	1.71 /lf	2,3
		Shielded PLTC / Inst Cable 1 Pair #16	595.00 If	16.0	1,290	277		-	-	2.63 /lf	1,567	6.29 /lf	3,7
		Unshielded Twisted Pair Cable, 4-Pair CAT 6 350Mhz Ultra II	765.00 If	18.0		309		-		2.30 /lf	1,759		4,2
		UTP Cable Connector, RJ45 CAT 6 Mini-Jack TX-5e (568A/B)	18.00 E	6.0		81 50		-		31.60 /E	569		1,3
		UTP Patch Cord, RJ45/RJ45 CAT 6E 350Mhz Data-Patch - 5ft UTP Wall Plate, 4-Port, CAT 6 350Mhz, RJ45/110 (568B), White	9.00 E 9.00 E	3.0		18		-	-	12.03 /E 29.06 /E	108		2
			9.00 E			10		-			244	64.74 /E	5
		4 Pair UTP Continuity Test	9.00 E	3.0 7.6						27.10 /E 68.29 /E	615		1,4
		4 Pair UTP Certification with Documentation UTP Cable Supports	54.00 E	3.6		28				5.94 /E	321		7
		Termination Labor Only - # 16 - #14	1,185.00 E	159.3	12,846	20				10.84 /E	12,846	25.90 /E	30,6
		Control Wire Testing	589.00 E	79.2	6,385					10.84 /E	6,385		15,2
		Wire Markers	1,118.00 E	15.0		58				1.14 /F	1,269		3,0
		Wire Markers	49.00 E	0.7		3		-	-	1.13 /E	56		1:
		Wire Markers	18.00 E	0.2		1		-	-	1.14 /E	20		
		Process Electrical, Wire/Cable	386.835.00 LF	3,423,2	276.054	26.587				0.78 /LF	302.641	1.87 /LF	723.08
		Process Electrical, Conduit	000,000.00 2.	0,12012	2.0,00	20,000				0.72	002,011	1101 721	. 20,00
		GRC Conduit @ Level 2 3/4"	5,625.00 If	665.4	53,657	8,475				11.05 /lf	62,132	26.39 /lf	148,4
		GRC Clibow 3/4"	198.00 E	66.5	5,366	1.769			-	36.03 /E	7,134		17,0
		GRC Elbow 3/4"	27.00 E	9.1	732	241			-	36.03 /E	973		2,32
		GRC Coupling 3/4"	45.00 E	3.0		116			-	7.99 /E	359		85
		GRC Coupling 3/4"	132.00 E	8.9		339			-	7.99 /E	1,055		2,5
		GRC Coupling 3/4"	21.00 E	1.4		54				7.99 /E	168		4(
		GRC Coupling 3/4"	27.00 E	1.8		69		-		7.99 /E	216		5′
		Rigid Conduit Hub 3/4"	118.00 F	49.2		1,577		-		46.97 /F	5,542		13,2
		Rigid Conduit Hub 3/4"	32.00 E	13.3	1,075	428	-	-	-	46.97 /E	1,503	112.23 /E	3,5
		Malleable LB Condulet - 3/4"	59.00 E	23.8	1,919	761		-	-	45.42 /E	2,680	108.53 /E	6,4
		Malleable LB Condulet - 3/4"	16.00 E	6.5	520	206	-	-	-	45.42 /E	727	108.53 /E	1,7
		Unistrut Straps 3/4"	150.00 E	6.0	488	286		-	-	5.16 /E	774	12.33 /E	1,8
		Unistrut Straps 3/4"	440.00 E	17.7	1,431	840	-	-	-	5.16 /E	2,271	12.33 /E	5,42
		Unistrut Straps 3/4"	160.00 E	6.5		306	-	-	-	5.16 /E	826		1,9
		Unistrut Conduit Hanger Allowance 3/4"	750.00 E	40.3		776		-	-	5.37 /E	4,027	12.83 /E	9,6
		EF Sealtite Flex 3/4"	15.00 If	0.6		38	-	-	-	5.81 /lf	87		21
		EF Sealtite Flex 3/4"	60.00 If	2.4		153		-	-	5.81 /lf	348		83
		LT Flex Connector Straight 3/4"	30.00 E	3.6		156		-	-	14.96 /E	449		1,0
		LT Flex Connector Straight 3/4"	88.00 E	10.6	859	458		-	-	14.97 /E	1,317	35.76 /E	3,1
		LT Flex Connector Straight 3/4"	32.00 E	3.9	312	167		-	-	14.96 /E	479	35.74 /E	1,1
		Process Electrical, Conduit	5,625.00 LF	940.6	75,852	17,216				16.55 /LF	93,068	39.53 /LF	222,30
		Electrical, Conduit and Wire/Cable - Controls	1.00 LS	4,363.9	351,906	43,803				395,709.38 /LS	395,709	945,449.31 /LS	945,44
		Electrical, Grounding											
		Process Electrical, Grounding											
		Miscellaneous Grounding	1.00 ls	80.7	6,504	2,585		-		9,089.08 /ls	9,089	21,716.08 /ls	21,7
		Process Electrical, Grounding	1.00 LF	80.7	6,504	2,585				9,089.08 /LF	9,089	21,716.08 /LF	21,7
		Electrical, Grounding	1.00 LS	80.7	6,504	2,585		İ		9,089.08 /LS	9,089	21,716.08 /LS	21,7
		26.15 Process Electrical	1.00 LS	9,296.1	749,650	268,444	10,547			1,028,641.61 /LS	1,028,642	2,457,683.68 /LS	2,457,6
	20.20		1.00 L3	3,230.1	749,030	200,444	10,347			1,020,041.01 /L3	1,020,042	2,931,003.00 /LS	2,457,0
-	26.20	Facility Electrical	+	-	-						-		
		Facility Electrical, Complete \$/SF Cost											
		Facility Electrical, Complete \$/SF Cost											
		PS Building, Electrical Subcontract, Division 16	8,855.00 sf		-	-	509,365	-	-	57.52 /sf	509,365	137.44 /sf	1,217,0
		Facility Electrical, Complete \$/SF Cost	8,855.00 SF				509,365			57.52 /SF	509,365	137.44 /SF	1,217,0
		Facility Electrical, Complete \$/SF Cost	1.00 LS				509,365			509,365.00 /LS	509,365	1,217,001.19 /LS	1,217,0
		26.20 Facility Electrical	1.00 LS				509,365			509,365.00 /LS	509,365	1,217,001.19 /LS	1,217,0
	26.25	Electrical Equipment	20				555,000			000,000.00 /20	553,500	1,211,001110 /20	.,217,0
	20.20												
		Electrical Equipment			-								
		Electrical, Testing											
		Megger/Check Elec Equipment	1.00 LS	188.2	15,176	-	-	-	-	15,176.07 /LS	15,176	36,259.43 /LS	36,2
		Electrical, Testing	1.00 LS	188.2	15,176					15,176.07 /LS	15,176	36,259.43 /LS	36,2
		Electrical Equipment, MCCs - General											
		LV MCC Vertical Sections - 600A	6.00 E	64.5	5,203	13.959				3,193.75 /E	19.163	7,630.69 /E	45,7



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual Estima

Revision / Date: Rev03, (10-4-2016) Estimate Class: 4

Estimator:

E.B. Smith/GNV, A. Frisch/PGH

MCC Main LI MCF PAIN LI MCF PAIN LI MCF PAIN LI MCF Circuit E Switchboard i Voltage monit modem Transformer, secondary, 34 Paneboards, drouts, NGO Electrical E Electrical E Med Volt Swg Low Volt Swg L	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
MCC FVNRS MCC Circuit E Switchboard I Voltage monit modem Transformer, secondary, 3(Panelboards, 3(Panelboa	trical Equipment, MCCs - General											
MCC Circuit E MCC Circuit Southboard i Voltage monit modern Transformer, secondary, 3(Panelboards, 3(Panelbo	Main Lug Only - 600A	1.00 E	3.4	271	1,396	-	-	-	1,666.90 /E	1,667		3,98
MCC Circuit Switchboard i Voltage monit modern Transformer, secondary, 3(Panelboards, circuits, NQO) Electrical E Electrical E Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Voltage i Switchboard i Voltage monit modern Electrical E Electrical E Electrical E Safey switch Switchboard i Voltage monit modern Electrical E	FVNR Starter w/ Circuit Breaker - Size 1	9.00 E	9.7	780 786	3,090 6,761		-		430.02 /E	3,870		9,24 18,03
Switchboard i Voltage monit modem Transformer, secondary, 33 Panelboards, circuits, NGO Electrical E Electrical E Med Volt Swg Med Voltage I Switchboard i Voltage monit modem Electrical E Electrical E Safety switch 3R Electrical E Electric		29.00 E 2.00 E		163					260.22 /E 337.21 /E	7,546		
Voltage monit modem Transformer, secondary, 34 Panelboards, circuits, NGO Electrical E Electrical E Med Volt Swg Med Voltage i Switchboard i Voltage monit modem Electrical E			2.0		512		-					1,61 17,44
modem Transformer, secondary, 30 Panelboards, circuits, NGO Electrical E Electrical E Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Voltage Electrical E Low Voltage monit modern Electrical E Low Volt Swg	chboard instruments, ground fault protection, ground return path	1.00 ea	4.0	321	6,980	-	-	-	7,300.86 /ea	7,301		
secondary, 32 Panelboards, circuits, NQOI Electrical E Electrical E Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Voltage Electrical E		1.00 ea			4,136		-	-	4,136.10 /ea	4,136		9,88
circuits, NGO Electrical E Electrical E Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Voltage Electrical E	sformer, dry-type, ventilated, 3 phase 480 V primary 120/208 V ndary, 30 kVA	1.00 ea	2.4	193	,-	-	-	-	1,717.84 /ea	1,718	, , , , , , , , , , , , , , , , , , , ,	4,10
Electrical E Med Volt Swg Med Voltage monit Med Med Med Med Med Med Med Med Med Med	lboards, 3 phase 4 wire, main lugs, 120/208 V, 100 amp, 30 its, NQOD, incl 20 A 1 pole plug-in breakers	1.00 ea	2.0	164	1,163	-	-	-	1,326.82 /ea	1,327	·	3,17
Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Voltage Med Med Med Med Low Volt Swg Low Volt Swg Low Volt Swg Med Med Med Med Med Med Med Med Med Med	trical Equipment, MCCs - General trical Equipment, Switchgear - 5 KV	1.00 LS	97.7	7,881	39,522				47,402.05 /LS	47,402	113,255.46 /LS	113,25
Med Voil Swg Med Med Med Med Med Med Med Med Med Med	Volt Swgr Section NEMA 1 1200A	4.00 E	80.7	6,504	20,681				6,796.14 /E	27,185	16,237.68 /E	64,95
Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Voltage : Switchboard i Voltage monit modem Electrical E Electrical E Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Voltage ronit voltage monit modem Electrical E Electrical	Volt Swgr Section NEMA 1 1200A	2.00 E	40.3	3,252	10,340				6,796.13 /E	13,592		32,47
Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Med Med Med Med Med Med Med Med Med	Volt Swgr Section NEMA 1 1200A	2.00 E	40.3	3,252	10,340				6,796.13 /E 6.796.14 /E	13,592		32,47
Med Vol Swg Med Vol Swg Med Vol Swg Med Vol Swg Med Vol Swg Med Vol Swg Med Vol Swg Med Vol Swg Med Vol Swg Med Voltage Med Voltage Med Voltage Switchboard i Voltage monit modem Electrical E Low Vol Swg Low Voll Swg Low Voll Swg Low Voll Swg Low Volt Swg Low Voltage monit modem Electrical E	Volt Swgr Main Breaker 1200A	1.00 E	2.7	217	51.701		-		51.918.06 /E	51,918		124.04
Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Volt Swg Med Voltage Med Voltage Med Voltage Med Voltage Switchboard Voltage monit modern Electrical E Electrical E Low Volt Swg Lo	Volt Swgr Main Breaker 1200A Volt Swgr Main Breaker 1200A	2.00 E	5.4	434	103,403		-		51,918.11 /E	103,836		248,09
Med Vols Swy Med Vols Swy Med Vols Swy Med Voltage i Med Voltage i Switchboard i Voltage monit modern Electrical E Low Volt Swy Low Volt Swy Low Volt Swy Low Volt Swy Low Volt Swy Low Volt Swy Low Volt Swy Low Volt Swy Low Volt Swy Low Voltage i Switchboard i Voltage monit modern Electrical E Electrical	Volt Swgr Main Breaker 1200A Volt Swgr Main Breaker 1200A	1.00 E	2.7	217	51,701				51,918.05 /E	51,918		124,04
Med Volt Swg Med Voltage Med Voltage Med Voltage Med Voltage Switchboard i Voltage monit modem Electrical E Electrical E Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Voltage monit modem Electrical E		1.00 E	2.7	217	31,701				216.84 /E	217		51
Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Med Voltage Voltage monit Description Electrical E Low Volt Swg Electrical E	Volt Swgr Feed Breaker 1200A	5.00 E	13.4	1,084	258,507		<u> </u>	· ·	51,918.11 /E	259,591		620,22
Med Voltage : Med Voltage Med Voltage Switchboard Voltage monit modem	Volt Swgr Metering	1.00 E	2.7	217	51.701			-	51,918.06 /F	51,918		124.04
Med Voltage : Switchboard i Voltage monit modern Electrical E Low Volt Swg Switchboard Safety switch 3R Electrical E Elect	Voltage Switchgear Breaker Calibration	6.00 E	8.1	650	310				160.11 /E	961		2,29
Switchboard i Voltage monit modem Electrical E Electrical E Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Voltage monit modem Electrical E Electrical E Electrical E Electrical E Flectrical E Electrical E	Voltage Switchgear Breaker Calibration	4.00 E	5.4	434	207				160.10 /E	640	382.53 /E	1,53
Voltage monit modem Electrical E Electrical E Low Voll Swg Low Voll Swg Low Voll Swg Low Voll Swg Low Voll Swg Low Voll Swg Low Voll Swg Low Voll Swg Electrical E Electrical E Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBO Electrical E Electrical E Electrical E Electrical E Generator set Low Low Low Low Low Low Low Low Low Low	chboard instruments, ground fault protection, ground return path	1.00 E	4.0	321	6,980				7,300.87 /ea	7,301		17,44
Electrical E Electrical E Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Voltage monit modem Electrical E Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBC Electrical E Electrical E Electrical E Generator set Generator set Generator set Low Low Low Low Low Low Low Low Low Low	ge monitor systems, AC voltage remote, add-on det only, w/internal	1.00 ea	4.0	- 321	4,136		-	-	4,136.10 /ea	4,136		9,88
Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Volt Swg Low Voltage Switchboard i Voltage monit modern Electrical E Electrical E Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBC Electrical E	trical Equipment, Switchgear - 5 KV	19.00 EA	208.3	16,798	570,007				30,884.47 /EA	586,805	73,790.77 /EA	1,402,02
Low Yolf Swg Low Yolf Swg Low Volf Swg Low Volf Swg Low Volfage Switchboard i Voltage monit modem Electrical E Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBG Electrical E Electrical E Electrical E Transformer, XVA, pad mo. Transformer, 3000 kYA, Electrical E Electrical E Electrical E Electrical E Generator set tank.excl con Electrical E	trical Equipment, Switchgear - 480V											
Low Yolf Swg Low Yolf Swg Low Volfage Switchboard I Voltage monit modern Electrical E Electrical E Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBC Electrical E	Volt Swgr Section NEMA 1 1200A	4.00 E	80.7	6,504	20,681	-	-	-	6,796.14 /E	27,185	16,237.69 /E	64,95
Low Voll Saye Low Vollage Switchboard i Voltage monit modem Electrical E Electrical E Safety switch 3R Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBC Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Transformer, 300 kVA, pad mou Transformer, 300 kVA, pad mou Electrical E	Volt Swgr Main Breaker 1200A	1.00 E	2.7	217	51,701	-	-	-	51,918.06 /E	51,918		124,04
Low Voll Saye Low Vollage Switchboard i Voltage monit modem Electrical E Electrical E Safety switch 3R Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBC Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Transformer, 300 kVA, pad mou Transformer, 300 kVA, pad mou Electrical E	Volt Swgr Feeder Breakers 400AF 600V	4.00 E	5.4	434	103,403				25,959.06 /E	103,836	62,022.72 /E	248,09
Switchboard I Voltage monit Voltage monit Plectrical E Electrical E Safety switch 3R Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBO Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Generator set tank.excl cont Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E	Volt Swgr Metering	1.00 E	2.0	163	25,851		-		26,013.21 /E	26,013	62,152.12 /E	62,15
Switchboard I Voltage monit Voltage monit Plectrical E Electrical E Safety switch 3R Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBO Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Generator set tank.excl cont Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E	Voltage Switchgear Breaker Calibration	5.00 E	6.7	542	259		-	-	160.10 /E	800	382.51 /E	1,91
Voltage monit modem Electrical E Electrical E Safety switch 3R Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBC Electrical E Electrical E Electrical E Electrical E Electrical E Generator set tank excl conc Electrical E	chboard instruments, ground fault protection, ground return path	1.00 ea	4.0	321	6,980				7,300.86 /ea	7,301		17,44
Electrical E Safety switch 3R Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBC Electrical E Transformer, kVA, pad mo. Transformer, 3000 kVA, pad Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E Electrical E	ge monitor systems, AC voltage remote, add-on det only, w/internal	1.00 ea		-	4,136	-	-	-	4,136.11 /ea	4,136	9,882.19 /ea	9,88
Safety switch 3R Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEM 1, FBC Electrical E Electrical E Transformer, kVA, pad mot Transformer, 3000 kVA, pa Electrical E	trical Equipment, Switchgear - 480V	17.00 EA	101.4	8,180	213,009				13,011.15 /EA	221,190	31,086.91 /EA	528,47
3R Electrical E Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBC Electrical E Electrical E Transformer, KVA, pad mou Transformer, 3000 KVA, Electrical E	trical Equipment, Switches - General											
Electrical E Variable frequ 1, FBO Variable frequ NEMA 1, FBO Variable frequ NEMA 1, FBO Electrical E Electrical E Transformer, KVA, pad mou Transformer, 3000 kVA, pa Electrical E Electrical E Generator set tank, excl cont Electrical E Electrical E Generator set tank, excl	ty switches, heavy duty, 3 pole, nonfusible, 600 volt, 30 amp, NEMA	34.00 ea	117.9	9,657	5,625	-	-	-	449.49 /ea	15,282	1,073.93 /ea	36,51
Variable frequency of the frequency of t	trical Equipment, Switches - General	1.00 LS	117.9	9,657	5,625				15,282.48 /LS	15,282	36,513.71 /LS	36,51
Variable frequ. NEMA 1, FSC Electrical E Electrical E Transformer, KVA, pad mo. Transformer, 3000 kVA, pad Electrical E Electrical E Generator set tank, excl conc Electrical E Electrical E	trical Equipment, VFDs - General ble frequency drives, enclosed, 480 volt, 215 HP motor size, NEMA	3.00 ea	192.0	15,692	620	-	1,410	-	5,907.45 /ea	17,722	14,114.39 /ea	42,34
Electrical E Electrical E Transformer, kVA, pad mot Transformer, 3000 kVA, pa Electrical E Electrical E Generator set tank.excl cond Electrical E Electrical E	ble frequency drives, enclosed, 4160 volt, 700 HP motor size,	4.00 ea	384.1	31,385	827	-	1,880	-	8,522.86 /ea	34,091	20,363.26 /ea	81,45
Electrical E Transformer, kVA, pad mo. Transformer, 300 kVA, pad Electrical E Electrical E Generator set tank.excl conc Electrical E Electrical E	A 1, FBO trical Equipment, VFDs - General	1.00 LS	576.1	47,077	1,448		3,289		51,813.79 /LS	51.814	123,796.18 /LS	123,79
kVA, pad mo. Transformer, 3000 kVA, pa Electrical E Electrical E Generator set tank, excl con Electrical E Electrical E	trical Equipment, Transformers - General								·		,	
3000 kVA, pa Electrical E Electrical E Generator set tank, excl con Electrical E Electrical E		1.00 ea	70.7	5,781	27,815	-	519	-	34,116.02 /ea	34,116	·	81,51
Electrical E Generator set tank,excl conc Electrical E Electrical E	sformer, liquid-filled, 15 kV primary, 4160 V secondary, 3 phase, kVA, pad mounted	1.00 ea	141.5	11,563	67,729	-	1,039	-	80,330.18 /ea	80,330	191,929.02 /ea	191,92
Generator set tank, excl cond Electrical E Electrical E	trical Equipment, Transformers - General trical Equipment, Generators - General	1.00 LS	212.2	17,344	95,544		1,558		114,446.20 /LS	114,446	273,440.78 /LS	273,44
Electrical E	erator set,diesel, 2.75MW,incl battery,charger,enclosure,muffler,day	1.00 ea	468.8	37,351	186,125	-	1,672	-	225,148.20 /ea	225,148	537,935.72 /ea	537,93
Electrical E	excl conduit,wiring,& concrete trical Equipment, Generators - General	1.00 LS	468.8	37,351	186,125		1,672		225,148.20 /LS	225,148	537,935.72 /LS	537,93
	trical Equipment	1.00 LS	1,970.8	159,464	1,111,279		6,520		1,277,263.21 /LS	1,277,263	3,051,703.27 /LS	3,051,70
20.20 E100ti	5 Electrical Equipment	1.00 LS	1,970.8	159,464	1,111,279		6,520		1,277,263.21 /LS	1,277,263		3,051,70
26 0 Floatri	Electrical Work	1.00 LS	11.512.2	928.897	1,384,496	519.912	7.504		2,840,810.07 /LS	2,840,810		6,787,41
		1.00 LS	11,512.2	920,097	1,384,496	519,912	1,504	-	2,040,010.07 /LS	2,840,810	0,707,410.23 /LS	0,707,41
	rior Improvements		-				-	-				
32.50 Site, Improv	Improvements											
Site Improv	Improvements, Pipe Bollards											
	Improvements, Bollards											
	bollards, steel, concrete filled/paint, 8' L x 4' D hole, 12" dia	13.00 ea	34.9	2,862	4,570				571.70 /ea	7,432	1,280.18 /ea	16,64
	Improvements, Bollards	13.00 EA	34.9	2,862	4,570				571.70 /EA	7,432		16,64
	Improvements, Boilards Improvements, Pipe Bollards	1.00 LS	34.9	2,862	4,570				7,432.07 /LS	7,432		16,64



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

Fac Wor		Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		32.50 Site, Improvements	1.00 AC	34.9	2,862	4,570				7,432.07 /AC	7,432	16,642.28 /AC	16,642
		32.0 Exterior Improvements	1.00 LS	34.9	2,862	4,570				7,432.07 /LS	7,432	16,642.28 /LS	16,642
40.0		Process Pipe											
	40.00	Exposed Process Pipe											
		12" DI Pipe											
		Process Pipe, Ductile Iron, 12"											
		Install 12" DI, flanged, spool <= 10'	4.00 ea	29.6	2,589	- 4.070		-	-	647.23 /ea	2,589		6,004
		12" Fabricated DI Spool, FxF, 5' 0" - FURNISH 12" DI, FL, Ell, 90	4.00 ea 4.00 ea	29.6	2,589	4,273 1,920			-	1,068.15 /ea 1,127.18 /ea	4,273 4,509		9,909 10,457
		12" DI, flanged coupling adapter	8.00 ea	55.1	4,820	2,184				875.50 /ea	7,004		16,244
		Process Pipe, Ductile Iron, 12"	5.00 LF	114.2	9,998	8,376				3,674.84 /LF	18,374		42,614
		12" DI Pipe	5.00 LF	114.2	9,998	8,376				3,674.84 /LF	18,374	8,522.88 /LF	42,614
		24" DI Pipe											
		Process Pipe, Ductile Iron, 24"											
		Install 24" DI, flanged, spool <= 10'	8.00 ea	128.8	11,278	-			-	1,409.78 /ea	11,278		26,157
		24" Fabricated DI Spool, FxF, 1' 0" - FURNISH	4.00 ea		-	7,424			-	1,856.08 /ea	7,424		17,219
		24" Fabricated DI Spool, FxF, 7' 0" - FURNISH	4.00 ea	400.0		14,319		-	-	3,579.80 /ea	14,319		33,210
		24" DI, FL, EII, 90 24" DI, FL, reducer, 24" x 12"	8.00 ea 4.00 ea	128.8 64.4	11,278 5,639	16,967 5,255			-	3,530.67 /ea 2,723.57 /ea	28,245 10,894		65,508 25,267
		24" DI, FL, base Ell, 90	4.00 ea	70.9		11,277			<u> </u>	4,370.19 /ea	17,481		40,542
		24" DI, flanged coupling adapter	4.00 ea	60.5	5,296	2,184			-	1,869.86 /ea	7,479		17,347
		Pipe support	1.00 ea	5.4		1,176		-	-	1,646.39 /ea	1,646		3,818
		Process Pipe, Ductile Iron, 24"	32.00 LF	458.8	40,166	58,602				3,086.50 /LF	98,768		229,068
		24" DI Pipe	32.00 LF	458.8	40,166	58,602				3,086.50 /LF	98,768	7,158.37 /LF	229,068
		Valves											
		Gate Valves, 12"											
		Install gate valve, Flgd, DIP, 12"	4.00 ea	32.3	2,747			- 2,016	-	1,190.74 /ea	4,763		11,046
	_	Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 12"	4.00 ea	20.0	0.747	5,121		2.040	-	1,280.13 /ea	5,121	2,968.94 /ea	11,876
		Gate Valves, 12"	4.00 EA	32.3	2,747	5,121		2,016		2,470.87 /EA	9,883	5,730.56 /EA	22,922
		Gate Valves, 24" Install gate valve, Figd, DIP, 24"	4.00 ea	66.7	5,677			- 4.166		2,460.85 /ea	9,843	5,707.32 /ea	22,829
		CI Valve Box & Cover, w/ Concrete Collar included	4.00 ea	16.1	1,373	620		- 1,008		750.45 /ea	3,002		6,962
		FURNISH Gate valve, iron body, solid wedge, Flgd, 250#, HWO, 24"	4.00 ea	10.1	- 1,070	127,963			-	31,990.70 /ea	127,963		296,778
		Gate Valves, 24"	4.00 EA	82.8	7,050	128,583		5,174		35,202.00 /EA	140,808	81,642.29 /EA	326,569
		Gate Valves, 30"											
		Install gate valve, Flgd, DIP, 30"	4.00 ea	75.3	6,410	-		- 4,704	-	2,778.41 /ea	11,114		25,775
		Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 30"	4.00 ea		-	127,963			-	31,990.70 /ea	127,963		296,778
		Gate Valves, 30"	4.00 EA	75.3	6,410	127,963		4,704		34,769.11 /EA	139,076	80,638.31 /EA	322,553
		Check Valves, 12"											
		Install check valve, Flgd, DIP, 12" Check valve, iron body, swing check, Flgd, 250#, 12"	4.00 ea 4.00 ea	32.3	2,747	11.875		- 2,016	-	1,190.74 /ea 2,968.69 /ea	4,763 11,875		11,047 27,541
		Check Valves, 12"	4.00 EA	32.3	2.747	11,875		2.016	·	4,159.43 /EA	16.638		38,587
		Flow Meter, 24"	4.00 EA	52.5	2,141	11,010		2,010		4,100.40 /LA	10,000	3,040.70 7EA	30,307
		Install magnetic flow meter, 24"	4.00 ea	66.7	5,837					1,459.22 /ea	5,837	3,384.30 /ea	13,537
		Flow Meters 24"	4.00 ea	0.0	0,007	99,266				24,816.62 /ea	99,266	57,555.99 /ea	230,224
		Flow Meter: Electrical Hookup Only, 24"	4.00 ea	67.2	5,420	-			-	1,355.01 /ea	5,420	3,142.61 /ea	12,570
		Flow Meter, 24"	4.00 EA	133.9	11,257	99,266				27,630.85 /EA	110,523		256,332
		Valves	1.00 LS	356.5	30,211	372,808		13,911		416,928.99 /LS	416,929	966,963.24 /LS	966,963
		30" DI Pipe											-
		Process Pipe, Ductile Iron, 30"											
	-	Install 30" DI, flanged, spool <= 10'	3.00 ea	60.9	5,327	-			-	1,775.73 /ea	5,327		12,355
	-	Install 30" DI, flanged, spool > 10"	4.00 ea	101.4	8,878	42.000	-	-	-	2,219.39 /ea	8,878		20,589
	+	30" Fabricated DI Spool, FxF, 8' 6" - FURNISH 30" Fabricated DI Spool, FxF, 9' 6" - FURNISH	2.00 ea 1.00 ea		-	13,639 7,342	<u> </u>		 	6,819.40 /ea 7,341.59 /ea	13,639 7,342		31,632 17,027
		30" Fabricated DI Spool, FxF, 14' 6" - FURNISH	4.00 ea		-	39,827			1	9,956.64 /ea	39,827	23,091.95 /ea	92,368
		30" DI, FL, EII, 90	8.00 ea	162.3	14,206	29,893				5,512.30 /ea	44,098		102,275
		30" DI, FL, wye, red, 30" x 24"	4.00 ea	101.4	8,878	37,595			-	11,618.05 /ea	46,472		107,781
	_	30" DI, FL, reducer, 30" x 18"	4.00 ea	81.1	7,103	9,560	-	-	-	4,165.73 /ea	16,663	9,661.37 /ea	38,645
	_	Process Pipe, Ductile Iron, 30"	69.50 LF	507.1	44,391	137,854	-	1		2,622.23 /LF	182,245		422,673
	+	30" DI Pipe	69.50 LF	507.1	44,391	137,854	-	-		2,622.23 /LF	182,245	6,081.62 /LF	422,673
	-	18" DI Pipe					-						
	-	Process Pipe, Ductile Iron, 12"	400					-		4.050.07		4,000,00, 1	
	+	18" DI, FL, reducer, 18" x 14" 18" DI, flanged coupling adapter	4.00 ea 4.00 ea	48.7 45.4	4,265 3,977	3,151 1,638			-	1,853.97 /ea 1,403.85 /ea	7,416 5,615		17,199 13,023
		Process Pipe, Ductile Iron, 12"	1.00 LF	94.2	8,242	4,789				13,031.26 /LF	13,031	30,222.76 /LF	30,223
		18" DI Pipe	1.00 LS	94.2		4,789				13.031.26 /LS	13,031	30,222.76 /LS	30,223
	+	40.00 Exposed Process Pipe	1.00 L3	1,530.8	133,008	582,429		13,911		13,031.26 /LS /LF	729,348	,	1,691,541
	40.30			1,000.0	133,000	302,429		13,311		/LF	125,340	/LF	1,031,341



Project: Boulevard Pump Station

Project No.: 478874
Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Equipment Sluice Gate											
		Sluice Gates, Rectangular, 36"											
		36" Wide Rectangular Sluice Gate Wall Thimble - FURNISH	3.00 ea		-	5,041				1,680.29 /ea	5,041	3,897.03 /ea	11,69
		36" Wide Rectangular Sluice Gate Wall Thimble - Installation	3.00 ea	145.2	10,917	-			-	3,639.13 /ea	10,917	8,440.05 /ea	25,32
		36" Wide Rectangular Sluice Gate - FURNISH	3.00 ea		-	16,131			-	5,376.94 /ea	16,131		37,41
		36" Wide Rectangular Sluice Gate - Installation	3.00 ea	96.8	7,278			-	-	2,426.08 /ea	7,278		16,88
		Sluice Gates, Rectangular, 36"	3.00 EA	242.0	18,196	21,172				13,122.44 /EA	39,367	30,434.25 /EA	91,30
		Sluice Gates, Rectangular, 42"											
		42" Wide Rectangular Sluice Gate Wall Thimble - FURNISH	5.00 ea		-	11,762		-	-	2,352.41 /ea	11,762		27,27
		42" Wide Rectangular Sluice Gate Wall Thimble - Installation	5.00 ea	282.3	21,228			-	-	4,245.63 /ea	21,228		49,23
		42" Wide Rectangular Sluice Gate - FURNISH 42" Wide Rectangular Sluice Gate - Installation	5.00 ea 5.00 ea	188.2	14,152	33,606				6,721.17 /ea 2,830.42 /ea	33,606 14,152		77,94 32,82
		Boxout Concrete at Sluice Gate Frame Invert	26.50 lf	7.1	536	37			-	21.61 /lf	573		1,32
		Grout Boxout at Sluice Gate Frame Invert	25.18 cf	50.8	3,817	937			-	188.86 /cf	4,754		11,02
		Sluice Gates, Rectangular, 42"	5.00 EA	528.4	39,733	46,342				17,215.06 /EA	86,075		199,63
		Equipment Sluice Gate	8.00 EA	770.3	57.929	67.514				15.680.33 /EA	125,443	36.366.63 /EA	290,93
		40.30 Water Control Gates	7.00 EA	770.3	57,929	67,514				17,920.37 /EA	125,443	41,561.86 /EA	290,93
		40.0 Process Pipe	1.00 LF	2.301.1	190.937	649.943		13.911		854,790.22 /LF	854,790		1,982,47
40.9		Instrumentation & Controls	1100 21	2,001	100,001	010,010		10,011		001,100122 721	551,155	1,002,110.01 72.	1,002,11
40.3	40.90	Instrumentation & Controls											
	40.30												
		Instrumentation & Controls I&C, Flow / Mag Meter / Indicators & Transmitters						1			+		
		FE - Flow Element - Mag Flowtube (inline)	4.00 ea	10.8	867	207				268.50 /ea	1,074	641.52 /ea	2,56
		FT / FIT - Flow Transmitter - Magnetic,	4.00 ea	10.8	5,420	74,450		-	-	19,967.48 /ea	79,870		190,82
		I&C, Flow / Mag Meter / Indicators & Transmitters	4.00 EA	78.0		74,450		·		20,235.98 /EA	80,944		193,39
		I&C, Level / Indicators & Transmitters	4.00 LA	70.0	0,207	74,037				20,233.30 /LA	00,344	40,340.00 /LA	193,39
		LE - Level Element / Sensor	2.00 ea	0.7	54	103				78.80 /ea	158	188.26 /ea	37
		IT / I IT - I evel Transmitter	2.00 ea	6.0		2,637			- :	1,562.29 /ea	3,125		7,46
		I&C, Level / Indicators & Transmitters	2.00 EA	6.7		2,740				1,641.08 /EA	3,282		7,84
		I&C, Pressure / Indicators & Transmitters	2.00 2.1		0.2	2,: 10				1,011100 7211	0,202	0,020,00 72,1	.,,,,,
		PI - Pressure Indicator - Stem Mounted	8.00 ea	5.4	434	2,688				390.26 /ea	3,122	932.42 /ea	7,45
		PE - Diaphragm Seal	8.00 ea	16.1	1,301	3,516			-	602.07 /ea	4,817		11,50
		I&C, Pressure / Indicators & Transmitters	8.00 EA	21.5	1,734	6,204				992.33 /EA	7,939		18,96
		I&C. Other / Switches									,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	, , , , , , , , , , , , , , , , , , , ,	
		Control Stations	44.00 E	59.1	4,770	4,420				208.85 /E	9,189	498.99 /E	21,95
		I&C, Other / Switches	44.00 EA	59.1	4,770	4,420				208.85 /EA	9,189	498.99 /EA	21,95
		I&C, Panels & Stands											
		Instrument Stand-Single, Galv.	6.00 ea	10.1	813	310				187.20 /ea	1,123	447.26 /ea	2,68
		Instrument Stand-Single, Galv.	2.00 ea	3.4	271	103			-	187.18 /ea	374	447.21 /ea	89
		Instrument Stand-Single, Galv.	44.00 ea	73.9	5,962	2,275			-	187.20 /ea	8,237		19,68
		I&C, Panels & Stands	52.00 EA	87.4	7,046	2,688				187.20 /EA	9,734	447.27 /EA	23,25
		I&C, PLC, Control Panels, Network Hardware											
		Network Hardware	1.00 ls	10.8		5,170			-	6,037.34 /ls	6,037		14,42
		Ethernet Radio [Wireless] - SCADA	1.00 ea	53.8	4,336	25,851			-	30,186.73 /ea	30,187		72,12
		Local Control Panel, Odor Control, FBO	1.00 ea	20.2		207		-	-	1,832.76 /ea	1,833		4,37
		Local Control Panel, Sump Pump Controller, FBO	1.00 ea	20.2	1,626 4,878	207 620			-	1,832.85 /ea 1,832.82 /ea	1,833 5,498		4,37 13,13
		Local Control Panel, Screen Control, FBO Local Control Panel, Generator Control, FBO	3.00 ea 1.00 ea	20.2	1,626	207			-	1,832.85 /ea	1,833		4,37
		Blvd PS - PLC Cabinet	1.00 ea	53.8	4,336	31,021				35,356.85 /ea	35,357		84,47
		I&C, PLC, Control Panels, Network Hardware	8.00 EA	239.3	19,295	63,282				10,322.23 /EA	82,578		197,29
		I&C, Sotfware, Programming	0.00 271	200.0	10,200	00,202				10,022,20 72,1	02,010	24,002141 7271	101,20
		SCADA Software Licenses	1.00 ea	0.0		3,619			_	3,619.09 /ea	3,619	8,646.94 /ea	8,64
		PLC / SCADA Software Development	292.00 pts	1,766.3	142,438	0,010				487.80 /pts	142.438		340,32
		I&C, Sotfware, Programming	292.00 EA	1,766.3	142,438	3,619				500.20 /EA	146,057		348,96
		I&C, Instrument Tubing, Piping, etc.		1,,, 00,0	1.2,100	2,010				727.	1.0,007	1,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	1 10,000
		Press Gauge / Press Sw Installation Materials - Stainless	8.00 ea	28.0	2,255	1,241				436.95 /ea	3,496	1,043.99 /ea	8,35
		I&C, Instrument Tubing, Piping, etc.	1.00 LF	28.0	2,255	1,241				3,495.61 /LF	3,496		8,35
		I&C, Other			,	,				., ,	5,742	.,	
		Receive & Store Instrument	61.00 ea	28.7	2,314	1				37.95 /ea	2,315	90.67 /ea	5,53
		Identification Tag - SS	6.00 ea	2.0		93			-	42.61 /ea	256		61
		Identification Tag - SS	2.00 ea	0.7		31			-	42.61 /ea	85		20
		Identification Tag - SS	8.00 ea	2.7	217	124			-	42.61 /ea	341	101.82 /ea	81
		Identification Tag - SS	1.00 ea	0.3		16		-	-	42.60 /ea	43		10
		Identification Tag - SS	44.00 ea	14.8		682		-	-	42.61 /ea	1,875		4,47
		Field Calibration - Simple	8.00 ea	5.4				-	-	54.20 /ea	434		1,0:
	-	Field Calibration - Average	52.00 ea	209.7	16,910			-	-	325.20 /ea	16,910		40,40
		Field Calibration - Severe Pre-Operation Check	1.00 ea 61.00 ea	8.1 76.3	650 6,152				-	650.45 /ea 100.85 /ea	650 6,152		1,5 14,6
	_	Startup - Stand-By (Manhours)	60.00 ea	69.9						93.95 /ea	5,637		13,4



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

		Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
			I&C, Other											
	_		Loop Check - Average	60.00 ea	139.8	11,274			-	-	187.90 /ea	11,274	448.93 /ea	26,936
			I&C, Other	1.00 EA	558.3	45,024	947				45,971.24 /EA	45,971	109,836.87 /EA	109,837
			Instrumentation & Controls	1.00 LS	2,844.6	229,392	159,798				389,190.24 /LS	389,190		929,873
			40.90 Instrumentation & Controls	1.00 LS	2,844.6	229,392	159,798				389,190.24 /LS	389,190		929,873
			40.9 Instrumentation & Controls	1.00 LS	2,844.6	229,392	159,798				389,190.24 /LS	389,190	929,873.44 /LS	929,873
41.	.0		Bulk Material Processing Equipment											
	4	1.00	Material Handling Equipment											
			Monorail Crane											
			Material Handling, Monorail Cranes											
	_		Monorail Cranes, under hung hoist, electric operating, 7.5 ton,	1.00 ea	45.7	4,237	51,701		200		56,137.73 /ea	56,138	125,706.51 /ea	125,707
			Material Handling, Monorail Cranes	1.00 EA	45.7	4,237	51,701		200	1	56,137.73 /EA	56,138	125,706.51 /EA	125,707
	_		Monorail Crane	1.00 EA	45.7	4,237	51,701		200		56,137.73 /EA	56,138	125,706.51 /EA	125,707
	_												-,	
			41.00 Material Handling Equipment	1.00 LS	45.7	4,237	51,701		200		56,137.73 /LS	56,138	125,706.51 /LS	125,707
			41.0 Bulk Material Processing Equipment	1.00 LS	45.7	4,237	51,701		200		56,137.73 /LS	56,138	125,706.51 /LS	125,70
43.	.0		Process Equipment - Industrial											
	4	3.05	Furnish and Install Process Equipment											
			Odor Control											
			Cast-In-Place Concrete, Slabs on Grade, 12" thick											
			Fine grade, for slab on grade, by hand	729.00 sf	6.9	402	23			-	0.58 /sf	425	1.33 /sf	972
			Fill, gravel subbase, under building slab on grade	13.50 cy	9.1	532	412			-	69.90 /cy	944	160.01 /cy	2,160
			Concrete pumping, subcontract, all inclusive price	27.00 cy		-		419	-		15.51 /cy	419	35.51 /cy	959
			Slab on grade edge forms, 7" to 12"	112.00 sf	27.1	2,028	116	-		-	19.14 /sf	2,143		4,907
			Reinforcing in place, A615 Gr 60, priced per lbs.	3,510.00 lb		-	1,815	1,452	-	-	0.93 /lb	3,266	2.13 /lb	7,478
			Concrete, ready mix, 4000 psi	27.00 CY		-	3,350	-		-	124.08 /CY	3,350	284.06 /CY	7,670
			Add for concrete waste, 4000 psi	1.35 cy		-	168	-	-	-	124.09 /cy	168		384
			Add amount for Fuel Surcharges - per concrete truck load	3.00 load		-	47	-	-	-	15.51 /load	47	35.50 /load	106
			Add amount for Environmental Fee - per concrete truck load	3.00 load		-	19	-	-	-	6.21 /load	19		43
	-		Placing concrete, concrete pump	27.00 cy	27.2		-		-	-	59.09 /cy	1,595	135.26 /cy	3,652
	-		Finishing floors, monolithic, trowel finish (machine)	729.00 sf	19.6	1,356	15		-	-	1.88 /sf	1,371	4.31 /sf	3,140
	_		Curing, water	729.00 sf	3.3	191	38		-	-	0.31 /sf	229	0.72 /sf	524
	_		Cast-In-Place Concrete, Slabs on Grade, 12" thick	27.00 CY	93.1	6,105	6,001	1,871			517.62 /CY	13,976	1,184.96 /CY	31,994
			Odor Control Equipment											
			Furnish Scrubber equipment associated accessories	1.00 ea			185,091	-	-		185,090.66 /ea	185,091	423,719.10 /ea	423,719
			Install Scrubber equipment and all associated accessories	1.00 ea	80.7	6,065	25,851	-		-	31,915.83 /ea	31,916	73,063.40 /ea	73,063
			30" FRP shop fabricated duct - FURNISH	51.00 LF		-	3,744	-	-	-	73.42 /LF	3,744		8,571
			30" FRP shop Ell, 90	1.00 ea		-	609		-	-	609.04 /ea	609		1,39
			30" FRP shop Tee	1.00 ea		-	914	-	-	-	913.56 /ea	914		2,09
			30" shop weld	6.00 ea		-	1,830	-	-	-	305.04 /ea	1,830		4,190
	_		36" FRP shop fabricated duct - FURNISH	20.00 LF		-	1,716		-	-	85.82 /LF	1,716		3,929
	_		36" shop weld	2.00 ea		0.005	682		-	-	341.23 /ea	682		1,562
	_		Odor Control Equipment	1.00 EA	80.7	6,065	220,437				226,502.47 /EA	226,502	· · · · · · · · · · · · · · · · · · ·	518,521
			Odor Control	1.00 LS	173.8	12,170	226,438	1,871			240,478.14 /LS	240,478	550,514.98 /LS	550,515
			43.05 Furnish and Install Process Equipment	1.00 LS	173.8	12,170	226,438	1,871			240,478.14 /LS	240,478	550,514.98 /LS	550,515
			43.0 Process Equipment - Industrial	1.00 LS	173.8	12,170	226,438	1,871			240,478.14 /LS	240,478	550,514.98 /LS	550,515
44.	.0		Process Equipment - Municipal											
	4	4.05	Furnish and Install Process Equipment											
			Furnish & Install 700 HP Pumps											
	_													
	_		Vertical Centrifugal Pump: 501hp-1000hp Functional Testing, Pumps, 501-1000 hp	4.00 ea	43.0	3,235	414				912.10 /ea	3,648	2,088.03 /ea	8,352
	_				43.0		414	E 704	-	-				20,66
	_		Align Pump & Motor, 501-1000 hp	4.00 ea 4.00 ea	21.5	3,235 1,617		5,791 2,895			2,256.33 /ea 1,128.17 /ea	9,025 4,513	5,165.31 /ea 2,582.66 /ea	10,33
	_		Vibration Testing, Pumps, 501-1000 hp Witnessed factory test	4.00 ea	21.5	1,017	-	2,095		2,068	1,126.17 /ea 1,034.03 /ea	4,513		9,469
			Local panel	4.00 ea	32.3	2,426	6,204	2,000		2,000	2,157.59 /ea	8,630		19,757
			Pressure indicators	8.00 ea	16.1	1,213	2,068				410.15 /ea	3,281	938.93 /ea	7,51
			Sleeved anchor bolts - Large	40.00 ea	26.9	2,022	1,158				79.50 /ea	3,180	181.99 /ea	7,28
			Non-Shrink Machine Grout	48.00 cuft	61.3	4,610	3,673		1 .		172.55 /cuft	8,282	395.01 /cuft	18,96
			Grease, Oil, and Lube Pumps, 501-1000 hp	4.00 ea	21.5	1,617	620		-	-	559.45 /ea	2,238	1,280.73 /ea	5,12
			FURNISH Vertical Centrifugal Pump, 501 - 1000 hp	4.00 EA		-	1,129,156			-	282,289.11 /EA	1,129,156	646,230.81 /EA	2,584,923
			Set pump assembly, 501 - 1000 hp	4.00 ea	387.1	29,113	414			-	7,381.64 /ea	29,527	16,898.42 /ea	67,59
			Vertical Centrifugal Pump: 501hp-1000hp	4.00 EA	652.8	49,088	1,143,707	10,754		2,068	301,404.29 /EA	1,205,617	689,990.29 /EA	2,759,96
			Furnish & Install 700 HP Pumps	4.00 EA	652.8	49,088	1,143,707	10,754		2,068	301,404.29 /EA	1,205,617	689,990.29 /EA	2,759,961
			Miscellaneous Euipment		112.0	1.5,550	,,. 0.	12,701	1	_,	,	.,,	,	_,,
			Process Equipment											
			Miscellaneous process equipment including, Mechanical Bar Screen,	2.00 ea	1,209.8	90,736	454,971		41,134		293,420.42 /ea	586.841	671,713.19 /ea	1,343,426
			Conveyors, Washer, Grinder & compactor	2.00 ea	1,209.8	90,736	454,971	_	41,134	-	586.840.84 /EA	586,841	1.343.426.37 /EA	1,343,420



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual Es

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016) Estimate Class: 4

ac Worl	k Trade	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Miscellaneous Euipment	1.00 LS	1,209.8	90,736	454,971		41,134		586,840.84 /LS	586,841	1,343,426.37 /LS	1,343,426
		44.05 Furnish and Install Process Equipment	1.00 EA	1,862.6	139,824	1,598,679	10,754	41,134	2,068	1,792,458.01 /EA	1,792,458	4,103,387.52 /EA	4,103,388
		44.0 Process Equipment - Municipal	1.00 LS	1,862.6	139,824	1,598,679	10,754	41,134	2,068	1,792,458.01 /LS	1,792,458	4,103,387.52 /LS	4,103,388
		0300 Boulevard Pump Station	1.00 LS	35,259.1	2,845,287	4,390,442	783,934	131,780	53,769	8,205,211.75 /LS	8,205,212	19,095,658.23 /LS	19,095,658
305		Dry Weather Pump Station											
01.0		General Requirements											
01.0	01.06	Startup & Commissioning											
	01.00	Startup and Testing											
		General Conditions, Other											
		Startup, Testing, and Contractor Commissioning Allowance	1.00 ls		39.858			13.286		53,144.34 /ls	53.144	113,689.12 /ls	113,689
		General Conditions, Other	1.00 LS		39,858			13,286		53,144.34 /LS	53,144	113,689.12 /LS	113,689
		Startup and Testing	1.00 LS		39.858			13,286		53,144.34 /LS	53.144	113.689.12 /LS	113,689
		01.06 Startup & Commissioning	1.00 LS		39,858			13,286		53,144.34 /LS	53,144	113,689.12 /LS	113,689
		01.0 General Requirements	1.00 LS		39.858			13,286		53,144.34 /LS	53.144		113,689
02.0		Existing Conditions	1.00 LO		33,000			10,200		30,144.04 720	30,144	110,003.12 720	110,000
02.0	02.40	Demolition											
	02.40	Demolition											
		General Site Demolition											
		Miscellaneous site demo	1.00 ls				25,550	_	_	25,550.14 /ls	25.550	58,490.70 /ls	58,491
		General Site Demolition	1.00 IS				25,550 25,550	_	_	25,550.14 /IS 25,550.14 /LS	25,550		58,491
		General Site Demolition, Aspalt Pavement	1.00 L3				23,330		<u> </u>	20,000.14 /L0	23,330	30,430.70 /L3	30,491
		Demolish, remove pavement & curb, remove bituminous pavement, 4" to	277.78 sy	35.1	2.353	_		1,216	_	12.85 /sy	3,570	29.42 /sy	8,172
		6" thick, excludes hauling and disposal fees	211.10 Sy	33.1	2,000			1,210	1	12.00 /sy	3,310	23.42 /3y	0,172
		load and haul pavement material for offiste disposal 15 miles	46.30 cy	6.5	434	-	-	707	-	24.64 /cy	1,141	56.40 /cy	2,611
		Dumping fees	46.30 cy				1,183	-	-	25.55 /cy	1,183		2,708
		General Site Demolition, Aspalt Pavement	278.00 SY	41.6	2,787		1,183	1,923		21.20 /SY	5,893	48.53 /SY	13,491
		General Site Demolition, Saw Cutting Asphalt											
		Selective demolition, saw cutting, each additional inch of depth over 3"	750.00 If	65.2	4,562	226		2,206	-	9.33 /lf	6,994	21.35 /lf	16,010
		General Site Demolition, Saw Cutting Asphalt	750.00 LF	65.2	4,562	226		2,206		9.33 /LF	6,994	21.35 /LF	16,010
		Demolition	1.00 LS	106.9	7,349	226	26,733	4,129		38,437.04 /LS	38,437	87,992.04 /LS	87,992
		02.40 Demolition	1.00 LS	106.9	7,349	226	26,733	4,129		38,437.04 /LS	38,437	87,992.04 /LS	87,992
		02.0 Existing Conditions	1.00 LS	106.9	7,349	226	26,733	4,129		38,437.04 /LS	38,437	87,992.04 /LS	87,992
03.0		Concrete Work											
	03.10	Cast-In-Place Concrete Work											
		36" Slab on Grade: 40' x 20' x 36" Thk											
		Cast-In-Place Concrete, Slabs on Grade, 36" thick											
		Fine grade, for slab on grade, by hand	800.00 sf	7.4	436	25		-		0.58 /sf	461	1.32 /sf	1,054
		Fill, gravel subbase, under building slab on grade	29.63 cy	19.7	1,154	893	-	-	-	69.08 /cy	2,047	158.14 /cy	4,686
		Concrete pumping, subcontract, all inclusive price	88.89 cy		-	-	1,363	-	-	15.33 /cy	1,363		3,120
		Slab on grade edge forms, > 24"	360.00 sf	119.6	8,946	460		-	-	26.13 /sf	9,406		21,533
		Waterstop, PVC, center bulb, 6" wide	160.00 lf	17.0	1,273	327		-	-	10.00 /lf	1,600		3,662
		Reinforcing in place, A615 Gr 60, priced per lbs. Concrete, ready mix, 4000 psi	14,222.22 lb 88.89 CY		-	7,268 10,901	5,814	-	-	0.92 /lb 122.64 /CY	13,082 10,901	2.11 /lb 280.76 /CY	29,947 24,956
		Add for concrete waste, 4000 psi	4.44 cy		-	545				122.64 /cy	545		1,248
		Placing concrete, concrete pump	88.89 cy	88.6	5,191	-	-	-	-	58.40 /cy	5,191		11,883
		Finishing floors, monolithic, trowel finish (machine)	800.00 sf	21.3		16		-	-	1.86 /sf	1,488		3,407
		Curing, membrane spray	800.00 sf	2.1	125	33	-	-	-	0.20 /sf	157		360
		Polyethelene vapor barrier, 10 mil thick	8.00 sq	2.3	173	87	-	-	-	32.47 /sq	260		595
		Cast-In-Place Concrete, Slabs on Grade, 36" thick	88.89 CY	278.0	18,769	20,555	7,177			523.12 /CY	46,500		106,451
		36" Slab on Grade: 40' x 20' x 36" Thk	88.89 CY	278.0	18,769	20,555	7,177			523.12 /CY	46,500	1,197.56 /CY	106,451
		12" SOG @ Valve Vault											
		Cast-In-Place Concrete, Slabs on Grade, 12" thick											
		Fine grade, for slab on grade, by hand	378.00 sf	3.5	206	12	-	-	-	0.58 /sf	217		498
		Concrete pumping, subcontract, all inclusive price	14.00 cy		-	-	215	-	-	15.33 /cy	215		491
	-	Slab on grade edge forms, 7" to 12"	78.00 sf	18.7	1,396	80 930	744	-	-	18.91 /sf 0.92 /lb	1,475 1,674		3,377
		Reinforcing in place, A615 Gr 60, priced per lbs. Concrete, ready mix, 4000 psi	1,820.00 lb 14.00 CY			1,717		 	 	0.92 /lb 122.64 /CY	1,674		3,832
		Add for concrete waste, 4000 psi	0.70 cy		1	86			1	122.64 /cy	86		197
		Add amount for Fuel Surcharges - per concrete truck load	2.00 load			31	-	-	-	15.34 /load	31		70
		Add amount for Environmental Fee - per concrete truck load	2.00 load			12				6.13 /load	12	14.03 /load	28
		Placing concrete, concrete pump	14.00 cy	13.9	818	-	-	-	-	58.40 /cy	818		1,872
		Finishing floors, monolithic, trowel finish (machine)	378.00 sf	10.0	695	8	-	-	-	1.86 /sf	703		1,610
		Curing, water	378.00 sf	1.7		19	-	-	-	0.31 /sf	117		269
		Cast-In-Place Concrete, Slabs on Grade, 12" thick	14.00 CY	47.8	3,212	2,894	959			504.66 /CY	7,065		16,174
1		12" SOG @ Valve Vault	14.00 CY	47.8	3,212	2,894	959			504.66 /CY	7,065	1,155.29 /CY	16,174
		24" Exterior Concrete Walls: 120' L x 20' H x 24" Thk											



Project

Project No.: 478874

Design Stage: conceptual

ct:	Boulevard Pump Station	Estimator:	E.B. Smith/GNV, A. Frisch/PGH
ct No.:	478874	Revision / Date:	Rev03, (10-4-2016)

ac Work	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Cast-In-Place Concrete, Straight Walls, 24" thick											
		Concrete pumping, subcontract, all inclusive price	177.78 cy		-		2,725	-	-	15.33 /cy	2,725		6,239
		Forms in place, structural walls, > 16' high, hand set	4,800.00 sf	1,084.1	81,112	6,623		-	-	18.28 /sf	87,735	41.84 /sf	200,847
		Waterstop, PVC, center bulb, 6" wide	240.00 lf	25.5	1,909	491		-	-	10.00 /lf	2,399		5,492
		Reinforcing in place, A615 Gr 60, priced per lbs.	32,000.00 lb		-	16,352	13,082	-	-	0.92 /lb	29,434	2.11 /lb	67,381
		Concrete, ready mix, 4000 psi Add for concrete waste, 4000 psi	177.78 CY 8.89 cy		-	21,803		-	-	122.64 /CY 122.64 /cy	21,803 1,090		49,912
		Placing concrete, concrete pump, for structural wall >12" - 24" thick	177.78 cy	177.1	10.382	1,090		-	-	122.64 /cy 58.40 /cy	1,090		2,496
		Patch & plug tieholes	4,800.00 sf	95.7	5,609	98				1.19 /sf	5,707		13,066
		Sack rub	4,800.00 sf	255.1	14.949	147				3.15 /sf	15.096	7.20 /sf	34,558
		Curing, membrane spray	4,800.00 sf	12.8	748	196				0.20 /sf	944	0.45 /sf	2,161
		Below grade damproofing, Bituminous Asphalt	2,400.00 sf		-	2,453		-	-	1.02 /sf	2,453	2.34 /sf	5,615
		Cast-In-Place Concrete, Straight Walls, 24" thick		1,650.3	114,708	49,253	15,807			/CY	179,768	/CY	411,534
		24" Exterior Concrete Walls: 120' L x 20' H x 24" Thk	177.78 CY	1.650.3	114.708	49.253	15,807			1,011.18 /CY	179,768	2,314.85 /CY	411,534
		12" Walls @ Valve Vault		1,0000	111,100	,	10,001			,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	110,100	3,011.000.101	1.1,00
		Cast-In-Place Concrete, Straight Walls, 12" thick											
		Concrete pumping, subcontract, all inclusive price	23.70 cy		-		363	-	-	15.33 /cy	363	35.09 /cy	832
		Forms in place, structural walls, to 8' high, hand set	1,280.00 sf	255.1	19,084	1,308	-	-	-	15.93 /sf	20,393	36.47 /sf	46,684
		Reinforcing in place, A615 Gr 60, priced per lbs.	3,204.10 lb		-	1,637	1,310	-	-	0.92 /lb	2,947		6,747
		Concrete, ready mix, 4000 psi	23.70 CY		-	2,907		-	-	122.64 /CY	2,907		6,655
		Add for concrete waste, 4000 psi	1.19 cy		-	145		-	-	122.63 /cy	145		333
		Add amount for Fuel Surcharges - per concrete truck load	3.00 load		-	46		-	-	15.33 /load	46		105
		Add amount for Environmental Fee - per concrete truck load	3.00 load 23.70 cy	26.8	1,569	18	-	-	-	6.13 /load 66.18 /cy	1,569		3,591
		Placing concrete, concrete pump, for structural wall to 12" thick Patch & plug tieholes	1,280.00 sf	25.5		26				1.19 /sf	1,509		3,484
		Sack rub	1,280.00 sf	68.0		39			1	3.15 /sf	4.026		9,216
		Curing, membrane spray	1,280.00 sf	3.4		52				0.20 /sf	252		576
		Cast-In-Place Concrete, Straight Walls, 12" thick	23.70 CY	378.8		6.180	1.673			1.442.53 /CY	34.188		78.265
		12" Walls @ Valve Vault	23.70 CY	378.8	26,335	6,180	1,673			1,442.53 /CY	34,188	-7	78,265
			23.70 C1	370.0	20,335	6,160	1,073			1,442.55 /C1	34,100	3,302.32 /C1	10,200
		12" Elevated Slab: 40' L x 20' W x 12" Thk											
		Cast-In-Place Concrete, Elevated Decks, 12" thick											
		Concrete pumping, subcontract, all inclusive price	29.63 cy		15.905		454	-	-	15.33 /cy	454 16.927		1,040
		Forms in place, elevated slab, soffit Forms in place, elevated slab, edge form	800.00 sf 120.00 sf	212.6		1,022 153		-	-	21.16 /sf 26.13 /sf	3,136		38,749 7,178
		Slab shoring	16,000.00 cf	148.6	11,121	818				0.75 /cf	11,939		27,330
		Waterstop, PVC, center bulb, 6" wide	240.00 lf	25.5	1,909	491				10.00 /lf	2,399		5,492
		Reinforcing in place, A615 Gr 60, priced per lbs.	6,518.52 lb	20.0	1,303	3.331	2.665			0.92 /lb	5,996		13,726
		Concrete, ready mix, 4000 psi	29.63 CY			3,634				122.64 /CY	3,634		8,319
		Add for concrete waste, 4000 psi	1.48 cy		-	182				122.64 /cy	182		416
		Placing concrete, concrete pump, for elevated slab to 12" thick	29.63 cy	19.7	1,154	-		-	-	38.93 /cy	1,154		2,641
		Curing, membrane spray	800.00 sf	2.1	125	33				0.20 /sf	157		360
		Cast-In-Place Concrete, Elevated Decks, 12" thick	14.67 CY	448.4	33,194	9,663	3,119			3,134.02 /CY	45,976	7,174.57 /CY	105,251
		12" Elevated Slab: 40' L x 20' W x 12" Thk	29.63 CY	448.4	33,194	9,663	3,119			1,551.68 /CY	45,976	3,552.17 /CY	105,251
		12" Elevated Slab @ Valve Vault				•	·			·	· ·	·	
		Cast-In-Place Concrete, Elevated Decks, 12" thick											
		Concrete pumping, subcontract, all inclusive price	14.00 cy				215			15.33 /cy	215	35.10 /cy	491
		Forms in place, elevated slab, soffit	378.00 sf	100.4	7,515	483				21.16 /sf	7,998		18,309
		Forms in place, elevated slab, edge form	78.00 sf	25.9		100		-	-	26.13 /sf	2,038		4,666
		Slab shoring	3,024.00 cf	28.1	2,102	155				0.75 /cf	2,256		5,165
		Reinforcing in place, A615 Gr 60, priced per lbs.	1,892.42 lb		-	967	774	-	-	0.92 /lb	1,741	2.11 /lb	3,985
		Concrete, ready mix, 4000 psi	14.00 CY		-	1,717		-	-	122.64 /CY	1,717		3,931
		Add for concrete waste, 4000 psi	0.70 cy		-	86		-	-	122.64 /cy	86		197
		Add amount for Fuel Surcharges - per concrete truck load	2.00 load			31		-	-	15.33 /load	31		70
		Add amount for Environmental Fee - per concrete truck load	2.00 load	-		12		-	-	6.13 /load	12		28
		Placing concrete, concrete pump, for elevated slab to 12" thick	14.00 cy	9.3	545	- 15		-	-	38.93 /cy	545		1,248
		Curing, membrane spray Cast-In-Place Concrete, Elevated Decks, 12" thick	378.00 sf 14.00 CY	1.0 164.7	12.159	3.565	988	<u> </u>	<u> </u>	0.20 /sf 1,193.76 /CY	74 16.713		38,259
_		12" Elevated Slab @ Valve Vault	14.00 CY	164.7	12,159	3,565	988			1,193.76 /CY	16,713	7	38,259
			14.00 CT	164.7	12,159	3,363	966			1,193.76 /C1	16,713	2,732.82 /C1	38,238
		8" Baffle Wall @ Wetwell									-	-	
		Cast-In-Place Concrete, Straight Walls, 8" thick		-				-			1		
	-	Concrete pumping, subcontract, all inclusive price	3.75 cy		-	-	58	-	-	15.33 /cy	58		132
		Forms in place, structural walls, > 8' to 16' high, hand set	304.00 sf	80.8	6,044	388	-	-	-	21.16 /sf	6,432		14,725
	-	Reinforcing in place, A615 Gr 60, priced per lbs.	760.97 lb	-	-	389	311	<u> </u>	-	0.92 /lb	700		1,602
		Concrete, ready mix, 4000 psi Add for concrete waste, 4000 psi	3.75 CY 0.19 cy		-	460 23	-	1	-	122.64 /CY 122.60 /cy	460		1,054
		Add amount for Fuel Surcharges - per concrete truck load	1.00 load		1	15			· ·	122.60 /cy 15.32 /load	15		35
		Add amount for Fuel Surcharges - per concrete truck load Add amount for Environmental Fee - per concrete truck load	1.00 load	1	1	15		<u> </u>	<u> </u>	15.32 /load 6.14 /load	15		14
		Placing concrete, concrete pump, for structural wall to 12" thick	3.75 cy	4.2	248			1 .		66.20 /cy	248		569
		Patch & plug tieholes	304.00 sf	6.1	355	6				1.19 /sf	361	2.72 /sf	82
		Sack rub	304.00 sf	16.2		9				3.14 /sf	956		2,18
		Curing, membrane spray	304.00 sf	0.8		12				0.20 /sf	60		13



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

ac Work	Trade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Cast-In-Place Concrete, Straight Walls, 8" thick	3.75 CY	108.0	7,641	1,310	369			2,485.26 /CY	9,320	5,689.37 /CY	21,335
		8" Baffle Wall @ Wetwell	3.75 CY	108.0	7,641	1,310	369			2,485.26 /CY	9,320	5,689.37 /CY	21,335
		03.10 Cast-In-Place Concrete Work	351.75 CY	3,076.1	216,019	93,419	30,092			965.26 /CY	339,530	2,209.72 /CY	777,270
		03.0 Concrete Work	351.75 CY	3.076.1	216.019	93,419	30,092			965.26 /CY	339.530	2,209.72 /CY	777,270
08.0		Openings		.,	-,							,	
00.0	08.10	Doors and Frames											
	00.10	Access Door											
	+												
	-	Specialty Doors and Frames, Access Doors											
		Floor, industrial, steel 300 psf L.L., dbl leaf, 6' x 4' opening, 645#	3.00 opng	63.8	5,781	20,236	-	-	-	8,672.32 /opng	26,017	19,853.12 /opng	59,55
		Specialty Doors and Frames, Access Doors	3.00 EA	63.8	5,781	20,236				8,672.32 /EA	26,017	19,853.12 /EA	59,55
		Access Door	1.00 EA	63.8	5,781	20,236				26,016.95 /EA	26,017	59,559.35 /EA	59,55
		08.10 Doors and Frames	3.00 EA	63.8	5,781	20,236				8,672.32 /EA	26,017	19,853.12 /EA	59,55
		08.0 Openings	1.00 LS	63.8	5,781	20,236				26,016.95 /LS	26,017	59,559.35 /LS	59,55
26.0		Electrical Work											
	26.00	Electrical											
	20.00	Electrical and I&C											
	+	Electrical, Other											
	+	Electrical and I&C allowance	1.00 ls			-	102,201	-	-	102,200.63 /ls	102,201	244,183.02 /ls	244,18
	1	Electrical, Other	1.00 LS				102,201			102,200.63 /LS	102,201	244,183.02 /LS	244,18
		I&C, Flow / Mag Meter / Indicators & Transmitters											
		FE - Flow Element - Mag Flowtube (inline)	3.00 ea	8.0	643	153	-	-	-	265.36 /ea	796	634.02 /ea	1,90
		FT / FIT - Flow Transmitter - Magnetic,	3.00 ea	49.8	4,018	55,188	-	-	-	19,735.35 /ea	59,206	47,152.71 /ea	141,45
		I&C, Flow / Mag Meter / Indicators & Transmitters	3.00 EA	57.8	4,660	55,342				20,000.71 /EA	60,002	47,786.73 /EA	143,36
		Electrical and I&C	1.00 LS	57.8	4,660	55,342	102,201			162,202.76 /LS	162,203	387,543.21 /LS	387,54
		26.00 Electrical	1.00 LS	57.8	4.660	55.342	102,201			162,202.76 /LS	162,203	387,543.21 /LS	387,54
		26.0 Electrical Work	1.00 LS	57.8	4,660	55.342	102,201			162,202.76 /LS	162,203	387,543.21 /LS	387,54
31.0		Earthwork	1.00 E0	57.0	4,000	00,042	102,201			102,202.70 720	102,200	307,343.21 723	307,04
31.0													
	31.15	Site Preparation											
		Site Preparation											
		Site Preparation, Erosion Controls / Pre-construction											
		Silt Fence, Heavy-Duty, Subcontracted	250.00 If	4.3			767	-	-	3.07 /lf	767	6.87 /lf	1,71
		Erosion control, hay bales, staked, Subcontracted, Install Only	20.00 ea	1.0			286	-	-	14.31 /ea	286	32.04 /ea	64
		Temp Seed	1.00 ls	5.3		-	511	-	-	511.00 /ls	511		1,14
		Temp Mulching	1.00 ls	0.5		-	511	-	-	511.01 /ls	511		1,14
		Inlet Protection, Subcontracted	8.00 ea	1.2		-	2,044	-	-	255.50 /ea	2,044		4,57
		Stabilized Construction Entrance, Clean Rock, 1-1/2" thru 3"	47.41 tn	12.6		969	-	1,038	-	61.69 /tn	2,925		6,54
		Filter Fabric under Stabilized Construction Entrance	88.89 sy	0.2		136	-		-	1.53 /sy	136	3.43 /sy	30
		Best Management Practice (BMP) Maintenance, Labor & Material	20.00 day	265.7	15,517		-	-	-	775.85 /day	15,517	1,737.32 /day	34,74
		Remove erosion control and dispose offsite	1.00 ls		-	3,577		-	-	3,577.02 /ls	3,577	8,009.83 /ls	8,01
		Site Preparation, Erosion Controls / Pre-construction	1.00 LS	290.8	16,434	4,682	4,119	1,038		26,273.46 /LS	26,273		58,83
		Site Preparation	1.00 LS	290.8	16,434	4,682	4,119	1,038		26,273.46 /LS	26,273	58,832.87 /LS	58,83
		31.15 Site Preparation	1.00 LS	290.8	16,434	4,682	4,119	1,038		26,273.46 /LS	26,273	58,832.87 /LS	58,83
	31.25	Earthworks, Structural				·				·			
	01120	Structural Excavation											
		Site Preparation, Dewatering	400.00 1	2,550.9	183.075			7.279		4.500.00 (4	190.354	0.550.00 / 1	426.25
	+	Dewatering, pumping 24 hr, 8 hrs attended, 6" centrifugal pump	120.00 day		,		-		-	1,586.28 /day		3,552.09 /day	
		Site Preparation, Dewatering	120.00 Day	2,550.9	183,075			7,279		1,586.28 /Day	190,354	3,552.09 /Day	426,25
		Earthworks, Sheeting and Shoring											
		Shoring, soldier beams & lagging with tie-backs and walers,	3,360.00 sf	1,176.0		-	137,358	-	-	40.88 /sf	137,358	91.54 /sf	307,57
		subcontracted											
		Earthworks, Sheeting and Shoring	3,360.00 SF	1,176.0			137,358			40.88 /SF	137,358	91.54 /SF	307,57
		Earthworks, Structural, Excavation											
		Fine grade, for slab on grade, by machine	900.00 sf	8.4	490	9	-	-	-	0.56 /sf	499	1.24 /sf	1,11
		Backfill from Select (Imported)	575.00 cy	8.5	586	8,815	-	1,072	-	18.21 /cy	10,472	40.78 /cy	23,45
		Compaction, vibratory plate, 8" lifts, common fill	575.00 cy	30.6			-	254	-	3.61 /cy	2,076	8.09 /cy	4,65
		Excav, Struct, common earth, hyd backhoe, 2 CY bkt	1,167.00 cy	124.0	8,635	-	-	34,914	-	37.32 /cy	43,549	83.56 /cy	97,51
		Load Excess Spoils for Off-Site Hauling, Excavator, Cat 320	1,167.00 cy	12.4		-	-	1,512	-	2.14 /cy	2,499		5,59
		Haul Excess Spoils Off-Site, 17 yd capacity, 50 miles RT	1,167.00 cy	149.5	10,012	-	-	15,029	-	21.46 /cy	25,041	48.05 /cy	56,07
		Excess Spoils (contaminated but not hazardous) Dump Charges for 17	1,167.00 cy		-	143,122	-	-	-	122.64 /cy	143,122	274.62 /cy	320,48
	-	yd end dumps, per cy											
		Earthworks, Structural, Excavation	1,167.00 CY	333.4	22,532	151,946		52,781		194.74 /CY	227,259	436.07 /CY	508,89
		Structural Excavation	1,167.00 CY	4,060.3	205,607	151,946	137,358	60,060		475.55 /CY	554,970	1,064.88 /CY	1,242,71
		Concrete Auger Cast Piles											
		Earthworks, Piling, Auger Cast		İ				İ					
		Mobilization for rig, average cost per vlf, add	600.00 vlf	6.0	461		_	2,884		5.57 /vlf	3,345	12.48 /vlf	7,48
		Uncasd drilld concrt piers,cast place augered piles,24"dm,priced using	600.00 VII	318.9	20.804	12.877		16.687	-	83.95 /vlf	50.368	187.98 /vlf	112,78
		40'lg,unless specifd otherws,excluds pile caps mobility, casing rnfrcng	000.00 VII	310.9	20,004	12,077	Ι	10,007]	05.35 /VII	30,308	107.30 /VII	112,700



Project: Boulevard Pump Station

Project No.: 478874

Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

ac Wo		rade Pkg	Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
			Earthworks, Piling, Auger Cast											
	_		Cast-in place adds for drilled concrete piers, for reinforcing steel, add	14,000.00 lb			17,885	-		-	1.28 /lb	17,885	2.86 /lb	40,04
	_		Pile Caps Site Prep and Test Piles	15.00 ea 1.00 ls	159.4	6,975 10,363	7,665		2,989 7,972	-	1,175.31 /ea 18,334.75 /ls	17,630 18,335	2,631.81 /ea 41,056.11 /ls	39,47 41,05
	_			600.00 LF	159.4	38.603	38.427	-	30.532	-	18,334.75 /IS 179.27 /LF	107.563	41,056.11 /ls 401.43 /LF	240.85
			Earthworks, Piling, Auger Cast			,						- ,		-,
			Concrete Auger Cast Piles	15.00 EA	484.3	38,603	38,427		30,532		7,170.83 /EA	107,563	16,057.30 /EA	240,85
			31.25 Earthworks, Structural	1,167.00 CY	4,544.6	244,211	190,373	137,358			567.72 /CY	662,533	1,271.28 /CY	1,483,57
			31.0 Earthwork	1.00 LS	4,835.3	260,645	195,056	141,476	91,630		688,806.44 /LS	688,806	1,542,410.97 /LS	1,542,41
33.0	0		Utilities											
	33.	3.05	Buried Process Piping											
			Yard Piping & Structures											
			Buried Pipe, Other											
			Miscellaneous Yard Piping	1.00 ls				102,201			102,200.62 /ls	102,201	233,962.94 /ls	233,96
			Buried Pipe, Other	1.00 10				102,201			/LS	102,201	/LS	233,96
		_						102,201			723	102,201	723	255,50
			Buried Structure, Concrete Junction Chamber	100				055 500			055 504 50 /	055 500	504.007.40	504.00
	_		Allowance for concrete junction box including gates	1.00 ea				255,502		-	255,501.58 /ea	255,502	584,907.43 /ea	584,90
			Buried Structure, Concrete Junction Chamber					255,502			/EA	255,502	/EA	584,90
			Yard Piping & Structures	1.00 LS				357,702			357,702.20 /LS	357,702	818,870.37 /LS	818,87
			Utility Relocation											
			Buried Pipe, Other											
			Miscellaneous utilities relocation at foot print of Dry Weather Pump	1.00 ls				76,650		-	76,650.48 /ls	76,650	175,472.23 /ls	175,47
			Station											
			Buried Pipe, Other					76,650			/LS	76,650	/LS	175,47
			Utility Relocation	1.00 LS				76,650			76,650.48 /LS	76,650	175,472.23 /LS	175,47
			Temporary Bypass Pumping	1100 =0				,			11,1001110 ,20	10,000	,	
	_		Buried Pipe Specials, Temporary Bypasses											
	_		Allowance for Bypass Pumping, System Operation	12.00 mon	318.9	27,580	49,056		1,594,330		139,247.15 /mon	1,670,966	318,771.76 /mon	3,825,26
					318.9		49,056			-				
			Buried Pipe Specials, Temporary Bypasses	12.00 EA		27,580	-,		1,594,330		139,247.15 /EA	1,670,966	318,771.76 /EA	3,825,26
			Temporary Bypass Pumping	12.00 MO	318.9	27,580	49,056		1,594,330		139,247.15 /MO	1,670,966	318,771.76 /MO	3,825,26
			33.05 Buried Process Piping	1.00 LS	318.9	27,580	49,056	434,353			2,105,318.43 /LS	2,105,318	4,819,603.75 /LS	4,819,60
			33.0 Utilities	1.00 LS	318.9	27,580	49,056	434,353	1,594,330		2,105,318.43 /LS	2,105,318	4,819,603.75 /LS	4,819,60
40.0	0		Process Pipe											
	40.	0.00	Exposed Process Pipe											
	- 101		12" DI Pipe											
	_		Process Pipe, Ductile Iron, 12"											
	_			10.00	116.9	10.235					000.70 /	40.005	1,483.64 /ea	00.70
	_		Install 12" DI, flanged, spool <= 10' 12" Fabricated DI Spool, FxF, 1' 0" - FURNISH	16.00 ea 3.00 ea	116.9	10,235	1,751	-		-	639.70 /ea 583.57 /ea	10,235 1,751	1,483.64 /ea 1,353.45 /ea	23,73
	_		12" Fabricated DI Spool, FxF, 2" 0" - FURNISH	3.00 ea		-	2,103			-	701.09 /ea	2,103	1,626.01 /ea	4,87
			12" Fabricated DI Spool, FxF, 3' 0" - FURNISH	4.00 ea			3,270				817.61 /ea	3,270	1,896.24 /ea	7,58
			12" Fabricated DI Spool, FxF, 3' 6" - FURNISH	3.00 ea			2,628			1	875.86 /ea	2,628	2,031.34 /ea	6,09
			12" Fabricated DI Spool, FxF, 8' 0" - FURNISH	3.00 ea			4,219			-	1,406.28 /ea	4,219	3,261.51 /ea	9,78
			12" DI, FL, EII, 90	7.00 ea	51.2	4,478	3,321			-	1,114.08 /ea	7,799	2,583.83 /ea	18,08
			12" DI, FL, tee, 12" x 12"	1.00 ea	9.1	800	757			-	1,557.28 /ea	1,557	3,611.71 /ea	3,61
			12" DI, flanged coupling adapter	3.00 ea	20.4	1,787	809		-	-	865.33 /ea	2,596	2,006.93 /ea	6,02
			Process Pipe, Ductile Iron, 12"	55.50 LF	197.6	17,300	18,858				651.49 /LF	36,158	1,510.98 /LF	83,85
			12" DI Pipe	55.50 LF	197.6	17,300	18,858		İ		651.49 /LF	36,158	1,510.98 /LF	83,8
			24" DI Pipe		.57.0	,500	. 5,000					33,100	1,010100 /EI	55,0
_	_	-	Process Pipe, Ductile Iron, 24"											
				0.00	31.8	2,787					4 000 00 /-	0	3,231.55 /ea	6.4
_			Install 24" DI, flanged, spool <= 10"	2.00 ea 1.00 ea	31.8	2,/87	2,117	-	<u> </u>	-	1,393.36 /ea 2,116.57 /ea	2,787 2,117	3,231.55 /ea 4,908.86 /ea	6,4
	_		24" Fabricated DI Spool, FxF, 2' 0" - FURNISH 24" Fabricated DI Spool, FxF, 3' 0" - FURNISH			-	2,117	-	 	-		2,117	4,908.86 /ea 5,574.91 /ea	4,9 5,5
	-		24" Fabricated DI Spool, FXF, 3" 0" - FURNISH 24" DI, FL, tee, red, 24" x 12"	1.00 ea 1.00 ea	19.9	1,742	1,996	-	· ·	-	2,403.76 /ea 3,738.24 /ea	3,738	5,574.91 /ea 8,669.95 /ea	5,5
	_		24" DI, FL, tee, red, 24" X 12" 24" DI, FL, reducer, 24" X 12"	1.00 ea	19.9	1,742	1,996	-	 	1	3,738.24 /ea 2,691.83 /ea	2,692	6,243.03 /ea	6,2
			Process Pipe, Ductile Iron, 24"	5.00 LF	67.7	5,922	7,815			-	2,747.42 /LF	13,737	6,371.97 /LF	31,8
_	_		24" DI Pipe	5.00 LF	67.7	5,922	7,815				2,747.42 /LF	13,737	6,371.97 /LF	31,8
		_	· · · · · · · · · · · · · · · · · · ·	5.00 LF	67.7	5,922	7,815				2,141.42 /LF	13,/3/	0,3/1.9/ /LF	31,8
			48" DI Pipe	1					-					
			Process Pipe, Ductile Iron, 48"											
			Install 48" DI, flanged, spool <= 10'	1.00 ea	33.0	2,890	-	-		-	2,890.29 /ea	2,890	6,703.30 /ea	6,7
			48" Fabricated DI Spool, FxF, 2' 0" - FURNISH	1.00 ea		-	9,174	-		-	9,173.54 /ea	9,174	21,275.73 /ea	21,2
			Process Pipe, Ductile Iron, 48"	2.00 LF	33.0	2,890	9,174				6,031.92 /LF	12,064	13,989.52 /LF	27,9
		T	48" DI Pipe	2.00 LF	33.0	2,890	9,174				6,031.92 /LF	12,064	13,989.52 /LF	27,9
			Valves											
		$\overline{}$	Gate Valves, 12"		1									
			Install gate valve, Flgd, DIP, 12"	3.00 ea	23.9	2,036	_	_	1,494		1,176.87 /ea	3,531	2,729.47 /ea	8,1
			Install gate valve, Figd, DIP, 12 Install gate valve, MJ, 12"	1.00 ea	5.6	2,036	-	-	349		823.93 /ea	824	1,910.89 /ea	1,9
	_		Gate valve, iron body, dbl disk, Flgd, 250#, HWO, 12"	3.00 ea	3.0	4/5	3,796	-	349	- 1	1,265.24 /ea	3,796	2,934.41 /ea	8,8
							3,130	-						



Project: Boulevard Pump Station

Project No.: 478874
Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

Fac Wo		Description	Takeoff Quantity	Labor Man Hrs	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Gate Valves, 12"											
		CI Valve Box & Cover, w/ Concrete Collar included	1.00 ea	4.0	339	153	-	249	-	741.79 /ea	742	1,720.39 /ea	1,720
		Gate Valves, 12"	4.00 EA	33.5	2,851	5,214		2,092		2,539.33 /EA	10,157	5,889.34 /EA	23,557
		Check Valves, 12"											
		Install check valve, Flgd, DIP, 12"	3.00 ea	23.9	2,036	-		1,494	-	1,176.87 /ea	3,531	2,729.45 /ea	8,188
		Check valve, iron body, swing check, Flgd, 250#, 12"	3.00 ea		-	8,803	-		-	2,934.18 /ea	8,803	6,805.11 /ea	20,415
		Check Valves, 12"	3.00 EA	23.9	2,036	8,803		1,494		4,111.05 /EA	12,333	9,534.56 /EA	28,604
		Valves	1.00 LS	57.4	4,887	14,017		3,587		22,490.45 /LS	22,490	52,161.03 /LS	52,161
		Miscellaneous Piping											
		Process Pipe, Other											
		Miscellaneous Piping	1.00 ls				76,650	-	-	76,650.47 /ls	76,650	177,771.73 /ls	177,772
		Process Pipe, Other	1.00 LS				76,650			76,650.47 /LS	76,650	177,771.73 /LS	177,772
		Miscellaneous Piping	1.00 LS				76,650			76,650.47 /LS	76,650	177,771.73 /LS	177,772
		Odor Control											
		FRP Duct, Round, 30"											
		Allowance for Odor control	1.00 ls				66,430		-	66.430.41 /ls	66,430	154.068.83 /ls	154.069
		FRP Duct, Round, 30"	150.00 LF				66.430			442.87 /LF	66,430	1.027.13 /LF	154.069
		Odor Control	1.00 LS				66,430			66.430.41 /LS	66.430	154,068.83 /LS	154,069
		40.00 Exposed Process Pipe	62.50 LF	355.7	30.999	49.863	143.081	3.587		3.640.48 /LF	227.530	· ·	527.700
		40.0 Process Pipe	62.50 LF	355.7	30,999	49,863	143,081	3,587		3,640,48 /LF	227,530		527,700
44.0	,	Process Equipment - Municipal	02.00 2.		55,555	10,000	110,001	0,00.		0,010110 721	221,000	0,110120 721	021,100
44.0	44.05	Furnish and Install Process Equipment											
	44.03	Furnish & Install 215 HP Pumps											
		Submersible Pump: 51hp-100hp											
		Functional Testing, Pumps, 101-500 hp Align Pump & Motor, 101-500 hp	3.00 ea 3.00 ea	15.9 23.9		307	3,219	-	-	501.84 /ea 1,672.55 /ea	1,506 5,018		3,447 11,487
		Vibration Testing, Pumps, 101-500 hp	3.00 ea	8.0			1,073		-	1,672.55 /ea 557.51 /ea	1.673		3,829
		Witnessed factory test	3.00 ea	0.0	-		1,533		1.533	1.022.01 /ea	3.066	2,339.63 /ea	7.019
		Local panel	3.00 ea	23.9	1,798	4,599	-	-	-	2,132.46 /ea	6,397		14,645
		Pressure indicators	6.00 ea	12.0		1,533	-	-	-	405.36 /ea	2,432		5,568
		Sleeved anchor bolts - Medium	24.00 ea	11.2	839	515	-		-	56.43 /ea	1,354	129.17 /ea	3,100
		Non-Shrink Machine Grout	24.00 cuft	30.3	2,278	1,815	-	-	-	170.54 /cuft	4,093		9,370
		Grease, Oil, and Lube Pumps, 101-500 hp	3.00 ea	15.9	1,199	230	-	-	-	476.29 /ea	1,429		3,271
		FURNISH Submersible Pump, 101 - 500 hp	3.00 EA		-	493,629	-	-	-	164,543.01 /EA	493,629		1,130,041
		Set pump assembly, 101 - 500 hp	3.00 ea	239.1	17,984	153		-		6,045.76 /ea	18,137		41,521
		Submersible Pump: 51hp-100hp	3.00 EA	380.2	-,	502,781	5,825		1,533	179,577.91 /EA	538,734	411,099.03 /EA	1,233,297
		Furnish & Install 215 HP Pumps	3.00 EA	380.2		502,781	5,825		1,533	179,577.91 /EA	538,734	411,099.03 /EA	1,233,297
		44.05 Furnish and Install Process Equipment	3.00 EA	380.2	28,594	502,781	5,825		1,533	179,577.91 /EA	538,734	411,099.03 /EA	1,233,297
		44.0 Process Equipment - Municipal	1.00 LS	380.2	28,594	502,781	5,825		1,533	538,733.73 /LS	538,734	1,233,297.09 /LS	1,233,297
		0305 Dry Weather Pump Station	1.00 LS	9,194.7	621,486	965,978	883,761	1,706,962	1,533	4,179,719.98 /LS	4,179,720	9,549,065.15 /LS	9,549,065



Project: Boulevard Pump Station

Project No.: 478874
Design Stage: conceptual

Estimator: E.B. Smith/GNV, A. Frisch/PGH

Revision / Date: Rev03, (10-4-2016)

Estimate Class: 4

Estimate Totals

Construction Costs	Amount	Totals	Rate	% of Total
Labor	3,466,774			12.10%
Material	5,356,420			18.70%
Subcontract	1,667,694			5.82%
Equipment	1,838,741			6.42%
Other	55,302			0.19%
Subtotal Raw Costs	12,384,931	12,384,931		43.24
Material Sales & Use Tax - %				
Construction Equip Tax - %				
Total Taxes		12,384,931		
Existing Conditions I,OH&P	161,863		15.000 %	0.57%
Concrete Work I,OH&P	75,225		15.000 %	0.26%
Architectural (Div 6-12)I,OH&P	87,552		15.000 %	0.31%
Mechanical Work I,OH&P	3,617		20.000 %	0.01%
Electrical Work I,OH&P	750,753		25.000 %	2.62%
Site/Civil I,OH&P	69,624		10.000 %	0.24%
Buried Piping I,OH&P	315,798		15.000 %	1.10%
Process Piping I,OH&P Instruments & Controls I,OH&P	194,818		18.000 % 25.000 %	0.68%
Process Equipment I.OH&P	97,298 385,750		15.000 %	0.34% 1.35%
Subtotal Subcontractor I,OH&P	2,150,239	14,535,170	15.000 //	7.51
Contractor Contingency				
Subtotal Contingency		14,535,170		
Total Cost To Prime Contractor		44 525 470		
Total Cost To Prime Contractor		14,535,170		
General Conditions	1,453,517		10.000 %	5.07%
Mobilization/Demobilization	639,547		4.000 %	2.23%
Subtotal Indirect Costs	2,093,064	16,628,234		7.31
Prime Contractor Home OfficeOH	1,330,259		8.000 %	4.64%
Prime Contractor Profit	1,795,849		10.000 %	6.27%
Blder's Risk & Gen Liab Ins -%	358,059		1.250 %	1.25%
Payment & Performance Bonds	358,059		1.250 %	1.25%
Subtotal OH&P	3,842,226	20,470,460		13.41
Design Contingency	6,141,138		30.000 %	21.44%
Subtotal Contingency	6,141,138	26 611 500		21.44
Subtotal Contingency	0,141,138	26,611,598		∠1.44
Escalation _	2,033,126		7.640 %	7.10%
Subtotal Escalation	2,033,126	28,644,724		7.10
Total Prime Contractor Costs		28,644,724		

Intermediate-Term Improvements Yale Campus Trumbull Street Area Phase 2A Project Sewer Separation

	•	2.6		
SPEC NUMBER	ESTIMATED QUANTITY	ITEM	NIT PRICE OLLARS	TENDED CE DOLLARS
201.01	1	LS Clearing and Grubbing	\$	\$ 75,000.00
201.02	1	EA Removal of Existing Tree (3" to 6" Caliper)	\$ 500.00	\$ 500.00
201.03	1	EA Removal of Existing Tree (6" to 10" Caliper)	\$ 800.00	\$ 800.00
201.04	1	EA Removal of Existing Tree (10" to 16" Caliper)	\$ 1,500.00	\$ 1,500.00
201.05	3	EA Removal of Existing Tree (16" to 24" Caliper)	\$ 2,200.00	\$ 6,600.00
201.06		EA Removal of Existing Tree (24" to 36" Caliper)	\$ 3,600.00	\$ 7,200.00
205.01	11,917	CY Trench Excavation - Earth	\$ 60.00	\$ 715,020.00
205.02	1,192	CY Trench Excavation - Rock	\$ 150.00	\$ 178,800.00
205.03	1,000	CY Trench Excavation - Unsuitable	\$ 60.00	\$ 60,000.00
205.05	400	CY Test Pit Excavation	\$ 110.00	\$ 44,000.00
205.06	40	EA Test Pit by Vacuum Method, Complete	\$ 1,500.00	\$ 60,000.00
205.07	1,559		\$ 30.00	\$ 46,770.00
209	5,255	SY Formation of Subgrade	\$ 8.00	\$ 42,040.00
210	1	LS Temporary Soil Erosion and Water Pollution Control	\$ 90,000.00	\$ 90,000.00
210.1	485	DAY Mechanical Street Sweeping	\$ 220.00	\$ 106,700.00
213	1,000		\$ 55.00	\$ 55,000.00
304	1,473	CY Processed Aggregate Base	\$ 65.00	\$ 95,745.00
305.01	2,703		\$ 45.00	\$ 121,635.00

SPEC NUMBER	ESTIMATED QUANTITY	ITEM	UNIT DOLL	PRICE ARS		ENDED E DOLLARS
305.02	792	CY	\$	50.00	\$	39,600.00
		Bedding Material - 3/4" Crushed Stone				
407.01	6,384		\$	20.00	\$	127,680.00
		2" Class 2 Temporary Pavement Trench in Roadways				
407.02	254		\$	20.00	\$	5,080.00
		Temporary Pavement for Sidewalk and Driveway, 2" Class 2 on Compacted Trench Backfill				
407.1	1,574	SY	\$	20.70	\$	32,581.80
10= 11	0.004	Bituminous Concrete Trench Repair Class 1, Thickness 1.5" (Base Bid)			_	
407.11	3,681		\$	27.60	\$	101,595.60
107.0	4.574	Bituminous Concrete Trench Repair Class 1, Thickness 2" (Base Bid)		04.05	•	40.070.70
407.2	1,574		\$	31.05	\$	48,872.70
107.01	0.004	Bituminous Concrete Trench Repair Class 2, Thickness 1.5" (Base Bid)		14 10	Φ.	450,000,40
407.21	3,681		\$	41.40	\$	152,393.40
407.4	1.574	Bituminous Concrete Trench Repair Class 2, Thickness 2" (Base Bid)	Φ.	66.00	ď	102 004 00
407.4	1,574	17.	\$	66.00	\$	103,884.00
407.51	500	Bituminous Concrete Trench Repair Class 4, Thickness 6" (2-3" lifts) (Base Bid)	\$	150.00	\$	75,000.00
407.51	300	Bituminous Concrete Skim Coat, Class 2, 1-inch Thickness	٩	150.00	Φ	75,000.00
407.6	1,000	SY	\$	25.00	\$	25,000.00
407.0	1,000	Bituminous Concrete Cold Patch, (Class 5)	Ψ	23.00	Ψ	23,000.00
407.7	2,000	SY	\$	35.00	\$	70,000.00
407.7	2,000	Hybrid Asphalt (2" thickness)	lΨ	33.00	Ψ	70,000.00
407.82	23	SY	\$	20.70	\$	476.10
107.02		Utility Bit. Conc. Trench Repair Class 1, Thickness 1.5" (Base Bid)	*	20.70	*	170.10
407.83	1,130	SY	\$	27.60	\$	31,188.00
	1,100	Utility Bit. Conc Trench Repair Class 1, Thickness 2" (Base Bid)	ľ		*	01,100.00
407.84	23	SY	\$	31.05	\$	714.15
		Utility Bit. Conc Trench Repair Class 2, Thickness 1.5" (Base Bid)	`		Ť	
407.85	1,130		\$	41.40	\$	46,782.00
	ŕ	Utility Bit. Conc Trench Repair Class 2, Thickness 2" (Base Bid)	·		·	,
407.86	23	SY	\$	66.00	\$	1,518.00
		Utility Bit. Conc Trench Repair Class 4, Thickness 6" (2-3" lifts) (Base Bid)	·			,
507.01	225	VF	\$	550.00	\$	123,750.00
		Catch Basin, Type "C" or "CL"				
507.02.1	266	VF	\$	475.00	\$	126,350.00
		Manhole - 4ft Dia. (Also Catch Basin Manhole)				

		D1C# 09-403-110				
SPEC	ESTIMATED		UNIT PRICE		EXTENDED	
NUMBER	QUANTITY	ITEM	DOL	LARS	PRIC	E DOLLARS
507.02.2	131	VF	\$	500.00	\$	65,500.00
		Manhole - 5ft Dia. (Also Catch Basin Manhole)				
507.02.3	66	VF	\$	550.00	\$	36,300.00
		Manhole - 6ft Dia. (Also Catch Basin Manhole)				
507.07C	33	EACH	\$	1,700.00	\$	56,100.00
		Frame Grate or Cover - Sanitary (Convert Ex. Combined MH)				
512.01	299	LF	\$	120.00	\$	35,880.00
		Sanitary Sewer 12" PVC				
512.05	100	CY	\$	400.00	\$	40,000.00
		Concrete Cradles and Encasement				
518.01.1	1,202	LF	\$	3.00	\$	3,606.00
		Sanitary Sewer Hydraulic Cleaning (Light) 12" VCP				
518.01.2	1,904	LF	\$	3.00	\$	5,712.00
		Sanitary Sewer Hydraulic Cleaning (Light) 15" VCP				
518.01.3	450	LF	\$	4.50	\$	2,025.00
		Sanitary Sewer Hydraulic Cleaning (Light) 18"x10" RCP Horseshoe				
518.01.4	298	LF	\$	4.50	\$	1,341.00
		Sanitary Sewer Hydraulic Cleaning (Light) 24"x15" RCP Egg				
518.01.5	1,139	LF	\$	7.00	\$	7,973.00
		Sanitary Sewer Hydraulic Cleaning (Light) 32"x24" Brick Horseshoe				
518.01.6	41	LF	\$	5.00	\$	205.00
		Sanitary Sewer Hydraulic Cleaning (Light) 18" RCP				
518.02.1	200	LF	\$	6.00	\$	1,200.00
		Sanitary Sewer Hydraulic Cleaning (Heavy) 12" VCP				
518.02.2	700	LF	\$	6.00	\$	4,200.00
		Sanitary Sewer Hydraulic Cleaning (Heavy) 15" VCP				
518.02.3	500		\$	9.00	\$	4,500.00
		Sanitary Sewer Hydraulic Cleaning (Heavy) 18"x10" RCP Horseshoe				
518.02.4	300		\$	11.00	\$	3,300.00
		Sanitary Sewer Hydraulic Cleaning (Heavy) 24"x15" RCP Egg				
518.02.5	450	LF	\$	15.00	\$	6,750.00
		Sanitary Sewer Hydraulic Cleaning (Heavy) 32"x24" Brick Horseshoe				,
518.04	29	EACH	\$	500.00	\$	14,500.00
		Lateral Connection Cleaning	1			•
520.01.1	1,202		\$	80.00	\$	96,160.00
		12" VCP Sanitary Sewer CIPP Lining	'			,

		D1C# 09-403-110				
SPEC	ESTIMATED		UNIT PRICE		EXTENDED	
NUMBER	QUANTITY	ITEM	DO	LLARS	PRIC	CE DOLLARS
520.01.2	1,904	LF	\$	90.00	\$	171,360.00
		15" VCP Sanitary Sewer CIPP Lining				
520.01.3	450	LF	\$	150.00	\$	67,500.00
		18"x10" RCP Horseshoe Sanitary Sewer CIPP Lining				
520.01.4	298		\$	190.00	\$	56,620.00
		24"x15" RCP Egg Sanitary Sewer CIPP Lining				
520.01.5	1,139		\$	225.00	\$	256,275.00
		32"x24" Brick Horseshoe Sanitary Sewer CIPP Lining				
520.01.6	41		\$	130.00	\$	5,330.00
		18" RCP Sanitary Sewer CIPP Lining				
520.1	143	EACH	\$	300.00	\$	42,900.00
		Re-establish House Service Connection				
520.11.1	61	EACH	\$	250.00	\$	15,250.00
		Cut Protruding (Clay/Plastic) Taps				
520.12	27	EACH	\$	5,000.00	\$	135,000.00
		Sewer Lateral / Sewer Main Connection Lining				
521.01	20		\$	200.00	\$	4,000.00
		Sanitary Sewer Point Repairs 12" VCP				
521.02	60	LF	\$	205.00	\$	12,300.00
		Sanitary Sewer Point Repairs 15" VCP				
521.03	40	LF	\$	800.00	\$	32,000.00
		Sanitary Sewer Point Repairs 32"x24" Brick Horseshoe				
522.01	1,202	LF	\$	2.00	\$	2,404.00
		Sanitary Sewer CCTV Inspection 12" VCP				
522.02	1,904	LF	\$	2.00	\$	3,808.00
		Sanitary Sewer CCTV Inspection 15" VCP				
522.03	450		\$	3.00	\$	1,350.00
		Sanitary Sewer CCTV Inspection 18"x10" RCP Egg				
522.04	298	LF	\$	3.00	\$	894.00
		Sanitary Sewer CCTV Inspection 24"x15" RCP Egg				
522.05	1,139		\$	3.00	\$	3,417.00
		Sanitary Sewer CCTV Inspection 32"x24" Brick Horseshoe				
522.06	41	LF	\$	2.50	\$	102.50
		Sanitary Sewer CCTV Inspection 18" RCP				
523.01	32	VF	\$	475.00	\$	15,200.00
		Sanitary Sewer Manhole				

		2.000.100.110		1	
SPEC NUMBER	ESTIMATED QUANTITY	ITEM	IIT PRICE LLARS		TENDED CE DOLLARS
523.06	1	EACH Proposed Connection at Existing Structure (Pearl Stub)	\$ 15,000.00	\$	15,000.00
601.05	50		\$ 400.00	\$	20,000.00
601.06	50	CY Miscellaneous Structural Concrete	\$ 400.00	\$	20,000.00
651.02	1,743	LF 15" RCP Storm Culvert	\$ 105.00	\$	183,015.00
651.03	317	LF 18" RCP Storm Culvert	\$ 125.00	\$	39,625.00
651.04	904	24" RCP Storm Culvert	\$ 180.00	\$	162,720.00
651.05	397	LF 30" RCP Storm Culvert	\$ 260.00	\$	103,220.00
651.06	1,205	LF 36" RCP Storm Culvert	\$ 300.00	\$	361,500.00
651.07	957	LF 42" RCP Storm Culvert	\$ 450.00	\$	430,650.00
651.08	75	LF 18" DIP Storm Culvert	\$ 180.00	\$	13,500.00
651.09	-	LF 24" DIP Storm Culvert	\$ 200.00	\$	-
651.1	31	LF 30" DIP Storm Culvert	\$ 280.00	\$	8,680.00
651.11	435	36" DIP Storm Culvert	\$ 340.00	\$	147,900.00
714	38,474	Temporary Wood Sheet Piling Left-in-Place	\$ 37.00	\$	1,423,538.00
813.1	260	Granite Stone Curbing (Straight)	\$ 40.00	\$	10,400.00
813.2	162	Granite Stone Curbing (Curved)	\$ 50.00	\$	8,100.00
814	33	LF Reset Stone Curbing	\$ 20.00	\$	660.00
921.01	846		\$ 15.00	\$	12,690.00

		DTC# 09-403-110			1	
SPEC NUMBER	ESTIMATED QUANTITY	ITEM		NIT PRICE DLLARS		ENDED CE DOLLARS
921.02	-	SF	\$	20.00	\$	-
		Concrete Driveway	*		Ť	
921.03	1,439		\$	20.00	\$	28,780.00
	,	Concrete Handicapped Ramp	·			•
942	100	TONS	\$	40.00	\$	4,000.00
		Calcium Chloride for Dust Control				•
944	14	CY	\$	75.00	\$	1,050.00
		Furnishing and Placing Topsoil 4" Thickness				
945	40	SY	\$	5.00	\$	200.00
		Fertilizing, Seeding and Mulching				
945.01	1	LS	\$	100,000.00	\$	100,000.00
		Tree Preservation				
949.01.1	7	EACH	\$	600.00	\$	4,200.00
		Planting Deciduous Tree (Trident Maple) (3" Cal.)				
949.01.2	7	EACH	\$	600.00	\$	4,200.00
		Planting Deciduous Tree (American Elm) (3" Cal.)				
949.01.3	7	EACH	\$	600.00	\$	4,200.00
		Planting Deciduous Tree (Hedge Maple) (3" Cal.)				
949.01.4	8	EACH	\$	600.00	\$	4,800.00
		Planting Deciduous Tree (Kwanzan Cherry) (3" Cal.)				
949.01.5	7	EACH	\$	600.00	\$	4,200.00
		Planting Deciduous Tree (Columnar Sargent Cherry) (3" Cal.)				
949.01.6	7	EACH	\$	600.00	\$	4,200.00
		Planting Deciduous Tree (Japanese Treet Lilac) (3" Cal.)				
969.02	24	MONTH	\$	5,000.00	\$	120,000.00
		Engineer's Field Office (Type B)				
971	1		\$	350,000.00	\$	350,000.00
		Maintenance and Protection of Traffic				
975	1		\$	290,000.00	\$	290,000.00
		Mobilization (Not to exceed 3% of total price excluding mobilization)				
985	1	1	\$	100,000.00	\$	100,000.00
		Project Survey and Stakeout				_
1208.1	240	SF	\$	40.00	\$	9,600.00
		Sign Face - Sheet Aluminum				
1208.2	240		\$	30.00	\$	7,200.00
		Temporary Signage (Building)				

SPEC	ESTIMATED		UNIT PRICE		EXTENDED	
NUMBER	QUANTITY	ITEM	DOLL			E DOLLARS
1208.3	240		\$	30.00	\$	7,200.00
		Temporary Signage (Miscellaneous)				
1209.1	6,542	LF	\$	4.00	\$	26,168.00
		Pavement Markings (Thermoplastic), 4" Wide, White or Yellow				
1209.11	357		\$	8.00	\$	2,856.00
		Pavement Markings (Thermoplastic), 12" Wide, White or Yellow				
1209.12	42	SF	\$	9.00	\$	378.00
		Pavement Markings (Thermoplastic), Symbols, Legends				
1209.13	12	EA	\$	900.00	\$	10,800.00
		Pavement Markings (Thermoplastic), White Stop Bars and Crosswalk Bars				
1209.4	2,867	LF	\$	1.50	\$	4,300.50
		Temporary Pavement Markings (Fast-drying Paint), 4" or 12" Wide				
1209.41	2,867	LF	\$	2.50	\$	7,167.50
		Temporary Pavement Markings (Tape) 4" or 12" Wide				
1209.42	3,024	SF	\$	4.50	\$	13,608.00
		Temporary Pavement Markings (Fast-drying Paint), Symbols, Legends				
1209.43	26	EA .	\$	600.00	\$	15,600.00
		Temp Pvmt Markings (Fast-drying Paint), White Stop Bars and White Crosswalk Bars				
1209.5	6,300	SF	\$	1.00	\$	6,300.00
		Power Washing for Removal of Paint Marks from Concrete/Brick				
1210.01	6,221	LF	\$	2.50	\$	15,552.50
		Pavement Markings (Epoxy Resin), 4" Wide, White or Yellow				
1210.02	956	LF .	\$	7.50	\$	7,170.00
		Pavement Markings (Epoxy Resin), 12" Wide, White or Yellow				
1210.03	1,008	SF	\$	7.50	\$	7,560.00
		Pavement Markings (Epoxy Resin), Symbols, Legends				
1210.04	9	EA	\$	900.00	\$	8,100.00
		Pavement Markings (Epoxy Resin) White Stop Bars and White Crosswalk Bars				
1210.1	18,661	LF	\$	1.75	\$	32,656.75
		Temporary Pavement Markings (Epoxy Resin) 4" Wide, White or Yellow				
1210.11	2,867	LF	\$	5.25	\$	15,051.75
		Temporary Pavement Markings (Epoxy Resin) 12" Wide, White or Yellow				
1210.12	3,024	SF	\$	5.25	\$	15,876.00
		Temporary Pavement Markings (Epoxy Resin) Symbols, Legends				
1210.13	26		\$	750.00	\$	19,500.00
		Temp Pvmt Markings (Epoxy Resin) White Stop Bars and White Crosswalk Bars				

SPEC NUMBER	ESTIMATED QUANTITY	ITEM	_	NIT PRICE PLLARS		TENDED CE DOLLARS
1500		ALLOWANCE	\$	873,000.00	\$	873,000.00
1500	'	Uniformed Police Officers	φ	673,000.00	Φ	673,000.00
1505.1	1	LS	\$	40,000.00	\$	40,000.00
1303.1	'	Special Precast Concrete Structure No.1	Ψ	40,000.00	Ψ	40,000.00
1506.1	300		\$	20.00	\$	6,000.00
1000.1		Abandoning Pipe in Place (4" to 10" I.D.)	l ^Ψ	20.00	*	0,000.00
1506.2	242		\$	25.00	\$	6,050.00
		Abandoning Pipe in Place (12" to 15" I.D.)		_0.00	–	0,000.00
1506.3	20	LF	\$	30.00	\$	600.00
		Abandoning Pipe in Place (18" to 24" I.D.)			•	
1506.4	3	EA	\$	1,000.00	\$	3,000.00
		Abandon Existing Catch Basin or Manhole Structure		•		·
1507.1	1,304	LF	\$	95.00	\$	123,880.00
		6" PVC Storm Lateral				
1507.2	112	LF	\$	100.00	\$	11,200.00
		12" PVC Storm Lateral				
1507.3	21	LF	\$	105.00	\$	2,205.00
		15" RCP Storm Lateral				
1507.4	103	EA	\$	500.00	\$	51,500.00
		Connection of New or Existing Storm Pipe/Lateral (6" to 15")				
1508.1	100	CY	\$	250.00	\$	25,000.00
		Controlled Low Strength Material (Miscellaneous)				
1508.2	100		\$	250.00	\$	25,000.00
		Controlled Low Strength Material (Trench Backfill)				
1510.1	4	EA	\$	1,000.00	\$	4,000.00
		Alter Existing Manhole, Catch Basin, or Drop Inlet				
1513	1		\$	50,000.00	\$	50,000.00
		Arborist Supervision During Construction				
1514	5,820	HR	\$	25.00	\$	145,500.00
		Uniformed Trafficman (Flagger)				
1516	53	SF	\$	20.00	\$	1,060.00
		Remove and Reset / Replace Brick Sidewalk				
1520	1,050		\$	175.00	\$	183,750.00
		Pervious Concrete Sidewalk				
1521.1	1	EACH	\$	18,000.00	\$	18,000.00
		Tree Box Filter / Bioswale 'A'				

SPEC NUMBER	ESTIMATED QUANTITY	ITEM		T PRICE LARS	ENDED E DOLLARS
1521.2	1	EACH Tree Box Filter / Bioswale 'B'	\$	18,000.00	\$ 18,000.00
1521.3	1	EACH Tree Box Filter / Bioswale 'C'	\$	18,000.00	\$ 18,000.00
1521.4	1	EACH Tree Box Filter / Bioswale 'D'	\$	18,000.00	\$ 18,000.00
1521.5	1	EACH Tree Box Filter / Bioswale 'E'	\$	18,000.00	\$ 18,000.00
1521.6	1	EACH Tree Box Filter / Bioswale 'F'	\$	18,000.00	\$ 18,000.00
1521.7	1	EACH Tree Box Filter / Bioswale 'G'	\$	18,000.00	\$ 18,000.00
102-16-19	10	EA Temporary Utility Pole Support	\$	1,800.00	\$ 18,000.00
102-16-19	1	EA Traffic Signal Span Pole Support	\$	20,000.00	\$ 20,000.00

TOTAL \$ 9,960,156.25

	ESTIMATED QUANTITY	ITEM		UNIT PRICE DOLLARS		-		_		EXTENDED PRICE DOLLARS	
BID ALTERN	ATIVE #1 MIL	L & OVERLAY									
405.02	23,604	SY		\$	4.00	\$	94,416.00				
		Bituminous Concrete Milling 0"-2"									
407.41	3,681	SY		\$	44.00	\$	161,964.00				
		Bituminous Concrete Base (Local), Class 4, Thickness 4" (single lift)									
407.42	1,574	SY		\$	88.00	\$	138,512.00				
		Bituminous Concrete Base (Collector), Class 4, 8" Thickness (2 -4" lifts)									
407.5	23,604	SY		\$	13.80	\$	325,735.20				
		Bituminous Concrete Overlay, Class 2, 2" Thick									
407.8	1,130	SY		\$	44.00	\$	49,720.00				
		Utility Trench Base Course (Local), Class 4, 4" thickness (single lift)									
407.81	23	SY		\$	88.00	\$	2,024.00				
		Utility Trench Base Course (Collector), Class 4, 8" thickness (2-4" lifts)									

TOTAL ALTERNATIVE #1 \$ 772,371.20

Long-Term Improvements
Phase II East Shore WPAF
Wet Weather Capacity Improvements
Preliminary Treatment and Odor Control



Project: GNHWPCA Long Term Control Plan Update
Facility: Preliminary Treatment

Estimate Type: Conceptual
Prepared By: J.Ososkie/HRT
Date: 10/4/2016

		Date	: 10/4/2016		
Item of Work		Qty	Unit	Unit Cost	Total Cost
Division 1 - General Requirements					
Included in percentages below					
	Div. 1 Subtotal:				
Division 2 - Site Work					
Demolition					
Existing Garage		3,000	SF	\$5	\$18,144
Existing Maintenance Facility		7,500	SF	\$8	\$68,040
Ecavation					
Preliminary Treatment Bldg		6,963	CY	\$30	\$252,673
Dewatering					
Preliminary Treatment Bldg		12,000	SF	\$30	\$435,457
Yard Piping					
Twin 72 inch Effluent Pipes		850	FT	\$1,275	\$1,310,907
Site Work					
Grading and Drainage		1	ALLOWANCE	\$10,000	\$12,096
Roads & paved areas		1,333	SQYDS	\$45	\$72,558
Floodplain Compensation		1	Estimate	\$300,000	\$362,881
	Div. 2 Subtotal:				\$2,532,756
Division 3 - Concrete					
Truck Bay					
Stone Base 6" Thick		80	CY	\$25	\$2,419
Base Slab		470	CY	\$500	\$284,257
3rd Floor Slab		310	CY	\$1,000	\$374,977
Fine Screening				Φ0.5	A 0.000
Stone Base 6" Thick		75 420	CY	\$25	\$2,268
Base Slab 2nd Floor Slab		430 220	CY CY	\$500 \$1,000	\$260,065 \$266,113
3rd Floor Slab		35	CY	\$1,000 \$1,000	\$42,336
Elec, Control, and HVAC		00		Ψ1,000	Ψ+2,000
Stone Base 6" Thick		30	CY	\$25	\$907
Base Slab		180	CY	\$500	\$108,864
2nd Floor Slab		90	CY	\$1,000	\$108,864
3rd Floor Slab		90	CY	\$1,000	\$108,864
Channels Screening Influent and Effluent		125	CY	\$1,000	\$151,200
Fine Screen Channels		70	CY	\$1,000 \$1,000	\$84,672
Grit Removal Channels		330	CY	\$1,000	\$399,169
Grit Removal		000		Ψ1,000	φοσο, τος
Stone Base 6" Thick		160	CY	\$25	\$4,838
Base Slab		950	CY	\$500	\$574,56
1st Floor Slab		475	CY	\$1,000	\$574,56
Pista Grit		390	CY	\$1,000	\$471,745
Below Grade Wall		360	CY	\$750	\$326,593
	Div. 3 Subtotal:				\$4,147,275
Division 4 - Masonry					
Included in Div 10	D				
	Div. 4 Subtotal:		1		



Project: GNHWPCA Long Term Control Plan Update
Facility: Preliminary Treatment

Estimate Type: Conceptual
Prepared By: J.Ososkie/HRT
Date: 10/4/2016

Item of Work		Qty	Unit	Unit Cost	Total Cost
Division 5 - Metals Other Metals Included in percentages below	Div. 5 Cubtatal				
Division 6 - Wood & Plastics Included in Div 10	Div. 5 Subtotal:				
Division 7 - Thermal & Moisture Pro	Div. 6 Subtotal:				
Included in Div 10	Div. 7 Subtotal:				
Division 8 - Doors & Windows Included in Div 10	Div. 8 Subtotal:				
Division 9 - Finishes Included in percentages below					
Division 10 Specialties	Div. 9 Subtotal:				
Division 10 - Specialties					
Truck Bay Superstructure Fine Screens Superstructure Elec, Control, HVAC Superstructure		8,450 3,900 4,875	SF SF SF	\$250 \$250 \$250	\$1,179,363
	Div. 10 Subtotal:				\$5,208,852
Division 11 - Equipment					
Fine Screens Fine Screens (70 MGD, 6mm) Screen Presses Transfer Screws (60' long, 15 deg) Sluice Gates		3 3 3 6	EA EA EA EA	\$290,000 \$85,000 \$70,000 \$55,400	\$308,449 \$254,017
Grit Removal Pista Grit Equipment Grit Pumps Classifier and Concentrator		3 6 3	EA EA EA	\$90,000 \$20,000 \$60,000	\$326,593 \$145,152 \$217,729
Sluice Gates Truck Bay Leveling Screws Hoppers with Load Cells		6 3 6	EA EA EA	\$33,300 \$70,000 \$100,000	\$254,017
Equipme	nt Installation	1	PERCENT	30%	\$1,178,347
	Div. 11 Subtotal:				\$5,106,169
Division 12 - Furnishings Not Used	Div. 12 Subtotal:				
Division 13 - Special Construction Included in Percentages Below					
	Div. 13 Subtotal:				
Division 14 - Conveying Systems					



Project: GNHWPCA Long Term Control Plan Update
Facility: Preliminary Treatment

Estimate Type: Conceptual
Prepared By: J.Ososkie/HRT
Date: 10/4/2016

Date. 10/4/2010						
Item of Work		Qty	Unit	Unit Cost	Total Cost	
Included in Div 11						
	Div. 14 Subtotal:					
Division 45 Machanical						
Division 15 - Mechanical Included in Percentages Below						
Included in Fercentages below	Div. 15 Subtotal:					
	Zivi io Gastotaii					
Division 16 - Electrical						
Included in Percentages Below						
	Div. 16 Subtotal:					
Subtototal Division 1 - 11 (54%)					\$16,995,052	
Subtototal Division 1 - 11 (34%)					\$10,993,032	
Percentage of Costs						
Metals		3%		\$31,472,318	\$944,170	
Finishes		0%		, , , , , , , , ,	4 5 1 1 , 1 1 5	
Process Mechanical Piping		15%		\$31,472,318	\$4,720,848	
I&C		6%		\$31,472,318	\$1,888,339	
Electrical		10%		\$31,472,318	\$3,147,232	
Facility Subtotal:					\$27,695,640	
General Requirements		10%		\$2,769,564		
Overhead		8%		\$2,437,216		
Profit		10%		\$3,046,520		
Mobilization/Demolization		3%		\$913,956		
Bond/Insurance		3%		\$913,956		
	Subtotal:				\$37,776,853	
Contingency		20%		\$7,555,371	\$7,555,371	

Total Facility Cost:

\$45,332,223

Long-Term Improvements
Phase II East Shore WPAF
Wet Weather Capacity Improvements
Primary Clarifiers with CEPT



Project: GNHWPCA Long Term Control Plan Update
Facility: Primary Clarifiers

Estimate Type: Conceptual
Prepared By: J. Ososkie/HRT
Date: 10/4/2016

	Date:	10/4/2016		
Item of Work	Qty	Unit	Unit Cost	Total Cost
Division 1 - General Requirements				
Included in percentages below				
Div. 1 Subtotal:				
Division 2 - Site Work				
Demolition				
Demolition of Primary Influent Channel	148	CY		
Demolition of Primary Clarifiers Wall and Footing	281	CY		
Demolition of Primary Clarifier Floor	329	CY		
Demolition of Primary Sludge Pits (3 exist, 2 older) Demolition of Primary Effluent Structure, clarifier 3	121 18	CY CY		
Demolition of Filmary Emident Structure, claimer 3 Demolition I Subtotal:	878	CY	\$150	\$159,315
			****	,
Demolition of Primaries chain and flight collectors	9	EA		
Demolition of Primaries scum collectors Demolition of Primaries sludge screw conveyors	9 3	EA EA		
Demolition of Primary Sludge Pumps	6	EA		
Demolition II Subtotal:	1	ALLOWANCE	\$250,000	\$302,401
Excavation				
Primary Clarifier 4	9,293	CY	\$30	
Primary Clarifier 4 Gallery	2,292	CY	\$30	
Gallery Clarifier 1-3	2,095	CY	\$30	\$76,017
Dewatering	1	ALLOWANCE	\$500,000	\$604,801
Yard Piping				
Effluent piping, 84 inch dia	320	FT	\$335	\$129,669
Sludge piping Scum piping 18 inch dia	640 260	FT FT	\$150 \$85	\$116,122 \$26,732
Scuri piping to incit dia	200		φοσ	φ20,732
Site Work			Φ=0.000	\$00.400
Grading and Drainage	1 489	ALLOWANCE SQYDS	\$50,000	
Roads (22 ft wide)	409	SQTDS	\$45	\$26,611
Div. 2 Subtotal:				\$1,922,553
Division 3 - Concrete				
Primary Clarifier 4		<u> </u>		
Stone Base 6" thick	310	CY	\$25	
Effluent Structure Walls	28	CY	\$750	
Effluent Structure Floor	19	CY	\$500	
Primary Clarifier Walls	628 1 850	CY CY	\$750 \$500	-
Primary Clarifier Floor Primary Clarifier Footings	1,859 244	CY CY	\$500 \$500	
Influent Pipe Encasement	1,048	CY	\$500 \$500	\$633,549
Primary Clarifier Gallery (1-4)	- ,		4530	4000,010
Stone Base 6" thick	175	CY	\$25	
Gallery Walls	756	CY	\$750	
Gallery Floor	1,042	CY	\$500	\$630,337
Gallery Roof Gallery Footings	521 131	CY CY	\$1,000 \$500	· · · · · · · · · · · · · · · · · · ·
Saliety i oddings	151		φυσο	φ <i>1</i> 3,430
Div. 3 Subtotal:				\$4,552,471
		l l		



Project: GNHWPCA Long Term Control Plan Update
Facility: Primary Clarifiers

Estimate Type: Conceptual
Prepared By: J. Ososkie/HRT
Date: 10/4/2016

		Date.	10/4/2016		
Item of Work		Qty	Unit	Unit Cost	Total Cost
Division 4 - Masonry					
Not used	Div. 4 Subtotal:				
Division F. Matala					
Division 5 - Metals					
Primary Tank Covers Hand Railing Other Metals Included in percentages below		16,728 500	SF LF	\$50 \$120	\$1,011,712 \$72,576
Other Metals Included in percentages below					
	Div. 5 Subtotal:				\$1,084,288
Division 6 - Wood & Plastics					
Not used	Div. 6 Subtotal:				
Division 7 - Thermal & Moisture Pro	tootion				
Not used	lection				
	Div. 7 Subtotal:				
Division 8 - Doors & Windows					
Not used	Div. 8 Subtotal:				
Division 9 - Finishes					
Included in percentages below	Div. 9 Subtotal:				
Division 40 Specialties					
Division 10 - Specialties Gallery Exits -2 (stairwells)		700	SF	\$150	\$127,008
	Div. 10 Subtotal:				\$127,008
Division 11 - Equipment					
Primary Clarifier Mechanism		4	EA	\$414,900	\$2,007,457
Clarifier influent slide gates Clarifier channel isolation gates		24 3	EA EA	\$6,800 \$8,800	\$197,407 \$31,934
Primary Sludge Pumps		12	EA	\$27,000	\$391,911
Primary Sludge Pump Drives		12	EA	\$10,000	\$145,152
PSD line 6" flow meters		12	EA	\$3,000	\$43,546
48" Mag Meter 48" Butterfly Valves		4 4	EA EA	\$38,500 \$18,000	\$186,279 \$87,091
Equipmen	nt Installation	1	PERCENT	30%	\$927,233
	Div. 11 Subtotal:				\$4,018,010
Division 12 - Furnishings					
Not used	Div. 12 Subtotal:				
Division 13 - Special Construction					
Not used	Div. 13 Subtotal:				
				į į	



Project: GNHWPCA Long Term Control Plan Update
Facility: Primary Clarifiers

Estimate Type: Conceptual
Prepared By: J. Ososkie/HRT
Date: 10/4/2016

Date: 10/4/2016					
	Qty	Unit	Unit Cost	Total Cost	
Div. 14 Subtotal:					
Div. 15 Subtotal:					
Div. 16 Subtotal:					
				\$11,704,330	
	3%		\$18,877,952	\$566,339	
	2%		\$18,877,952	\$377,559	
	15%		\$18,877,952	\$2,831,693	
				\$1,132,677	
	10%		\$18,877,952	\$1,887,795	
				\$18,500,393	
	10%		\$1,850,039		
	8%		\$1,628,035		
	10%		\$2,035,043		
	3%		\$610,513	4 :	
Subtotal:				\$25,234,536	
	20%		\$5,046,907	\$5,046,907	
	Div. 15 Subtotal:	Div. 14 Subtotal: Div. 15 Subtotal: Div. 16 Subtotal: 3% 2% 15% 6% 10% 8% 10% 8% 10% 3% 3% 3% 3%	Div. 14 Subtotal: Div. 15 Subtotal: 3% 2% 15% 6% 10% 10% 8% 10% 3% 3% 3% 3% 3% 3%	Div. 14 Subtotal: Div. 15 Subtotal: Div. 16 Subtotal: 3% 2% 15% 6% 118,877,952 15% 6% \$18,877,952 10% \$18,877,952 \$18,877,952 \$18,877,952 \$18,877,952 \$10% \$1,850,039 \$1,628,035 \$2,035,043 3% \$10% 3% \$\$3% \$\$610,513 \$\$610,513	

Total Facility Cost:

\$30,281,443

Long-Term Improvements
Phase II East Shore WPAF
Wet Weather Capacity Improvements
Head Works with CEPT and Septage



Project: GNHWPCA Long Term Control Plan Update

Facility: Head Works with CEPT & Septage

Estimate Type: Conceptual
Prepared By: J. Ososkie/HRT
Date: 10/4/2016

Item of Work		Qty	Unit	Unit Cost	Total Cost
Division 1 - General Requirements Included in percentages below	Div. 1 Subtotal:				
Division 2 - Site Work					
Demolition Demolition of existing grit removal equipment		1	ALLOWANCE	\$150,000	\$181,440
Excavation CEPT Chemical Containment		259	CY	\$25	\$7,840
Dewatering		1	ALLOWANCE	\$5,000	\$6,048
Yard Piping FeCl ₃ Pipes, 2" PVC PO Pipes, 2" PVC		300 300	FT FT	\$65 \$65	\$23,587 \$23,587
Site Work Grading and Drainage Roads (22 ft wide)		1 222	ALLOWANCE SQYDS	\$10,000 \$45	\$12,096 \$12,096
	Div. 2 Subtotal:				\$266,695
Division 3 - Concrete					
Basement Screen channel covers Grit channel covers Grit channel benching Grit channel modifications at gates		11 59 237 1	CY CY CY ALLOWANCE	\$1,000 \$1,000 \$500 \$100,000	\$13,440 \$71,680 \$143,360 \$120,960
Chemical containment Stone Base 6" thick base slab walls		19 111 39	CY CY CY	\$25 \$500 \$750	\$560 \$67,200 \$34,944
	Div. 3 Subtotal:				\$452,145
Division 4 - Masonry Not used	Div. 4 Cubtatal				
	Div. 4 Subtotal:				
Division 5 - Metals Included in percentages below	Div. 5 Subtotal:				
Division 6 - Wood & Plastics Not used	Div. 6 Subtotal:				
Division 7 - Thermal & Moisture Protection Not used					
	Div. 7 Subtotal:				
Division 8 - Doors & Windows Not used	Div. 8 Subtotal:				



Project: GNHWPCA Long Term Control Plan Update Facility: Head Works with CEPT & Septage

Estimate Type: Conceptual Prepared By: J. Ososkie/HRT Date: 10/4/2016

Item of Work	Qty	Unit	Unit Cost	Total Cost
Division 9 - Finishes Included in percentages below Div. 9 Subtotal:				
Division 10 - Specialties				
Headworks Bldg. Life Safety (egress, fire protcection, NFPA, etc) Change of use & Upgrades (doors, windows, thermal protection, etc) Chemical containment super structure	10,080 10,080 1,000	SQFT SQFT SQFT	\$75 \$75 \$250	\$914,460 \$914,460 \$302,401
Div. 10 Subtotal:				\$2,131,320
Division 11 - Equipment				
Screening Compactors Screen isolation gates	2 4	EA EA	\$50,000 \$50,000	\$120,960 \$241,921
Septage receiving tank Septage grinder Septage control valve	1 1 1	EA EA EA	\$50,000 \$13,000 \$5,000	
FeCI ₃ Metering Pumps Polymer Metering Pumps Polymer Blending Units FeCI ₃ Storage Tank	5 5 4 2	EA EA EA	\$9,500 \$6,000 \$15,000 \$21,500	\$57,456 \$36,288 \$72,576 \$52,013
NaOCI Metering Pumps	4	EA	\$9,500	\$45,965
Equipment Installation	1	PERCENT	30%	\$188,154
Div. 11 Subtotal:				\$815,333
Division 12 - Furnishings Not used Div. 12 Subtotal:				
Division 13 - Special Construction Not used				
Div. 13 Subtotal:				
Division 14 - Conveying Systems Not used Div. 14 Subtotal:				
Division 15 - Mechanical Included in percentages below				
Div. 15 Subtotal: Division 16 - Electrical Included in percentages below Div. 16 Subtotal:				
Subtototal Division 1 - 11 (62%)				\$3,665,493
Percentage of Costs				
Metals Finishes Process Mechanical Piping	3% 2% 15%		\$5,912,086 \$5,912,086 \$5,912,086	\$177,363 \$118,242 \$886,813



Project: GNHWPCA Long Term Control Plan Update Facility: Head Works with CEPT & Septage

Estimate Type: Conceptual Prepared By: J. Ososkie/HRT Date: 10/4/2016

	Date.	10/4/2010		
Item of Work	Qty	Unit	Unit Cost	Total Cost
I&C	6%		\$5,912,086	\$354,725
Electrical	12%		\$5,912,086	\$709,450
Facility Subtotal:				\$5,912,086
General Requirements	10%		\$591,209	
Overhead	8%		\$520,264	
Profit	10%		\$650,329	
Mobilization/Demolization	3%		\$195,099	
Bond/Insurance	3%		\$195,099	
Subtotal:				\$8,064,085
Contingency	20%		\$1,612,817	\$1,612,817

Total Facility Cost:

\$9,676,902

Long-Term Improvements
Phase II East Shore WPAF
Wet Weather Capacity Improvements
Disinfection



Project: GNHWPCA Long Term Control Plan Update
Facility: Disinfection
Estimate Type: Conceptual
Prepared By: J. Ososkie/HRT
Date: 10/4/2016

Item of Work		Qty	e: 10/4/2016 Unit	Unit Cost	Total Cost
			T		
Division 1 - General Requirements Included in percentages below					
motaucu m porcomagos solon	Div. 1 Subtotal:				
Division 2 - Site Work					
Demolition					
Existing CCT1 baffle walls Effluent channel wall to beach gate		318 12	CY CY	\$150 \$150	\$57,607 \$2,150
Ecavation					
Dry/Wet Weather Flow Split		356	CY	\$30	\$12,902
Chlorine Contact Tanks Wet Weather Conduit		8,889 10,276	CY CY	\$30 \$30	\$322,561 \$372,880
Dewatering					
Dry/Wet Weather Flow Split		1	ALLOWANCE ALLOWANCE	\$50,000	\$60,480
Chlorine Contact Tanks Wet Weather Conduit		1 1	ALLOWANCE	\$150,000 \$100,000	\$181,440 \$120,960
Yard Piping					
NaOCl Pipes, 2" PVC		1,200	FT	\$65	\$94,349
Site Work					*
Grading and Drainage Roads (22 ft wide)		1 1,333	ALLOWANCE SQYDS	\$100,000 \$45	\$120,960 \$72,576
	Div. 2 Subtotal:				\$1,418,867
Division 3 - Concrete					
Primary Effluent Conduit					
84 inch dia RCP		600	FT	\$335	\$243,130
84 inch fittings		2	EA	\$5,500	\$13,306
Dry/Wet Weather Flow Split					•
Stone Base 6" thick Footings		15 47	CY CY	\$25 \$500	\$448 \$28,224
Base slab		89	CY	\$500 \$500	\$53,760
Walls		213	CY	\$750	\$193,536
Wet Weather Chlorine Contact Tanks					
Stone Base 6" thick		296 4.770	CY CY	\$25	\$8,960
Base slab Footings		1,778 202	CY	\$500 \$500	\$1,075,203 \$122,304
Baffle walls		428	CY	\$750	\$387,879
Wet Weather Effluent Conduit New CCT to plant effluent Conduit		1,445	FT	\$1,292	\$2,257,995
Dry Weather UV					
Channel covers (50%)		415 117	CY CY	\$750 \$1,000	\$376,321 \$141,120
Channel covers (50%)	D. 0.6.1	117	CY	\$1,000	\$141,120
	Div. 3 Subtotal:				\$4,902,187



Project: GNHWPCA Long Term Control Plan Update
Facility: Disinfection
Estimate Type: Conceptual
Prepared By: J. Ososkie/HRT
Date: 10/4/2016

	Date: 10/4/2016				
Item of Work		Qty	Unit	Unit Cost	Total Cost
Division 4 - Masonry					
Not used	Subtotal:				
DIV. 4	Subiolai.				
Division 5 - Metals					
Chlorine Contact Tank Covers		16,000	SF	\$50	\$967,682
Included in percentages below		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,			, ,
Div. 5	Subtotal:				\$967,682
Division 6 - Wood & Plastics Not used					
	Subtotal:				
Division 7 - Thermal & Moisture Protection	,				
Not used	'				
Div. 7	Subtotal:				
Division 8 - Doors & Windows					
Not used					
Div. 8	Subtotal:				
Division 9 - Finishes					
Not used	Subtotal:				
Div. 9	Subtotal.				
Division 10 - Specialties		0.450	0.5	4.5 0	4574 507
UV Canopy		3,150	SF	\$150	\$571,537
Div. 10	Subtotal:				\$571,537
Division 11 - Equipment					
Mechanical Constant Level Gates		3	EA	\$39,500	\$143,338
UV Equipment		1	EA	\$1,600,000	\$1,935,365
Slide Gate, 48" w/ operator		1	EA	\$6,800	\$8,225
42" Butterfly Valves, Flow Split Box		3	EA	\$18,000	\$65,319
Partial Flume (dry weather) Partial Flume (wet weather)		1	EA EA	\$9,600 \$33,300	\$11,612 \$40,280
Equipment Insta	allation	1	PERCENT	30%	\$661,241
Div. 11	Subtotal:				\$2,865,380
B					
Division 12 - Furnishings Not used					
	Subtotal:				
Division 13 - Special Construction					
Included in percentages below					
Div. 13	Subtotal:				
Division 14 - Conveying Systems					
Not used					
Div. 14	Subtotal:				
ı	ı			1	



Project: GNHWPCA Long Term Control Plan Update
Facility: Disinfection
Estimate Type: Conceptual
Prepared By: J. Ososkie/HRT
Date: 10/4/2016

Item of Work		Qty	Unit	Unit Cost	Total Cost
item of work		Qiy	Unit	Unit Cost	TOTAL COST
Division 15 - Mechanical					
Included in percentages below					
	Div. 15 Subtotal:				
Division 16 - Electrical					
Included in percentages below					
,	Div. 16 Subtotal:				
Subtototal Division 1 - 11 (81%)					\$10,725,654
Percentage of Costs					
Metals		1.5%		\$13,241,548	\$198,623
Finishes		1%		\$13,241,548	\$132,415
Process Mechanical Piping		7.5%		\$13,241,548	\$993,116
I&C		3%		\$13,241,548	\$397,246
Electrical		6%		\$13,241,548	\$794,493
Facility Subtotal:					\$13,241,548
General Requirements		10%		\$1,324,155	
Overhead		8%		\$1,165,256	
Profit		10%		\$1,456,570	
Mobilization/Demolization		3%		\$436,971	
Bond/Insurance		3%		\$436,971	
	Subtotal:				\$18,061,472
Contingency		20%		\$3,612,294	\$3,612,294
Total	Facility Cost:		<u> </u>	1	\$21,673,766

Long-Term Improvements
Phase II East Shore WPAF
Wet Weather Capacity Improvements
Power Distribution



Project: GNHWPCA Long Term Control Plan Update
Facility: Electrical Upgrade
Estimate Type: Conceptual - Capital Improvements Planning
Prepared By: J. Ososkie/HRT
Date: 10/4/2016

Item of Work		Qty	Unit	Unit Cost	Total Cost
Division 1 - General Requirements Included in percentages below	Div. 1 Subtotal:				
Division 2 - Site Work					
Duct Banks to existing facilities Main Building Aeration Tanks Sludge Bldg. Influent Bldg Duct Banks to new facilities		0 0 0 0	LF LF LF LF	\$50 \$50 \$50 \$50	
Preliminary Treatment South Odor Control		600 50	LF LF	\$350 \$350	\$210,000 \$17,500
	Div. 2 Subtotal:				\$227,500
Division 3 - Concrete					
Generator pad Switch Gear Bldg.		0 0	CY CY	\$500 \$500	
	Div. 3 Subtotal:				
Division 4 - Masonry Not used	Div. 4 Subtotal:				
Division 5 - Metals Not used	Div. 5 Subtotal:				
Division 6 - Wood & Plastics Not used	Div. 6 Subtotal:				
Division 7 - Thermal & Moisture Prof					
Not used	Div. 7 Subtotal:				
Division 8 - Doors & Windows Not used					
	Div. 8 Subtotal:				
Division 9 - Finishes Not used	Div. 9 Subtotal:				
Division 10 - Specialties Switch Gear Bldg. Suoerstructure		0	SF	\$250	
	Div. 10 Subtotal:				
Division 11 - Equipment					
Main Building					



Project: GNHWPCA Long Term Control Plan Update
Facility: Electrical Upgrade
Estimate Type: Conceptual - Capital Improvements Planning
Prepared By: J. Ososkie/HRT
Date: 10/4/2016

	Bato.	10/4/2016		
Item of Work	Qty	Unit	Unit Cost	Total Cost
MCC-M1	0	EA	\$10,000	
MCC-M2	0	EA	\$10,000	
MCC-M3 (ABANDONED-2002)	0	EA	\$10,000	
MCC-M4(MODIFIED 2002)	0	EA	\$10,000	
MCC-M5	0	EA	\$10,000	
MCC-M6	0	EA	\$10,000	
MCC-M7	0	EA	\$10,000	
		EA		
MCC-M8(FIND DRAWINGS)	0		\$10,000	
MCC-M10 (INSTALLED 1986)	0	EA	\$10,000	
MCC-M11 (INSTALLED 1997)	0	EA	\$10,000	
MCC-Z1	0	EA	\$10,000	
MCC-T1	0	EA	\$10,000	
SWBD-M1 (INSTALLED 2002)		EA		
SWBD-M2 (INSTALLED 2002)		EA		
SUB NO.1 FEEDER BRKR	0	EA	\$25,000	
SUB NO.1 MAIN/TIE BRKR	0	EA	\$75,000	
SUB NO.1 XFMR (2000 KVA)	0	EA	\$100,000	
SUB NO.1 HV SWITCH	0	EA	\$50,000	
Aeration tanks				
MCC-A5 (INSTALLED 1996)	0	EA	\$10,000	
MCC-A6 (INSTALLED 1996)	0	EA	\$10,000	
MCC-A7 (INSTALLED 1996)	0	EA	\$10,000	
MCC-A8 (INSTALLED 1996)	0	EA	\$10,000	
,				
MCC-A9 (INSTALLED 1996)	0	EA	\$10,000	
SUB NO.2 FEEDER BRKR	0	EA	\$25,000	
SUB NO.2 MAIN/TIE BRKR	0	EA	\$75,000	
SUB NO.2 XFMR (2000 KVA)	0	EA	\$100,000	
SUB NO.2 HV SWITCH	0	EA	\$50,000	
Sludge Building				
MCC-S3	0	EA	\$10,000	
MCC-S4	0	EA	\$10,000	
MCC-S5 (INSTALLED 1998)		EA	\$10,000	
,	0			
MCC-S6 (INSTALLED 1998)	0	EA	\$10,000	
SUB NO.3 FEEDER BRKR	0	EA	\$25,000	
SUB NO.3 MAIN/TIE BRKR	0	EA	\$75,000	
SUB NO.3 XFMR (2000 KVA)	0	EA	\$100,000	
SUB NO.3 HV SWITCH	0	EA	\$50,000	
lead Works Building				
MCC-PW	0	EA	\$10,000	
MCC-PW2 (INSTALLED 1997)	0	EA	\$10,000	
Generator Building				
MCC-GEN BLDG	6		\$10,000	\$72,576
SUB GEN BLDG FEEDER BRKR	2		\$25,000	\$60,480
SUB GEN BLDG MAIN/TIE BRKR	3		\$75,000	\$272,161
SUB GEN BLDG XFMR (750 KVA)	2		\$75,000	\$181,440
SUB GEN BLDG AFMIX (730 KVA)	2		\$50,000	\$120,960
Grit Building				
MCC-Grit BLDG	10		\$10,000	\$120,960
SUB GRIT BLDG FEEDER BRKR	2		\$25,000	\$60,480



Project: GNHWPCA Long Term Control Plan Update
Facility: Electrical Upgrade
Estimate Type: Conceptual - Capital Improvements Planning
Prepared By: J. Ososkie/HRT
Date: 10/4/2016

Item of Work	Qty	Unit	Unit Cost	Total Cost
SUB GRIT BLDG MAIN/TIE BRKR SUB GRIT BLDG XFMR (750 KVA) SUB GRIT BLDG HV SWITCH	3 2 2		\$75,000 \$75,000 \$50,000	\$272,161 \$181,440 \$120,960
Generator with outdoor enclosure Main Switch Gear	0 0	EA EA	\$600,000 \$1,000,000	
Electrical Installation	1	PERCENT	30%	\$439,086
Div. 11 Subtotal:				\$1,902,705
Division 12 - Furnishings Not used Div. 12 Subtotal:				
Division 13 - Special Construction Not used Div. 13 Subtotal:				
Division 14 - Conveying Systems				
Not used Div. 14 Subtotal:				
Division 15 - Mechanical Not used Div. 15 Subtotal:				
Division 16 - Electrical Included in percentages below Div. 16 Subtotal:				
Subtototal Division 1 - 11 (65%)				\$2,130,205
Percentage of Costs				
Metals Finishes I&C Electrical	0% 0% 0% 20%		\$3,550,342 \$3,550,342 \$3,550,342 \$3,550,342	\$0 \$0 \$0 \$710,068
Facility Subtotal:				\$2,840,274
General Requirements Overhead Profit Mobilization/Demolization Bond/Insurance Subtotal:	10% 8% 10% 3% 3%		\$284,027 \$249,944 \$312,430 \$93,729 \$93,729	\$3,874,133
Contingency	20%		\$774,827	\$774,827
Total Facility Cost:		<u> </u>		\$4 648 960

Total Facility Cost:

\$4,648,960

Long-Term Improvements
Phase II East Shore WPAF
Wet Weather Capacity Improvements
Nitrogen Removal (IFAS)



Project: GNHWPCA Long Term Control Plan Update Facility: IFAS
Estimate Type: Conceptual Prepared By: J. Ososkie/HRT
Date: 10/4/2016

		. 10/4/2016		
Item of Work	Qty	Unit	Unit Cost	Total Cost
Division 1 - General Requirements Included in percentages below Div. 1 Subtotal:				
Division 2 - Site Work Not Used Div. 2 Subtotal:				
Baffle walls Channel Div. 3 Subtotal:	652 296	CY CY	\$750 \$1,000	\$591,36 ² \$358,40 ² \$949,762
Division 4 - Masonry Not Used Div. 4 Subtotal:				
Division 5 - Metals other items included in percentages below				
Div. 5 Subtotal:				
Division 6 - Wood & Plastics Not Used Div. 6 Subtotal:				
Division 7 - Thermal & Moisture Protection Not Used				
Div. 7 Subtotal:				
Division 8 - Doors & Windows Not Used				
Div. 8 Subtotal:				
Division 9 - Finishes Included in percentages below Div. 9 Subtotal:				
Division 10 - Specialties Not Used				
Div. 10 Subtotal:				
Division 11 - Equipment				
Media Reactor Sieves Weir Gates	1 1 12	EA EA EA	\$4,150,000 \$500,000 \$12,500	\$5,019,85 \$604,80 \$181,44
Aeration basin diffuser grid modifications Remove diffuser grid in IFAS zone Add diffusers in IFAS zone	16,000 16,000	SQFT SQFT	\$3 \$30	\$48,38 \$580,60
Blower and Air Distribution Modifications Capacity controls and piping	1	ALLOWANCE	\$0	
Equipment Installation	1	PERCENT	30%	\$1,930,52
Div. 11 Subtotal:				\$8,365,61



Project: GNHWPCA Long Term Control Plan Update Facility: IFAS
Estimate Type: Conceptual Prepared By: J. Ososkie/HRT
Date: 10/4/2016

Item of Work		Qty	Unit	Unit Cost	Total Cost
Division 12 - Furnishings					
Not Used					
	Div. 12 Subtotal:				
Division 13 - Special Construction <i>Not Used</i>					
Not Osed	Div. 13 Subtotal:				
Division 14 - Conveying Systems Not Used					
7161 6666	Div. 14 Subtotal:				
Division 15 - Mechanical					
Included in percentages below	Div. 15 Subtotal:				
Division 16 - Electrical					
Included in percentages below	Div. 16 Subtotal:				
Subtototal Division 1 - 11 (64%)					\$9,315,375
Percentage of Costs					
Metals		3%		\$14,555,274	\$436,658
Finishes		0%		\$14,555,274	
Process Mechanical Piping		15%		\$14,555,274	\$2,183,291
I&C		6%		\$14,555,274	\$873,316
Electrical		12%		\$14,555,274	\$1,746,633
Facility Subtotal:					\$14,555,274
General Requirements		10%		\$1,455,527	
Overhead		8%		\$1,280,864	
Profit		10%		\$1,601,080	
Mobilization/Demolization		3.0%		\$480,324	
Bond/Insurance		3%		\$480,324	
	Subtotal:				\$19,853,394
Contingency		20%		\$3,970,679	\$3,970,679
	Facility Cost:				\$23 824 073

Total Facility Cost:

\$23,824,073

Long-Term Improvements Fair Haven Sewer Separation



Project: GNHWPCA Long Term Control Plan Update

Facility: Fair Haven Sewer Separation

Estimate Type: Conceptual Prepared By: J. Ososkie
Date: 10/4/2016

Item of Work	Qty	Unit	Unit Cost	Total Cost
Sewer Separation				
15" Storm	55,487	LF	450	\$24,969,150
18" Storm	4,132	LF	500	\$2,066,000
21" Storm	1,754	LF	600	\$1,052,400
24" Storm	1,928	LF	700	\$1,349,600
27" Storm	1,261	LF	1,000	\$1,261,000
30" Storm	2,535	LF	1,250	\$3,168,750
36" Storm	1,564	LF	1,500	\$2,346,000
42" Storm	646	LF	1,800	\$1,162,800
48" Storm	1,749	LF	1,900	\$3,323,100
54" Storm	1,390	LF	2,000	\$2,780,000
Subtototal				\$43,478,800
General Requirements	10%			\$4,347,880.00
Overhead	8%			\$3,478,304.00
Profit	10%			\$4,347,880.00
Mobilization/Demolization	3%			\$1,304,364.00
Bond/Insurance	3%			\$1,304,364.00
Subtototal				\$58,261,592
Contingency	35%			\$20,391,557.20
				#70.C52.440

Total Cost: \$78,653,149

Long-Term Improvements CSO Storage Tanks

Great New Haven WWTP Master Plan Storage Tank Estimate Construction Cost Estimate for Conceptual Design

Project name GNH WWTP Master Plan

Estimator Tweneboa-Kodua, A/WDC

Project Number 478874
Estimate Class 1-5 4
Design Stage Concept

Project Manager John Ososkie/HRT Rev No. / Date R04/(11-30-2016)



Facility Summary

GNH WWTP Master Plan Tweneboa-Kodua, A/WDC Project: Estimator:

Job Size: 1 LS Project No.: 478874 Revision / Date: R04/(11-30-2016)

1 LS **Duration:** Design Stage: Concept Estimate Class: 4

Facility	Description	Direct Amount	Grand Total w/Markups	Percent of Total
003	CSO 003 Storage Tank	1,079,209	1,995,205	4.005
004	CSO 004 Storage Tank	3,299,209	6,172,411	12.389
005	CSO 005 Storage Tank	6,999,209	13,134,419	26.363
012	CSO 006 StorageTank	5,852,209	10,976,197	22.031
014	CSO 011 StorageTank	5,630,209	10,558,476	21.193
016	CSO 015 StorageTank	2,152,209	4,014,188	8.057
018	CSO 016 StorageTank	1,597,209	2,969,887	5.961

Estimate Totals

Construction Costs	Amount	Totals	Rate	% of Total
Labor	12,057,956			24.20%
Material	30,940,144			62.10%
Subcontract	4,389,447			8.81%
Equipment	1,890,198			3.79%
Other_	543,037			1.09%
Total Prime Contractor Costs	49,820,782	49,820,782		100.00



Project: GNH WWTP Master Plan

Tweneboa-Kodua, A/WDC Estimator: Project No.: 478874 Revision / Date: R04/(11-30-2016)

Design Stage: Concept Estimate Class: 4

Fac	Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
003			CSO 003 Storage Tank										
003	13.0		Effluent Pump Station										
	13.0	13-10	Buildings Complete										
		13-10	Effluent Pump Station										
			Masonry Building										
			Pump Building Masonry 20' x 20'	400.00 sf	28,638	28,000	_	105,072	_	404.27 /sf	161,710	740.48 /sf	296,191
			Masonry Building	400.00 SF	28.638	28,000		105,072		404.27 /SF	161,710		296,191
			Mechanical, Other	400.00 01	20,000	20,000		100,072		404.21 701	101,710	140.40 701	230,131
			Miscelleneous piping allowance	1.00 ls		-	200,000	-		200,000.00 /ls	200,000	366,324.80 /ls	366,325
			Mechanical, Other	400.00 SF			200,000			500.00 /SF	200,000		366.325
			Mechanical, HVAC										
			Condensing unit, air cooled, compressor, 4 ton, includes standard controls	1.00 ea	3,095	8,500	-	-	-	11,595.04 /ea	11,595	21,237.76 /ea	21,238
			Mechanical, HVAC	400.00 SF	3,095	8,500				28.99 /SF	11,595	53.09 /SF	21,238
			Electrical, Other										
			Miscellaneous electrical and I&C	1.00 ls	-	-	100,000	-	-	100,000.00 /ls	100,000		183,162
			Electrical, Other	400.00 SF			100,000			250.00 /SF	100,000	457.91 /SF	183,162
			Electrical Equipment, Generators - >300 to 400 KW										
			Emergency Generator 400 KW	1.00 E	7,541	120,000	-	-	-	127,540.92 /E	127,541	233,606.99 /E	233,607
	1		Electrical Equipment, Generators - >300 to 400 KW	1.00 EA	7,541	120,000				127,540.92 /EA	127,541	233,606.99 /EA	233,607
			I&C, Flow / Mag Meter / Indicators & Transmitters										
			Pump Flow Meter including transmitter	2.00 ea	1,194	20,400	-		-	10,796.99 /ea	21,594	19,776.03 /ea	39,552
			I&C, Flow / Mag Meter / Indicators & Transmitters	2.00 EA	1,194	20,400				10,796.99 /EA	21,594	19,776.03 /EA	39,552
			I&C, Level / Switches										
			Float switch	8.00 ea	1,203	-	-	-	-	150.40 /ea	1,203		2,204
			Float switch bracket	2.00 ea	602	300	-	-	-	450.80 /ea	902		1,651
			I&C, Level / Switches	10.00 EA	1,805	300				210.48 /EA	2,105	385.52 /EA	3,855
			I&C, Panels & Stands	0.00	4.000	40.000				0.004.00 /	40.000	40.004.05 /:-	04.400
			System panel	2.00 ea	1,203 1,203	12,000 12,000	-	-	-	6,601.60 /ea	13,203 13,203		24,183
			I&C, Panels & Stands Submersible Pump: 35Hp	2.00 EA	1,203	12,000				6,601.60 /EA	13,203	12,091.65 /EA	24,183
			Functional Testing, Submersible Pumps, 21 - 50 hp	2.00 ea	602	100				350.80 /ea	702	642.54 /ea	1,285
			FURNISH Submersible Pump, 35 hp	2.00 EA	- 002	63,000		-		31,500.00 /EA	63,000		115,392
			Set base elbow / pump assembly, 35 hp	2.00 ea	5,414	100				2,757.20 /ea	5,514		10,100
			Stainless steel guide rails, 3",	40.00 lf	1,306	694	-	-	-	50.00 /lf	2,000		3,663
			Install upper guide rail bracket	2.00 ea	226	20	-	-	-	122.80 /ea	246		450
			Submersible Pump: 35Hp	2.00 EA	7,547	63,914				35,730.80 /EA	71,462		130,891
			Effluent Pump Station	1.00 EA	51,023	253,114	300,000	105,072		709,209.14 /EA	709,209		1,299,004
			13-10 Buildings Complete	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,004
			13.0 Effluent Pump Station	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,004
	33.5		Tank Construction										
		33.90	Tanks										
			Cast-In-Place Concrete Storage Tank										
			Tanks, Other										
			Storage Tanks construction, below grade, cast-in-place concrete, 100,000 gaillons, incluidng sitework, miscellaneous piping excludiing	100,000.00 gal	105,714	264,286		-		3.70 /gal	370,000	6.96 /gal	696,201
			pump station Tanks, Other	100,000.00 GAL	105,714	264.286				3.70 /GAL	370,000	6.96 /GAL	696,201
			Cast-In-Place Concrete Storage Tank	100,000.00 GAL	105,714	264,286				3.70 /GAL	370,000		696,201
			•	100,000.00 GAL	105,714	264,286				3.70 /GAL	370,000		696,201
			33.90 Tanks										
			33.5 Tank Construction	100,000.00 GAL	105,714	264,286				3.70 /GAL	370,000		696,201
			003 CSO 003 Storage Tank	0.10 MG	156,737	517,400	300,000	105,072		10,792,091.40 /MG	1,079,209	19,952,053.40 /MG	1,995,205
004			CSO 004 Storage Tank										
	13.0		Effluent Pump Station										
		13-10	Buildings Complete										
			Effluent Pump Station										
			Masonry Building										
			Pump Building Masonry 20' x 20'	400.00 sf	28,638	28,000		105,072	-	404.27 /sf	161,710		296,191
			Masonry Building	400.00 SF	28,638	28,000		105,072		404.27 /SF	161,710	740.48 /SF	296,191
			Mechanical, Other										
			Miscelleneous piping allowance	1.00 ls	-	-	200,000	-	-	200,000.00 /ls	200,000		366,325
			Mechanical, Other	400.00 SF			200,000			500.00 /SF	200,000	915.81 /SF	366,325
			Mechanical, HVAC										
			Condensing unit, air cooled, compressor, 4 ton, includes standard	1.00 ea	3,095	8,500	-	-	-	11,595.04 /ea	11,595	21,237.75 /ea	21,238
			controls	1	1		I	1	ı		T.	1	



Project: GNH WWTP Master Plan

Project No.: 478874 Revision / Date: R04/(11-30-2016)

Tweneboa-Kodua, A/WDC

Estimator:

Estimate Class: 4

Design Stage: Concept

	Trade Pkg	Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Mechanical, HVAC	400.00 SF	3,095	8,500				28.99 /SF	11,595	53.09 /SF	21,23
		Electrical, Other										
		Miscellaneous electrical and I&C	1.00 ls	-	-	100,000	-	-	100,000.00 /ls	100,000	183,162.39 /ls	183,16
		Electrical, Other	400.00 SF			100,000			250.00 /SF	100,000	457.91 /SF	183,16
		Electrical Equipment, Generators - >300 to 400 KW										
		Emergency Generator 400 KW	1.00 E	7,541	120,000 120,000	-	-	-	127,540.92 /E	127,541	233,607.02 /E	233,60
		Electrical Equipment, Generators - >300 to 400 KW I&C, Flow / Mag Meter / Indicators & Transmitters	1.00 EA	7,541	120,000				127,540.92 /EA	127,541	233,607.02 /EA	233,60
		Pump Flow Meter including transmitter	2.00 ea	1,194	20,400				10,796.99 /ea	21,594	19,776.01 /ea	39,55
		I&C, Flow / Mag Meter / Indicators & Transmitters	2.00 EA	1,194	20,400			1	10,796.99 /EA	21,594	19,776.01 /EA	39,55
		I&C, Level / Switches	2.00 LA	1,134	20,400				10,730.33 7LA	21,004	13,170.01 724	00,00
		Float switch	8.00 ea	1,203	-	-	-	-	150.40 /ea	1,203	275.48 /ea	2,20
		Float switch bracket	2.00 ea	602	300		-	-	450.80 /ea	902	825.70 /ea	1,65
		I&C, Level / Switches	10.00 EA	1,805	300				210.48 /EA	2,105	385.52 /EA	3,85
		I&C, Panels & Stands										
		System panel	2.00 ea	1,203	12,000	-	-	-	6,601.60 /ea	13,203	12,091.65 /ea	24,18
		I&C, Panels & Stands	2.00 EA	1,203	12,000				6,601.60 /EA	13,203	12,091.65 /EA	24,18
		Submersible Pump: 35Hp										
		Functional Testing, Submersible Pumps, 21 - 50 hp	2.00 ea	602	100	-	-	-	350.80 /ea	702	642.54 /ea	1,28
		FURNISH Submersible Pump, 35 hp Set base elbow / pump assembly, 35 hp	2.00 EA 2.00 ea	5,414	63,000 100		-		31,500.00 /EA 2,757.20 /ea	63,000 5,514	57,696.16 /EA 5,050.15 /ea	115,39 10,10
		Stainless steel guide rails, 3",	40.00 lf	1,306	694	-	_	-	50.00 /lf	2.000	91.58 /lf	3.66
		Install upper guide rail bracket	2.00 ea	226	20	-	-	-	122.80 /ea	246	224.93 /ea	45
		Submersible Pump: 35Hp	2.00 EA	7,547	63,914				35,730.80 /EA	71,462	65,445.39 /EA	130,89
		Effluent Pump Station	1.00 EA	51,023	253,114	300,000	105,072		709,209.14 /EA	709,209	1,299,004.45 /EA	1,299,00
		13-10 Buildings Complete	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,00
		13.0 Effluent Pump Station	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,00
33.5		Tank Construction										
33	3.90	Tanks										
		Cast-In-Place Concrete Storage Tank										
		Tanks, Other										
		Storage Tanks construction, below grade, cast-in-place concrete, 700,000 gaillons, incluidng sitework, miscellaneous piping excludiing pump station	700,000.00 gal	740,000	1,850,000				3.70 /gal	2,590,000	6.96 /gal	4,873,40
		Tanks, Other	700,000.00 GAL	740,000	1,850,000				3.70 /GAL	2,590,000	6.96 /GAL	4,873,40
		Cast-In-Place Concrete Storage Tank	700,000.00 GAL	740,000	1,850,000				3.70 /GAL	2,590,000	6.96 /GAL	4,873,40
		33.90 Tanks	700,000.00 GAL	740,000	1,850,000				3.70 /GAL	2,590,000	6.96 /GAL	4,873,40
		33.5 Tank Construction	700,000.00 GAL	740,000	1,850,000				3.70 /GAL	2,590,000	6.96 /GAL	4,873,40
		004 CSO 004 Storage Tank	0.70 MG	791,023	2,103,114	300,000	105,072		4,713,155.91 /MG	3,299,209	8,817,729.34 /MG	6,172,41
005		CSO 005 Storage Tank		101,020	_,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	200,000	100,012		,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,	5,200,200	0,011,120011	*,,
13.0		Effluent Pump Station										
		Buildings Complete										
		Effluent Pump Station										
		Masonry Building										
		Pump Building Masonry 20' x 20'	400.00 sf	28,638	28,000	-	105,072	-	404.27 /sf	161,710	740.48 /sf	296,19
		Masonry Building	400.00 SF	28,638	28,000		105,072		404.27 /SF	161,710	740.48 /SF	296,19
		Mechanical, Other										
		Miscelleneous piping allowance	1.00 ls	-	-	200,000	-	-	200,000.00 /ls	200,000	366,324.80 /ls	366,32
		Mechanical, Other	400.00 SF			200,000			500.00 /SF	200,000	915.81 /SF	366,32
		Mechanical, HVAC										
		Condensing unit, air cooled, compressor, 4 ton, includes standard	1.00 ea	3,095	8,500	-	-	-	11,595.04 /ea	11,595	21,237.75 /ea	21,23
		controls	400.00.05	0.005	0.500				20.00 /05	44.505	50.00 (05	
		Mechanical, HVAC Electrical, Other	400.00 SF	3,095	8,500				28.99 /SF	11,595	53.09 /SF	21,23
		Miscellaneous electrical and I&C	1.00 ls			100.000			100,000.00 /ls	100.000	183,162.40 /ls	183.16
		Electrical, Other	400.00 SF		-	100,000	_		250.00 /SF	100,000	457.91 /SF	183,16
		Electrical Equipment, Generators - >300 to 400 KW	-30.00 01			100,000			200.00 /01	100,000	-707.01 701	100,10
		Emergency Generator 400 KW	1.00 E	7.541	120.000	-			127.540.92 /E	127.541	233.607.00 /E	233.60
		Electrical Equipment, Generators - >300 to 400 KW	1.00 EA	7,541	120,000				127,540.92 /EA	127,541	233,607.00 /EA	233,60
		I&C, Flow / Mag Meter / Indicators & Transmitters		1 .,	,_				,	,311	,	
		Pump Flow Meter including transmitter	2.00 ea	1,194	20,400	-	-	-	10,796.99 /ea	21,594	19,776.03 /ea	39,5
		I&C, Flow / Mag Meter / Indicators & Transmitters	2.00 EA	1,194	20,400				10,796.99 /EA	21,594	19,776.03 /EA	39,55
		I&C, Level / Switches										
		Float switch	8.00 ea	1,203	-	-	-	-	150.40 /ea	1,203	275.48 /ea	2,2
		Float switch bracket	2.00 ea	602	300				450.80 /ea	902	825.70 /ea	1,



Project: GNH WWTP Master Plan

Design Stage: Concept Estimate Class: 4

Tweneboa-Kodua, A/WDC Estimator: Project No.: 478874 Revision / Date: R04/(11-30-2016)

ac Worl		Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		I&C, Level / Switches	10.00 EA	1,805	300				210.48 /EA	2,105	385.52 /EA	3,855
		I&C, Panels & Stands										
		System panel	2.00 ea	1,203	12,000	-	-	-	6,601.60 /ea	13,203	12,091.65 /ea	24,183
		I&C, Panels & Stands	2.00 EA	1,203	12,000				6,601.60 /EA	13,203	12,091.65 /EA	24,183
		Submersible Pump: 35Hp							/			
	_	Functional Testing, Submersible Pumps, 21 - 50 hp FURNISH Submersible Pump, 35 hp	2.00 ea	602	100 63.000	-	-	-	350.80 /ea 31.500.00 /EA	702 63.000	642.54 /ea 57.696.14 /EA	1,285 115.392
		Set base elbow / pump assembly, 35 hp	2.00 EA	5,414	100	-	-		2,757.20 /ea	5,514	5,050.14 /EA	10,100
		Stainless steel guide rails, 3",	40.00 If	1,306	694	-	-	-	50.00 /lf	2,000	91.58 /lf	3,663
		Install upper guide rail bracket	2.00 ea	226	20	-	-	-	122.80 /ea	246	224.91 /ea	450
		Submersible Pump: 35Hp	2.00 EA	7,547	63,914				35,730.80 /EA	71,462	65,445.39 /EA	130,891
		Effluent Pump Station	1.00 EA	51,023	253,114	300,000			709,209.14 /EA	709,209	1,299,004.45 /EA	1,299,004
		13-10 Buildings Complete	400.00 SF 400.00 SF	51,023 51,023	253,114 253,114	300,000	105,072 105,072		1,773.02 /SF	709,209	3,247.51 /SF 3,247.51 /SF	1,299,004
33.5		13.0 Effluent Pump Station Tank Construction	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,004
33.5	33.90	Tanks										
	33.90	Cast-In-Place Concrete Storage Tank										
		Tanks, Other										
		Storage Tanks construction, below grade, cast-in-place concrete,	1,700,000.00 gal	1,797,143	4,492,857		-		3.70 /gal	6,290,000	6.96 /gal	11,835,415
		1,700,000 gaillons, incluiding sitework, miscellaneous piping excludiing	1,700,000.00 gui	1,707,710	1, 102,007				0.70 /gai	0,200,000	0.50 /gai	11,000,110
		pump station										
		Tanks, Other	1,700,000.00 GAL	1,797,143	4,492,857				3.70 /GAL	6,290,000	6.96 /GAL	11,835,415
		Cast-In-Place Concrete Storage Tank	1,700,000.00 GAL	1,797,143	4,492,857				3.70 /GAL	6,290,000	6.96 /GAL	11,835,415
		33.90 Tanks	1,700,000.00 GAL	1,797,143	4,492,857				3.70 /GAL	6,290,000	6.96 /GAL	11,835,415
		33.5 Tank Construction	1,700,000.00 GAL	1,797,143	4,492,857				3.70 /GAL	6,290,000	6.96 /GAL	11,835,415
		005 CSO 005 Storage Tank	1.70 MG	1,848,166	4,745,972	300,000	105,072		4,117,181.85 /MG	6,999,209	7,726,128.97 /MG	13,134,419
)12		CSO 006 StorageTank										
13.0		Effluent Pump Station										
	13-10	Buildings Complete										
		Effluent Pump Station										
		Masonry Building										
		Pump Building Masonry 20' x 20'	400.00 sf	28,638	28,000	-	105,072	-	404.27 /sf	161,710	740.48 /sf	296,191
		Masonry Building	400.00 SF	28,638	28,000		105,072		404.27 /SF	161,710	740.48 /SF	296,191
		Mechanical, Other	1.00 ls			200,000			200,000.00 /ls	200,000	366,324.78 /ls	366,325
		Miscelleneous piping allowance Mechanical, Other	400.00 SF	-	-	200,000		-	500.00 /SF	200,000	915.81 /SF	366,325
		Mechanical, HVAC	400.00 01			200,000			300.00 701	200,000	310.01 701	300,323
		Condensing unit, air cooled, compressor, 4 ton, includes standard	1.00 ea	3.095	8,500	-		-	11,595.04 /ea	11,595	21,237.76 /ea	21,238
		controls		.,					,	,,,,,,	,	
		Mechanical, HVAC	400.00 SF	3,095	8,500				28.99 /SF	11,595	53.09 /SF	21,238
		Electrical, Other										
		Miscellaneous electrical and I&C	1.00 ls	-	-	100,000		-	100,000.00 /ls	100,000	183,162.41 /ls	183,162
		Electrical, Other	400.00 SF			100,000			250.00 /SF	100,000	457.91 /SF	183,162
		Electrical Equipment, Generators - >300 to 400 KW Emergency Generator 400 KW	1.00 E	7,541	120,000				127,540.92 /E	127,541	222 CO7 OO /F	233,607
		Electrical Equipment, Generators - >300 to 400 KW	1.00 EA	7,541	120,000	-	-		127,540.92 /EA	127,541	233,607.00 /E 233,607.00 /EA	233,607
		I&C, Flow / Mag Meter / Indicators & Transmitters	1.00 LA	1,041	120,000				127,040.02 7EA	121,041	200,007.00 72A	200,007
		Pump Flow Meter including transmitter	2.00 ea	1,194	20,400	-			10,796.99 /ea	21,594	19,776.03 /ea	39,552
		I&C, Flow / Mag Meter / Indicators & Transmitters	2.00 EA	1,194	20,400				10,796.99 /EA	21,594	19,776.03 /EA	39,552
		I&C, Level / Switches										
		Float switch	8.00 ea	1,203	-	-	-	-	150.40 /ea	1,203	275.48 /ea	2,204
		Float switch bracket	2.00 ea	602	300	-	-	-	450.80 /ea	902	825.70 /ea	1,651
		I&C, Level / Switches	10.00 EA	1,805	300		-		210.48 /EA	2,105	385.52 /EA	3,855
		I&C, Panels & Stands System panel	2.00 ea	1,203	12,000		-		6,601.60 /ea	13,203	12,091.66 /ea	24,183
		I&C. Panels & Stands	2.00 ea	1,203	12,000	-	-	-	6,601.60 /EA	13,203	12,091.66 /ea	24,183 24.183
	_	Submersible Pump: 35Hp	2.00 EA	1,203	12,000				0,001.00 /EA	13,203	12,031.00 /EA	24,103
	_	Functional Testing, Submersible Pumps, 21 - 50 hp	2.00 ea	602	100		-		350.80 /ea	702	642.53 /ea	1,285
		FURNISH Submersible Pump, 35 hp	2.00 EA	- 002	63,000		-		31,500.00 /EA	63,000	57,696.15 /EA	115,392
		Set base elbow / pump assembly, 35 hp	2.00 ea	5,414	100	-	-	-	2,757.20 /ea	5,514	5,050.15 /ea	10,100
		Stainless steel guide rails, 3",	40.00 lf	1,306	694	-	-	-	50.00 /lf	2,000	91.58 /lf	3,663
		Install upper guide rail bracket Submersible Pump: 35Hp	2.00 ea 2.00 EA	226 7.547	63.914	-	-	-	122.80 /ea 35.730.80 /EA	71.462	224.94 /ea 65.445.39 /EA	450 130.891
	+		1.00 EA	51,023	253,114	300,000	105,072		35,/30.80 /EA 709,209.14 /EA	709,209	1,299,004.47 /EA	
	+	Effluent Pump Station 13-10 Buildings Complete	1.00 EA 400.00 SF	51,023	253,114	300,000				709,209		1,299,004 1,299,004
1	1	1 13-10 buildings Complete	400.00 SF	51.023	253.114	300.000	105.072	1	1,773.02 /SF	/09.209	3,247.51 /SF	1.299



Project: GNH WWTP Master Plan

Tweneboa-Kodua, A/WDC Estimator: Project No.: 478874 Revision / Date: R04/(11-30-2016)

Design Stage: Concept Estimate Class: 4

Fac Wor		Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		13.0 Effluent Pump Station	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,004
33.5		Tank Construction										
	33.90	Tanks										
		Cast-In-Place Concrete Storage Tank										
		Tanks, Other										
		Storage Tanks construction, below grade, cast-in-place concrete,	1,390,000.00 gal	1,469,429	3,673,571				3.70 /gal	5,143,000	6.96 /gal	9,677,192
		3,200,000 gaillons, incluiding sitework, miscellaneous piping excludiing pump station							, and the second second second second second second second second second second second second second second se			
		Tanks, Other	1,390,000.00 GAL	1,469,429	3,673,571				3.70 /GAL	5,143,000	6.96 /GAL	9,677,192
		Cast-In-Place Concrete Storage Tank	1,390,000.00 GAL	1,469,429	3,673,571				3.70 /GAL	5,143,000	6.96 /GAL	9,677,192
		33.90 Tanks	1,390,000.00 GAL	1,469,429	3,673,571				3.70 /GAL	5,143,000	6.96 /GAL	9,677,192
		33.5 Tank Construction	1,390,000.00 GAL	1,469,429	3,673,571				3.70 /GAL	5,143,000	6.96 /GAL	9,677,192
		012 CSO 006 StorageTank	1.39 MG	1,520,452	3,926,686	300,000	105,072		4,210,222.40 /MG	5,852,209	7,896,544.27 /MG	10,976,197
014			1.00 1110	1,020,402	0,020,000	000,000	100,012		4,210,222.40 /1110	0,002,200	7,000,044.27 71110	10,010,101
		CSO 011 StorageTank										
13.0		Effluent Pump Station										
	13-10	Buildings Complete										
		Effluent Pump Station										
		Masonry Building										
		Pump Building Masonry 20' x 20'	400.00 sf	28,638	28,000	-	105,072	-	404.27 /sf	161,710	740.48 /sf	296,191
		Masonry Building	400.00 SF	28,638	28,000		105,072		404.27 /SF	161,710	740.48 /SF	296,191
		Mechanical, Other										
		Miscelleneous piping allowance	1.00 ls	-	-	200,000	-	-	200,000.00 /ls	200,000	366,324.79 /ls	366,325
		Mechanical, Other	400.00 SF			200,000			500.00 /SF	200,000	915.81 /SF	366,325
		Mechanical, HVAC										
		Condensing unit, air cooled, compressor, 4 ton, includes standard controls	1.00 ea	3,095	8,500	-	-	-	11,595.04 /ea	11,595	21,237.76 /ea	21,238
		Mechanical, HVAC	400.00 SF	3,095	8,500				28.99 /SF	11,595	53.09 /SF	21,238
		Electrical, Other										
		Miscellaneous electrical and I&C	1.00 ls	-	-	100,000	-	-	100,000.00 /ls	100,000	183,162.39 /ls	183,162
		Electrical, Other	400.00 SF			100,000			250.00 /SF	100,000	457.91 /SF	183,162
		Electrical Equipment, Generators - >300 to 400 KW										
		Emergency Generator 400 KW	1.00 E	7,541	120,000		-	-	127,540.92 /E	127,541	233,607.01 /E	233,607
		Electrical Equipment, Generators - >300 to 400 KW	1.00 EA	7,541	120,000				127,540.92 /EA	127,541	233,607.01 /EA	233,607
		I&C, Flow / Mag Meter / Indicators & Transmitters										
		Pump Flow Meter including transmitter	2.00 ea	1,194	20,400	-	-	-	10,796.99 /ea	21,594	19,776.03 /ea	39,552
		I&C, Flow / Mag Meter / Indicators & Transmitters	2.00 EA	1,194	20,400				10,796.99 /EA	21,594	19,776.03 /EA	39,552
		I&C, Level / Switches										
		Float switch	8.00 ea	1,203	-	-	-	-	150.40 /ea	1,203	275.48 /ea	2,204
		Float switch bracket	2.00 ea	602 1.805	300 300		-	-	450.80 /ea	902	825.69 /ea 385.52 /EA	1,651 3.855
		I&C, Level / Switches	10.00 EA	1,805	300				210.48 /EA	2,105	385.52 /EA	3,855
		I&C, Panels & Stands										
		System panel	2.00 ea 2.00 EA	1,203 1,203	12,000		-	-	6,601.60 /ea 6,601.60 /EA	13,203 13,203	12,091.66 /ea 12,091.66 /EA	24,183
		I&C, Panels & Stands	2.00 EA	1,203	12,000				6,001.00 /EA	13,203	12,091.66 /EA	24,183
		Submersible Pump: 35Hp	2.00 ea	000	100				350.80 /ea	702	040.50 /:-	1.285
		Functional Testing, Submersible Pumps, 21 - 50 hp FURNISH Submersible Pump, 35 hp	2.00 ea 2.00 EA	602	63,000		 	 	350.80 /ea 31,500.00 /EA	63,000	642.53 /ea 57,696.15 /EA	1,285
		Set base elbow / pump assembly, 35 hp	2.00 EA	5,414	100		-	-	2,757.20 /ea	5,514		10,100
		Stainless steel guide rails, 3",	40.00 lf	1,306	694		-	-	50.00 /lf	2,000	91.58 /lf	3,663
		Install upper guide rail bracket	2.00 ea	226	20	-	-	-	122.80 /ea	246	224.92 /ea	450
		Submersible Pump: 35Hp	2.00 EA	7,547	63,914				35,730.80 /EA	71,462	65,445.38 /EA	130,891
		Effluent Pump Station	1.00 EA	51,023	253,114	300,000	105,072		709,209.14 /EA	709,209	1,299,004.46 /EA	1,299,004
		13-10 Buildings Complete	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,004
		13.0 Effluent Pump Station	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,004
33.5		Tank Construction		- /					, , , , , , , , , , , , , , , , , , , ,			,,
	33.90	Tanks										
		Cast-In-Place Concrete Storage Tank				İ	1	1				
		Tanks. Other										
		Storage Tanks construction, below grade, cast-in-place concrete, 3,200,000 gaillons, incluidng sitework, miscellaneous piping excludiing	1,330,000.00 gal	1,406,000	3,515,000		-		3.70 /gal	4,921,000	6.96 /gal	9,259,472
		pump station										
	-	Tanks, Other	1,330,000.00 GAL	1,406,000	3,515,000				3.70 /GAL	4,921,000	6.96 /GAL	9,259,472
		Cast-In-Place Concrete Storage Tank	1,330,000.00 GAL	1,406,000	3,515,000				3.70 /GAL	4,921,000	6.96 /GAL	9,259,472
		33.90 Tanks	1,330,000.00 GAL	1,406,000	3,515,000				3.70 /GAL	4,921,000	6.96 /GAL	9,259,472
	1	33.5 Tank Construction	1,330,000.00 GAL	1,406,000	3,515,000	I	1	1	3.70 /GAL	4,921,000	6.96 /GAL	9,259,472



Project: GNH WWTP Master Plan

Project No.: 478874

Design Stage: Concept

Estimator: Tweneboa-Kodua, A/WDC

Revision / Date: R04/(11-30-2016)

Estimate Class: 4

	ork Trac		Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		014 CSO 011 StorageTank	1.33 MG	1,457,023	3,768,114	300,000	105,072		4,233,239.96 /MG	5,630,209	7,938,703.79 /MG	10,558,476
016		CSO 015 StorageTank				-						
13	.0	Effluent Pump Station										
	_	Buildings Complete										
	- 10 11	Effluent Pump Station										
		Masonry Building										
		Pump Building Masonry 20' x 20'	400.00 sf	28,638	28,000	-	105,072	-	404.27 /sf	161,710	740.48 /sf	296,19
		Masonry Building	400.00 SF	28,638	28,000		105,072		404.27 /SF	161,710	740.48 /SF	296,191
		Mechanical, Other			·							
		Miscelleneous piping allowance	1.00 ls	-	-	200,000	-	-	200,000.00 /ls	200,000	366,324.79 /ls	366,32
		Mechanical, Other	400.00 SF			200,000			500.00 /SF	200,000	915.81 /SF	366,325
		Mechanical, HVAC										
		Condensing unit, air cooled, compressor, 4 ton, includes standard controls	1.00 ea	3,095	8,500	-		-	11,595.04 /ea	11,595	21,237.75 /ea	21,23
		Mechanical, HVAC	400.00 SF	3,095	8,500				28.99 /SF	11,595	53.09 /SF	21,23
		Electrical, Other										
		Miscellaneous electrical and I&C	1.00 ls	-	-	100,000	-	-	100,000.00 /ls	100,000	183,162.40 /ls	183,16
		Electrical, Other	400.00 SF			100,000			250.00 /SF	100,000	457.91 /SF	183,162
		Electrical Equipment, Generators - >300 to 400 KW										
		Emergency Generator 400 KW	1.00 E	7,541	120,000	-	-	-	127,540.92 /E	127,541	233,607.00 /E	233,60
		Electrical Equipment, Generators - >300 to 400 KW	1.00 EA	7,541	120,000				127,540.92 /EA	127,541	233,607.00 /EA	233,60
		I&C, Flow / Mag Meter / Indicators & Transmitters										
		Pump Flow Meter including transmitter	2.00 ea	1,194	20,400		-	-	10,796.99 /ea	21,594	19,776.03 /ea	39,55
		I&C, Flow / Mag Meter / Indicators & Transmitters	2.00 EA	1,194	20,400				10,796.99 /EA	21,594	19,776.03 /EA	39,55
		I&C, Level / Switches										
		Float switch	8.00 ea	1,203	-	-	-	-	150.40 /ea	1,203	275.48 /ea	2,20
		Float switch bracket	2.00 ea	602	300	-	-	-	450.80 /ea	902	825.70 /ea	1,65
_		I&C, Level / Switches I&C, Panels & Stands	10.00 EA	1,805	300				210.48 /EA	2,105	385.52 /EA	3,855
		System panel	2.00 ea	1,203	12.000				6,601.60 /ea	13,203	12,091.65 /ea	24,183
		I&C, Panels & Stands	2.00 ea	1,203	12,000		-	-	6,601.60 /EA	13,203	12,091.65 /EA	24,18
		Submersible Pump: 35Hp	2.00 EA	1,203	12,000				0,001.00 /LA	13,203	12,091.03 /LA	24,10
		Functional Testing, Submersible Pumps, 21 - 50 hp	2.00 ea	602	100	_	_	_	350.80 /ea	702	642.53 /ea	1,28
		FURNISH Submersible Pump, 35 hp	2.00 EA	- 002	63,000	-		-	31,500.00 /EA	63,000	57,696.15 /EA	115,39
		Set base elbow / pump assembly, 35 hp	2.00 ea	5,414	100	-	-	-	2,757.20 /ea	5,514	5,050.15 /ea	10,10
		Stainless steel guide rails, 3",	40.00 lf	1,306	694	-	-	-	50.00 /lf	2,000	91.58 /lf	3,66
		Install upper guide rail bracket	2.00 ea	226	20	-	-	-	122.80 /ea	246	224.94 /ea	45
		Submersible Pump: 35Hp	2.00 EA	7,547	63,914				35,730.80 /EA	71,462	65,445.40 /EA	130,89
		Effluent Pump Station	1.00 EA	51,023	253,114	300,000	105,072		709,209.14 /EA	709,209	1,299,004.47 /EA	1,299,00
		13-10 Buildings Complete	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,004
		13.0 Effluent Pump Station	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,004
33	-	Tank Construction										
	33.90											
		Cast-In-Place Concrete Storage Tank										
		Tanks, Other										
		Storage Tanks construction, below grade, cast-in-place concrete, 390,000 gaillons, incluidng sitework, miscellaneous piping excluding	390,000.00 gal	288,600	288,600	288,600	288,600	288,600	3.70 /gal	1,443,000	6.96 /gal	2,715,183
		pump station Tanks, Other	390,000.00 GAL	288,600	288,600	288,600	288,600	288,600	3.70 /GAL	1,443,000	6.96 /GAL	2,715,18
		Cast-In-Place Concrete Storage Tank	390,000.00 GAL	288,600	288.600	288.600	288,600	288.600	3.70 /GAL	1,443,000	6.96 /GAL	2,715,183
-		33.90 Tanks	390,000.00 GAL	288,600	288,600	288,600	288,600	288,600	3.70 /GAL	1,443,000	6.96 /GAL	2,715,183
		33.5 Tank Construction	390,000.00 GAL	288,600	288,600	288,600	288,600	288,600	3.70 /GAL	1,443,000	6.96 /GAL	2,715,183
		016 CSO 015 StorageTank	0.39 MG	339.623	541.714	588.600	393.672	288.600		2.152.209	10,292,789.33 /MG	4.014.18
018		CSO 016 StorageTank		· 1	,	,	,	·	<u> </u>	, ,	, ,	
13	0	Effluent Pump Station										
- 10	13-10											
	10-10	Effluent Pump Station										
		Masonry Building										
		Pump Building Masonry 20' x 20'	400.00 sf	28,638	28,000	-	105,072	-	404.27 /sf	161,710	740.48 /sf	296,19
			400.00 SF	28,638	28,000		105,072		404.27 /SF	161,710	740.48 /SF	296,19
		Masonry Building	400.00 SF									
			400.00 SF	20,030	20,000		100,072		404.27 701	101,710	740.40 /3F	200,10
		Masonry Building Mechanical, Other Miscelleneous piping allowance	1.00 ls	-	-	200,000	-	-	200,000.00 /ls	200,000	366,324.80 /ls	
		Mechanical, Other		-	-	200,000 200,000	-	-				366,329 366,329



Project: GNH WWTP Master Plan

Tweneboa-Kodua, A/WDC Estimator: Project No.: 478874 Revision / Date: R04/(11-30-2016)

Design Stage:	Concept	Estimate Class

Work Pkg	Trade Pkg	Description	Takeoff Quantity	Labor Amount	Material Amount	Sub Amount	Equip Amount	Other Amount	Direct Cost/Unit	Direct Amount	Grand Total Unit Price	Grand Total w/Markups
		Mechanical, HVAC										
		Condensing unit, air cooled, compressor, 4 ton, includes standard	1.00 ea	3,095	8,500	-	-	-	11,595.04 /ea	11,595	21,237.74 /ea	21,23
		controls										
		Mechanical, HVAC	400.00 SF	3,095	8,500				28.99 /SF	11,595	53.09 /SF	21,23
		Electrical, Other										
		Miscellaneous electrical and I&C	1.00 ls	-	-	100,000	-	-	100,000.00 /ls	100,000	183,162.41 /ls	183,10
		Electrical, Other	400.00 SF			100,000			250.00 /SF	100,000	457.91 /SF	183,10
		Electrical Equipment, Generators - >300 to 400 KW										
		Emergency Generator 400 KW	1.00 E	7,541	120,000	-	-	-	127,540.92 /E	127,541	233,607.00 /E	233,60
		Electrical Equipment, Generators - >300 to 400 KW	1.00 EA	7,541	120,000				127,540.92 /EA	127,541	233,607.00 /EA	233,60
		I&C, Flow / Mag Meter / Indicators & Transmitters										
		Pump Flow Meter including transmitter	2.00 ea	1,194	20,400		-	-	10,796.99 /ea	21,594	19,776.02 /ea	39,55
		I&C, Flow / Mag Meter / Indicators & Transmitters	2.00 EA	1,194	20,400				10,796.99 /EA	21,594	19,776.02 /EA	39,55
		I&C, Level / Switches										
		Float switch	8.00 ea	1,203	-			-	150.40 /ea	1,203	275.48 /ea	2,2
		Float switch bracket	2.00 ea	602	300		-	-	450.80 /ea	902	825.70 /ea	1,6
		I&C, Level / Switches	10.00 EA	1,805	300				210.48 /EA	2,105	385.52 /EA	3,8
		I&C, Panels & Stands										
		System panel	2.00 ea	1,203	12,000		-	-	6,601.60 /ea	13,203	12,091.65 /ea	24,18
		I&C. Panels & Stands	2.00 EA	1,203	12.000				6.601.60 /EA	13,203	12.091.65 /EA	24,18
		Submersible Pump: 35Hp			,,,,,,				.,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,,		, , , , , , , , , , , , , , , , , , , ,	
		Functional Testing, Submersible Pumps, 21 - 50 hp	2.00 ea	602	100	-			350.80 /ea	702	642.54 /ea	1.28
		FURNISH Submersible Pump, 35 hp	2.00 EA	-	63.000			-	31.500.00 /EA	63.000	57.696.16 /EA	115.3
		Set base elbow / pump assembly, 35 hp	2.00 ea	5,414	100	-	-	-	2,757.20 /ea	5,514	5,050.15 /ea	10,10
		Stainless steel guide rails, 3",	40.00 lf	1,306	694		-	-	50.00 /lf	2,000	91.58 /lf	3,6
		Install upper guide rail bracket	2.00 ea	226	20	-	-	-	122.80 /ea	246	224.93 /ea	45
		Submersible Pump: 35Hp	2.00 EA	7,547	63,914				35,730.80 /EA	71,462	65,445.40 /EA	130,89
		Effluent Pump Station	1.00 EA	51,023	253,114	300,000	105,072		709,209.14 /EA	709,209	1,299,004.48 /EA	1,299,00
		13-10 Buildings Complete	400.00 SF	51,023	253,114	300,000	105,072		1,773.02 /SF	709,209	3,247.51 /SF	1,299,00
		13.0 Effluent Pump Station	400.00 SF	51.023	253,114	300.000	105.072		1.773.02 /SF	709,209	3.247.51 /SF	1,299.00
33.5		Tank Construction							,			,,
	33.90	Tanks										
	00.00	Cast-In-Place Concrete Storage Tank										
		Tanks. Other										
+		Storage Tanks construction, below grade, cast-in-place concrete,	240,000.00 gal	253.714	634,286				3.70 /gal	888.000	6.96 /gal	1.670.88
		240,000 gaillons, incluidng sitework, miscellaneous piping excluding pump station	240,000.00 gai	253,714	634,266		-		3.70 /gai	000,000	6.96 /gai	1,670,80
		Tanks, Other	240.000.00 GAL	253.714	634.286				3.70 /GAL	888.000	6.96 /GAL	1.670.88
		Cast-In-Place Concrete Storage Tank	240.000.00 GAL	253,714	634,286				3.70 /GAL	888.000	6.96 /GAL	1,670,88
		33.90 Tanks	240,000.00 GAL	253,714	634,286				3.70 /GAL	888.000	6.96 /GAL	1,670,88
+		33.5 Tank Construction	240,000.00 GAL	253,714	634,286				3.70 /GAL	888.000	6.96 /GAL	1,670,88
-			-,									,. ,,.,
		018 CSO 016 StorageTank	0.24 MG	304,737	887,400	300,000	105,072		6,655,038.08 /MG	1,597,209	12,374,527.29 /MG	2,969,88



Project: GNH WWTP Master Plan

Project No.: 478874 Design Stage: Concept Estimator: Tweneboa-Kodua, A/WDC

Revision / Date: R04/(11-30-2016)

Estimate Class: 4

Estimate Totals

Construction Costs	Amount	Totals	Rate	% of Tota
Labor	6,417,762			12.88%
Material	16,490,401			33.10%
Subcontract	2,388,600			4.79%
Equipment	1,024,101			2.06%
Other _	288,600			0.58%
Subtotal Raw Costs	26,609,464	26,609,464		53.41
Material Sales & Use Tax - %				
Construction Equip Tax - %				
Total Taxes		26,609,464		
Tank Construction I,OH&P _	4,329,000		20.000 %	8.69%
Subtotal Subcontractor I,OH&P	5,073,670	31,683,134		10.18
Subtotal Contingency		31,683,134		
Total Cost To Prime Contractor		31,683,134		
General Conditions	3,168,313		10.000 %	6.36%
Mobilization/Demobilization	950,494		3.000 %	
Subtotal Indirect Costs	4,118,807	35,801,941		8.27
Prime Contractor Home OfficeOH	2,864,155		8.000 %	5.75%
Prime Contractor Profit	3,580,194		10.000 %	7.19%
Blder's Risk & Gen Liab Ins -%	498,208		1.000 %	1.00%
Payment & Performance Bonds	577,921		1.160 %	1.16%
Subtotal OH&P	7,520,478	43,322,419		15.10
Design Contingency	6,498,363		15.000 %	13.04%
				13.04
Subtotal Contingency	6,498,363	49,820,782		
Subtotal Contingency	6,498,363	49,820,782		
· · · · -	6,498,363	49,820,782 49,820,782		