


# GREATER NEW HAVEN WATER POLLUTION CONTROL AUTHORITY CONSTRUCTION DETAILS



## NOTES:

1. CLEAN-OUT PIPE SIZE SHALL MATCH EXISTING LATERAL.
2. NEW SEWER LATERALS AND CLEAN-OUTS SHALL BE 6-INCH OR AS APPROVED BY THE GNHWPCA.
3. ENTIRE WYE SECTION TO BE ENCASED IN CONTROLLED LOW STRENGTH MATERIAL OR GRANULAR FILL, AS DIRECTED BY THE GNHWPCA.

## STANDARD CLEAN-OUT NTS

REVISIONS	
NO.	DATE
1	JUNE 2008