

Criscuolo Engineering, LLC

Consulting Engineers
Civil Engineers
Land Surveyors

Robert A. Criscuolo, P.E., L.S.
Paul L. Nott, L.S.
James M. Pretti, Jr., P.E.
Linda C. Dow, P.E.

Records of:

Associated Surveys
Charles H. Miller
George A. Firth

MEMORANDUM

To: Greater New Haven Water Pollution Control Authority
From: James M. Pretti, Jr., P.E.
Date: 3/28/2016
Re: Arch Street Pump Station Rehab. Project – Addendum #2
CE File No: 2014.017
cc: file

In regards to questions set forth in email from The Associated Construction Company dated March 24, 2016, we have the following responses:

Div. 2 – Site work/Demolition

1. DI materials are not required to be domestic but are preferred.
2. The pumping plan shall be prepared by a qualified professional.
3. At this point it should be assumed that delivery of items to be kept by the GNHWPCA will be to the Treatment Plant at 245 East Shore Parkway, New Haven, CT
4. The specification 02225.1.01.B lists the items to be kept by the GNHWPCA

Div. 5 – Steel

1. The dehumidifier shelf will be constructed to support the size and weight of the final selection of the dehumidifier. Coordination will be required.

Div. 15 – Plumbing

1. Requirements for the water heater were stated in Addendum #1
2. The ½” holes in the stilling well are only required on the bottom 8’ of length.
3. A sump pump “or equal” to the Water Ace is required and will be reviewed during the submittal process.
4. The EZ vent caps are no longer required. All tank vents will be connected by PVC to the passive canister.
5. The type of plumbing fixtures were indicated in Addendum #1
6. Consult the current plumbing code for required mounting heights and separating distances of plumbing fixtures.
7. The unit heater will be a 5KW ceiling mounted electric heater, similar to the existing one on the control room level.

Div. 16 – Electrical

1. The existing SCADA Panel will be removed from the existing cabinet and re-installed into the new control cabinet. The existing SCADA cabinet will then be delivered to the GNHWPCA.
2. See note #7 above regarding the heater.
3. The interior lighting to be used shall be Lithonia VAP LED or approved equal.
4. The nomenclature for the Motor Room Level heater that reads: "HVAC PNL-PP8" means that it is part of the heating system and is powered at PP8, which is Power Panel breaker #8.

Question stated in an email from Flow Tech, Inc dated: March 22, 2016:

The existing louvered vents (2) to be removed and replace are approximately 30"x30". Contractor shall verify dimensions prior to ordering units.

Questions stated in an email from Delray Contracting, Inc. dated March 23, 2016:

1. The depth of the window well above the discharge piping is approximately 32" from existing grade.
2. The GNHWPCA will only pay for materials stored on site either within the station or within a locked storage container located within the fenced in Arch Street secured property. The contractor is responsible to supply such a storage container if so desired. The GNHWPCA is not responsible for lost, damaged or stolen stored equipment or materials.
3. There has not been an extensive hazardous materials survey performed. There is an allowance for the testing and removal of asbestos. Other pump stations similar to Arch Street have had small amounts of material that needed to be removed. For example: original wiring sheathings and caulking between the concrete sidewalk and building.
4. The removal of hazardous material will be paid under the allowance stated above.
5. The depth of the 4" PVC vent piping varies as the pipe should pitch away from the passive canister. The approximate depth is 12-24" and the pipe shall be bedded in ¾" crushed stone.
6. In Section 102-16-#8 – The paragraph the begins: "The maintenance and protection of vehicular..." shall be deleted.
7. The previously asked questions are attached herein.
8. Do not count on surcharging the incoming effluent pipes.
9. The Tideflex check valves should be a 12" dia. Tideflex Checkmate style. Once the wetwell is cleaned the contractor shall verify the actual opening dimension and coordinate proper size valve.

Other items to be noted:

Drawing #A101 – All concrete sidewalks are to be replaced with the addition of some other small areas. See attached sketch.

Specification Corrections:

Section #11300-4.02.K – The space for the existing SCADA equipment shall be 24"x24"

Section #11300-5.03- 3" PVC should read 6" D.I. Pipe

Section #11300-5.07 – The existing pressure transducer junction box shall be relocated outside.

Section #13420-3.05.A – The sentence that reads: "The services under the maintenance contract will take place at the plant site." should read: "The services under the maintenance contract will take place at the Arch Street Pump Station.



Section #16490-2.02.D – The space for the existing SCADA equipment shall be 24"x24".

The existing Antenna Cable will not reach the new location, therefore the existing cable will need to be removed and replaced with a single run, no splices are allowed.


GENERAL NOTES:

1. LOT AREA = 7,986 SF OR 0.183 ACRES.
2. NORTH ARROW AND BEARINGS ARE BASED ON REFERENCE MAP 3A.
3. REFERENCE IS HEREBY MADE TO THE FOLLOWING MAPS:
 - A. "PROPERTY SURVEY EXISTING CONDITIONS, PROPERTY LOCATED AT #151 ARCH STREET, HAMDEN, CONNECTICUT", SCALE 1"=10', DATED 8/19/2013 AND PREPARED BY CRISCUOLO ENGINEERING, LLC.
4. PROPERTY LINE AND PLANNING INFORMATION DEPICTED HEREON WAS REPRODUCED FROM THE REFERENCE MAP NOTED. ALL EXISTING CONDITIONS AND FEATURES ARE NOT NECESSARILY INDICATED ON THE DRAWING.
5. ALL ELEVATIONS ARE REFERENCED TO THE NATIONAL GEODETIC VERTICAL DATUM OF 1988.
6. UTILITY LOCATIONS DEPICTED ON THE DRAWINGS HAVE BEEN COMPILED FROM UTILITY COMPANY MAPS AND FIELD LOCATIONS OF ABOVE-GROUND FACILITIES AND UTILITY COMPANY MARKOUTS. ALL LOCATIONS SHOWN SHOULD BE CONSIDERED APPROXIMATE ONLY AND ALL UTILITIES MAY NOT BE SHOWN. THE CONTRACTOR SHALL BE RESPONSIBLE FOR LOCATING ALL UTILITIES AND FOR THE MAINTENANCE AND PROTECTION THEREOF. THE CONTRACTOR SHALL CONTACT "CALL BEFORE YOU DIG" (1-800-922-4400) PRIOR TO THE START OF WORK TO ESTABLISH AND MARK MARKERS ON THE GROUND THE LOCATION OF ALL UNDERGROUND UTILITIES. THE CONTRACTOR SHALL NOTIFY THE ENGINEER IN THE EVENT A UTILITY IS LOCATED OR IS UNCOVERED DURING THE PROGRESS OF THE WORK THAT WAS NOT INDICATED ON OR IS NOT IN ACCORDANCE WITH THE DRAWINGS.
7. THE CONTRACTOR SHALL ADOPT TO THE REGULATIONS AND STANDARDS OF THE TOWN OF HAMDEN, ALL APPLICABLE STATE AND FEDERAL REGULATORY AUTHORITIES, THE PROVISIONS OF THE CONTRACT DOCUMENTS, AND ANY APPROVALS AND/OR PERMITS ATTACHED THERETO.


8. UNLESS OTHERWISE NOTED, ALL WORK AND MATERIALS SHALL CONFORM TO THE "STATE OF CONNECTICUT DEPARTMENT OF TRANSPORTATION STANDARD SPECIFICATIONS FOR ROADS, BRIDGES AND INCIDENTAL CONSTRUCTION FORM B-107, DATED 2004, AND ALL SUPPLEMENTS THERETO.
9. THE INSTALLATION OF ALL UTILITIES SHALL BE IN CONFORMANCE WITH THE REQUIREMENTS OF THE RESPECTIVE UTILITY COMPANIES. THE CONTRACTOR SHALL COORDINATE ALL WORK WITHIN THE ARCH STREET OR FAIRVIEW AVENUE RIGHTS OF WAY WITH THE RESPECTIVE UTILITY COMPANIES.
10. PRIOR TO THE START OF WORK, THE CONTRACTOR SHALL THOROUGHLY REVIEW THE CONTRACT DOCUMENTS AND THE SITE OF THE WORK AND FAMILIARIZE HIMSELF WITH ALL EXISTING CONDITIONS AND FEATURES. THE CONTRACTOR SHALL VERIFY ALL ELEVATIONS PRIOR TO THE START OF WORK. THE CONTRACTOR SHALL NOTIFY THE ENGINEER OF ANY DISCREPANCIES BETWEEN THE DRAWINGS AND EXISTING CONDITIONS AND FEATURES IN THE FIELD PRIOR TO THE START OF WORK.
11. THE CONTRACTOR SHALL CONFINES HIS OPERATIONS AND ACTIVITIES WITHIN THE PROJECT SITE PROPERTY LINES AND/OR THE CONTRACT LIMITS SHOWN ON THE DRAWINGS.
12. EXISTING CONDITIONS AND FEATURES SHALL BE MAINTAINED WHERE NEW CONSTRUCTION IS NOT SHOWN ON THE DRAWINGS UNLESS OTHERWISE DIRECTED BY THE ENGINEER. EXISTING CONDITIONS AND FEATURES NOT SHOWN AS A RESULT OF THE CONTRACTOR'S OPERATIONS OR ACTIVITIES WHERE NEW CONSTRUCTION IS NOT SHOWN SHALL BE RESTORED TO ORIGINAL CONDITION UNLESS OTHERWISE SPECIFIED OR DIRECTED BY THE ENGINEER.
13. SHOULD DETERMINING OF EXCAVATIONS, STRUCTURES, PIPELINES, ETC. BE REQUIRED, THE DISCHARGE FROM DRAINAGE OPERATIONS SHALL BE DIRECTED TO A SETTLING AND/OR FILTER FACILITY. THE CONTRACTOR SHALL MAINTAIN ACCESS TO ALL ADJACENT PROPERTIES AND A LOCATION APPROVED BY THE ENGINEER.
14. JOB SITE SAFETY IS SOLELY THE RESPONSIBILITY OF THE CONTRACTOR. REVIEW OF THE CONSTRUCTION BY THE ENGINEER IS FOR CONFORMANCE WITH THE DESIGN ASPECTS ONLY. NOT TO REVIEW THE CONTRACTOR'S PROVISIONS FOR JOB SITE SAFETY. LACK OF COMMENT ON THE PART OF THE ENGINEER WITH REGARD TO THE JOB SITE IS NOT TO BE INTERPRETED AS APPROVAL OF JOB SITE SAFETY ASPECTS.



LEGEND	
EXISTING	PROPOSED
Street Line	Street Line
Property Line	Property Line
Line	Line
Easement Line	Easement Line
Curb	Curb
Wood Fence	Wood Fence
Wire Fence	Wire Fence
Stone Wall	Stone Wall
Elevation Contour	Elevation Contour
Spot Elevation	Spot Elevation
Watercourse Line	Watercourse Line
Wooded Boundary	Wooded Boundary
Vegetation Line	Vegetation Line
Deciduous Tree	Deciduous Tree
Coniferous Tree	Coniferous Tree
Catch Basin	Catch Basin
Manhole	Manhole
Utility Pole (With Guy)	Utility Pole (With Guy)
Water Valve/Service	Water Valve/Service
Over Head Wire	Over Head Wire
Water Main/Service	Water Main/Service
Sanitary Lateral	Sanitary Lateral
Sanitary Sewer	Sanitary Sewer
Gas Line	Gas Line
Road Drain	Road Drain
Footing Drain	Footing Drain
Stormwater Pipe <12" Diameter	Stormwater Pipe <12" Diameter
Stormwater Pipe >12" Diameter	Stormwater Pipe >12" Diameter
Grade to Drain	Grade to Drain




CRISCUOLO ENGINEERING LLC CONSULTING ENGINEERS LAND SURVEYORS 401 East Main Street Building 1, Suite 2 Hamden, CT 06530 Tel. (203) 284-0000 Fax (203) 284-0001		JOB TITLE: _____ PREPARED BY: _____ SCALE: 1"=10' DRAWN: JWP CHECKED: RAC DATE: 2/16/16 JOB: 2014-0176	PROPERTY LOCATED AT #151 ARCH STREET HAMDEN, CONNECTICUT GREATER NEW HAVEN WATER POLLUTION CONTROL AUTHORITY EXISTING SITE PLAN w/ PROPOSED IMPROVEMENTS & DETAILS A101 2020 JUL 2014-0176
--	--	--	---



PLAN

TROWELED JOINT DETAIL




SECTION A-A

TROWELED JOINT, TYP.

6 x 6 W1.4 x W1.4
WELDED WIRE FABRIC

1/2" PREFORMED
EXPANSION JOINT FILLER

SET TOP OF EXPANSION JOINT
JOINT FILLER 1/4" BELOW
WALK SURFACE, TYP.



SECTION B-B

CRISCUOLO
ENGINEERING LLC

CONSULTING
ENGINEERS

LAND SURVEYORS

420 East Main Street
Building 1 - Suite 9
Branford, CT 06405
TEL: 203/481-0807
FAX: 203/488-5729

**ARCH STREET PUMP STATION REHABILITATION
#151 ARCH STREET
HAMDEN, CONNECTICUT**

DRAWING TITLE:

**CONCRETE SIDEWALK
DETAIL**

SCALE: NONE

DRAWING INFO.

DATE:

3/28/16

DETAIL NUMBER

FIG. 1

FILE NAME

2014-017POB



THE ASSOCIATED CONSTRUCTION COMPANY
GENERAL CONTRACTORS / CONSTRUCTION MANAGERS
1010 WETHERSFIELD AVENUE, SUITE 304 / HARTFORD, CT 06114

Request for Information #2

Date: March 24, 2016

To: Tom Sgroi
Company: GNHWA
Phone#: 203-466-5280
Fax#: 203-466-5286
From: Michael Kirdzik, Estimator

Project: Arch Street Pump Station Rehabilitation Project
151 Arch Street
Hamden, CT

of pages: 2 including cover page

RE: Request for Information

Dear Mr Sgroi,

Please respond to the following questions as soon as possible:

Div. 2 – Site work/Demolition:

1. Specifications do not mention if DI material needs to be domestic or if an AIS job. Please advise.
2. Is a PE stamp required for the by-pass pumping system?
3. Specification section 02225 Selective Demolition 1.01 B states that specified items will remain the property of GNHWPCA and shall be delivered to a location to be determined. Where is the location?
4. Please provide an exact list of owner kept items.

Div. 5 – Steel:

1. Please provide the stainless steel shelf requirements for the for the dehumidifier on drawing A-107 (Gauge thickness, length, width, height, and sections).

Div. 15 – Plumbing:

1. Please provide a Spec on the tankless water heater (Manufacture and model number).
2. The still well notes on drawing A113 shows ½" holes drilled every 6" throughout the entire length of pipe. Is this required?
3. Sump pump Water Ace RS3 is no longer available. Please specify a new make and model.
4. Drawing A101 indicates a new PVC vent system tied into a Carbtrol passive canister. Drawing A106 indicates that we are to install vent caps by EZ Vent. It is our understanding that you can only install one or the other. Please confirm system design and if EZ Vents are required? Please provide model numbers.
5. Please provide model number for the new plumbing fixtures (toilet, sink, hot water heater?
6. Please provide architectural details for wall mounted plumbing fixtures.

BUILDING SUCCESS THROUGH PERFORMANCE.

7. Please provide make and model for the existing unit heater.

Div. 15 – HVAC:

1. In regards to the sump pump Water ACE RS3 that is listed in the memo dated 3/15/16 does not exist. Please clarify.

Div. 16 – Electrical:

1. On Drawing A-102 the existing SCADA cabinet is noted to be removed, on A-111 electrical demo drawing it says the SCADA Panel is to be delivered to the owner, but in spec section 16005-3 part 1.04 sub section says “the existing SCADA systems panels are to remain” Do we remove it and replace it or keep the existing SCADA system and cabinet and reuse it and you the owner update the software?
2. Please provide the part number and manufacturer for the new heater to be installed.
3. On DWG A-113 Note 10 says to replace existing lighting fixture with new led fixtures. Please specify the model number and manufacture associated with the fixture.
4. On DWG A-113 in the motor room detail there is lettering HVAC PLN-PP8, Please specify the meaning to the abbreviation.

Please call with any questions.

Thank you,

Michael Kirdzik
Estimator

Jim Pretti

From: Bridget Buckley <BBuckley@gnhwpca.com>
Sent: Tuesday, March 22, 2016 4:14 PM
To: Tom Sgroi; Jim Pretti
Subject: FW: Arch Street Pump Station Rehabilitation SSF 2015-04

From: Mike Davis [<mailto:mdavis@flowtechinc.com>]
Sent: Tuesday, March 22, 2016 4:11 PM
To: Engineering
Subject: Arch Street Pump Station Rehabilitation SSF 2015-04

Please reference drawings A106 and A110 and showing the two (2) existing vents to be removed and replaced. Please provide a size (width and height) for each of the new replacement vents.

Thank you,

Michael O. Davis, PE, LEED Green Associate



Flow Tech, Inc.
10 Bidwell Road | South Windsor, CT 06074
D: (860) 221.0887 | C: (860) 685.0062
O: (860) 291.8886 x 127 | F: (860) 291.9908
mdavis@FlowTechInc.com | www.FlowTechInc.com
Affirmative Action/EOE



Jim Pretti

From: Bridget Buckley <BBuckley@gnhwpca.com>
Sent: Wednesday, March 23, 2016 10:47 AM
To: Tom Sgroi; Jim Pretti
Subject: FW: Arch St Pump Station NO.: SSF 2015-04 RFI's

From: Nate Carlson [<mailto:ncarlson@delrayinc.com>]
Sent: Wednesday, March 23, 2016 10:40 AM
To: Engineering
Subject: Arch St Pump Station NO.: SSF 2015-04 RFI's

Please see RFI's below for the above mentioned project.

- 1 What is the depth of the window well above the new discharge piping that we have to excavate under?
- 2 Will the Owner pay for stored materials?
- 3 Has there been an extensive hazardous materials survey? If no, should the GC carry these costs in our base bid?
- 4 Is the GC responsible to remove all noted hazardous materials or only those impacted by new work? Should this be
- 5 What is the depth of the proposed new 4" PVC Header? Is there a trench detail?
- 6 in reference to section 102-16 #8 it makes reference to maintaining vehicular and pedestrian access to the adjacent
- 7 Can you include the previously asked questions from addendum #1?
- 8 How much can we surcharge the 8" and 15" influent lines?
- 9 Is there a specification for the tideflex check valves?

NATE CARLSON

delray
contracting, inc.



www.delrayinc.com

p. 860.870.8100

c. 860.558.4251

f. 860.870.9554



THE ASSOCIATED CONSTRUCTION COMPANY
GENERAL CONTRACTORS / CONSTRUCTION MANAGERS
1010 WETHERSFIELD AVENUE, SUITE 304 / HARTFORD, CT 06114

Request for Information #1

Date: March 9, 2016

To: GREATER NEW HAVEN WATER POLLUTION CONTROL AUTHORITY
Phone#: 203-466-5280
Fax#: 203-466-5286
From: Michael Kirdzik, Estimator

Project: Arch Street Pump Station Rehabilitation Project
151 Arch Street
Hamden, CT

of pages: 2 including cover page

RE: Request for Information

Dear Sir/Madame,

Please respond to the following questions as soon as possible:

Div 1 – General Requirements:

1. Please confirm as per specification section 102-16, 2. A all bidders are to include the cost of the building permit in their bid.
2. The bidder's checklist item mentions #1 Itemized Bid Proposal and #3 Bidders Qualification form. Please provide these forms.
3. Is there a specified Bid Bond form required or shall we assume the standard AIA bid form is acceptable?
4. Specification section 102-16, 9 indicates sections 02535 and 07620 however these sections are missing from the specifications. Please provide
5. Under Insurance Section 107-6010, Termination or Change of Insurance "The words "endeavor to" and "but failure to mail such notice shall impose no obligation or any liability of any kind upon the company, its agents or representatives" shall be deleted from the certificate form's cancellation provision." Our insurance carrier stated they are not allowed to delete this wording. Please advise.

Div. 2 – Site work/Demolition:

1. There are significant costs with regards to cleaning out the existing sludge in the wet wells.
 - a. When were the existing wet wells last cleaned?
 - b. Will the water be drained out?
 - c. Will only sludge need to be removed?
 - d. How much sludge is estimated to be in the wet wells?

Div. 5 – Steel:

1. What is the finish for the new steel ladder and gate (painted or galvanized)?

Div. 7 – Thermal and Moisture:

1. Drawing A106 indicates a new 48" x 84" water tight locking aluminum hatch. Please provide specifications for this new wet well hatch:

BUILDING SUCCESS THROUGH PERFORMANCE.

- a. Make and model number?
 - b. Type of finish required (i.e. mill finish)?
 - c. What type of loading is required?
 - d. What type of hardware?
 - e. Is safety grating needed?
2. Drawing A106 indicates a ceiling hatch. Please provide specifications for this 2'x2' hatch in ceiling for attic access.

Please call with any questions.

Thank you,

Michael Kirdzik
Estimator



March 9, 2016

Greater New Haven Water Pollution Control Authority
260 East Street
New Haven, CT, 06511

Attn: Engineering Dept.
engineering@gnhwpca.com

Re: Arch Street Pump Station Rehabilitation Project
Hamden, CT Q-1234

Request for Information #1

Dear Sir:

We have the following questions regarding the Arch Street Pump Station Rehabilitation Project bid:

1. Since the property line extends into the parking lot area of 173 Arch Street, as shown on drawing A101. Will the owners of the properties allow us use of the parking area and access into the site?
2. Is the town of Hamden waiving the building permit fees for the project?
3. Since part of the project is to provide a new electrical service to the pump station, can a line item be added to the bid form for the cost of the utility company's service connection fees?
4. Is the contractor responsible to clean out the existing pump station wet well? Have the owners cleaned the wet well in the past few years? Can we dispose of the material from the wet well at the WWTP without paying fees?
5. Is the contractor responsible to clean out all three of the existing pump station storm surge tanks? Have the owners cleaned the wet well in the past few years? Can we dispose of the material from the wet well at the WWTP without paying fees? Since the amount of sedimentation in the tanks is not known, can a line item be added to the bid form for sedimentation disposal?
6. Since there is excavation required on top of the existing storm surge tanks, is there any weight restriction for equipment on top of the tank? Are there any backfill material restrictions for excavation materials on top of the tank?
7. On specification section 102-10, subsection 2 D Scope of Work. Item # 1 notes to clean all existing brick surfaces and to waterproof. This is not noted in any other location in the specification or drawings. Is this work required? If this is required work, can you provide us with a specification on the waterproofing material?
8. The existing motor room floor and walls are painted. Do we have to remove the existing paint before we install the new sloped concrete floor as shown on drawings A109 & A107? Does the existing paint have lead in it? Is there a

Page 1 of 2

- specified bonding agent required to bond the new concrete to the existing floor?
9. On Drawing A107, a new sink, toilet and water heater is shown on the motor level of the existing pump station. Can we be provided with a manufacturer, model number and specification on the sink, toilet and water heater? Can we be provided with a plumbing schematic and drawing for the plumbing to the new bathroom? Where is the new electrical water heater mounted? There is no electrical wiring shown on the electrical drawings for the new water heater.
 10. The new carbon air purification unit shown on drawing A101 requires electrical power. The electrical drawings show no power wiring for the unit. Are we using an existing electrical outlet to power the unit?
 11. On drawing A107, a new sump pump is shown. Can we be provided with a manufacturer, model number and specification on the pump?
 12. On drawing A107, a new dehumidifier is shown. Can we be provided with a manufacturer, model number and specification on the new dehumidifier?
 13. On drawing A107, a new fixed pane window is noted. How many window assemblies get replaced? Can we be provided with a manufacturer, model number, size and specification on the new window?
 14. On drawing A102, the existing electrical heater is noted to remain, but on drawing A111 it is noted to replace with new unit. Please clarify. Can we be provided with a manufacturer, model number and specification on the electrical heaters?
 15. On drawing A112, there is a dry well ventilation system control schematic shown on the drawing. Is this an existing system? There is no exhaust fan shown on the drawings, is the exhaust fan existing?
 16. On drawing A109, one pressure gauge assembly is shown. How many pressure gauge assemblies are required?
 17. What material is required for pipe supports and hardware located inside wet well?
 18. The existing chain link fence is topped with barbed wire, and it has a gate for the sidewalk to the station. Is the gate and barbed wire required for the new fence? Can a specification be provided for the chain link fence and gate?
 19. On page 102-16-4, the specification note section 07620, Sheet Metal Flashing is part of the specification, but our specification book is missing that section. Can we be provided with that specification section?
 20. In the specification 13420, subsection 2.01, the specification describes a remote mounted transmitter and it is to be mounted in a Nema 4X enclosure, yet on drawing A113 (motor room level detail,) it states that the new flow transmitters go to a new metering digital panel on the control room level. Are the flow transmitters to be integral on the flow tube, and a new digital display panel will be furnished with digital panel meters on the control room level? If so, what is the digital display meter to be used for?

Very truly yours,

KOVACS CONSTRUCTION CORPORATION
David Allen
David Allen

Page 2 of 2

GENERAL CONTRACTOR
297 White Street, Danbury, CT 06810
Tel: (203) 743-4022 • Fax: (203) 790-1326