

# Criscuolo Engineering, LLC

---

Consulting Engineers  
Civil Engineers  
Land Surveyors

Robert A. Criscuolo, P.E., L.S.  
Paul L. Nott, L.S.  
James M. Pretti, Jr., P.E.  
Linda C. Dow, P.E.

Records of:

Associated Surveys  
Charles H. Miller  
George A. Firth

## MEMORANDUM

**To:** Greater New Haven Water Pollution Control Authority  
**From:** James M. Pretti, Jr., P.E.  
**Date:** 4/9/2018  
**Re:** Humphrey St & Mitchell Dr. Pump Station Rehab. Project – Addendum #1  
**CE File No:** 2017.043 & 2017.044  
**cc:** file

---

In regards to questions set forth in email from The Associated Construction Company dated April 6, 2018, we have the following responses:

Div 15 –Plumbing

1. The fitting noted as #13 inside the valve pit should be flg.x flg. In general, all buried fittings outside of structures shall be M.J. x M.J. The Stilling well at Humphrey Street is to be 6” PVC
2. On Sheet M103, the fitting #10 should be a 4” plug valve.
3. The stilling well at Mitchell Drive shall be ductile iron, as it will be exposed.