

**GREATER NEW HAVEN WATER POLLUTION CONTROL AUTHORITY
CWF 2017-01 CAPACITY UPGRADES AT EAST STREET PUMP STATION
FOR CSO REDUCTION
ADDENDUM NO. 3**

A. GENERAL

1. Inclusion of this Addendum must be acknowledged by inserting its number on the appropriate page(s) of the Bid Forms. Failure to acknowledge any and all addenda in the above specified bid may be cause for rejection by the Owner on the grounds that it is non-responsive.

SUBMITTED QUESTIONS and REQUESTS FOR INFORMATION/CLARIFICATION:

1. Question: Drawing S-201 – Please confirm the 2” grating over the two trench drains are to be aluminum per Section 05 53 16 and not a heavy-duty cast-iron trench grate.

Response: Heavy duty cast-iron trench grate and frame shall be provided, and shall be H20 rated.

2. Question: Drawing S-203 – The stainless-steel bolt-on angle at the perimeter of the FRP planks is listed as L4x4x3/8. Sections 1 and 3 on Drawing S-208 show this support angle as L6x6x3/8. Please clarify if all the angle to support the 6” FRP plank is to be L6x6x3/8 or L4x4x3/8.

Response: Angle sizes vary to support the FRP planks. Instances where the support spans require more robust members. In lieu of the L6x6x3/8 angle, provide C8x11.5 and L3x3x1/4 for supports.

3. Question: Drawing S-305 – Please confirm the details (size of bearing plate, decking support angle, bridging) are the same details as shown on drawing S-210.

Response: Confirmed. Note that Drawing S-210 Detail 4/5 has been clarified to indicate 2 studs.

4. Question: Drawing M- 401 - Note 4 clarifies the two Harbor Crossing lines will need to be dewatered of sewage prior to the removal of the blind flanges and installation of the new air release valves. If available, please provide an elevation of the chamber or invert of the pipe at both sides of the harbor crossing.

Response: Record Drawings were provided in Addendum No. 2.

The following changes are hereby made part of and must be attached to the Project Manual and Contract Drawings:

C. CHANGES TO GENERAL INSTRUCTIONS

1. Invitation to Construction. Revise the Bid Opening time from “Thursday November 21st, 2024 at 2:00 PM Local Time” to “Thursday December 12th, 2024 at 2:00 PM Local Time”.
2. Invitation to Construction. Revise the deadline for submitting questions from “12:00 noon on Friday, November 1st, 2024” to “12:00 noon on Friday, November 22nd, 2024”.

D. CHANGES TO CONTRACT DRAWINGS

1. Drawing S-203, modify callouts for L6x6x3/8 angle to indicate C8x11.5 and L3x3x1/4 for supports.
2. Drawing S-210, revise callout on Detail 4/5 as follows, “1/2"X7"X9" PL GALV, W/ 3/4" DIA GALV X 6" LG WELD STUD, TYP OF 2”.

END OF ADDENDUM NO. 3
