

GREATER NEW HAVEN WATER POLLUTION CONTROL AUTHORITY

ADDENDUM No. 5

**TO
CONTRACT DOCUMENTS
FOR**

**GNHWPCA WIND RESILIENCY PROJECT
PROJECT NO. SSF 2021-03
260 EAST STREET
345 EAST SHORE PARKWAY
NEW HAVEN, CONNECTICUT**

Bidders are hereby notified of the following additions, deletions, and modifications to the Contract Documents for the Wind Resiliency Project. The content of this Addendum modifies the scope of work.

Bidders shall acknowledge receipt of this Addendum in the space provided in Article 5.03 of the Bid Form for Construction Contract.

A. RESPONSE TO BIDDER QUESTIONS

Question 53: The admin building shows the ADM-W5 frame with a pair of doors. We have a rfi out there on what type of doors are required which still has not been addressed. In looking at the elevations can you confirm the count for W5 is (1). It's shown 3 times within the elevations. We are not sure if there is a vestibule frame shown that is a part of this?

Response 53: The note on drawing ADM-201 and ADM-202 says to 'REPLACE STOREFRONT IN-KIND'. The design intent is to provide a similar style aluminum store front double door. The door type is similar to a Special-Lite SL-16F Fluted Aluminum Flush Door (double door). Door hardware is specified in spec section 08 71 00 – Finish Hardware."

B. SPECIFICATIONS

None.

C. DRAWINGS

None.

END OF ADDENDUM